

## 測定月報

(1/7)

測定日: 2017/05

日	モニタ											
	A001 正門警備所 (DM76)			A002 正門警備所 (DM74)			A003 免震重要棟(DM-45)			A004 免震重要棟(DM-52)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	4.25E-06	1.0	100	4.17E-06	1.1	100	4.07E-06	8.0	100	3.91E-06	7.0	100
2	2.99E-06	0.9	100	3.03E-06	1.1	100	*1 3.06E-06	7.7	100	2.77E-06	7.2	100
3	5.23E-06	1.0	100	5.65E-06	1.1	100	5.36E-06	7.9	100	5.34E-06	7.0	100
4	4.88E-06	0.9	100	5.09E-06	1.1	100	4.93E-06	7.9	100	5.02E-06	7.0	100
5	2.20E-06	0.9	100	2.05E-06	1.2	100	2.07E-06	8.0	100	2.05E-06	7.0	100
6	6.47E-06	1.0	100	6.35E-06	1.2	100	5.89E-06	7.9	100	5.55E-06	7.2	100
7	2.71E-06	1.0	100	2.68E-06	1.2	100	2.71E-06	8.0	100	2.79E-06	7.0	100
8	3.01E-06	0.9	100	3.07E-06	1.1	100	3.12E-06	7.9	100	3.11E-06	7.0	100
9	2.64E-06	0.9	100	2.57E-06	1.2	100	2.33E-06	8.0	100	2.28E-06	7.2	100
10	6.50E-06	1.0	100	6.56E-06	1.2	100	5.83E-06	7.9	100	5.53E-06	7.0	100
11	4.01E-06	1.0	100	*1 4.34E-06	1.1	100	3.73E-06	8.0	100	3.86E-06	6.9	100
12	2.93E-06	1.0	100	2.80E-06	1.2	100	2.87E-06	8.0	100	2.90E-06	7.0	100
13	1.98E-06	1.0	100	1.99E-06	1.1	100	1.76E-06	8.0	100	1.86E-06	6.9	100
14	6.63E-07	1.0	100	6.88E-07	1.1	100	7.82E-07	7.5	100	7.16E-07	6.7	100
15	9.80E-07	0.9	100	9.73E-07	1.1	100	8.15E-07	7.9	100	1.01E-06	6.7	100
16	3.06E-06	0.9	100	2.85E-06	1.1	100	2.69E-06	8.0	100	2.95E-06	6.7	100
17	3.35E-06	0.9	100	3.12E-06	1.2	100	2.80E-06	7.8	100	2.70E-06	7.1	100
18	4.64E-06	1.0	100	4.43E-06	1.1	100	4.38E-06	7.9	100	4.32E-06	7.0	100
19	*1 4.66E-06	1.0	100	4.69E-06	1.1	100	3.97E-06	7.9	100	*1 4.09E-06	6.9	100
20	5.83E-06	1.0	100	6.08E-06	1.1	100	5.29E-06	7.9	100	5.06E-06	6.9	100
21	9.89E-06	1.0	100	9.56E-06	1.2	100	9.51E-06	7.8	100	8.80E-06	6.9	100
22	9.96E-06	1.0	100	9.57E-06	1.3	100	8.33E-06	7.9	100	7.55E-06	7.0	100
23	1.74E-06	0.9	100	1.72E-06	1.1	100	1.88E-06	7.5	100	1.55E-06	6.8	100
24	3.24E-06	0.9	100	3.08E-06	1.2	100	2.81E-06	7.9	100	2.49E-06	7.1	100
25	6.50E-06	1.0	100	6.04E-06	1.2	100	5.99E-06	8.2	100	5.54E-06	6.9	100
26	1.80E-06	0.9	100	1.87E-06	1.1	100	*1 1.75E-06	7.7	100	1.56E-06	7.0	100
27	2.93E-06	0.9	100	2.97E-06	1.0	100	2.44E-06	7.7	100	2.34E-06	7.0	100
28	4.76E-06	0.9	100	4.71E-06	1.1	100	3.74E-06	7.7	100	3.58E-06	7.1	100
29	4.00E-06	0.9	100	4.01E-06	1.1	100	3.60E-06	7.7	100	3.44E-06	7.0	100
30	7.35E-06	0.9	100	7.24E-06	1.2	100	5.98E-06	8.2	100	6.01E-06	7.0	100
31	8.52E-06	1.0	100	8.63E-06	1.1	100	6.63E-06	8.0	100	6.64E-06	7.0	100
1ヶ月値	4.31E-06	1.0	100	4.28E-06	1.1	100	3.91E-06	7.9	100	3.78E-06	7.0	100
*1 最大値	3.50E-05	1.0	103	3.10E-05	1.3	102	4.62E-05	8.2	102	2.40E-05	7.2	102
最大値日時	05/22 00:27	05/01 00:12	05/13 13:33	05/22 04:26	05/22 03:57	05/01 02:51	05/26 16:01	05/25 00:27	05/13 16:10	05/10 04:12	05/02 04:12	05/13 19:39
*2 最小値	3.09E-07	0.9	97	0.00E+00	1.0	98	0.00E+00	7.5	97	0.00E+00	6.6	97
最小値日時	05/14 11:08	05/02 00:12	05/13 14:22	05/05 03:58	05/27 03:57	05/01 02:40	05/01 00:27	05/14 00:27	05/15 01:31	05/01 04:12	05/14 04:12	05/14 08:38

\*1:ろ紙交換

\*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

(2/7)

測定日: 2017/05

日	モニタ											
	A005 5/6号警備所前(DM61)			A006 5/6号警備所前(DM54)			A007 1号北側法面上(旧厚生棟)(DM-70)			A008 1号北側法面上(旧厚生棟)(DM-75)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	4.01E-06	1.6	100	4.30E-06	1.9	100	3.77E-06	10.4	100	4.07E-06	8.7	100
2	2.58E-06	1.6	100	3.02E-06	1.9	100	2.61E-06	10.6	100	*1 3.07E-06	8.6	100
3	5.15E-06	1.5	100	5.96E-06	2.0	100	5.05E-06	10.4	100	5.58E-06	8.5	100
4	4.68E-06	1.7	100	5.09E-06	1.9	100	4.45E-06	10.6	100	5.03E-06	8.9	100
5	2.01E-06	1.6	100	2.32E-06	1.9	100	2.22E-06	10.2	100	2.24E-06	8.8	100
6	5.32E-06	1.7	100	6.22E-06	1.9	100	5.60E-06	10.4	100	6.39E-06	8.7	100
7	2.50E-06	1.6	100	2.85E-06	1.9	100	2.54E-06	10.4	100	3.05E-06	8.5	100
8	2.83E-06	1.7	100	3.23E-06	1.9	100	2.75E-06	10.7	100	3.26E-06	8.6	100
9	2.19E-06	1.6	100	2.54E-06	1.8	100	2.00E-06	10.3	100	2.26E-06	8.8	100
10	5.00E-06	1.7	100	5.66E-06	1.9	100	4.94E-06	10.3	100	5.31E-06	8.7	100
11	3.56E-06	1.6	100	4.06E-06	1.8	100	3.31E-06	10.6	100	3.87E-06	8.7	100
12	2.80E-06	1.7	100	*1 3.25E-06	1.9	100	2.72E-06	10.4	100	3.13E-06	8.6	100
13	1.55E-06	1.7	100	1.75E-06	1.9	100	1.65E-06	10.5	100	1.78E-06	8.8	100
14	6.79E-07	1.5	100	6.70E-07	1.8	100	5.72E-07	10.5	100	6.95E-07	8.7	100
15	8.37E-07	1.5	100	8.55E-07	1.9	100	6.94E-07	10.3	100	7.64E-07	8.7	100
16	2.19E-06	1.6	100	2.49E-06	1.8	100	2.43E-06	9.5	100	2.47E-06	8.5	100
17	2.42E-06	1.6	100	2.69E-06	1.9	100	2.37E-06	10.0	100	2.80E-06	8.2	100
18	3.96E-06	1.7	100	4.34E-06	1.9	100	3.94E-06	9.7	100	4.55E-06	8.1	100
19	*1 3.84E-06	1.7	100	4.53E-06	1.8	100	*1 3.92E-06	9.7	100	4.30E-06	8.2	100
20	5.07E-06	1.7	100	6.20E-06	1.8	100	4.69E-06	9.9	100	5.55E-06	8.2	100
21	8.32E-06	1.6	100	1.00E-05	1.8	100	8.41E-06	9.6	100	9.76E-06	8.2	100
22	7.79E-06	1.7	100	9.25E-06	2.0	100	7.79E-06	10.0	100	9.33E-06	8.0	100
23	1.36E-06	1.6	100	1.56E-06	1.9	100	1.46E-06	9.7	100	1.72E-06	8.1	100
24	2.09E-06	1.6	100	2.46E-06	1.9	100	2.29E-06	9.7	100	2.50E-06	8.3	100
25	4.41E-06	1.7	100	5.09E-06	1.8	100	4.84E-06	9.8	100	5.65E-06	8.1	100
26	1.53E-06	1.6	100	1.79E-06	1.8	100	1.56E-06	9.7	100	*1 1.80E-06	8.2	100
27	2.11E-06	1.6	100	2.50E-06	1.8	100	2.24E-06	9.7	100	2.37E-06	8.2	100
28	3.15E-06	1.6	100	3.77E-06	1.8	100	3.43E-06	9.9	100	4.00E-06	8.1	100
29	3.36E-06	1.7	100	3.94E-06	1.9	100	3.69E-06	9.6	100	3.90E-06	8.1	100
30	5.71E-06	1.6	100	6.90E-06	1.8	100	5.98E-06	9.6	100	6.57E-06	8.3	100
31	5.38E-06	1.7	100	6.20E-06	2.0	100	5.70E-06	9.9	100	6.45E-06	8.4	100
1ヶ月値	3.50E-06	1.6	100	4.05E-06	1.9	100	3.54E-06	10.1	100	4.01E-06	8.4	100
*2 最大値	2.45E-05	1.7	105	2.62E-05	2.0	103	3.41E-05	10.7	103	3.60E-05	9.0	103
最大値日時	05/22 00:52	05/04 00:42	05/14 20:23	05/22 04:35	05/03 04:27	05/14 07:41	05/22 00:48	05/08 00:42	05/13 20:56	05/22 04:44	05/04 04:42	05/08 03:23
*2 最小値	0.00E+00	1.5	96	0.00E+00	1.8	97	0.00E+00	9.5	97	0.00E+00	7.9	97
最小値日時	05/02 00:42	05/03 00:42	05/14 21:32	05/01 04:27	05/01 00:01	05/14 00:48	05/02 00:42	05/16 00:42	05/13 15:49	05/02 04:42	05/22 04:42	05/11 02:25

\*1: ろ紙交換

\*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

(3/7)

測定日: 2017/05

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上(DM46)			1/2号西側法面上(DM65)			3/4号西側法面上(DM48)			3/4号西側法面上(DM51)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	4.14E-06	8.0	100	3.75E-06	9.3	100	3.82E-06	5.2	100	3.73E-06	5.6	100
2	3.01E-06	8.1	100	2.57E-06	9.4	100	*1 2.82E-06	4.9	100	*1 2.72E-06	5.3	100
3	5.29E-06	8.5	100	4.78E-06	9.3	100	4.97E-06	5.1	100	4.90E-06	5.3	100
4	5.18E-06	8.1	100	4.63E-06	9.1	100	4.60E-06	5.1	100	4.65E-06	5.3	100
5	2.27E-06	8.0	100	2.04E-06	9.2	100	2.09E-06	5.0	100	1.98E-06	5.5	100
6	6.04E-06	8.1	100	5.59E-06	9.2	100	5.62E-06	5.2	100	5.73E-06	5.5	100
7	2.68E-06	8.4	100	2.71E-06	9.2	100	2.60E-06	5.2	100	2.59E-06	5.6	100
8	3.09E-06	8.3	100	2.92E-06	9.3	100	2.87E-06	5.3	100	2.96E-06	5.4	100
9	2.44E-06	8.0	100	2.10E-06	9.4	100	2.10E-06	5.1	100	2.23E-06	5.5	100
10	5.62E-06	8.2	100	4.93E-06	9.3	100	5.18E-06	5.1	100	5.03E-06	5.5	100
11	3.91E-06	8.3	100	3.79E-06	9.2	100	3.50E-06	5.3	100	3.72E-06	5.6	100
12	2.96E-06	8.3	100	*1 2.88E-06	9.3	100	2.69E-06	5.1	100	2.72E-06	5.7	100
13	2.05E-06	8.0	100	1.88E-06	9.3	100	1.69E-06	5.1	100	1.70E-06	5.5	100
14	7.68E-07	8.0	100	6.97E-07	9.1	100	5.38E-07	5.1	100	5.69E-07	5.4	100
15	8.72E-07	8.2	100	1.06E-06	9.0	100	8.54E-07	5.0	100	9.64E-07	5.2	100
16	2.78E-06	8.1	100	2.90E-06	9.1	100	2.55E-06	5.2	100	2.67E-06	5.3	100
17	2.89E-06	8.0	100	2.93E-06	9.0	100	2.54E-06	5.1	100	2.75E-06	5.4	100
18	4.56E-06	8.1	100	4.40E-06	9.2	100	4.15E-06	5.1	100	4.10E-06	5.4	100
19	*1 4.19E-06	8.1	100	4.20E-06	9.2	100	4.09E-06	5.0	100	4.12E-06	5.3	100
20	5.12E-06	8.2	100	5.93E-06	9.0	100	5.44E-06	5.2	100	5.27E-06	5.5	100
21	8.94E-06	8.0	100	9.87E-06	9.0	100	9.21E-06	5.3	100	9.34E-06	5.4	100
22	7.61E-06	8.2	100	8.78E-06	9.0	100	7.78E-06	5.2	100	8.09E-06	5.6	100
23	1.56E-06	8.0	100	1.68E-06	9.1	100	1.51E-06	5.1	100	1.52E-06	5.4	100
24	2.63E-06	8.0	100	2.77E-06	9.1	100	2.58E-06	5.3	100	2.57E-06	5.6	100
25	5.68E-06	8.1	100	6.13E-06	9.0	100	5.82E-06	5.1	100	5.73E-06	5.4	100
26	1.71E-06	8.0	100	1.64E-06	9.3	100	*1 1.60E-06	5.2	100	*1 1.69E-06	5.5	100
27	2.27E-06	8.3	100	2.75E-06	8.9	100	2.36E-06	5.1	100	2.39E-06	5.3	100
28	3.90E-06	8.0	100	4.12E-06	9.1	100	3.82E-06	5.2	100	3.68E-06	5.4	100
29	3.59E-06	8.1	100	3.93E-06	9.2	100	3.47E-06	5.1	100	3.52E-06	5.4	100
30	6.17E-06	8.1	100	6.66E-06	9.1	100	6.05E-06	5.2	100	6.06E-06	5.5	100
31	6.83E-06	8.0	100	7.52E-06	9.0	100	6.48E-06	5.4	100	6.69E-06	5.7	100
1ヶ月値	3.89E-06	8.1	100	3.95E-06	9.2	100	3.72E-06	5.1	100	3.76E-06	5.4	100
*2 最大値	2.82E-05	8.5	103	3.36E-05	9.4	102	2.51E-05	5.4	104	3.20E-05	5.7	103
最大値日時	05/04 01:12	05/03 01:12	05/14 23:47	05/08 04:57	05/02 04:57	05/01 19:10	05/25 01:57	05/31 01:27	05/14 18:37	05/22 05:27	05/12 05:12	05/13 22:39
*2 最小値	0.00E+00	8.0	97	0.00E+00	8.8	98	0.00E+00	4.8	97	0.00E+00	5.1	97
最小値日時	05/02 01:12	05/01 01:12	05/15 01:29	05/02 04:57	05/27 05:24	05/01 00:44	05/02 14:36	05/02 14:35	05/14 15:26	05/02 05:12	05/15 05:12	05/13 17:00

\*1: ろ紙交換

\*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

## 測定月報

(4/7)

測定日: 2017/05

日	モニタ											
	A013			A014			A015			A016		
	4号南側法面上[3号南側](DM69)			4号南側法面上[3号南側](DM62)			登録S休憩所 (DM50)			登録S休憩所 (DM68)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	4.09E-06	0.9	100	4.09E-06	1.2	100	3.89E-06	2.6	100	3.92E-06	2.2	100
2	3.03E-06	0.8	100	2.91E-06	1.2	100	3.04E-06	2.6	100	3.08E-06	2.1	100
3	5.51E-06	0.9	100	5.50E-06	1.1	100	5.79E-06	2.7	100	5.76E-06	2.1	100
4	4.99E-06	0.8	100	5.04E-06	1.1	100	5.35E-06	2.6	100	5.22E-06	2.1	100
5	2.20E-06	0.8	100	2.15E-06	1.1	100	2.08E-06	2.6	100	2.05E-06	2.2	100
6	6.34E-06	0.9	100	6.09E-06	1.1	100	6.44E-06	2.6	100	6.21E-06	2.3	100
7	2.95E-06	0.9	100	2.81E-06	1.2	100	2.70E-06	2.7	100	2.70E-06	2.1	100
8	3.39E-06	0.8	100	3.19E-06	1.1	100	3.06E-06	2.7	100	2.96E-06	2.2	100
9	2.54E-06	0.8	100	2.39E-06	1.2	100	2.59E-06	2.6	100	2.65E-06	2.1	100
10	5.78E-06	0.9	100	5.73E-06	1.1	100	6.54E-06	2.8	100	6.88E-06	2.2	100
11	3.97E-06	0.8	100	3.98E-06	1.1	100	3.70E-06	2.7	100	3.88E-06	2.2	100
12	3.01E-06	0.8	100	3.02E-06	1.1	100	2.82E-06	2.7	100	2.80E-06	2.3	100
13	1.91E-06	0.9	100	1.87E-06	1.1	100	1.83E-06	2.6	100	1.75E-06	2.3	100
14	6.82E-07	0.9	100	7.43E-07	1.0	100	6.60E-07	2.7	100	6.76E-07	2.2	100
15	*1 9.91E-07	0.8	100	1.01E-06	1.0	100	*1 9.48E-07	2.7	100	*1 9.64E-07	2.2	100
16	2.54E-06	0.9	100	2.67E-06	1.1	100	2.89E-06	2.7	100	2.91E-06	2.1	100
17	2.73E-06	0.8	100	2.82E-06	1.1	100	2.95E-06	2.7	100	3.05E-06	2.1	100
18	4.27E-06	0.8	100	4.25E-06	1.1	100	4.44E-06	2.6	100	4.24E-06	2.2	100
19	4.14E-06	0.9	100	*1 4.26E-06	1.1	100	4.56E-06	2.7	100	4.53E-06	2.2	100
20	5.88E-06	0.9	100	5.62E-06	1.1	100	5.73E-06	2.6	100	5.39E-06	2.2	100
21	9.58E-06	0.9	100	9.35E-06	1.1	100	9.64E-06	2.5	100	8.99E-06	2.3	100
22	8.48E-06	0.9	100	8.19E-06	1.1	100	9.01E-06	2.7	100	9.22E-06	2.3	100
23	1.56E-06	0.8	100	1.50E-06	1.1	100	1.66E-06	2.6	100	1.55E-06	2.2	100
24	2.81E-06	0.8	100	2.55E-06	1.1	100	2.96E-06	2.7	100	2.84E-06	2.2	100
25	6.36E-06	0.9	100	5.73E-06	1.1	100	6.13E-06	2.8	100	5.86E-06	2.2	100
26	1.72E-06	0.8	100	1.71E-06	1.0	100	1.80E-06	2.6	100	1.68E-06	2.2	100
27	2.52E-06	0.8	100	2.49E-06	1.0	100	2.90E-06	2.6	100	2.63E-06	2.1	100
28	4.55E-06	0.9	100	4.24E-06	1.1	100	4.36E-06	2.6	100	4.22E-06	2.2	100
29	3.75E-06	0.9	100	3.61E-06	1.1	100	3.87E-06	2.6	100	3.64E-06	2.2	100
30	6.57E-06	0.9	100	6.46E-06	1.1	100	6.91E-06	2.7	100	6.84E-06	2.2	100
31	7.28E-06	0.9	100	6.71E-06	1.2	100	8.41E-06	2.6	100	7.75E-06	2.2	100
1ヶ月値	4.07E-06	0.9	100	3.96E-06	1.1	100	4.18E-06	2.7	100	4.09E-06	2.2	100
最大値	2.77E-05	0.9	103	2.35E-05	1.2	103	3.08E-05	2.8	102	2.80E-05	2.3	102
最大値日時	05/25 02:13	05/01 00:01	05/14 05:18	05/31 05:38	05/01 00:01	05/14 19:15	05/22 02:25	05/10 01:57	05/10 12:16	05/22 06:00	05/01 00:01	05/01 06:00
最小値	0.00E+00	0.8	97	0.00E+00	1.0	97	0.00E+00	2.5	97	0.00E+00	2.1	98
最小値日時	05/14 01:44	05/02 01:42	05/13 22:10	05/02 05:28	05/14 05:27	05/14 06:21	05/01 01:57	05/21 01:57	05/14 09:55	05/07 05:42	05/02 05:42	05/01 16:01

\*1: ろ紙交換

\*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

(5/7)

測定日: 2017/05

日	モニタ											
	A019 シールド中央制御室(DM-49)			A020 シールド中央制御室(DM-60)			A021 Hタンクエリア (DM67)			A022 Hタンクエリア (DM55)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	3.64E-06	2.6	100	3.96E-06	3.0	100	4.14E-06	2.3	100	3.81E-06	2.9	100
2	2.62E-06	2.5	100	2.68E-06	3.0	100	2.98E-06	2.4	100	2.79E-06	2.8	100
3	4.81E-06	2.5	100	5.17E-06	3.0	100	5.45E-06	2.3	100	5.20E-06	2.7	100
4	4.27E-06	2.6	100	4.52E-06	3.1	100	4.97E-06	2.3	100	4.47E-06	2.8	100
5	1.78E-06	2.6	100	2.01E-06	3.0	100	2.20E-06	2.2	100	1.98E-06	2.8	100
6	5.29E-06	2.4	100	5.72E-06	3.1	100	6.05E-06	2.3	100	5.60E-06	2.8	100
7	2.36E-06	2.6	100	2.71E-06	3.0	100	2.80E-06	2.3	100	2.68E-06	2.8	100
8	2.71E-06	2.6	100	2.96E-06	3.0	100	3.18E-06	2.3	100	3.03E-06	2.8	100
9	2.10E-06	2.6	100	2.26E-06	3.1	100	2.45E-06	2.5	100	2.50E-06	2.8	100
10	5.13E-06	2.6	100	5.78E-06	3.0	100	6.27E-06	2.3	100	5.99E-06	2.9	100
11	*1 3.46E-06	2.5	100	3.87E-06	3.0	100	4.20E-06	2.3	100	3.66E-06	2.8	100
12	2.57E-06	2.5	100	2.85E-06	3.0	100	3.03E-06	2.3	100	*1 2.98E-06	2.8	100
13	1.67E-06	2.5	100	1.86E-06	3.0	100	1.97E-06	2.3	100	1.94E-06	2.7	100
14	6.61E-07	2.4	100	6.57E-07	2.9	100	7.25E-07	2.1	100	8.31E-07	2.5	100
15	8.61E-07	2.5	100	9.47E-07	2.9	100	*1 9.40E-07	2.2	100	1.01E-06	2.6	100
16	2.48E-06	2.5	100	2.69E-06	2.9	100	3.04E-06	2.3	100	3.15E-06	2.7	100
17	2.38E-06	2.6	100	2.67E-06	3.0	100	2.97E-06	2.3	100	3.12E-06	2.8	100
18	3.77E-06	2.6	100	4.02E-06	3.0	100	4.42E-06	2.3	100	4.50E-06	2.8	100
19	3.87E-06	2.5	100	*1 4.05E-06	3.0	100	4.51E-06	2.3	100	4.39E-06	2.8	100
20	5.17E-06	2.5	100	5.36E-06	3.0	100	5.69E-06	2.3	100	5.72E-06	2.8	100
21	8.57E-06	2.5	100	9.08E-06	2.9	100	9.66E-06	2.4	100	9.87E-06	2.7	100
22	7.86E-06	2.6	100	8.33E-06	3.0	100	9.04E-06	2.4	100	9.11E-06	2.8	100
23	1.38E-06	2.6	100	1.52E-06	2.9	100	1.66E-06	2.4	100	1.70E-06	2.8	100
24	2.42E-06	2.5	100	2.47E-06	3.1	100	3.04E-06	2.3	100	3.13E-06	2.8	100
25	5.43E-06	2.6	100	5.70E-06	3.0	100	6.29E-06	2.3	100	6.37E-06	2.7	100
26	1.48E-06	2.6	100	1.70E-06	2.9	100	1.69E-06	2.3	100	1.81E-06	2.7	100
27	2.31E-06	2.5	100	2.44E-06	3.0	100	2.69E-06	2.2	100	2.76E-06	2.7	100
28	3.93E-06	2.6	100	3.98E-06	3.0	100	4.36E-06	2.3	100	4.29E-06	2.7	100
29	3.39E-06	2.5	100	3.43E-06	3.0	100	3.97E-06	2.3	100	3.99E-06	2.9	100
30	5.59E-06	2.6	100	5.97E-06	3.0	100	7.17E-06	2.3	100	7.08E-06	2.8	100
31	6.15E-06	2.6	100	6.74E-06	2.9	100	8.17E-06	2.4	100	8.03E-06	2.7	100
1ヶ月値	3.55E-06	2.5	100	3.81E-06	3.0	100	4.18E-06	2.3	100	4.11E-06	2.8	100
X2-最大値	2.62E-05	2.7	103	2.68E-05	3.2	102	3.16E-05	2.5	102	2.70E-05	3.0	103
最大値日時	05/25 02:48	05/01 00:01	05/13 17:35	05/10 06:30	05/24 06:12	05/01 14:46	05/25 02:57	05/09 02:42	05/01 09:27	05/22 06:37	05/29 06:27	05/14 01:18
X2-最小値	0.00E+00	2.4	97	0.00E+00	2.8	97	0.00E+00	2.1	97	0.00E+00	2.4	96
最小値日時	05/01 02:27	05/06 02:27	05/04 04:17	05/01 06:12	05/23 06:12	05/14 20:06	05/02 02:42	05/14 02:42	05/14 22:14	05/01 06:27	05/14 06:27	05/14 05:34

\*1:ろ紙交換

\*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

(6/7)

測定日: 2017/05

日	モニタ											
	A027			A028			A029			A030		
	1号機海側4m盤(DM-71)			1号機海側4m盤(DM-72)			3号機海側4m盤(DM-63)			3号機海側4m盤(DM-66)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	4.08E-06	5.6	100	4.54E-06	6.5	100	3.63E-06	6.6	100	3.78E-06	4.5	100
2	2.83E-06	5.6	100	3.25E-06	6.5	100	2.46E-06	6.6	100	2.50E-06	4.5	100
3	5.30E-06	5.6	100	5.83E-06	6.5	100	4.54E-06	6.6	100	4.64E-06	4.5	100
4	4.70E-06	5.6	100	5.14E-06	6.5	100	4.34E-06	6.6	100	4.46E-06	4.5	100
5	2.16E-06	5.6	100	2.48E-06	6.5	100	1.83E-06	6.6	100	1.88E-06	4.5	100
6	5.45E-06	5.6	100	5.83E-06	6.5	100	4.66E-06	6.6	100	5.04E-06	4.5	100
7	2.82E-06	5.6	100	3.10E-06	6.5	100	2.43E-06	6.6	100	2.58E-06	4.5	100
8	3.46E-06	5.6	100	3.74E-06	6.5	100	2.82E-06	6.6	100	3.03E-06	4.5	100
9	2.20E-06	5.6	100	2.56E-06	6.5	100	1.75E-06	6.6	100	1.92E-06	4.5	100
10	4.76E-06	5.6	100	5.08E-06	6.5	100	4.31E-06	6.6	100	4.47E-06	4.5	100
11	4.07E-06	5.6	100	4.31E-06	6.5	100	3.45E-06	6.6	100	3.74E-06	4.5	100
12	*1 2.98E-06	5.6	100	*1 3.04E-06	6.9	100	*1 2.60E-06	6.4	100	*1 2.68E-06	4.4	100
13	1.62E-06	5.7	100	1.41E-06	7.6	100	1.59E-06	6.1	100	1.63E-06	4.3	100
14	6.44E-07	5.7	100	4.15E-07	7.6	100	6.34E-07	6.1	100	6.22E-07	4.3	100
15	7.95E-07	5.7	100	6.01E-07	7.6	100	7.46E-07	6.1	100	7.65E-07	4.3	100
16	2.27E-06	5.7	100	2.17E-06	7.6	100	2.19E-06	6.1	100	2.29E-06	4.3	100
17	2.40E-06	5.7	100	2.35E-06	7.6	100	2.35E-06	6.1	100	2.39E-06	4.3	100
18	3.97E-06	5.7	100	3.89E-06	7.6	100	3.77E-06	6.1	100	3.81E-06	4.3	100
19	4.35E-06	5.7	100	4.24E-06	7.6	100	4.03E-06	6.1	100	4.19E-06	4.3	100
20	5.20E-06	5.7	100	5.06E-06	7.6	100	5.12E-06	6.1	100	5.15E-06	4.3	100
21	9.37E-06	5.7	100	9.05E-06	7.6	100	8.89E-06	6.1	100	9.28E-06	4.3	100
22	8.85E-06	5.7	100	8.67E-06	7.6	100	8.44E-06	6.1	100	9.02E-06	4.3	100
23	1.44E-06	5.7	100	1.26E-06	7.6	100	1.40E-06	6.1	100	1.37E-06	4.3	100
24	2.07E-06	5.7	100	1.90E-06	7.6	100	2.07E-06	6.1	100	2.06E-06	4.3	100
25	3.94E-06	5.7	100	3.83E-06	7.6	100	3.75E-06	6.1	100	3.89E-06	4.3	100
26	1.57E-06	5.7	100	1.40E-06	7.6	100	1.52E-06	6.1	100	1.51E-06	4.3	100
27	2.31E-06	5.7	100	2.05E-06	7.6	100	2.29E-06	6.1	100	2.21E-06	4.3	100
28	3.55E-06	5.7	100	3.32E-06	7.6	100	3.34E-06	6.1	100	3.41E-06	4.3	100
29	3.73E-06	5.7	100	3.57E-06	7.6	100	3.41E-06	6.1	100	3.65E-06	4.3	100
30	6.13E-06	5.7	100	5.94E-06	7.6	100	5.63E-06	6.1	100	5.89E-06	4.3	100
31	5.73E-06	5.7	100	5.57E-06	7.6	100	5.27E-06	6.1	100	5.40E-06	4.3	100
1ヶ月値	3.70E-06	5.7	100	3.73E-06	7.2	100	3.40E-06	6.3	100	3.52E-06	4.4	100
*2 最大値	2.33E-05	5.7	103	2.27E-05	7.6	102	2.14E-05	6.6	103	2.33E-05	4.5	103
最大値日時	05/22 00:54	05/12 14:57	05/14 03:05	05/22 04:20	05/12 15:25	05/01 02:06	05/22 04:08	05/01 00:01	05/13 13:54	05/22 00:56	05/01 00:01	05/14 03:42
*2 最小値	0.00E+00	5.6	97	0.00E+00	6.5	97	0.00E+00	6.1	97	0.00E+00	4.3	97
最小値日時	05/12 14:58	05/01 00:01	05/03 20:45	05/12 15:26	05/01 00:01	05/13 14:35	05/12 14:48	05/12 14:48	05/03 07:45	05/12 15:18	05/12 15:17	05/13 23:55

\*1: ろ紙交換

\*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

# 測定月報

(7/7)

測定日: 2017/05

日	モニタ											
	A031 HTI南側(DM-73)			A032 HTI南側(DM-77)								
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	3.91E-06	12.2	100	4.00E-06	9.7	100						
2	2.46E-06	12.2	100	2.57E-06	9.7	100						
3	4.86E-06	12.2	100	4.66E-06	9.7	100						
4	4.29E-06	12.2	100	4.57E-06	9.7	100						
5	1.95E-06	12.2	100	2.06E-06	9.7	100						
6	6.20E-06	12.2	100	6.21E-06	9.7	100						
7	2.55E-06	12.2	100	2.70E-06	9.7	100						
8	2.78E-06	12.2	100	2.85E-06	9.7	100						
9	2.00E-06	12.2	100	2.06E-06	9.7	100						
10	4.94E-06	12.2	100	4.79E-06	9.7	100						
11	*1 3.75E-06	12.0	100	*1 3.96E-06	9.5	100						
12	2.91E-06	11.7	100	3.15E-06	9.3	100						
13	1.75E-06	11.7	100	1.79E-06	9.3	100						
14	4.59E-07	11.7	100	3.57E-07	9.3	100						
15	9.49E-07	11.7	100	9.63E-07	9.3	100						
16	2.57E-06	11.7	100	2.70E-06	9.3	100						
17	2.70E-06	11.7	100	2.81E-06	9.3	100						
18	4.20E-06	11.7	100	4.27E-06	9.3	100						
19	4.42E-06	11.7	100	4.49E-06	9.3	100						
20	5.63E-06	11.7	100	6.06E-06	9.3	100						
21	9.72E-06	11.7	100	1.04E-05	9.3	100						
22	9.01E-06	11.7	100	9.43E-06	9.3	100						
23	1.60E-06	11.7	100	1.66E-06	9.3	100						
24	2.61E-06	11.7	100	2.70E-06	9.3	100						
25	5.00E-06	11.7	100	5.17E-06	9.3	100						
26	1.65E-06	11.7	100	1.75E-06	9.3	100						
27	2.40E-06	11.7	100	2.51E-06	9.3	100						
28	4.07E-06	11.7	100	4.28E-06	9.3	100						
29	3.78E-06	11.7	100	3.91E-06	9.3	100						
30	6.63E-06	11.7	100	6.96E-06	9.3	100						
31	6.82E-06	11.7	100	6.99E-06	9.3	100						
1ヶ月値	3.82E-06	11.9	100	3.96E-06	9.4	100						
*2 最大値	2.76E-05	12.2	102	2.47E-05	9.7	102						
最大値日時	05/11 14:05	05/01 00:01	05/02 01:24	05/22 04:15	05/01 00:01	05/01 08:32						
*2 最小値	0.00E+00	11.7	98	0.00E+00	9.3	98						
最小値日時	05/05 17:45	05/11 14:05	05/01 11:37	05/14 03:51	05/11 14:37	05/01 21:14						

\*1: ろ紙交換

\*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする