

測定月報

測定日：2017/10

(1/11)

日	モニタ									
	B001	B002	B003	B004	B005	B006	B007	B008	B009	B010
	入退域管理棟周辺 線量率 (μ Sv/h)	正門警備所周辺 線量率 (μ Sv/h)	環境管理棟周辺 線量率 (μ Sv/h)	車両スクリーニング場周辺 線量率 (μ Sv/h)	厚生棟休憩所周辺 線量率 (μ Sv/h)	登録センター休憩所周辺 線量率 (μ Sv/h)	5/6号サービス建屋休憩所周辺 線量率 (μ Sv/h)	シールド中央制御室周辺 線量率 (μ Sv/h)	免震重要棟周辺 線量率 (μ Sv/h)	5/6号防護本部周辺 線量率 (μ Sv/h)
1	0.244	0.574	2.305	0.518	0.643	1.570	1.263	2.897	6.803	1.110
2	0.244	0.573	2.304	0.525	0.644	1.577	1.273	2.903	6.851	1.129
3	0.245	0.572	2.298	0.530	0.647	1.573	1.279	2.934	6.854	1.133
4	0.238	0.568	2.289	0.524	0.642	1.563	1.268	2.901	6.784	1.109
5	0.238	0.564	2.284	0.520	0.638	1.557	1.255	2.886	6.739	1.097
6	0.241	0.565	2.285	0.519	0.640	1.552	1.260	2.888	6.749	1.100
7	0.238	0.554	2.250	0.512	0.632	1.539	1.223	2.823	6.719	1.081
8	0.240	0.559	2.278	0.517	0.634	1.555	1.240	2.856	6.754	1.086
9	0.241	0.567	2.278	0.518	0.637	1.552	1.250	2.870	6.764	1.097
10	0.244	0.567	2.288	0.520	0.644	1.560	1.262	2.883	6.812	1.120
11	0.241	0.564	2.269	0.516	0.633	1.576	1.239	2.844	6.735	1.097
12	0.242	0.568	2.269	0.520	0.635	1.567	1.252	2.856	6.773	1.103
13	0.237	0.542	2.231	0.510	0.625	1.533	1.203	2.773	6.638	1.056
14	0.234	0.539	2.225	0.508	0.624	1.529	1.201	2.783	6.627	1.056
15	0.234	0.548	2.251	0.510	0.622	1.534	1.211	2.797	6.669	1.064
16	0.234	0.544	2.231	0.509	0.619	1.529	1.200	2.775	6.552	1.047
17	0.231	0.549	2.237	0.513	0.621	1.540	1.200	2.783	6.593	1.053
18	0.232	0.543	2.251	0.512	0.623	1.546	1.209	2.807	6.613	1.062
19	0.231	0.537	2.209	0.506	0.614	1.522	1.178	2.747	6.503	1.032
20	0.232	0.530	2.192	0.508	0.611	1.523	1.176	2.722	6.512	1.032
21	0.235	0.537	2.211	0.508	0.621	1.529	1.192	2.757	6.594	1.050
22	0.233	0.531	2.177	0.504	0.612	1.519	1.172	2.700	6.575	1.034
23	0.233	0.540	2.197	0.509	0.619	1.517	1.186	2.670	6.594	1.048
24	0.231	0.538	2.232	0.510	0.626	1.524	1.198	2.754	6.579	1.052
25	0.231	0.549	2.246	0.511	0.628	1.533	1.209	2.764	6.606	1.057
26	0.229	0.558	2.250	0.509	0.626	1.540	1.216	2.751	6.615	1.064
27	0.231	0.557	2.246	0.509	0.624	1.541	1.218	2.688	6.613	1.066
28	0.233	0.557	2.247	0.510	0.625	1.534	1.220	2.698	6.635	1.069
29	0.233	0.549	2.187	0.497	0.609	1.506	1.180	2.615	6.545	1.041
30	0.228	0.560	2.230	0.505	0.620	1.522	1.202	2.643	6.585	1.056
31	0.228	0.556	2.232	0.502	0.619	1.534	1.204	2.654	6.561	1.053
1ヶ月値	0.236	0.554	2.248	0.513	0.627	1.542	1.220	2.788	6.663	1.073
最大値	0.286	0.675	2.392	0.576	0.706	1.823	1.336	3.176	7.003	1.184
最大値日時	10/03 20:00	10/30 09:40	10/01 13:20	10/03 23:10	10/04 07:00	10/24 07:00	10/04 18:50	10/02 09:50	10/03 13:40	10/03 11:30
最小値	0.180	0.484	2.045	0.460	0.555	1.413	1.087	2.218	6.275	0.958
最小値日時	10/24 20:20	10/21 19:30	10/23 03:00	10/26 20:40	10/23 06:10	10/22 17:30	10/23 03:00	10/23 03:10	10/24 14:10	10/22 21:00

測定月報

測定日：2017/10

(2/11)

日	モニタ									
	B011	B012	B013	B014	B015	B016	B017	B018	B019	B020
	1号北側法面上周辺	1/2号西側法面上周辺	3/4号西側法面上周辺	4号南側法面上周辺	一般焼却炉周辺	車両整備場周辺	多核種除去施設周辺	キャスク仮保管施設周辺	野島の森五差路周辺	5/6号機西側周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	58.250	49.278	11.668	1.908	※1	0.806	0.779	0.539	3.012	6.474
2	58.698	49.738	11.878	1.929		0.815	0.787	0.553	3.101	6.509
3	58.917	49.877	11.951	1.940		0.844	0.782	0.562	3.129	6.526
4	58.120	49.000	11.584	1.904		0.890	0.776	0.538	2.949	6.522
5	57.510	48.508	11.379	1.880		0.837	0.795	0.537	2.863	6.496
6	57.484	48.619	11.454	1.879		0.875	0.769	0.411	2.899	6.498
7	56.740	48.270	11.454	1.857	22.521	0.816	0.749	0.347	2.943	6.256
8	57.268	48.628	11.497	1.874	22.800	0.821	0.760	0.344	2.949	6.341
9	57.553	48.723	11.529	1.889	22.900	0.824	0.762	0.347	2.960	6.386
10	58.270	49.295	11.777	1.918	22.844	0.867	0.775	0.358	3.066	6.433
11	57.248	48.458	11.540	1.875	※1	0.849	0.753	0.349	2.948	6.348
12	57.567	48.684	11.611	1.895		0.857	0.735	0.347	3.029	6.386
13	55.651	47.031	11.123	1.792		0.864	0.678	0.332	2.811	6.134
14	55.486	46.999	11.091	1.798		0.852	0.635	0.328	2.801	6.130
15	55.799	47.299	11.135	1.813		0.856	0.641	0.328	2.816	6.202
16	55.095	46.669	10.925	1.780		0.848	0.649	0.327	2.708	6.173
17	55.722	46.933	11.092	1.811		0.826	0.667	0.326	2.778	6.183
18	55.875	47.110	11.035	1.796		0.828	0.671	0.330	2.768	6.266
19	54.551	46.131	10.804	1.750	21.901	0.825	0.647	0.330	2.705	6.084
20	54.538	46.224	10.904	1.725	21.668	0.849	0.652	0.337	2.750	6.021
21	55.383	46.849	11.167	1.758	21.960	0.882	0.670	0.346	2.851	6.073
22	55.030	46.482	11.199	1.708	21.131	0.872	0.668	0.351	2.879	5.921
23	54.873	46.485	11.218	1.710	21.395	0.874	0.689	0.363	2.908	5.964
24	54.984	46.541	11.002	1.750	22.301	0.878	0.700	0.351	2.735	6.178
25	55.153	46.638	10.981	1.766	22.417	0.888	0.707	0.351	2.744	6.218
26	55.704	46.831	10.986	1.780	22.484	0.893	0.705	0.352	2.782	6.250
27	55.817	46.895	11.047	1.781	22.524	0.900	0.695	0.354	2.781	6.263
28	55.853	47.014	11.072	1.784	22.615	0.903	0.689	0.352	2.793	6.273
29	54.609	46.120	10.946	1.711	21.570	0.881	0.652	0.346	2.805	6.020
30	55.198	46.430	10.978	1.747	22.213	0.884	0.671	0.343	2.796	6.162
31	54.894	46.115	10.780	1.750	22.368	0.889	0.674	0.334	2.715	6.212
1ヶ月値	56.259	47.543	11.251	1.815	22.191	0.858	0.709	0.377	2.863	6.255
最大値	60.085	50.615	12.263	2.046	23.253	1.241	1.078	0.729	3.277	6.689
最大値日時	10/03 14:20	10/03 13:20	10/03 13:20	10/03 11:20	10/09 11:50	10/06 08:10	10/10 12:50	10/03 08:40	10/03 03:00	10/06 13:20
最小値	48.550	41.573	9.639	1.519	19.323	0.719	0.567	0.276	2.530	5.487
最小値日時	10/25 15:30	10/17 15:40	10/26 08:50	10/23 03:10	10/23 03:10	10/18 11:40	10/19 12:10	10/16 08:10	10/16 13:40	10/23 02:40

*1: 通信エラーに伴う欠測

測定月報

測定日: 2017/10

(3/11)

日	モニタ									
	B021 西門周辺	B022 さくら通り正門側	B023 増設多核種除去設備西側周辺	B024 Hタンクエリア周辺(濃縮ダストモニタの設置)	B025 1・2号機海側(4m壁)	B026 3・4号機海側(4m壁)	B027 固体廃棄物貯蔵庫管理棟周辺	B028 高性能多核種除去設備周辺	B029 サブドレン浄化設備周辺	B030 給油所周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	1.681	0.994	0.362	6.342	※1	21.054	9.159	1.309	0.329	0.520
2	1.702	0.983	0.372	6.364		21.194	9.194	1.316	0.332	0.524
3	1.695	0.978	0.375	6.386		21.292	9.234	1.318	0.329	0.523
4	1.680	0.966	0.355	6.365	※1	20.875	9.175	1.297	0.319	0.521
5	1.668	0.964	0.349	6.354			9.105	1.293	0.314	0.516
6	1.696	0.975	0.353	6.341			9.106	1.291	0.314	0.517
7	1.697	0.940	0.360	6.214			8.869	1.284	0.319	0.506
8	1.703	0.949	0.359	6.264			8.945	1.290	0.327	0.510
9	1.672	0.956	0.359	6.290			8.998	1.291	0.320	0.509
10	1.727	0.969	0.369	6.329			9.056	1.307	0.319	0.520
11	1.694	0.953	0.359	6.272			8.915	1.285	0.319	0.511
12	1.656	0.958	0.366	6.285			8.948	1.293	0.322	0.512
13	1.624	0.940	0.351	6.147			8.688	1.259	0.319	0.502
14	1.622	0.938	0.346	6.142			8.698	1.258	0.316	0.499
15	1.630	0.947	0.344	6.181			8.764	1.261	0.319	0.499
16	1.620	0.953	0.342	6.149			8.679	1.250	0.317	0.498
17	1.731	0.941	0.344	6.157			8.692	1.257	0.318	0.498
18	1.817	0.940	0.340	6.202			8.782	1.262	0.313	0.499
19	1.696	0.936	0.339	6.091			8.588	1.242	0.317	0.499
20	1.602	0.945	0.347	6.037			8.542	1.240	0.330	0.521
21	1.613	0.961	0.355	6.084			8.626	1.261	0.349	0.538
22	1.619	0.950	0.362	5.944			8.511	1.247	0.358	0.547
23	1.686	0.952	0.368	5.946			8.576	1.266	0.365	0.562
24	1.666	0.955	0.346	6.147			8.664	1.271	0.351	0.564
25	1.634	0.946	0.348	6.175			8.731	1.283	0.338	0.558
26	1.641	0.961	0.350	6.188			8.768	1.290	0.333	0.558
27	1.630	0.958	0.352	6.200			8.777	1.300	0.345	0.568
28	1.626	0.945	0.350	6.204			8.795	1.299	0.334	0.556
29	1.595	0.913	0.351	6.009			8.536	1.284	0.327	0.538
30	1.611	0.931	0.349	6.123			8.668	1.297	0.324	0.530
31	1.618	0.939	0.338	6.160			8.716	1.292	0.322	0.525
1ヶ月値	1.663	0.953	0.354	6.197		21.128	8.822	1.280	0.328	0.524
最大値	2.046	1.074	0.433	6.595		21.715	9.886	1.398	0.500	0.637
最大値日時	10/17 10:50	10/03 13:00	10/03 13:20	10/06 13:20		10/03 13:40	10/31 18:30	10/10 05:00	10/08 16:30	10/10 13:00
最小値	1.504	0.848	0.302	5.303		19.969	7.964	1.183	0.259	0.446
最小値日時	10/24 14:40	10/29 18:10	10/18 22:20	10/23 03:20		10/04 07:50	10/30 10:40	10/22 13:30	10/12 11:00	10/17 05:20

*1:線量標示器の故障に伴う欠測

測定月報

測定日: 2017/10

(4/11)

日	モニタ									
	B031	B032	B033	B034	B035	B036	B037	B038	B039	B040
	HIC保管エリア周辺	H8タンクエリア周辺	H4タンクエリア周辺	H5タンクエリア周辺	J2タンクエリア周辺	G6タンクエリア周辺	セシウム吸着塔中間貯蔵施設周辺	2uR/B西側	1uR/B西側	1uR/B北側
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	0.663	0.591	2.621	1.079	1.960	1.980	1.311	91.282	95.662	59.433
2	0.670	0.593	2.658	1.077	1.969	1.982	1.315	91.781	94.537	59.917
3	0.678	0.593	2.679	1.070	1.982	1.985	1.348	92.128	93.961	60.145
4	0.649	0.589	2.576	1.061	1.961	2.143	1.311	90.600	93.457	59.554
5	0.646	0.567	2.529	1.061	1.986	2.106	1.296	89.881	92.953	59.213
6	0.654	0.561	2.539	1.064	1.978	1.926	1.306	90.235	93.389	59.178
7	0.649	0.547	2.559	0.949	1.927	1.867	1.301	90.172	92.861	57.512
8	0.649	0.549	2.576	0.957	1.944	1.888	1.303	90.528	93.181	57.981
9	0.655	0.555	2.558	0.971	1.955	1.899	1.302	90.761	90.039	58.269
10	0.665	0.561	2.610	0.977	1.970	1.903	1.334	91.317	89.142	58.884
11	0.652	0.526	2.507	0.967	1.964	1.878	1.273	89.503	85.143	57.180
12	0.661	0.507	2.536	0.978	1.978	1.916	1.192	89.543	85.699	57.020
13	0.637	0.496	2.404	0.966	1.929	1.867	1.060	86.783	84.183	55.310
14	0.636	0.497	2.409	0.970	1.921	1.907	1.054	87.234	83.942	55.214
15	0.636	0.494	2.426	0.972	1.899	1.915	1.061	87.479	84.214	55.582
16	0.630	0.490	2.351	0.967	1.992	1.881	1.061	86.141	83.161	54.937
17	0.633	0.494	2.400	0.969	2.024	1.885	1.099	87.535	81.587	55.324
18	0.632	0.502	2.421	0.967	2.005	1.913	1.164	87.088	83.313	55.574
19	0.623	0.504	2.370	1.002	1.926	1.877	1.167	85.531	82.266	54.425
20	0.628	0.535	2.380	1.209	1.892	1.838	1.161	86.403	82.378	54.424
21	0.637	0.563	2.466	1.318	1.842	1.867	1.170	56.863	71.335	54.972
22	0.638	0.584	2.430	1.361	1.766	1.824	1.162	34.707	64.129	54.629
23	0.646	0.596	2.394	1.434	1.770	1.823	1.171	34.392	63.954	54.535
24	0.635	0.591	2.390	1.440	1.796	1.876	1.148	61.569	72.312	54.937
25	0.637	0.574	2.411	1.359	1.814	1.887	1.142	88.644	81.212	54.964
26	0.637	0.577	2.427	1.372	1.827	1.898	1.140	88.742	82.332	55.218
27	0.639	0.591	2.430	1.405	1.835	1.892	1.147	88.171	82.233	55.949
28	0.639	0.570	2.446	1.293	1.841	1.917	1.152	88.523	81.534	56.028
29	0.632	0.545	2.408	1.210	1.775	1.838	1.129	87.782	80.410	54.410
30	0.634	0.532	2.408	1.157	1.805	1.867	1.138	87.268	82.051	54.494
31	0.625	0.526	2.373	1.123	1.811	1.868	1.123	86.580	82.432	54.422
1ヶ月値	0.643	0.549	2.473	1.120	1.905	1.907	1.195	83.504	84.249	56.457
最大値	0.731	0.813	2.792	1.532	2.708	2.448	2.585	93.460	96.878	60.972
最大値日時	10/06 10:00	10/04 11:40	10/03 14:00	10/24 09:50	10/05 11:00	10/04 13:30	10/03 07:20	10/03 10:20	10/01 11:10	10/03 12:40
最小値	0.569	0.439	2.175	0.872	1.667	1.057	1.002	33.437	45.238	49.139
最小値日時	10/04 11:50	10/17 13:50	10/23 03:40	10/10 16:20	10/23 02:50	10/04 09:50	10/14 02:50	10/23 06:00	10/24 10:40	10/23 03:10

測定月報

測定日: 2017/10

(5/11)

日	モニタ									
	B041	B042	B043	B044	B045	B046	B047	B048	B049	B050
	集中RW西側法面上	大型メンテナンス建屋 東側	大熊通り中央付近	1~4号機PPゲート前	12uS/B周辺	3.4uS/B周辺	集中RW東側	集中RW南側	共用プール西側	4uR/B西側
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	2.803	3.866	3.661	22.851	32.959	88.767	15.660	7.825	36.186	9.931
2	2.856	3.927	3.712	23.034	33.051	87.778	11.528	7.848	36.326	9.982
3	2.877	3.953	3.729	23.159	33.510	84.828	11.522	7.873	36.390	10.064
4	2.738	3.836	3.672	22.721	33.805	85.304	11.814	7.859	36.342	10.080
5	2.674	3.776	3.649	22.419	34.042	81.128	9.158	7.851	36.347	9.989
6	2.731	3.790	3.652	22.551	34.240	82.741	12.209	7.809	36.259	9.874
7	2.769	3.814	3.550	22.328	33.669	85.943	15.244	7.479	34.555	9.773
8	2.789	3.816	3.578	22.445	33.942	87.236	15.699	7.688	35.440	9.856
9	2.806	3.831	3.611	22.529	34.026	87.689	14.683	7.745	35.635	9.892
10	2.845	3.894	3.666	22.861	34.756	87.081	14.851	7.780	35.848	9.948
11	2.773	3.824	3.598	22.501	34.789	81.090	12.303	7.695	35.425	9.810
12	2.757	3.863	3.619	22.647	34.935	81.121	9.576	7.676	35.196	9.797
13	2.630	3.737	3.491	21.861	33.826	82.812	8.275	7.403	33.520	9.499
14	2.629	3.721	3.483	21.793	33.991	81.465	8.151	7.448	33.814	9.479
15	2.646	3.725	3.506	21.937	34.225	82.363	8.151	7.588	34.548	9.560
16	2.562	3.666	3.472	21.594	33.694	83.340	8.072	7.462	33.983	9.412
17	2.614	3.711	3.497	21.765	33.853	84.114	8.845	7.530	34.159	9.500
18	2.632	3.697	3.519	21.800	33.934	84.945	10.829	7.592	34.714	9.294
19	2.550	3.645	3.442	21.245	33.310	83.379	12.076	*1	33.195	8.797
20	2.529	3.680	3.448	21.310	33.574	80.961	10.307		31.978	8.751
21	2.645	3.728	3.473	21.762	34.375	82.109	8.670		32.683	8.743
22	2.633	3.753	3.460	21.699	34.053	80.065	8.161		30.889	8.564
23	2.635	3.779	3.490	21.620	33.738	79.704	7.824		31.097	8.576
24	2.588	3.668	3.471	21.474	33.539	82.609	7.929		34.035	8.762
25	2.604	3.685	3.494	21.542	33.106	83.066	8.641	7.582	34.326	8.843
26	2.615	3.683	3.522	21.625	33.041	84.898	8.896	7.603	34.495	8.926
27	2.628	3.684	3.533	21.641	33.149	84.584	9.620	7.647	34.555	8.905
28	2.639	3.690	3.538	21.705	33.362	85.224	11.466	7.656	34.602	8.924
29	2.589	3.693	3.456	21.261	32.509	81.457	10.804	7.114	31.393	8.635
30	2.584	3.699	3.487	21.443	32.577	82.839	10.909	7.501	33.463	8.775
31	2.519	3.640	3.482	21.371	32.646	84.038	10.634	7.575	34.309	8.776
1ヶ月値	2.673	3.757	3.547	22.015	33.694	83.743	10.727	7.625	34.385	9.361
最大値	3.028	4.106	3.876	23.731	38.257	89.643	17.698	8.057	36.985	10.389
最大値日時	10/03 14:20	10/03 10:40	10/10 12:50	10/03 14:10	10/10 13:10	10/01 11:30	10/06 14:40	10/03 12:50	10/06 12:30	10/04 13:10
最小値	1.948	3.497	3.297	18.961	29.478	66.766	7.149	6.791	27.840	8.094
最小値日時	10/20 13:10	10/31 03:50	10/23 02:50	10/19 07:10	10/02 10:20	10/03 17:20	10/24 15:10	10/29 20:50	10/23 03:10	10/23 03:00

*1: 通信エラーに伴う欠測

測定月報

測定日: 2017/10

(6/11)

日	モニタ									
	B051	B052	B053	B054	B055	B056	B057	B058	B059	B060
	3uR/B西側	2uR/B西側	1uR/B西側	1uR/B北側	物揚場周辺	固体庫1, 2棟周辺	旧事務本館北側	固体庫第9棟建設地周辺	危険物屋外貯蔵所周辺	6号機D/G建屋周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	124.443	97.212	97.295	62.424	6.806	5.264	13.790	0.398	1.314	2.282
2	124.051	97.509	95.848	62.930	6.764	5.271	13.936	0.396	1.330	2.300
3	124.123	97.820	94.621	63.138	6.862	5.291	13.984	0.396	1.339	2.249
4	123.823	96.710	94.231	62.458	6.539	5.173	13.741	0.393	1.330	2.277
5	122.982	96.052	94.308	62.119	6.465	5.125	13.568	0.387	1.319	2.294
6	123.309	96.050	95.304	61.986	6.524	5.158	13.614	0.399	1.323	2.297
7	121.551	95.234	94.836	60.436	6.449	5.074	13.455	0.356	1.260	2.126
8	122.431	95.710	95.211	60.855	6.507	5.125	13.595	0.327	1.281	2.231
9	122.664	95.841	92.538	61.170	6.552	5.068	13.618	0.344	1.290	2.271
10	123.769	96.373	91.880	61.843	6.700	5.149	13.820	0.355	1.293	2.286
11	122.521	95.273	87.581	60.075	6.534	4.997	13.537	0.351	1.271	2.260
12	123.254	95.707	88.621	60.026	6.547	5.005	13.638	0.342	1.273	2.236
13	120.993	93.943	87.233	58.317	6.186	4.929	13.138	0.314	1.219	2.060
14	120.955	93.685	86.965	58.237	6.247	4.963	13.127	0.351	1.223	2.079
15	121.496	93.935	87.289	58.624	6.288	5.016	13.246	0.379	1.233	2.186
16	120.414	93.086	86.193	57.782	6.108	4.926	12.982	0.369	1.228	2.141
17	120.538	93.669	84.413	58.123	6.210	4.878	13.110	0.375	1.229	2.115
18	121.275	93.756	86.344	58.181	6.273	4.930	13.145	0.356	1.247	2.211
19	118.423	92.471	85.469	57.005	6.045	4.826	12.758	0.335	1.202	2.046
20	117.614	92.575	85.689	56.928	6.108	4.857	12.734	0.333	1.182	1.987
21	118.909	85.440	79.254	57.567	6.283	4.955	13.065	0.336	1.198	2.019
22	115.078	80.104	75.359	57.206	6.250	4.890	12.797	0.322	1.163	1.947
23	115.369	79.946	75.030	57.143	6.287	4.946	12.818	0.334	1.179	2.033
24	121.019	85.631	79.606	57.399	6.140	4.954	12.927	0.319	1.231	2.204
25	120.435	92.904	85.548	57.425	6.212	4.981	13.054	0.335	1.241	2.228
26	119.133	92.830	86.577	57.774	6.256	5.037	13.114	0.377	1.249	2.180
27	120.107	92.187	86.168	58.432	6.167	5.060	13.126	0.380	1.256	2.233
28	120.129	92.659	85.129	58.563	6.141	5.069	13.147	0.391	1.260	2.245
29	119.238	91.557	83.873	56.995	6.053	4.896	12.737	0.391	1.186	2.017
30	121.088	92.686	85.331	57.040	6.145	4.957	13.010	0.365	1.214	2.166
31	120.405	93.269	85.677	56.913	6.101	4.921	12.965	*9 0.386	1.233	2.225
1ヶ月値	121.049	93.029	87.791	59.207	6.346	5.022	13.268	0.360	1.251	2.175
最大値	127.796	98.918	98.738	64.036	7.101	5.551	14.300	0.443	1.393	2.394
最大値日時	10/06 09:40	10/03 12:50	10/01 14:10	10/03 13:20	10/02 15:00	10/03 13:10	10/03 13:00	10/04 13:00	10/04 16:00	10/01 16:40
最小値	88.114	66.884	46.752	52.676	5.199	4.183	11.606	0.264	1.061	1.668
最小値日時	10/19 07:30	10/24 09:30	10/24 10:40	10/23 03:10	10/25 07:40	10/12 21:40	10/23 03:10	10/25 03:00	10/22 21:40	10/23 03:00

*9: その他

測定月報

測定日: 2017/10

(7/11)

日	モニタ									
	B061 5・6号機放水口周辺	B062 焼却設備建屋周辺	B063 Fタンクエリア周辺	B064 ヤード P1東側周辺	B065 焼却設備建屋前道路カーブ側	B066 資材置場	B067 一時保管エリアC周辺	B068 一時保管エリアI周辺	B069 一時保管エリアH1周辺	B070 土捨場資材置場
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	1.460	1.966	6.020	12.698	2.836	3.536	1.710	13.428	3.855	0.716
2	1.472	1.971	6.026	12.714	2.851	3.546	1.726	13.508	3.863	0.721
3	1.478	1.977	6.041	12.717	2.858	3.559	1.727	13.587	3.886	0.726
4	1.470	1.969	6.148	12.731	2.843	3.545	1.723	13.619	3.893	0.719
5	1.469	1.955	7.077	12.705	2.831	3.535	1.688	13.651	3.897	0.713
6	1.469	1.953	8.489	12.697	2.831	3.553	1.679	13.649	3.891	0.712
7	1.409	1.905	8.706	12.542	2.763	3.510	1.637	12.919	3.711	0.684
8	1.435	1.925	8.742	12.595	2.782	3.533	1.647	13.096	3.758	0.688
9	1.439	1.939	8.748	12.617	2.796	3.546	1.658	13.231	3.791	0.697
10	1.453	1.953	8.531	12.643	2.814	3.567	1.732	13.351	3.824	0.705
11	1.437	1.932	8.582	12.591	2.790	3.456	1.673	13.153	3.766	0.687
12	1.435	1.945	8.351	12.601	2.803	3.485	1.787	13.126	3.769	0.692
13	1.394	1.886	17.380	12.454	2.726	3.409	1.693	12.613	3.638	0.658
14	1.393	1.881	30.769	12.432	2.719	3.420	1.643	12.665	3.648	0.658
15	1.409	1.894	30.803	12.474	2.745	3.442	1.656	12.841	3.685	0.666
16	1.402	1.883	30.740	12.431	2.724	3.410	1.655	12.751	3.679	0.657
17	1.404	1.885	30.759	12.422	2.728	3.442	1.663	12.762	3.670	0.656
18	1.414	1.898	30.745	12.460	2.741	3.490	1.651	13.000	3.736	0.663
19	1.378	1.861	30.604	12.347	2.689	3.397	1.601	12.557	3.620	0.648
20	1.366	1.854	30.647	12.288	2.670	3.326	1.569	12.218	3.556	0.642
21	1.380	1.862	30.699	12.331	2.693	3.337	1.578	12.347	3.593	0.644
22	1.359	1.844	30.656	12.259	2.655	3.301	1.542	11.936	3.506	0.636
23	1.382	1.864	30.650	12.261	2.675	3.324	1.497	12.143	3.540	0.640
24	1.400	1.880	30.618	12.341	2.710	3.376	1.562	12.756	3.680	0.646
25	1.410	1.890	30.614	12.438	2.733	3.427	*1 1.569	12.881	3.706	0.654
26	1.418	1.892	30.623	12.484	2.742	3.457		12.972	3.734	0.659
27	1.424	1.897	30.626	12.492	2.738	3.438		13.028	3.752	0.653
28	1.429	1.903	30.628	12.516	2.748	3.451		13.066	3.760	0.652
29	1.370	1.851	30.487	12.345	2.669	3.349		12.288	3.579	0.628
30	1.401	1.876	30.462	12.363	2.702	3.369		12.643	3.667	0.636
31	1.407	1.878	30.460	12.425	2.708	3.373		12.903	3.709	0.642
1ヶ月値	1.418	1.904	21.323	12.497	2.752	3.447	1.653	12.926	3.722	0.671
最大値	1.556	2.058	31.171	13.004	2.966	3.691	8.409	13.947	4.058	0.894
最大値日時	10/02 02:20	10/03 05:30	10/17 14:10	10/06 14:10	10/03 07:10	10/06 12:30	10/10 07:10	10/06 14:10	10/05 17:50	10/10 06:20
最小値	1.277	1.749	5.624	10.656	2.510	3.173	1.354	11.222	3.230	0.581
最小値日時	10/22 20:30	10/23 05:20	10/05 07:40	10/17 11:10	10/18 11:40	10/22 18:10	10/23 07:10	10/23 02:40	10/23 03:30	10/29 09:10

*1: 通信エラーに伴う欠測

測定月報

測定日: 2017/10

(8/11)

日	モニタ									
	B071	B072	B073	B074	B075	B076	B077	B078	B079	B080
	土捨場東側資材置場	瓦礫保管Aテント周辺	覆土式瓦礫保管エリアL北側	覆土式瓦礫保管エリアL南側	一時保管エリアG2周辺	一時保管エリアG1周辺	5・6号機迂回道路付近	一時保管エリアM周辺	旧研修棟正面玄関前	3・4号機北面ダストモニタ周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	2.122	25.900	4.725	0.712	0.452	1.205	3.690	1.939	54.179	12.473
2	2.131	25.857	4.744	0.723	0.458	1.212	3.707	1.958	54.291	12.751
3	2.139	25.708	4.739	0.722	0.458	1.219	3.717	1.972	57.786	12.841
4	2.118	25.817	4.730	0.707	0.449	1.216	3.698	1.977	58.727	12.363
5	2.113	25.888	4.724	0.700	0.443	1.209	3.703	1.962	57.856	12.086
6	2.115	25.999	4.767	0.710	0.449	1.215	3.706	1.970	55.763	12.169
7	2.079	25.217	4.583	0.705	0.448	1.170	3.552	1.875	54.807	12.198
8	2.097	25.526	4.664	0.707	0.453	1.183	3.598	1.892	55.558	12.269
9	2.113	25.714	4.696	0.712	0.453	1.193	3.626	1.906	55.831	12.298
10	2.116	25.781	4.725	0.724	0.460	1.203	3.655	1.930	56.231	12.628
11	2.101	25.583	4.687	0.700	0.455	1.190	3.603	1.904	55.547	12.300
12	2.102	25.470	4.675	0.712	0.455	1.192	3.618	1.905	56.012	12.462
13	2.051	24.708	4.457	0.685	0.441	1.142	3.485	1.830	54.816	11.822
14	2.046	24.779	4.466	0.677	0.435	1.141	3.499	1.824	54.831	11.776
15	2.061	24.982	4.536	0.681	0.437	1.152	3.535	1.841	55.326	11.829
16	2.044	25.049	4.535	0.674	0.434	1.142	3.498	1.826	53.250	11.563
17	2.056	25.369	4.530	0.683	0.436	1.151	3.504	1.827	50.608	11.788
18	2.059	25.636	4.599	0.682	0.435	1.162	3.544	1.856	51.154	11.728
19	2.026	25.040	4.449	0.668	0.431	1.128	3.460	1.798	49.619	11.442
20	2.016	24.825	4.317	0.671	0.431	1.100	3.425	1.770	47.412	11.582
21	2.029	24.408	4.279	0.666	0.426	1.115	3.463	1.780	48.182	11.995
22	1.999	23.927	4.053	0.660	0.426	1.045	3.391	1.737	46.086	12.115
23	2.012	23.704	3.840	0.668	0.427	1.062	3.436	1.741	45.597	12.153
24	2.029	24.339	4.288	0.658	0.422	1.118	3.507	1.802	48.880	11.727
25	2.042	24.746	4.397	0.674	0.433	1.152	3.523	1.819	50.993	11.689
26	2.039	25.196	4.485	0.678	0.438	1.173	3.535	1.835	56.316	11.746
27	2.053	25.223	4.567	0.679	0.440	1.179	3.555	1.835	65.373	11.726
28	2.053	25.199	4.579	0.679	0.438	1.180	3.580	1.845	65.048	11.753
29	2.016	24.237	4.365	0.672	0.435	1.116	3.441	1.757	63.246	11.650
30	2.034	24.673	4.381	0.674	0.436	1.157	3.488	1.796	64.696	11.668
31	2.035	24.970	4.416	0.671	0.433	1.167	3.522	1.819	65.164	11.392
1ヶ月値	2.066	25.149	4.515	0.688	0.441	1.161	3.553	1.855	55.097	11.997
最大値	2.230	29.220	4.890	0.780	0.500	1.401	3.889	2.056	70.812	13.338
最大値日時	10/03 13:40	10/16 16:40	10/01 14:50	10/10 00:10	10/17 10:20	10/04 11:10	10/06 16:20	10/06 09:10	10/26 19:40	10/03 13:00
最小値	1.898	22.668	3.428	0.600	0.377	0.759	3.151	1.595	39.848	10.917
最小値日時	10/17 07:40	10/23 02:40	10/23 03:10	10/30 14:30	10/24 01:20	10/23 03:10	10/05 14:50	10/23 03:10	10/18 16:30	10/31 06:00

測定月報

測定日: 2017/10

(9/11)

日	モニタ									
	B081 事務本館南	B082 大型メンテナンス建屋周辺	B083 2, 3号機間道路西側(10m盤)	B084 2号機海側 (4m盤)	B085 中央交差点	B086 No.4倉庫周辺	B087 1, 2u排気筒西側	B088 1・2号機海側(4m盤)	B089 線量表示器89	B090 線量表示器90
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	13.610	1.294	100.570	25.886	1.057	13.345	1301.411			
2	13.888	1.318	100.930	25.931	1.060	13.410	1303.267			
3	13.953	1.320	101.315	26.206	1.064	13.442	1303.301	※		
4	13.432	1.279	99.923	25.531	1.057	13.409	1298.416	13.486		
5	13.141	1.261	99.032	25.158	1.056	13.350	1295.700	13.385		
6	13.257	1.269	99.342	25.379	1.055	13.357	1296.674	13.507		
7	13.352	1.268	98.747	25.128	1.021	12.849	1292.256	13.480		
8	13.387	1.278	99.104	25.364	1.031	13.054	1294.421	13.562		
9	13.383	1.282	99.200	25.348	1.037	13.168	1295.024	13.635		
10	13.715	1.306	99.817	25.727	1.046	13.305	1297.060	13.913		
11	13.315	1.272	98.510	25.301	1.026	13.083	1285.560	13.629		
12	13.489	1.297	99.314	25.445	1.030	13.098	1285.590	13.811		
13	12.823	1.242	97.123	24.245	1.001	12.610	1274.724	13.199		
14	12.768	1.234	96.729	24.386	0.998	12.614	1272.909	13.178		
15	12.788	1.241	96.983	24.632	1.007	12.759	1275.233	13.261		
16	12.498	1.221	96.161	24.412	1.000	12.650	1270.245	13.000		
17	12.722	1.229	96.519	24.966	1.000	12.712	1271.997	13.255		
18	12.670	1.233	96.674	24.371	1.016	12.910	1324.932	13.257		
19	12.397	1.211	95.265	23.554	0.988	12.498	1429.833	13.009		
20	12.585	1.219	95.363	23.592	0.975	12.328	1432.256	13.160		
21	12.887	1.238	86.128	24.205	0.981	12.466	1436.898	13.549		
22	12.932	1.233	75.459	24.021	0.961	12.080	1434.499	13.543		
23	12.902	1.244	75.229	23.967	0.975	12.171	1431.736	13.522		
24	12.477	1.221	87.510	23.826	0.995	12.729	1433.727	13.215		
25	12.489	1.224	95.327	23.934	1.003	12.833	1417.525	13.269		
26	12.558	1.236	95.431	24.093	1.008	12.902	1398.569	13.305		
27	12.616	1.232	95.121	24.069	1.016	12.949	1398.721	13.257		
28	12.629	1.236	95.647	24.162	1.015	12.961	1400.939	13.313		
29	12.597	1.224	95.036	23.623	0.974	12.383	1393.940	13.115		
30	12.544	1.227	95.175	23.804	0.993	12.710	1393.553	13.114		
31	12.263	1.219	94.775	23.729	1.006	12.859	1391.883	12.915		
1ヶ月値	12.969	1.252	95.443	24.646	1.015	12.868	1342.509	13.348		
最大値	14.460	1.392	102.684	26.880	1.168	13.725	1443.102	14.267		
最大値日時	10/03 13:20	10/03 12:30	10/03 14:10	10/03 14:30	10/10 13:00	10/03 13:20	10/18 15:20	10/12 14:40		
最小値	11.764	1.141	52.421	21.283	0.888	10.995	318.227	12.382		
最小値日時	10/31 03:40	10/31 07:20	10/21 09:30	10/05 11:50	10/23 03:10	10/23 03:30	10/18 14:20	10/16 08:50		

* 1: B025の故障に伴い設置