

構内連続ダストモニタ測定記録(2020 年 2 月)

注記：表中、最大値・最小値に関しては、BG 測定による影響があるため値は参考値扱いとする。

測定月報

(1/8)

測定日: 2020/02

日	モニタ											
	A001 正門警備所 (DM72)			A002 正門警備所 (DM68)			A003 免震重要棟(DM74)			A004 免震重要棟(DM55)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	9.42E-07	1.4	100	1.02E-06	1.0	100	9.81E-07	11.9	100	1.10E-06	5.0	100
2	2.74E-06	1.4	100	2.90E-06	1.0	100	2.55E-06	11.9	100	2.73E-06	5.0	100
3	5.37E-06	1.4	100	5.65E-06	1.0	100	4.86E-06	11.9	100	5.21E-06	5.0	100
4	3.87E-06	1.4	100	4.11E-06	1.0	100	3.60E-06	11.9	100	3.89E-06	5.0	100
5	3.75E-06	1.4	100	3.98E-06	1.0	100	3.61E-06	11.9	100	3.88E-06	5.0	100
6	3.17E-06	1.4	100	3.32E-06	1.0	100	3.09E-06	11.9	100	3.38E-06	5.0	100
7	2.59E-06	1.4	100	2.76E-06	1.0	100	2.56E-06	11.9	100	2.80E-06	5.0	100
8	4.00E-06	1.4	100	4.26E-06	1.0	100	3.82E-06	11.9	100	4.11E-06	5.0	100
9	1.22E-06	1.4	100	1.35E-06	1.0	100	1.26E-06	11.9	100	1.42E-06	5.0	100
10	2.73E-06	1.4	100	2.98E-06	1.0	100	2.52E-06	11.9	100	2.77E-06	5.0	100
11	3.17E-06	1.4	100	3.46E-06	1.0	100	2.95E-06	11.9	100	3.21E-06	5.0	100
12	*1 5.47E-06	1.3	100	5.81E-06	1.0	100	4.86E-06	11.9	100	*1 4.99E-06	5.2	100
13	7.65E-06	1.3	100	*1 7.88E-06	1.0	100	6.38E-06	11.9	100	6.46E-06	5.4	100
14	2.89E-06	1.3	100	3.05E-06	1.0	100	2.74E-06	11.9	100	2.68E-06	5.4	100
15	4.97E-06	1.3	100	5.25E-06	1.0	100	4.63E-06	11.9	100	4.57E-06	5.4	100
16	4.67E-06	1.3	100	4.98E-06	1.0	100	4.56E-06	11.9	100	4.53E-06	5.4	100
17	3.09E-06	1.3	100	3.28E-06	1.0	100	2.95E-06	11.9	100	2.88E-06	5.4	100
18	2.87E-06	1.3	100	2.97E-06	1.0	100	2.57E-06	11.9	100	2.48E-06	5.4	100
19	1.99E-06	1.3	100	2.07E-06	1.0	100	1.91E-06	11.9	100	1.83E-06	5.4	100
20	4.07E-06	1.3	100	4.34E-06	1.0	100	3.64E-06	11.9	100	3.64E-06	5.4	100
21	4.48E-06	1.3	100	4.75E-06	1.0	100	3.90E-06	11.9	100	3.90E-06	5.4	100
22	6.14E-06	1.3	100	6.55E-06	1.0	100	5.59E-06	11.9	100	5.64E-06	5.4	100
23	4.56E-06	1.3	100	4.76E-06	1.0	100	4.34E-06	11.9	100	4.31E-06	5.4	100
24	5.54E-06	1.3	100	5.87E-06	1.0	100	5.24E-06	11.9	100	5.26E-06	5.4	100
25	5.05E-06	1.3	100	5.41E-06	1.0	100	*1 4.80E-06	11.8	100	4.68E-06	5.4	100
26	4.60E-06	1.3	100	4.89E-06	1.0	100	4.39E-06	11.8	100	4.28E-06	5.4	100
27	4.16E-06	1.3	100	4.44E-06	1.0	100	3.96E-06	11.8	100	3.95E-06	5.4	100
28	2.70E-06	1.3	100	2.89E-06	1.0	100	2.48E-06	11.8	100	2.42E-06	5.4	100
29	4.66E-06	1.3	100	4.88E-06	1.0	100	3.88E-06	11.8	100	3.81E-06	5.4	100
30												
31												
1ヶ月値	3.90E-06	1.3	100	4.13E-06	1.0	100	3.61E-06	11.9	100	3.68E-06	5.2	100
最大値	2.07E-05	1.4	103	2.04E-05	1.0	102	1.25E-04	11.9	103	1.54E-05	5.4	102
最大値日時	02/13 08:08	02/01 00:01	02/07 06:31	02/13 07:48	02/01 00:01	02/01 14:09	02/25 09:21	02/01 00:01	02/04 03:33	02/13 08:06	02/12 09:21	02/01 01:54
最小値	2.78E-07	1.3	98	3.37E-07	1.0	98	0.00E+00	11.8	97	0.00E+00	5.0	98
最小値日時	02/01 17:28	02/12 10:17	02/01 00:35	02/01 17:01	02/01 00:01	02/01 08:12	02/01 06:27	02/25 09:21	02/03 01:37	02/12 09:21	02/01 00:01	02/01 19:26

*1: ろ紙交換

測定月報

(2/8)

測定日: 2020/02

日	モニタ											
	A005 5/6号警備所前(DM66)			A006 5/6号警備所前(DM48)			A007 1号北側法面上(旧厚生棟)(DM61)			A008 1号北側法面上(旧厚生棟)(DM70)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.02E-06	3.2	100	9.32E-07	1.5	100	9.80E-07	9.0	100	8.77E-07	6.4	100
2	2.78E-06	3.2	100	2.50E-06	1.5	100	2.54E-06	9.0	100	2.67E-06	6.4	100
3	5.30E-06	3.2	100	4.84E-06	1.5	100	4.92E-06	9.0	100	5.26E-06	6.4	100
4	3.98E-06	3.2	100	3.51E-06	1.5	100	3.59E-06	9.0	100	3.77E-06	6.4	100
5	*1 4.00E-06	3.2	100	3.55E-06	1.5	100	3.59E-06	9.0	100	*1 3.97E-06	6.2	100
6	3.51E-06	3.2	100	3.10E-06	1.5	100	3.13E-06	9.0	100	3.48E-06	6.1	100
7	2.78E-06	3.2	100	2.45E-06	1.5	100	2.54E-06	9.0	100	2.86E-06	6.1	100
8	4.23E-06	3.2	100	3.69E-06	1.5	100	3.72E-06	9.0	100	4.18E-06	6.1	100
9	1.34E-06	3.2	100	1.19E-06	1.5	100	1.30E-06	9.0	100	1.43E-06	6.1	100
10	2.66E-06	3.2	100	2.31E-06	1.5	100	2.57E-06	9.0	100	2.83E-06	6.1	100
11	3.39E-06	3.2	100	2.94E-06	1.5	100	3.02E-06	9.0	100	3.42E-06	6.1	100
12	5.50E-06	3.2	100	4.85E-06	1.5	100	5.10E-06	9.0	100	5.59E-06	6.1	100
13	7.33E-06	3.2	100	6.40E-06	1.5	100	6.34E-06	9.0	100	7.25E-06	6.1	100
14	3.16E-06	3.2	100	2.75E-06	1.5	100	2.89E-06	9.0	100	3.32E-06	6.1	100
15	5.17E-06	3.2	100	4.59E-06	1.5	100	4.60E-06	9.0	100	5.24E-06	6.1	100
16	5.31E-06	3.2	100	4.54E-06	1.5	100	4.58E-06	9.0	100	5.15E-06	6.1	100
17	3.41E-06	3.2	100	2.99E-06	1.5	100	3.01E-06	9.0	100	3.42E-06	6.1	100
18	2.95E-06	3.2	100	*1 2.56E-06	1.6	100	*1 2.60E-06	9.1	100	2.98E-06	6.1	100
19	2.17E-06	3.2	100	1.88E-06	1.6	100	1.92E-06	9.2	100	2.25E-06	6.1	100
20	4.18E-06	3.2	100	3.61E-06	1.6	100	3.61E-06	9.2	100	4.11E-06	6.1	100
21	4.56E-06	3.2	100	3.91E-06	1.6	100	3.98E-06	9.2	100	4.58E-06	6.1	100
22	6.80E-06	3.2	100	5.78E-06	1.6	100	5.60E-06	9.2	100	6.41E-06	6.1	100
23	5.12E-06	3.2	100	4.40E-06	1.6	100	4.34E-06	9.2	100	4.90E-06	6.1	100
24	5.90E-06	3.2	100	5.23E-06	1.6	100	5.28E-06	9.2	100	5.98E-06	6.1	100
25	5.47E-06	3.2	100	4.76E-06	1.6	100	4.68E-06	9.2	100	5.35E-06	6.1	100
26	5.07E-06	3.2	100	4.40E-06	1.6	100	4.33E-06	9.2	100	4.94E-06	6.1	100
27	4.66E-06	3.2	100	4.06E-06	1.6	100	3.98E-06	9.2	100	4.56E-06	6.1	100
28	2.84E-06	3.2	100	2.45E-06	1.6	100	2.48E-06	9.2	100	2.92E-06	6.1	100
29	4.19E-06	3.2	100	3.67E-06	1.6	100	3.86E-06	9.2	100	4.46E-06	6.1	100
30												
31												
1ヶ月値	4.10E-06	3.2	100	3.58E-06	1.5	100	3.62E-06	9.1	100	4.07E-06	6.1	100
最大値	1.65E-05	3.2	102	1.43E-05	1.6	102	1.58E-05	9.2	102	1.99E-05	6.4	101
最大値日時	02/13 07:57	02/01 00:01	02/02 04:42	02/13 08:11	02/18 10:59	02/01 07:14	02/13 07:52	02/18 10:59	02/01 05:39	02/05 10:50	02/01 00:01	02/01 00:16
最小値	0.00E+00	3.2	98	3.34E-07	1.5	98	0.00E+00	9.0	97	0.00E+00	6.1	98
最小値日時	02/05 10:58	02/01 00:01	02/02 01:30	02/01 17:43	02/01 00:01	02/01 08:35	02/01 03:49	02/01 00:01	02/03 02:01	02/05 10:53	02/05 10:50	02/10 14:52

*1: ろ紙交換

測定月報

測定日: 2020/02

(3/8)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上(DM51)			1/2号西側法面上(DM58)			3/4号西側法面上(DM57)			3/4号西側法面上(DM45)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.09E-06	5.4	100	9.57E-07	9.9	100	9.38E-07	3.9	100	9.97E-07	3.5	100
2	2.85E-06	5.4	100	2.52E-06	9.9	100	2.63E-06	3.9	100	2.68E-06	3.5	100
3	5.42E-06	5.4	100	4.83E-06	9.9	100	5.05E-06	3.9	100	5.14E-06	3.5	100
4	4.01E-06	5.4	100	3.55E-06	9.9	100	3.77E-06	3.9	100	3.87E-06	3.5	100
5	4.02E-06	5.4	100	3.60E-06	9.9	100	3.73E-06	3.9	100	3.81E-06	3.5	100
6	3.43E-06	5.4	100	*1 3.08E-06	9.9	100	*1 3.16E-06	3.8	100	3.23E-06	3.5	100
7	2.78E-06	5.4	100	2.45E-06	9.9	100	2.66E-06	3.8	100	2.61E-06	3.5	100
8	4.17E-06	5.4	100	3.65E-06	9.9	100	3.96E-06	3.8	100	3.88E-06	3.5	100
9	1.35E-06	5.4	100	1.19E-06	9.9	100	1.28E-06	3.8	100	1.23E-06	3.5	100
10	2.78E-06	5.4	100	2.47E-06	9.9	100	2.68E-06	3.8	100	2.59E-06	3.5	100
11	3.30E-06	5.4	100	2.93E-06	9.9	100	3.09E-06	3.8	100	3.07E-06	3.5	100
12	5.47E-06	5.4	100	4.95E-06	9.9	100	5.37E-06	3.8	100	5.27E-06	3.5	100
13	*1 7.06E-06	5.5	100	6.43E-06	9.9	100	7.10E-06	3.8	100	6.90E-06	3.5	100
14	3.02E-06	5.5	100	2.75E-06	9.9	100	2.97E-06	3.8	100	2.91E-06	3.5	100
15	5.07E-06	5.5	100	4.64E-06	9.9	100	4.90E-06	3.8	100	4.87E-06	3.5	100
16	4.94E-06	5.5	100	4.45E-06	9.9	100	4.77E-06	3.8	100	4.71E-06	3.5	100
17	3.21E-06	5.5	100	2.84E-06	9.9	100	3.13E-06	3.8	100	3.05E-06	3.5	100
18	2.80E-06	5.5	100	2.47E-06	9.9	100	2.68E-06	3.8	100	*1 2.72E-06	3.5	100
19	2.07E-06	5.5	100	1.85E-06	9.9	100	1.95E-06	3.8	100	2.01E-06	3.5	100
20	4.00E-06	5.5	100	3.60E-06	9.9	100	3.97E-06	3.8	100	4.11E-06	3.5	100
21	4.42E-06	5.5	100	3.93E-06	9.9	100	4.26E-06	3.8	100	4.34E-06	3.5	100
22	6.22E-06	5.5	100	5.56E-06	9.9	100	5.94E-06	3.8	100	6.12E-06	3.5	100
23	4.78E-06	5.5	100	4.35E-06	9.9	100	4.57E-06	3.8	100	4.69E-06	3.5	100
24	5.80E-06	5.5	100	5.16E-06	9.9	100	5.59E-06	3.8	100	5.79E-06	3.5	100
25	5.20E-06	5.5	100	4.68E-06	9.9	100	5.01E-06	3.8	100	5.14E-06	3.5	100
26	4.78E-06	5.5	100	4.28E-06	9.9	100	4.64E-06	3.8	100	4.73E-06	3.5	100
27	4.33E-06	5.5	100	3.89E-06	9.9	100	4.10E-06	3.8	100	4.25E-06	3.5	100
28	2.71E-06	5.5	100	2.43E-06	9.9	100	2.59E-06	3.8	100	2.70E-06	3.5	100
29	4.26E-06	5.5	100	3.86E-06	9.9	100	4.31E-06	3.8	100	4.47E-06	3.5	100
30												
31												
1ヶ月値	3.98E-06	5.5	100	3.56E-06	9.9	100	3.82E-06	3.8	100	3.86E-06	3.5	100
最大値	1.58E-05	5.5	101	3.83E-05	9.9	102	1.78E-05	3.9	102	1.82E-05	3.5	102
最大値日時	02/13 07:41	02/13 10:23	02/01 00:04	02/06 10:32	02/01 00:01	02/01 01:22	02/13 07:22	02/01 00:01	02/07 00:52	02/13 07:51	02/01 00:01	02/02 00:36
最小値	0.00E+00	5.4	98	0.00E+00	9.9	97	0.00E+00	3.8	98	1.73E-07	3.5	97
最小値日時	02/13 10:23	02/01 00:01	02/07 01:03	02/01 16:48	02/01 00:01	02/02 08:06	02/06 10:40	02/06 10:40	02/01 14:55	02/01 17:03	02/01 00:01	02/15 15:47

*1:ろ紙交換

測定月報

(4/8)

測定日: 2020/02

日	モニタ											
	A013			A014			A015			A016		
	4号南側法面上[3号南側](DM52)			4号南側法面上[3号南側](DM46)			登録C休憩所 (DM76)			登録C休憩所 (DM50)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.32E-06	2.7	100	1.10E-06	1.3	100	9.91E-07	2.2	100	1.00E-06	2.3	100
2	3.02E-06	2.7	100	2.97E-06	1.3	100	2.80E-06	2.2	100	2.95E-06	2.3	100
3	5.52E-06	2.7	100	5.76E-06	1.3	100	5.66E-06	2.2	100	6.02E-06	2.3	100
4	4.20E-06	2.7	100	4.32E-06	1.3	100	3.94E-06	2.2	100	4.25E-06	2.3	100
5	4.07E-06	2.7	100	4.16E-06	1.3	100	*1 3.88E-06	2.2	100	4.10E-06	2.3	100
6	3.55E-06	2.7	100	3.58E-06	1.3	100	3.19E-06	2.2	100	*1 3.51E-06	2.2	100
7	2.93E-06	2.7	100	2.90E-06	1.3	100	2.63E-06	2.2	100	2.90E-06	2.1	100
8	4.28E-06	2.7	100	4.40E-06	1.3	100	4.05E-06	2.2	100	4.46E-06	2.1	100
9	1.59E-06	2.7	100	1.41E-06	1.3	100	1.24E-06	2.2	100	1.40E-06	2.1	100
10	2.95E-06	2.7	100	2.92E-06	1.3	100	2.83E-06	2.2	100	3.10E-06	2.1	100
11	3.45E-06	2.7	100	3.53E-06	1.3	100	3.28E-06	2.2	100	3.56E-06	2.1	100
12	*1 5.25E-06	3.0	100	5.74E-06	1.3	100	5.47E-06	2.2	100	5.89E-06	2.1	100
13	6.98E-06	3.2	100	7.86E-06	1.3	100	7.32E-06	2.2	100	7.87E-06	2.1	100
14	2.89E-06	3.2	100	3.17E-06	1.3	100	2.97E-06	2.2	100	3.25E-06	2.1	100
15	4.78E-06	3.2	100	5.36E-06	1.3	100	5.02E-06	2.2	100	5.48E-06	2.1	100
16	4.71E-06	3.2	100	5.20E-06	1.3	100	4.64E-06	2.2	100	5.14E-06	2.1	100
17	3.10E-06	3.2	100	3.49E-06	1.3	100	*3 3.18E-06	2.2	100	3.42E-06	2.1	100
18	2.72E-06	3.2	100	2.98E-06	1.3	100	2.84E-06	2.2	100	2.98E-06	2.1	100
19	1.94E-06	3.2	100	2.14E-06	1.3	100	2.07E-06	2.2	100	2.20E-06	2.1	100
20	3.91E-06	3.2	100	4.36E-06	1.3	100	4.18E-06	2.2	100	4.40E-06	2.1	100
21	4.24E-06	3.2	100	4.65E-06	1.3	100	4.81E-06	2.2	100	4.98E-06	2.1	100
22	5.78E-06	3.2	100	6.42E-06	1.3	100	6.76E-06	2.2	100	6.89E-06	2.1	100
23	4.58E-06	3.2	100	5.06E-06	1.3	100	4.81E-06	2.2	100	4.95E-06	2.1	100
24	5.41E-06	3.2	100	6.02E-06	1.3	100	5.83E-06	2.2	100	6.08E-06	2.1	100
25	4.86E-06	3.2	100	*1 5.49E-06	1.2	100	5.33E-06	2.2	100	5.57E-06	2.1	100
26	4.52E-06	3.2	100	5.17E-06	1.2	100	4.85E-06	2.2	100	5.04E-06	2.1	100
27	4.10E-06	3.2	100	4.64E-06	1.2	100	4.37E-06	2.2	100	4.57E-06	2.1	100
28	2.62E-06	3.2	100	2.98E-06	1.2	100	2.95E-06	2.2	100	3.09E-06	2.1	100
29	4.28E-06	3.2	100	4.76E-06	1.2	100	4.87E-06	2.2	100	5.14E-06	2.1	100
30												
31												
1ヶ月値	3.92E-06	3.0	100	4.23E-06	1.3	100	4.03E-06	2.2	100	4.28E-06	2.1	100
最大値	1.81E-05	3.2	102	1.95E-05	1.3	102	1.89E-05	2.2	102	3.48E-05	2.3	102
最大値日時	02/13 07:29	02/12 11:36	02/01 12:33	02/13 07:44	02/01 00:01	02/02 21:28	02/13 08:06	02/01 00:01	02/18 02:07	02/06 09:49	02/01 00:01	02/01 11:58
最小値	0.00E+00	2.7	98	3.44E-07	1.2	98	0.00E+00	2.2	98	0.00E+00	2.1	98
最小値日時	02/12 11:36	02/01 00:01	02/01 14:51	02/01 17:01	02/25 11:13	02/01 01:44	02/05 10:06	02/01 00:01	02/07 00:11	02/06 09:50	02/06 09:49	02/02 16:01

*1: 3紙交換 *3: 年次点検

測定月報

測定日: 2020/02

(5/8)

日	モニタ											
	A017 旧情報棟(DM71)			A018 旧情報棟(DM77)			A019 シールド中央制御室(DM65)			A020 シールド中央制御室(DM44)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.07E-06	5.6	100	9.36E-07	5.4	100	1.01E-06	2.2	100	8.62E-07	2.7	100
2	2.68E-06	5.6	100	2.54E-06	5.4	100	2.81E-06	2.2	100	2.51E-06	2.7	100
3	5.37E-06	5.6	100	5.31E-06	5.4	100	5.39E-06	2.2	100	4.86E-06	2.7	100
4	3.80E-06	5.6	100	3.73E-06	5.4	100	3.97E-06	2.2	100	3.57E-06	2.7	100
5	3.89E-06	5.6	100	3.75E-06	5.4	100	3.97E-06	2.2	100	3.51E-06	2.7	100
6	*1 3.27E-06	5.7	100	3.17E-06	5.4	100	3.35E-06	2.2	100	2.96E-06	2.7	100
7	2.53E-06	5.8	100	2.59E-06	5.4	100	2.69E-06	2.2	100	2.36E-06	2.7	100
8	3.84E-06	5.8	100	3.96E-06	5.4	100	4.10E-06	2.2	100	3.68E-06	2.7	100
9	1.17E-06	5.8	100	1.20E-06	5.4	100	1.41E-06	2.2	100	1.22E-06	2.7	100
10	2.60E-06	5.8	100	2.69E-06	5.4	100	2.77E-06	2.2	100	2.49E-06	2.7	100
11	2.95E-06	5.8	100	3.01E-06	5.4	100	3.34E-06	2.2	100	2.99E-06	2.7	100
12	5.16E-06	5.8	100	5.28E-06	5.4	100	5.42E-06	2.2	100	4.87E-06	2.7	100
13	6.34E-06	5.8	100	6.55E-06	5.4	100	7.43E-06	2.2	100	6.69E-06	2.7	100
14	2.82E-06	5.8	100	2.92E-06	5.4	100	3.01E-06	2.2	100	2.66E-06	2.7	100
15	4.71E-06	5.8	100	4.76E-06	5.4	100	5.05E-06	2.2	100	4.55E-06	2.7	100
16	4.56E-06	5.8	100	4.58E-06	5.4	100	4.96E-06	2.2	100	4.40E-06	2.7	100
17	2.89E-06	5.8	100	*3 3.15E-06	5.3	100	3.20E-06	2.2	100	2.81E-06	2.7	100
18	2.58E-06	5.8	100	2.85E-06	5.2	100	*1 2.78E-06	2.3	100	2.45E-06	2.7	100
19	1.82E-06	5.8	100	2.07E-06	5.2	100	2.00E-06	2.3	100	1.80E-06	2.7	100
20	3.63E-06	5.8	100	3.95E-06	5.2	100	4.11E-06	2.3	100	3.67E-06	2.7	100
21	4.08E-06	5.8	100	4.47E-06	5.2	100	4.44E-06	2.3	100	3.99E-06	2.7	100
22	5.57E-06	5.8	100	5.95E-06	5.2	100	6.15E-06	2.3	100	5.53E-06	2.7	100
23	4.46E-06	5.8	100	4.81E-06	5.2	100	4.76E-06	2.3	100	4.26E-06	2.7	100
24	5.27E-06	5.8	100	5.67E-06	5.2	100	5.64E-06	2.3	100	5.11E-06	2.7	100
25	4.63E-06	5.8	100	5.11E-06	5.2	100	5.17E-06	2.3	100	*1 4.59E-06	2.8	100
26	4.20E-06	5.8	100	4.66E-06	5.2	100	4.78E-06	2.3	100	4.25E-06	2.8	100
27	3.89E-06	5.8	100	4.21E-06	5.2	100	4.29E-06	2.3	100	3.79E-06	2.8	100
28	2.40E-06	5.8	100	2.72E-06	5.2	100	2.71E-06	2.3	100	2.32E-06	2.8	100
29	3.97E-06	5.8	100	4.31E-06	5.2	100	4.46E-06	2.3	100	3.86E-06	2.8	100
30												
31												
1ヶ月値	3.66E-06	5.8	100	3.82E-06	5.3	100	3.97E-06	2.2	100	3.54E-06	2.7	100
最大値	6.19E-05	5.8	102	1.59E-05	5.4	102	1.86E-05	2.3	102	1.70E-05	2.8	102
最大値日時	02/06 10:22	02/06 10:22	02/08 18:19	02/13 08:27	02/01 00:01	02/01 19:35	02/13 08:00	02/18 10:29	02/04 07:38	02/13 07:44	02/25 11:05	02/02 21:16
最小値	0.00E+00	5.6	98	0.00E+00	5.2	98	0.00E+00	2.2	98	0.00E+00	2.7	98
最小値日時	02/06 10:23	02/01 00:01	02/01 04:08	02/17 10:11	02/17 10:11	02/01 06:00	02/18 10:29	02/01 00:01	02/02 05:28	02/25 11:05	02/01 00:01	02/01 08:01

*1:ろ紙交換 *3:年次点検

測定月報

測定日: 2020/02

(6/8)

日	モニタ											
	A021			A022			A023			A024		
	Hタンクエリア (DM47)			Hタンクエリア (DM64)			2u西側(DM73)			2u西側(DM54)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.01E-06	2.5	100	1.03E-06	2.1	100	7.15E-07	19.1	100	7.49E-07	19.2	100
2	2.87E-06	2.5	100	2.98E-06	2.1	100	2.38E-06	19.1	100	2.40E-06	19.2	100
3	5.51E-06	2.5	100	5.56E-06	2.1	100	5.10E-06	19.1	100	5.08E-06	19.2	100
4	4.01E-06	2.5	100	4.11E-06	2.1	100	3.72E-06	19.1	100	3.72E-06	19.2	100
5	4.00E-06	2.5	100	4.06E-06	2.1	100	3.68E-06	19.1	100	3.82E-06	19.2	100
6	3.31E-06	2.5	100	3.44E-06	2.1	100	3.09E-06	19.1	100	3.30E-06	19.2	100
7	2.76E-06	2.5	100	2.81E-06	2.1	100	2.37E-06	19.1	100	2.61E-06	19.2	100
8	4.09E-06	2.5	100	4.26E-06	2.1	100	3.78E-06	19.1	100	3.91E-06	19.2	100
9	1.33E-06	2.5	100	1.36E-06	2.1	100	9.08E-07	19.1	100	1.18E-06	19.2	100
10	2.82E-06	2.5	100	2.87E-06	2.1	100	2.16E-06	19.1	100	2.74E-06	19.2	100
11	3.29E-06	2.5	100	3.37E-06	2.1	100	2.41E-06	19.1	100	2.99E-06	19.2	100
12	*1 5.55E-06	2.5	100	*1 5.65E-06	2.1	100	*1 6.14E-06	17.0	100	*1 5.45E-06	19.2	100
13	7.45E-06	2.5	100	*1 7.67E-06	2.1	100	8.32E-06	15.2	100	*1 7.00E-06	19.1	100
14	2.99E-06	2.5	100	3.04E-06	2.1	100	4.29E-06	15.2	100	2.90E-06	19.1	100
15	5.17E-06	2.5	100	5.27E-06	2.1	100	6.35E-06	15.2	100	4.86E-06	19.1	100
16	4.91E-06	2.5	100	5.06E-06	2.1	100	6.05E-06	15.2	100	4.55E-06	19.1	100
17	3.21E-06	2.5	100	3.31E-06	2.1	100	4.28E-06	15.2	100	2.84E-06	19.1	100
18	2.75E-06	2.5	100	2.86E-06	2.1	100	3.80E-06	15.2	100	2.35E-06	19.1	100
19	2.01E-06	2.5	100	2.07E-06	2.1	100	3.23E-06	15.2	100	1.80E-06	19.1	100
20	4.15E-06	2.5	100	4.22E-06	2.1	100	5.29E-06	15.2	100	3.85E-06	19.1	100
21	4.53E-06	2.5	100	4.74E-06	2.1	100	5.52E-06	15.2	100	4.06E-06	19.1	100
22	6.22E-06	2.5	100	6.47E-06	2.1	100	7.34E-06	15.2	100	5.74E-06	19.1	100
23	4.73E-06	2.5	100	4.84E-06	2.1	100	5.76E-06	15.2	100	4.31E-06	19.1	100
24	5.71E-06	2.5	100	5.89E-06	2.1	100	6.89E-06	15.2	100	5.34E-06	19.1	100
25	5.24E-06	2.5	100	5.35E-06	2.1	100	6.33E-06	15.2	100	4.75E-06	19.1	100
26	4.80E-06	2.5	100	4.89E-06	2.1	100	5.84E-06	15.2	100	4.25E-06	19.1	100
27	4.31E-06	2.5	100	4.45E-06	2.1	100	5.43E-06	15.2	100	3.86E-06	19.1	100
28	2.73E-06	2.5	100	2.82E-06	2.1	100	3.78E-06	15.2	100	2.35E-06	19.1	100
29	4.62E-06	2.5	100	4.76E-06	2.1	100	5.54E-06	15.2	100	4.01E-06	19.1	100
30												
31												
1ヶ月値	4.00E-06	2.5	100	4.11E-06	2.1	100	4.50E-06	16.7	100	3.68E-06	19.1	100
最大値	1.98E-05	2.5	102	1.88E-05	2.1	102	1.49E-04	19.1	101	1.84E-05	19.2	101
最大値日時	02/13 07:40	02/01 00:01	02/01 09:50	02/13 07:58	02/01 00:01	02/01 14:33	02/12 11:02	02/01 00:01	02/01 00:32	02/13 07:30	02/01 00:01	02/01 01:06
最小値	0.00E+00	2.5	98	2.33E-07	2.1	98	0.00E+00	15.2	98	0.00E+00	19.1	99
最小値日時	02/12 10:10	02/01 00:01	02/01 01:23	02/01 17:35	02/01 00:01	02/02 02:55	02/01 00:19	02/12 11:02	02/05 09:59	02/01 00:07	02/13 10:09	02/01 00:31

*1: ろ紙交換

測定月報

測定日：2020/02

(7/8)

日	モニタ											
	A027 1号機海側2、5m盤(DM62)			A028 1号機海側2、5m盤(DM53)			A029 3号機海側2、5m盤(DM49)			A030 3号機海側2、5m盤(DM60)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.16E-06	4.0	100	1.02E-06	6.2	100	1.04E-06	3.1	100	1.16E-06	3.7	100
2	2.97E-06	4.0	100	2.69E-06	6.2	100	2.50E-06	3.1	100	2.94E-06	3.7	100
3	5.52E-06	4.0	100	5.05E-06	6.2	100	4.65E-06	3.1	100	5.38E-06	3.7	100
4	4.21E-06	4.0	100	3.79E-06	6.2	100	3.50E-06	3.1	100	4.04E-06	3.7	100
5	5.13E-06	4.0	100	4.61E-06	6.2	100	3.69E-06	3.1	100	4.22E-06	3.7	100
6	4.73E-06	4.0	100	4.00E-06	6.2	100	3.09E-06	3.1	100	3.49E-06	3.7	100
7	4.08E-06	4.0	100	3.37E-06	6.2	100	2.63E-06	3.1	100	2.95E-06	3.7	100
8	5.45E-06	4.0	100	4.62E-06	6.2	100	3.64E-06	3.1	100	4.15E-06	3.7	100
9	2.56E-06	4.0	100	1.94E-06	6.2	100	1.37E-06	3.1	100	1.42E-06	3.7	100
10	3.87E-06	4.0	100	3.15E-06	6.2	100	2.49E-06	3.1	100	2.72E-06	3.7	100
11	4.53E-06	4.0	100	3.72E-06	6.2	100	2.96E-06	3.1	100	3.31E-06	3.7	100
12	6.79E-06	4.0	100	5.76E-06	6.2	100	4.92E-06	3.1	100	*1 5.67E-06	3.6	100
13	8.61E-06	4.0	100	7.35E-06	6.2	100	6.15E-06	3.1	100	7.16E-06	3.6	100
14	4.42E-06	4.0	100	3.55E-06	6.2	100	2.74E-06	3.1	100	3.19E-06	3.6	100
15	6.54E-06	4.0	100	5.54E-06	6.2	100	4.48E-06	3.1	100	5.35E-06	3.6	100
16	6.27E-06	4.0	100	5.38E-06	6.2	100	4.31E-06	3.1	100	5.11E-06	3.6	100
17	4.50E-06	4.0	100	3.68E-06	6.2	100	2.88E-06	3.1	100	3.33E-06	3.6	100
18	4.31E-06	4.0	100	*1 3.10E-06	6.7	100	2.73E-06	3.1	100	3.07E-06	3.6	100
19	3.36E-06	4.0	100	2.14E-06	7.1	100	1.99E-06	3.1	100	2.27E-06	3.6	100
20	5.39E-06	4.0	100	3.98E-06	7.1	100	3.64E-06	3.1	100	4.20E-06	3.6	100
21	5.61E-06	4.0	100	4.29E-06	7.1	100	3.90E-06	3.1	100	4.49E-06	3.6	100
22	7.62E-06	4.0	100	6.09E-06	7.1	100	5.25E-06	3.1	100	6.26E-06	3.6	100
23	6.19E-06	4.0	100	4.85E-06	7.1	100	4.25E-06	3.1	100	4.94E-06	3.6	100
24	7.19E-06	4.0	100	5.72E-06	7.1	100	5.02E-06	3.1	100	5.91E-06	3.6	100
25	*1 6.07E-06	4.9	100	5.13E-06	7.1	100	*1 4.49E-06	3.2	100	5.27E-06	3.6	100
26	5.02E-06	5.9	100	4.64E-06	7.1	100	4.01E-06	3.3	100	4.85E-06	3.6	100
27	4.61E-06	5.9	100	4.32E-06	7.1	100	3.72E-06	3.3	100	4.41E-06	3.6	100
28	2.81E-06	5.9	100	2.69E-06	7.1	100	2.31E-06	3.3	100	2.80E-06	3.6	100
29	4.30E-06	5.9	100	4.08E-06	7.1	100	3.58E-06	3.3	100	4.36E-06	3.6	100
30												
31												
1ヶ月値	4.96E-06	4.3	100	4.15E-06	6.6	100	3.51E-06	3.1	100	4.08E-06	3.6	100
最大値	1.84E-05	5.9	102	1.62E-05	7.1	102	1.42E-05	3.3	102	1.72E-05	3.7	102
最大値日時	02/13 08:31	02/25 12:42	02/01 07:35	02/13 07:45	02/18 11:20	02/01 05:01	02/13 07:46	02/25 12:42	02/01 15:18	02/13 07:39	02/01 00:01	02/02 16:23
最小値	0.00E+00	4.0	98	0.00E+00	6.2	98	0.00E+00	3.1	97	2.33E-07	3.6	98
最小値日時	02/25 12:42	02/01 00:01	02/01 05:17	02/18 11:22	02/01 00:01	02/01 00:58	02/25 12:42	02/01 00:01	02/23 23:46	02/01 17:23	02/12 10:47	02/01 06:16

*1:ろ紙交換

測定月報

(8/8)

測定日: 2020/02

日	モニタ											
	A031 HTI南側(DM63)			A032 HTI南側(DM69)								
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.39E-06	9.9	100	1.11E-06	7.5	100						
2	3.05E-06	9.9	100	3.04E-06	7.5	100						
3	5.40E-06	9.9	100	5.70E-06	7.5	100						
4	4.17E-06	9.9	100	4.29E-06	7.5	100						
5	4.12E-06	9.9	100	4.23E-06	7.5	100						
6	3.52E-06	9.9	100	3.57E-06	7.5	100						
7	2.99E-06	9.9	100	2.92E-06	7.5	100						
8	4.25E-06	9.9	100	4.41E-06	7.5	100						
9	1.70E-06	9.9	100	1.43E-06	7.5	100						
10	2.97E-06	9.9	100	2.90E-06	7.5	100						
11	3.42E-06	9.9	100	3.45E-06	7.5	100						
12	5.63E-06	9.9	100	*1 6.23E-06	7.3	100						
13	7.36E-06	9.9	100	8.20E-06	7.1	100						
14	3.18E-06	9.9	100	3.64E-06	7.1	100						
15	5.08E-06	9.9	100	5.65E-06	7.1	100						
16	4.89E-06	9.9	100	5.45E-06	7.1	100						
17	3.13E-06	9.9	100	3.43E-06	7.1	100						
18	2.89E-06	9.9	100	3.09E-06	7.1	100						
19	2.27E-06	9.9	100	2.37E-06	7.1	100						
20	4.19E-06	9.9	100	4.75E-06	7.1	100						
21	4.55E-06	9.9	100	5.09E-06	7.1	100						
22	5.93E-06	9.9	100	6.68E-06	7.1	100						
23	4.76E-06	9.9	100	5.38E-06	7.1	100						
24	5.65E-06	9.9	100	6.43E-06	7.1	100						
25	*1 5.05E-06	10.2	100	5.69E-06	7.1	100						
26	4.28E-06	10.6	100	5.04E-06	7.1	100						
27	4.01E-06	10.6	100	4.72E-06	7.1	100						
28	2.50E-06	10.6	100	3.09E-06	7.1	100						
29	4.16E-06	10.6	100	4.89E-06	7.1	100						
30												
31												
1ヶ月値	4.02E-06	10.0	100	4.37E-06	7.3	100						
最大値	6.79E-05	10.6	102	2.25E-05	7.5	102						
最大値日時	02/25 12:51	02/25 12:51	02/01 02:52	02/13 07:38	02/01 00:01	02/03 09:10						
最小値	0.00E+00	9.9	97	0.00E+00	7.1	98						
最小値日時	02/25 12:52	02/01 00:01	02/04 19:48	02/12 10:57	02/12 10:54	02/02 20:57						

*1: ろ紙交換