

構内連続ダストモニタ測定記録(2021 年 8 月)

※表中、最大値・最小値に関しては、BG 測定による影響があるため値は参考値扱いとする。

測定月報

測定日：2021/08

(1/8)

日	モニタ											
	A001 正門警備所			A002 正門警備所			A003 免震重要棟			A004 免震重要棟		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.92E-06	0.8	100	2.05E-06	1.4	100	1.96E-06	5.8	100	1.74E-06	5.4	100
2	1.38E-06	0.8	100	1.47E-06	1.4	100	1.52E-06	5.8	100	1.35E-06	5.4	100
3	4.45E-07	0.8	100	4.84E-07	1.4	100	4.76E-07	5.8	100	3.99E-07	5.4	100
4	2.21E-06	0.8	100	2.35E-06	1.4	100	2.02E-06	5.8	100	1.88E-06	5.4	100
5	2.97E-06	0.8	100	3.07E-06	1.4	100	3.10E-06	5.8	100	2.90E-06	5.4	100
6	5.15E-06	0.8	100	5.46E-06	1.4	100	5.41E-06	5.8	100	5.07E-06	5.4	100
7	3.49E-06	0.8	100	3.72E-06	1.4	100	3.66E-06	5.8	100	3.39E-06	5.4	100
8	2.93E-06	0.8	100	3.13E-06	1.4	100	2.91E-06	5.8	100	2.67E-06	5.4	100
9	1.39E-06	0.8	100	1.48E-06	1.4	100	1.53E-06	5.8	100	1.39E-06	5.4	100
10	1.14E-06	0.8	100	1.19E-06	1.4	100	1.25E-06	5.8	100	*1 1.12E-06	5.4	100
11	1.00E-06	0.8	100	1.06E-06	1.4	100	9.67E-07	5.8	100	8.42E-07	5.4	100
12	4.00E-07	0.8	100	4.23E-07	1.4	100	4.48E-07	5.8	100	3.53E-07	5.4	100
13	6.48E-07	0.8	100	6.81E-07	1.4	100	6.81E-07	5.8	100	5.46E-07	5.4	100
14	4.89E-07	0.8	100	5.05E-07	1.4	100	4.52E-07	5.8	100	3.60E-07	5.4	100
15	5.34E-07	0.8	100	5.71E-07	1.4	100	5.25E-07	5.8	100	4.14E-07	5.4	100
16	5.01E-07	0.8	100	*1 5.61E-07	1.3	100	5.22E-07	5.8	100	4.35E-07	5.4	100
17	1.17E-06	0.8	100	1.28E-06	1.3	100	1.16E-06	5.8	100	1.04E-06	5.4	100
18	5.37E-07	0.8	100	6.09E-07	1.3	100	*1 5.82E-07	5.7	100	4.38E-07	5.4	100
19	3.77E-06	0.8	100	3.91E-06	1.3	100	3.47E-06	5.7	100	3.34E-06	5.4	100
20	2.59E-06	0.8	100	2.78E-06	1.3	100	2.56E-06	5.7	100	2.44E-06	5.4	100
21	1.71E-06	0.8	100	1.87E-06	1.3	100	1.90E-06	5.7	100	1.72E-06	5.4	100
22	3.44E-06	0.8	100	3.66E-06	1.3	100	3.06E-06	5.7	100	2.82E-06	5.4	100
23	5.26E-06	0.8	100	5.62E-06	1.3	100	4.98E-06	5.7	100	4.78E-06	5.4	100
24	*1 4.97E-06	0.8	100	5.33E-06	1.3	100	4.70E-06	5.7	100	4.43E-06	5.4	100
25	5.96E-06	0.8	100	6.59E-06	1.3	100	5.74E-06	5.7	100	5.49E-06	5.4	100
26	3.58E-06	0.8	100	3.91E-06	1.3	100	3.71E-06	5.7	100	3.51E-06	5.4	100
27	5.04E-06	0.8	100	5.47E-06	1.3	100	5.22E-06	5.7	100	5.03E-06	5.4	100
28	5.60E-06	0.8	100	5.99E-06	1.3	100	6.01E-06	5.7	100	5.71E-06	5.4	100
29	5.30E-06	0.8	100	5.69E-06	1.3	100	5.11E-06	5.7	100	4.92E-06	5.4	100
30	6.31E-06	0.8	100	6.76E-06	1.3	100	6.21E-06	5.7	100	6.04E-06	5.4	100
31	7.19E-06	0.8	100	7.69E-06	1.3	100	7.19E-06	5.7	100	6.95E-06	5.4	100
1ヶ月値	2.87E-06	0.8	100	3.08E-06	1.3	100	2.87E-06	5.8	100	2.69E-06	5.4	100
最大値	2.49E-05	0.8	102	2.68E-05	1.4	102	2.59E-05	5.8	102	2.43E-05	5.4	102
最大値日時	08/06 06:32	08/01 00:01	08/02 10:46	08/06 06:50	08/01 00:01	08/01 09:43	08/06 06:29	08/01 00:01	08/04 09:51	08/06 06:16	08/01 00:01	08/06 18:40
最小値	0.00E+00	0.8	98	0.00E+00	1.3	97	0.00E+00	5.7	98	0.00E+00	5.4	98
最小値日時	08/06 16:39	08/01 00:01	08/01 20:51	08/02 13:40	08/16 10:37	08/31 04:53	08/02 11:53	08/18 08:46	08/02 23:32	08/02 11:57	08/01 00:01	08/01 06:42

*1:ろ紙交換

測定月報

測定日：2021/08

(2/8)

日	モニタ											
	A005 5/6号警備所前			A006 5/6号警備所前			A007 1号北側法面上(旧厚生棟)			A008 1号北側法面上(旧厚生棟)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.84E-06	1.5	100	1.85E-06	1.7	100	1.86E-06	8.1	100	1.91E-06	5.6	100
2	1.45E-06	1.5	100	1.47E-06	1.7	100	1.45E-06	8.1	100	*1 1.55E-06	5.4	100
3	3.05E-07	1.5	100	3.09E-07	1.7	100	3.71E-07	8.1	100	4.84E-07	5.3	100
4	2.02E-06	1.5	100	2.04E-06	1.7	100	2.02E-06	8.1	100	2.13E-06	5.3	100
5	2.21E-06	1.5	100	2.26E-06	1.7	100	2.40E-06	8.1	100	2.56E-06	5.3	100
6	4.72E-06	1.5	100	4.86E-06	1.7	100	4.86E-06	8.1	100	4.96E-06	5.3	100
7	4.73E-06	1.5	100	4.84E-06	1.7	100	4.67E-06	8.1	100	4.76E-06	5.3	100
8	3.24E-06	1.5	100	3.32E-06	1.7	100	3.32E-06	8.1	100	3.45E-06	5.3	100
9	1.89E-06	1.5	100	1.93E-06	1.7	100	1.82E-06	8.1	100	1.92E-06	5.3	100
10	1.23E-06	1.5	100	1.18E-06	1.7	100	1.22E-06	8.1	100	1.36E-06	5.3	100
11	9.42E-07	1.5	100	9.70E-07	1.7	100	9.37E-07	8.1	100	1.06E-06	5.3	100
12	3.90E-07	1.5	100	4.01E-07	1.7	100	4.00E-07	8.1	100	5.28E-07	5.3	100
13	6.51E-07	1.5	100	6.75E-07	1.7	100	6.68E-07	8.1	100	8.05E-07	5.3	100
14	4.05E-07	1.5	100	4.10E-07	1.7	100	4.67E-07	8.1	100	6.09E-07	5.3	100
15	4.86E-07	1.5	100	4.90E-07	1.7	100	5.21E-07	8.1	100	6.61E-07	5.3	100
16	4.76E-07	1.5	100	*1 5.05E-07	1.6	100	4.77E-07	8.1	100	6.30E-07	5.3	100
17	1.11E-06	1.5	100	1.16E-06	1.6	100	1.12E-06	8.1	100	1.27E-06	5.3	100
18	*1 4.68E-07	1.4	100	4.74E-07	1.6	100	4.61E-07	8.1	100	5.86E-07	5.3	100
19	3.69E-06	1.4	100	3.57E-06	1.6	100	3.64E-06	8.1	100	3.79E-06	5.3	100
20	2.62E-06	1.4	100	2.52E-06	1.6	100	2.48E-06	8.1	100	2.62E-06	5.3	100
21	1.96E-06	1.4	100	1.91E-06	1.6	100	1.83E-06	8.1	100	1.96E-06	5.3	100
22	3.14E-06	1.4	100	3.05E-06	1.6	100	2.97E-06	8.1	100	3.18E-06	5.3	100
23	4.79E-06	1.4	100	4.68E-06	1.6	100	4.78E-06	8.1	100	4.89E-06	5.3	100
24	4.92E-06	1.4	100	4.86E-06	1.6	100	*1 4.98E-06	8.0	100	5.01E-06	5.3	100
25	6.01E-06	1.4	100	5.89E-06	1.6	100	6.05E-06	7.9	100	6.13E-06	5.3	100
26	3.96E-06	1.4	100	3.86E-06	1.6	100	3.99E-06	7.9	100	4.08E-06	5.3	100
27	5.57E-06	1.4	100	5.38E-06	1.6	100	5.42E-06	7.9	100	*1 5.48E-06	5.5	100
28	6.82E-06	1.4	100	6.54E-06	1.6	100	6.61E-06	7.9	100	6.53E-06	5.7	100
29	5.48E-06	1.4	100	5.33E-06	1.6	100	5.26E-06	7.9	100	5.25E-06	5.7	100
30	7.05E-06	1.4	100	6.79E-06	1.6	100	6.66E-06	7.9	100	6.60E-06	5.7	100
31	8.04E-06	1.4	100	7.69E-06	1.6	100	7.88E-06	7.9	100	7.90E-06	5.7	100
1ヶ月値	2.99E-06	1.5	100	2.95E-06	1.6	100	2.95E-06	8.1	100	3.05E-06	5.4	100
最大値	2.16E-05	1.5	102	2.13E-05	1.7	102	2.18E-05	8.1	102	1.95E-05	5.7	118
最大値日時	08/06 07:45	08/01 00:01	08/06 01:03	08/06 07:38	08/01 00:01	08/06 01:37	08/24 09:00	08/01 00:01	08/05 17:58	08/06 07:22	08/27 09:51	08/02 08:36
最小値	0.00E+00	1.4	98	0.00E+00	1.6	98	0.00E+00	7.9	98	0.00E+00	5.3	98
最小値日時	08/02 13:26	08/18 10:07	08/02 01:42	08/02 12:21	08/16 09:39	08/24 23:52	08/01 00:39	08/24 09:00	08/01 05:57	08/02 08:37	08/02 08:36	08/01 04:14

*1: ろ紙交換

測定月報

測定日：2021/08

(3/8)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上			1/2号西側法面上			3/4号西側法面上			3/4号西側法面上		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.87E-06	5.9	100	1.95E-06	7.6	100	1.83E-06	8.7	100	1.83E-06	3.7	100
2	*1 1.43E-06	5.8	100	*1 1.47E-06	7.8	100	1.36E-06	8.7	100	1.35E-06	3.7	100
3	4.56E-07	5.7	100	3.74E-07	7.9	100	4.04E-07	8.7	100	4.04E-07	3.7	100
4	2.09E-06	5.7	100	2.00E-06	7.9	100	1.99E-06	8.7	100	1.93E-06	3.7	100
5	2.84E-06	5.7	100	2.75E-06	7.9	100	2.76E-06	8.7	100	2.68E-06	3.7	100
6	5.27E-06	5.7	100	5.30E-06	7.9	100	5.15E-06	8.7	100	4.99E-06	3.7	100
7	4.20E-06	5.7	100	4.17E-06	7.9	100	3.96E-06	8.7	100	3.87E-06	3.7	100
8	2.97E-06	5.7	100	2.92E-06	7.9	100	2.90E-06	8.7	100	2.78E-06	3.7	100
9	1.63E-06	5.7	100	1.59E-06	7.9	100	1.55E-06	8.7	100	1.54E-06	3.7	100
10	1.22E-06	5.7	100	1.18E-06	7.9	100	1.14E-06	8.7	100	1.16E-06	3.7	100
11	9.81E-07	5.7	100	8.85E-07	7.9	100	8.65E-07	8.7	100	8.64E-07	3.7	100
12	4.75E-07	5.7	100	3.77E-07	7.9	100	3.12E-07	8.7	100	3.18E-07	3.7	100
13	7.33E-07	5.7	100	6.35E-07	7.9	100	5.51E-07	8.7	100	5.78E-07	3.7	100
14	5.24E-07	5.7	100	4.15E-07	7.9	100	3.66E-07	8.7	100	3.95E-07	3.7	100
15	5.75E-07	5.7	100	4.80E-07	7.9	100	3.88E-07	8.7	100	4.22E-07	3.7	100
16	5.53E-07	5.7	100	4.43E-07	7.9	100	3.81E-07	8.7	100	3.80E-07	3.7	100
17	1.21E-06	5.7	100	1.08E-06	7.9	100	1.01E-06	8.7	100	1.05E-06	3.7	100
18	6.04E-07	5.7	100	3.96E-07	7.9	100	4.15E-07	8.7	100	*1 5.22E-07	3.6	100
19	3.62E-06	5.7	100	3.47E-06	7.9	100	3.53E-06	8.7	100	3.41E-06	3.6	100
20	2.60E-06	5.7	100	2.43E-06	7.9	100	2.34E-06	8.7	100	2.39E-06	3.6	100
21	1.91E-06	5.7	100	1.73E-06	7.9	100	1.63E-06	8.7	100	1.70E-06	3.6	100
22	2.91E-06	5.7	100	2.85E-06	7.9	100	2.68E-06	8.7	100	2.71E-06	3.6	100
23	4.62E-06	5.7	100	4.71E-06	7.9	100	4.69E-06	8.7	100	4.68E-06	3.6	100
24	4.53E-06	5.7	100	4.60E-06	7.9	100	*1 4.70E-06	8.6	100	4.55E-06	3.6	100
25	5.49E-06	5.7	100	5.61E-06	7.9	100	5.68E-06	8.6	100	5.48E-06	3.6	100
26	3.70E-06	5.7	100	3.72E-06	7.9	100	3.76E-06	8.6	100	3.63E-06	3.6	100
27	*1 5.33E-06	5.5	100	*1 5.31E-06	7.7	100	5.19E-06	8.6	100	5.03E-06	3.6	100
28	6.19E-06	5.4	100	6.10E-06	7.5	100	5.99E-06	8.6	100	5.64E-06	3.6	100
29	5.14E-06	5.4	100	5.14E-06	7.5	100	5.15E-06	8.6	100	4.83E-06	3.6	100
30	6.14E-06	5.4	100	6.27E-06	7.5	100	6.22E-06	8.6	100	5.88E-06	3.6	100
31	7.46E-06	5.4	100	7.49E-06	7.5	100	7.41E-06	8.6	100	7.06E-06	3.6	100
1ヶ月値	2.88E-06	5.7	100	2.83E-06	7.8	100	2.78E-06	8.7	100	2.71E-06	3.7	100
最大値	2.31E-05	5.9	104	2.27E-05	7.9	102	2.23E-05	8.7	102	5.00E-05	3.7	102
最大値日時	08/06 06:47	08/01 00:01	08/14 01:07	08/06 06:38	08/02 10:36	08/08 22:18	08/06 07:01	08/01 00:01	08/02 02:19	08/18 09:21	08/01 00:01	08/02 19:40
最小値	0.00E+00	5.4	96	0.00E+00	7.5	1	0.00E+00	8.6	98	0.00E+00	3.6	97
最小値日時	08/02 10:14	08/27 11:11	08/15 14:34	08/02 10:36	08/27 11:43	08/24 10:47	08/01 00:01	08/24 09:33	08/01 05:29	08/02 12:26	08/18 09:21	08/16 12:15

*1:ろ紙交換

測定月報

測定日：2021/08

(4/8)

日	モニタ											
	A013 4号南側法面上[3号南側]			A014 4号南側法面上[3号南側]			A015 登録C休憩所			A016 登録C休憩所		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.05E-06	1.3	100	1.86E-06	3.1	100	1.88E-06	1.8	100	1.95E-06	2.3	100
2	1.52E-06	1.3	100	1.36E-06	3.1	100	1.35E-06	1.8	100	1.43E-06	2.3	100
3	4.59E-07	1.3	100	3.66E-07	3.1	100	4.54E-07	1.8	100	5.10E-07	2.3	100
4	2.15E-06	1.3	100	1.96E-06	3.1	100	2.09E-06	1.8	100	2.15E-06	2.3	100
5	2.92E-06	1.3	100	2.70E-06	3.1	100	2.95E-06	1.8	100	3.04E-06	2.3	100
6	5.84E-06	1.3	100	5.38E-06	3.1	100	4.84E-06	1.8	100	4.94E-06	2.3	100
7	4.60E-06	1.3	100	4.31E-06	3.1	100	3.28E-06	1.8	100	3.40E-06	2.3	100
8	3.20E-06	1.3	100	3.00E-06	3.1	100	2.78E-06	1.8	100	2.86E-06	2.3	100
9	1.88E-06	1.3	100	1.72E-06	3.1	100	1.29E-06	1.8	100	1.35E-06	2.3	100
10	*1 1.33E-06	1.3	100	1.19E-06	3.1	100	1.10E-06	1.8	100	1.16E-06	2.3	100
11	1.06E-06	1.4	100	9.77E-07	3.1	100	8.79E-07	1.8	100	9.37E-07	2.3	100
12	4.36E-07	1.4	100	3.92E-07	3.1	100	3.93E-07	1.8	100	4.52E-07	2.3	100
13	7.18E-07	1.4	100	6.53E-07	3.1	100	6.26E-07	1.8	100	7.06E-07	2.3	100
14	5.22E-07	1.4	100	4.62E-07	3.1	100	4.70E-07	1.8	100	5.37E-07	2.3	100
15	5.68E-07	1.4	100	5.06E-07	3.1	100	5.10E-07	1.8	100	5.83E-07	2.3	100
16	5.28E-07	1.4	100	*1 4.54E-07	3.2	100	4.87E-07	1.8	100	*1 5.27E-07	2.4	100
17	1.26E-06	1.4	100	1.14E-06	3.2	100	1.12E-06	1.8	100	1.14E-06	2.4	100
18	4.80E-07	1.4	100	4.18E-07	3.2	100	*1 4.82E-07	1.9	100	5.22E-07	2.4	100
19	2.04E-06	1.4	100	3.71E-06	3.2	100	3.39E-06	1.9	100	3.48E-06	2.4	100
20	2.73E-06	1.4	100	2.50E-06	3.2	100	2.37E-06	1.9	100	2.52E-06	2.4	100
21	1.91E-06	1.4	100	1.70E-06	3.2	100	1.57E-06	1.9	100	1.68E-06	2.4	100
22	3.02E-06	1.4	100	2.69E-06	3.2	100	3.07E-06	1.9	100	3.25E-06	2.4	100
23	5.23E-06	1.4	100	4.90E-06	3.2	100	4.99E-06	1.9	100	5.31E-06	2.4	100
24	5.18E-06	1.4	100	4.90E-06	3.2	100	4.53E-06	1.9	100	4.78E-06	2.4	100
25	6.46E-06	1.4	100	6.01E-06	3.2	100	5.68E-06	1.9	100	5.97E-06	2.4	100
26	4.19E-06	1.4	100	3.88E-06	3.2	100	3.32E-06	1.9	100	3.49E-06	2.4	100
27	5.64E-06	1.4	100	5.32E-06	3.2	100	4.75E-06	1.9	100	5.08E-06	2.4	100
28	6.66E-06	1.4	100	6.19E-06	3.2	100	5.42E-06	1.9	100	5.66E-06	2.4	100
29	5.53E-06	1.4	100	5.17E-06	3.2	100	5.37E-06	1.9	100	5.55E-06	2.4	100
30	6.86E-06	1.4	100	6.40E-06	3.2	100	6.01E-06	1.9	100	6.22E-06	2.4	100
31	8.20E-06	1.4	100	7.80E-06	3.2	100	6.80E-06	1.9	100	7.14E-06	2.4	100
1ヶ月値	3.09E-06	1.4	100	2.90E-06	3.2	100	2.72E-06	1.8	100	2.85E-06	2.4	100
最大値	2.51E-05	1.4	102	2.21E-05	3.2	102	2.47E-05	1.9	102	2.69E-05	2.4	102
最大値日時	08/06 06:48	08/10 12:13	08/08 06:29	08/06 07:05	08/16 09:55	08/04 21:01	08/06 06:51	08/18 10:19	08/01 17:46	08/16 09:26	08/16 09:26	08/01 00:02
最小値	0.00E+00	1.3	98	0.00E+00	3.1	98	0.00E+00	1.8	97	0.00E+00	2.3	97
最小値日時	08/06 17:24	08/01 00:01	08/02 01:41	08/02 12:07	08/01 00:01	08/01 19:40	08/02 12:50	08/01 00:01	08/22 22:46	08/02 12:27	08/01 00:01	08/24 20:37

*1:ろ紙交換

測定月報

測定日：2021/08

(5/8)

日	モニタ											
	A017 旧情報棟			A018 旧情報棟			A019 シールド中央制御室			A020 シールド中央制御室		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.97E-06	5.5	100	1.87E-06	5.0	100	1.62E-06	2.0	100	1.85E-06	2.7	100
2	*1 1.47E-06	5.4	100	1.43E-06	5.0	100	*1 1.23E-06	2.0	100	1.43E-06	2.7	100
3	4.28E-07	5.3	100	4.01E-07	5.0	100	3.18E-07	2.0	100	3.46E-07	2.7	100
4	2.18E-06	5.3	100	2.00E-06	5.0	100	1.81E-06	2.0	100	2.10E-06	2.7	100
5	2.64E-06	5.3	100	2.43E-06	5.0	100	2.49E-06	2.0	100	2.87E-06	2.7	100
6	5.18E-06	5.3	100	4.83E-06	5.0	100	4.82E-06	2.0	100	5.74E-06	2.7	100
7	4.72E-06	5.3	100	4.45E-06	5.0	100	3.53E-06	2.0	100	4.19E-06	2.7	100
8	3.38E-06	5.3	100	3.24E-06	5.0	100	2.38E-06	2.0	100	2.78E-06	2.7	100
9	1.85E-06	5.3	100	1.72E-06	5.0	100	1.38E-06	2.0	100	1.59E-06	2.7	100
10	1.33E-06	5.3	100	1.21E-06	5.0	100	1.02E-06	2.0	100	*1 1.24E-06	2.6	100
11	1.01E-06	5.3	100	9.13E-07	5.0	100	8.20E-07	2.0	100	1.08E-06	2.5	100
12	4.00E-07	5.3	100	3.87E-07	5.0	100	3.32E-07	2.0	100	5.05E-07	2.5	100
13	7.07E-07	5.3	100	6.59E-07	5.0	100	5.42E-07	2.0	100	7.52E-07	2.5	100
14	4.77E-07	5.3	100	4.74E-07	5.0	100	3.92E-07	2.0	100	5.74E-07	2.5	100
15	5.21E-07	5.3	100	5.21E-07	5.0	100	4.31E-07	2.0	100	6.25E-07	2.5	100
16	4.84E-07	5.3	100	4.91E-07	5.0	100	4.08E-07	2.0	100	5.90E-07	2.5	100
17	1.22E-06	5.3	100	1.15E-06	5.0	100	9.96E-07	2.0	100	1.29E-06	2.5	100
18	4.94E-07	5.3	100	4.71E-07	5.0	100	3.96E-07	2.0	100	5.59E-07	2.5	100
19	3.94E-06	5.3	100	3.60E-06	5.0	100	3.25E-06	2.0	100	3.85E-06	2.5	100
20	2.68E-06	5.3	100	2.49E-06	5.0	100	2.31E-06	2.0	100	2.79E-06	2.5	100
21	1.88E-06	5.3	100	1.79E-06	5.0	100	1.55E-06	2.0	100	1.99E-06	2.5	100
22	3.12E-06	5.3	100	2.88E-06	5.0	100	2.57E-06	2.0	100	3.17E-06	2.5	100
23	5.29E-06	5.3	100	4.89E-06	5.0	100	4.36E-06	2.0	100	5.28E-06	2.5	100
24	5.15E-06	5.3	100	*1 4.88E-06	4.9	100	4.35E-06	2.0	100	5.27E-06	2.5	100
25	6.39E-06	5.3	100	6.10E-06	4.8	100	5.33E-06	2.0	100	6.38E-06	2.5	100
26	4.25E-06	5.3	100	4.12E-06	4.8	100	3.38E-06	2.0	100	4.14E-06	2.5	100
27	*1 5.71E-06	5.3	100	5.44E-06	4.8	100	*1 4.73E-06	2.0	100	5.60E-06	2.5	100
28	6.55E-06	5.3	100	6.42E-06	4.8	100	5.44E-06	2.0	100	6.47E-06	2.5	100
29	5.40E-06	5.3	100	5.36E-06	4.8	100	4.60E-06	2.0	100	5.53E-06	2.5	100
30	6.60E-06	5.3	100	6.49E-06	4.8	100	5.72E-06	2.0	100	6.79E-06	2.5	100
31	8.04E-06	5.3	100	7.86E-06	4.8	100	6.83E-06	2.0	100	8.18E-06	2.5	100
1ヶ月値	3.08E-06	5.3	100	2.93E-06	5.0	100	2.56E-06	2.0	100	3.08E-06	2.6	100
最大値	2.03E-05	5.5	102	1.91E-05	5.0	101	2.22E-05	2.0	103	2.58E-05	2.7	101
最大値日時	08/06 06:59	08/01 00:01	08/15 03:33	08/06 07:17	08/01 00:01	08/01 00:04	08/06 07:00	08/01 00:01	08/21 22:17	08/06 06:56	08/01 00:01	08/01 00:01
最小値	0.00E+00	5.3	98	0.00E+00	4.8	98	0.00E+00	2.0	83	0.00E+00	2.5	99
最小値日時	08/02 09:13	08/02 09:13	08/01 17:14	08/02 11:48	08/24 09:45	08/21 17:32	08/02 10:29	08/01 00:01	08/27 11:33	08/02 11:34	08/10 12:05	08/01 00:10

*1:ろ紙交換

測定月報

測定日：2021/08

(6/8)

日	モニタ											
	A021 Hタンクエリア			A022 Hタンクエリア			A023 2u西側			A024 2u西側		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.04E-06	1.9	100	2.19E-06	2.6	100	1.58E-06	14.0	100	2.05E-06	15.5	100
2	1.54E-06	1.9	100	*1 1.61E-06	2.5	100	1.21E-06	14.0	100	*1 1.52E-06	15.6	100
3	5.19E-07	1.9	100	5.56E-07	2.5	100	2.05E-07	14.0	100	4.01E-07	15.6	100
4	2.33E-06	1.9	100	2.44E-06	2.5	100	1.84E-06	14.0	100	2.27E-06	15.6	100
5	3.28E-06	1.9	100	3.39E-06	2.5	100	2.35E-06	14.0	100	2.75E-06	15.6	100
6	5.59E-06	1.9	100	5.93E-06	2.5	100	4.80E-06	14.0	100	5.38E-06	15.6	100
7	3.79E-06	1.9	100	4.10E-06	2.5	100	4.27E-06	14.0	100	4.83E-06	15.6	100
8	2.97E-06	1.9	100	3.22E-06	2.5	100	2.95E-06	14.0	100	3.29E-06	15.6	100
9	1.53E-06	1.9	100	1.66E-06	2.5	100	1.37E-06	14.0	100	1.73E-06	15.6	100
10	*1 1.30E-06	1.9	100	1.38E-06	2.5	100	*1 1.05E-06	13.8	100	1.22E-06	15.6	100
11	1.04E-06	1.9	100	1.11E-06	2.5	100	9.33E-07	13.6	100	9.61E-07	15.6	100
12	4.76E-07	1.9	100	5.09E-07	2.5	100	3.84E-07	13.6	100	2.61E-07	15.6	100
13	7.22E-07	1.9	100	7.85E-07	2.5	100	6.23E-07	13.6	100	4.77E-07	15.6	100
14	4.77E-07	1.9	100	5.41E-07	2.5	100	4.34E-07	13.6	100	2.47E-07	15.6	100
15	5.29E-07	1.9	100	5.84E-07	2.5	100	4.73E-07	13.6	100	2.50E-07	15.6	100
16	5.67E-07	1.9	100	6.04E-07	2.5	100	5.30E-07	13.6	100	3.17E-07	15.6	100
17	1.21E-06	1.9	100	1.33E-06	2.5	100	1.16E-06	13.6	100	9.99E-07	15.6	100
18	5.43E-07	1.9	100	6.13E-07	2.5	100	4.81E-07	13.6	100	3.83E-07	15.6	100
19	3.88E-06	1.9	100	4.11E-06	2.5	100	3.71E-06	13.6	100	3.77E-06	15.6	100
20	2.71E-06	1.9	100	2.95E-06	2.5	100	2.43E-06	13.6	100	2.61E-06	15.6	100
21	1.88E-06	1.9	100	2.01E-06	2.5	100	1.77E-06	13.6	100	1.89E-06	15.6	100
22	3.22E-06	1.9	100	3.46E-06	2.5	100	2.87E-06	13.6	100	2.95E-06	15.6	100
23	5.27E-06	1.9	100	5.80E-06	2.5	100	4.70E-06	13.6	100	4.91E-06	15.6	100
24	5.10E-06	1.9	100	5.54E-06	2.5	100	4.78E-06	13.6	100	5.02E-06	15.6	100
25	6.20E-06	1.9	100	6.70E-06	2.5	100	5.81E-06	13.6	100	6.08E-06	15.6	100
26	3.89E-06	1.9	100	4.22E-06	2.5	100	4.02E-06	13.6	100	4.25E-06	15.6	100
27	5.42E-06	1.9	100	*1 5.87E-06	2.6	100	5.36E-06	13.6	100	*1 5.77E-06	15.5	100
28	6.10E-06	1.9	100	6.56E-06	2.6	100	6.35E-06	13.6	100	6.73E-06	15.4	100
29	5.37E-06	1.9	100	5.80E-06	2.6	100	5.31E-06	13.6	100	5.59E-06	15.4	100
30	6.45E-06	1.9	100	6.97E-06	2.6	100	6.55E-06	13.6	100	6.92E-06	15.4	100
31	7.67E-06	1.9	100	8.29E-06	2.6	100	7.95E-06	13.6	100	8.34E-06	15.4	100
1ヶ月値	3.02E-06	1.9	100	3.25E-06	2.5	100	2.85E-06	13.7	100	3.04E-06	15.6	100
最大値	2.73E-05	1.9	102	2.92E-05	2.6	102	1.99E-05	14.0	101	5.03E-05	15.6	101
最大値日時	08/06 06:11	08/01 00:01	08/03 01:35	08/06 06:54	08/01 00:01	08/13 14:02	08/06 07:01	08/01 00:01	08/01 01:01	08/27 10:17	08/02 09:05	08/01 01:01
最小値	0.00E+00	1.9	98	0.00E+00	2.5	98	0.00E+00	13.6	99	0.00E+00	15.4	98
最小値日時	08/02 13:35	08/01 00:01	08/01 05:39	08/02 10:21	08/02 10:21	08/06 15:28	08/01 00:04	08/10 11:00	08/01 00:06	08/01 00:01	08/27 10:17	08/13 06:31

*1:ろ紙交換

測定月報

測定日：2021/08

(7/8)

日	モニタ											
	A027 1号機海側2、5m盤			A028 1号機海側2、5m盤			A029 3号機海側2、5m盤			A030 3号機海側2、5m盤		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.88E-06	4.0	100	1.90E-06	4.7	100	1.74E-06	2.7	100	1.86E-06	2.2	100
2	1.41E-06	4.0	100	1.42E-06	4.7	100	1.28E-06	2.7	100	1.37E-06	2.2	100
3	2.46E-07	4.0	100	2.91E-07	4.7	100	2.35E-07	2.7	100	2.89E-07	2.2	100
4	1.89E-06	4.0	100	1.92E-06	4.7	100	1.70E-06	2.7	100	1.82E-06	2.2	100
5	2.05E-06	4.0	100	2.08E-06	4.7	100	1.88E-06	2.7	100	2.03E-06	2.2	100
6	4.61E-06	4.0	100	4.58E-06	4.7	100	4.13E-06	2.7	100	4.32E-06	2.2	100
7	5.15E-06	4.0	100	5.16E-06	4.7	100	4.74E-06	2.7	100	5.01E-06	2.2	100
8	3.51E-06	4.0	100	3.56E-06	4.7	100	3.24E-06	2.7	100	3.42E-06	2.2	100
9	2.06E-06	4.0	100	2.10E-06	4.7	100	1.95E-06	2.7	100	2.10E-06	2.2	100
10	*1 1.33E-06	3.9	100	1.34E-06	4.7	100	1.19E-06	2.7	100	1.31E-06	2.2	100
11	1.05E-06	3.9	100	1.05E-06	4.7	100	9.53E-07	2.7	100	1.08E-06	2.2	100
12	4.21E-07	3.9	100	3.91E-07	4.7	100	3.59E-07	2.7	100	4.53E-07	2.2	100
13	6.97E-07	3.9	100	6.60E-07	4.7	100	6.11E-07	2.7	100	7.28E-07	2.2	100
14	4.75E-07	3.9	100	4.58E-07	4.7	100	4.34E-07	2.7	100	5.34E-07	2.2	100
15	4.96E-07	3.9	100	4.71E-07	4.7	100	4.59E-07	2.7	100	5.64E-07	2.2	100
16	4.75E-07	3.9	100	4.46E-07	4.7	100	4.45E-07	2.7	100	5.44E-07	2.2	100
17	1.15E-06	3.9	100	1.12E-06	4.7	100	1.06E-06	2.7	100	1.18E-06	2.2	100
18	4.30E-07	3.9	100	4.31E-07	4.7	100	*1 4.26E-07	2.6	100	4.82E-07	2.2	100
19	3.80E-06	3.9	100	3.85E-06	4.7	100	3.61E-06	2.6	100	3.75E-06	2.2	100
20	2.48E-06	3.9	100	2.48E-06	4.7	100	2.34E-06	2.6	100	2.45E-06	2.2	100
21	1.86E-06	3.9	100	1.85E-06	4.7	100	1.77E-06	2.6	100	1.82E-06	2.2	100
22	2.90E-06	3.9	100	2.90E-06	4.7	100	2.75E-06	2.6	100	2.87E-06	2.2	100
23	4.51E-06	3.9	100	4.46E-06	4.7	100	4.18E-06	2.6	100	4.33E-06	2.2	100
24	4.90E-06	3.9	100	*1 4.85E-06	4.7	100	4.60E-06	2.6	100	*1 4.76E-06	2.2	100
25	5.89E-06	3.9	100	5.73E-06	4.7	100	5.44E-06	2.6	100	5.62E-06	2.2	100
26	4.03E-06	3.9	100	3.99E-06	4.7	100	3.76E-06	2.6	100	3.85E-06	2.2	100
27	5.41E-06	3.9	100	5.29E-06	4.7	100	5.04E-06	2.6	100	5.21E-06	2.2	100
28	7.00E-06	3.9	100	6.82E-06	4.7	100	6.53E-06	2.6	100	6.65E-06	2.2	100
29	5.28E-06	3.9	100	5.16E-06	4.7	100	4.95E-06	2.6	100	5.12E-06	2.2	100
30	7.02E-06	3.9	100	6.74E-06	4.7	100	6.41E-06	2.6	100	6.58E-06	2.2	100
31	8.13E-06	3.9	100	7.98E-06	4.7	100	7.57E-06	2.6	100	7.80E-06	2.2	100
1ヶ月値	2.99E-06	3.9	100	2.95E-06	4.7	100	2.77E-06	2.7	100	2.90E-06	2.2	100
最大値	1.95E-05	4.0	102	1.89E-05	4.7	102	1.66E-05	2.7	102	1.77E-05	2.2	101
最大値日時	08/08 04:17	08/01 00:01	08/25 02:41	08/06 08:30	08/01 00:01	08/01 21:23	08/08 04:53	08/01 00:01	08/01 06:54	08/25 07:54	08/01 00:01	08/01 00:05
最小値	0.00E+00	3.9	98	0.00E+00	4.7	98	0.00E+00	2.6	98	0.00E+00	2.2	99
最小値日時	08/02 11:27	08/10 10:49	08/07 06:33	08/02 11:44	08/01 00:01	08/02 05:10	08/02 12:19	08/18 09:09	08/01 00:09	08/02 12:22	08/01 00:01	08/01 00:14

*1:ろ紙交換

測定月報

測定日：2021/08

(8/8)

日	モニタ											
	A031 HTI南側			A032 HTI南側								
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.10E-06	9.9	100	2.23E-06	6.1	100						
2	*1 1.44E-06	10.1	100	1.73E-06	6.1	100						
3	3.52E-07	10.2	100	5.80E-07	6.1	100						
4	2.10E-06	10.2	100	2.36E-06	6.1	100						
5	2.63E-06	10.2	100	2.78E-06	6.1	100						
6	5.32E-06	10.2	100	5.64E-06	6.1	100						
7	5.01E-06	10.2	100	5.23E-06	6.1	100						
8	3.35E-06	10.2	100	3.57E-06	6.1	100						
9	1.80E-06	10.2	100	2.07E-06	6.1	100						
10	1.20E-06	10.2	100	1.45E-06	6.1	100						
11	1.02E-06	10.2	100	1.21E-06	6.1	100						
12	3.08E-07	10.2	100	5.11E-07	6.1	100						
13	4.72E-07	10.2	100	6.26E-07	6.1	100						
14	2.77E-07	10.2	100	4.14E-07	6.1	100						
15	3.22E-07	10.2	100	4.76E-07	6.1	100						
16	4.01E-07	10.2	100	6.24E-07	6.1	100						
17	1.11E-06	10.2	100	1.30E-06	6.1	100						
18	3.78E-07	10.2	100	5.91E-07	6.1	100						
19	4.10E-06	10.2	100	4.25E-06	6.1	100						
20	2.81E-06	10.2	100	2.98E-06	6.1	100						
21	1.92E-06	10.2	100	2.14E-06	6.1	100						
22	2.94E-06	10.2	100	3.25E-06	6.1	100						
23	5.14E-06	10.2	100	5.30E-06	6.1	100						
24	5.09E-06	10.2	100	*1 5.36E-06	6.2	100						
25	6.32E-06	10.2	100	6.39E-06	6.3	100						
26	4.26E-06	10.2	100	4.32E-06	6.3	100						
27	*1 5.83E-06	10.1	100	5.73E-06	6.3	100						
28	6.84E-06	10.0	100	6.88E-06	6.3	100						
29	5.66E-06	10.0	100	5.65E-06	6.3	100						
30	7.04E-06	10.0	100	6.90E-06	6.3	100						
31	8.49E-06	10.0	100	8.37E-06	6.3	100						
1ヶ月値	3.10E-06	10.2	100	3.25E-06	6.1	100						
最大値	2.31E-05	10.2	105	2.22E-05	6.3	102						
最大値日時	08/06 07:19	08/02 08:55	08/27 10:25	08/06 07:14	08/24 09:26	08/02 05:16						
最小値	0.00E+00	9.9	98	0.00E+00	6.1	98						
最小値日時	08/01 00:04	08/01 00:01	08/01 00:19	08/02 12:41	08/01 00:01	08/03 10:37						

*1: ろ紙交換