

GM	メンバー

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta+\gamma$	$\gamma$	$\beta+\gamma$
ZK-00380	2024/11/1	6	F1-ICWBL-56	0.002	0.002	0.003	—
ZK-00373	2024/11/1	6	F1-ICWBL-56	0.002	0.002	0.003	—
TB-024	2024/11/1	6	F1-ICWBL-56	0.002	0.002	0.002	—
2019 FU-00122	2024/11/1	6	F1-ICWBL-56	0.002	0.002	0.002	—
ZK-00943	2024/11/1	6	F1-ICWBL-56	0.002	0.002	0.002	—
ZK-00916	2024/11/1	6	F1-ICWBL-56	0.002	0.002	0.004	—
2019 FU-00206G	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.004	—
ZK-00017	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.80	—
2019 ZK-03102	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.004	—
2020 FU-00155	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.004	—
2019 SS-00287	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.20	—
2020 ZK-03644	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.019	—
2020 ZK-03630	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.046	—
2021 SS-30176	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.004	—
2020 SS-00110	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.004	—
2019 ZK-02226	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.010	—
2021 NM-00046	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.63	—
2019 SS-00514	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.023	—
2019 NS-00065	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.004	—
2018 ZK-01424	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.004	—
S006	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.40	—
ZK-00300	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.026	—
S040	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.44	—
TB-183	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.004	—
ZK-01087	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.004	—
S059	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.090	—
ZK-00474	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.073	—
ZK-00296	2024/11/5	6	F1-ICWBL-89	0.004	0.004	0.019	—
ZK-01236	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.006	—
ZK-00511	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.040	—
2021 SS-30200	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.004	—
2021 FU-00154	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.004	—
S057	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.016	—
ZK-00610	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.004	—
2020 SS-00358	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.022	—
2019 ZK-02837	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.17	—
2020 FU-00184	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.058	—



瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m <sup>3</sup> )	測定器No.	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
2020 SS-00256 ✓	2024/11/6 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.11 ✓	—
2019 ZK-03129 ✓	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.017 ✓	—
2021 SS-40439 ✓	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.10 ✓	—
2018 FU-00079 ✓	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.084 ✓	—
2020 ZK-03555 ✓	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.054 ✓	—
2019 FU-00323 ✓	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.051 ✓	—
2019 ZK-03107 ✓	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
2019 SS-00250 ✓	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.017 ✓	—
2022 SK-00994 ✓	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.049 ✓	—
2020 ZK-04536 ✓	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.073 ✓	—
2022 SK-00747 ✓	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.045 ✓	—
2020 ZK-03472 ✓	2024/11/6	6	F1-ICWBL-89	0.004	0.004	0.49 ✓	—
2021 SS-30415 ✓	2024/11/7 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.045 ✓	—
2019 ZK-02501 ✓	2024/11/7	6	F1-ICWBL-89	0.004	0.004	0.008 ✓	—
2019 ZK-02462 ✓	2024/11/7	6	F1-ICWBL-89	0.004	0.004	0.018 ✓	—
ZK-01251 ✓	2024/11/7	6	F1-ICWBL-89	0.004	0.004	0.015 ✓	—
2018 ZK-01473 ✓	2024/11/7	6	F1-ICWBL-89	0.004	0.004	0.012 ✓	—
2019 ZK-03151 ✓	2024/11/7	6	F1-ICWBL-89	0.004	0.004	0.098 ✓	—
2020 ZK-03635 ✓	2024/11/7	6	F1-ICWBL-89	0.004	0.004	0.060 ✓	—
2019 ZK-02957 ✓	2024/11/7	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
2019 FU-00361 ✓	2024/11/12 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.020 ✓	—
ZK-00245 ✓	2024/11/12	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
TB-266 ✓	2024/11/12	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
ZK-00368 ✓	2024/11/12	6	F1-ICWBL-89	0.004	0.004	0.041 ✓	—
ZK-00271 ✓	2024/11/12	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
ZK-00935 ✓	2024/11/12	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
ZK-00286 ✓	2024/11/12	6	F1-ICWBL-89	0.004	0.004	0.016 ✓	—
ZK-00263 ✓	2024/11/12	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
ZK-00572 ✓	2024/11/13 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.004 ✓	—
ZK-00475 ✓	2024/11/13	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
ZK-00261 ✓	2024/11/13	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
TB-131 ✓	2024/11/13	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
ZK-00259 ✓	2024/11/13	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
TB-193 ✓	2024/11/13	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
ZK-00262 ✓	2024/11/13	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
ZK-00297 ✓	2024/11/13	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
TB-256 ✓	2024/11/13	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—



瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m <sup>3</sup> )	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
ZK-01115	2024/11/13	6	F1-ICWBL-89	0.004	0.004	0.004	—
ZK-01179	2024/11/13	6	F1-ICWBL-89	0.004	0.004	0.004	—
2021 SS-30114	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.15	—
2021 FU-00155	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.10	—
2018 ZK-01505	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.16	—
2021 SS-30299	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.20	—
2021 SS-30181	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.12	—
2021 SS-30119	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.19	—
2020 ZK-04546	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.074	—
2019 FU-00262G	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.59	—
2019 SS-00427	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.095	—
ZK-00768	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.15	—
ZK-01023	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.16	—
2021 FU-00112	2024/11/15	6	F1-ICWBL-56	0.004	0.004	0.18	—
TB-206	2024/11/16	6	F1-ICWBL-56	0.004	0.004	0.008	—
ZK-01027	2024/11/16	6	F1-ICWBL-56	0.004	0.004	0.011	—
2019 NS-00109	2024/11/16	6	F1-ICWBL-56	0.004	0.004	0.013	—
2021 SS-30199	2024/11/16	6	F1-ICWBL-56	0.004	0.004	0.045	—
2019 ZK-03122	2024/11/16	6	F1-ICWBL-56	0.004	0.004	0.007	—
2019 ZK-02582	2024/11/16	6	F1-ICWBL-56	0.004	0.004	0.006	—
2019 SS-00342	2024/11/16	6	F1-ICWBL-56	0.004	0.004	0.005	—
2019 ZK-02753	2024/11/16	6	F1-ICWBL-56	0.004	0.004	0.008	—
2020 SS-00067	2024/11/18	6	F1-ICWBL-56	0.004	0.004	0.54	—
2019 SS-00060	2024/11/18	6	F1-ICWBL-56	0.004	0.004	0.059	—
2019 ZK-02438	2024/11/18	6	F1-ICWBL-56	0.004	0.004	0.65	—
2020 SS-00405	2024/11/18	6	F1-ICWBL-56	0.004	0.004	0.48	—
2019 ZK-02497	2024/11/18	6	F1-ICWBL-56	0.004	0.004	0.40	—
2019 FU-00156G	2024/11/18	6	F1-ICWBL-56	0.004	0.004	0.17	—
2020 FU-00254	2024/11/18	6	F1-ICWBL-56	0.004	0.004	0.19	—
2019 SS-00059	2024/11/18	6	F1-ICWBL-56	0.004	0.004	0.75	—
2019 ZK-02506	2024/11/18	6	F1-ICWBL-89	0.004	0.004	0.64	—
2019 ZK-02511	2024/11/18	6	F1-ICWBL-89	0.004	0.004	0.45	—
2019 SS-00382	2024/11/18	6	F1-ICWBL-89	0.004	0.004	0.062	—
2019 SS-00324	2024/11/18	6	F1-ICWBL-89	0.004	0.004	0.16	—
2019 SS-00293	2024/11/18	6	F1-ICWBL-89	0.004	0.004	0.28	—
2019 SS-00297	2024/11/18	6	F1-ICWBL-89	0.004	0.004	0.12	—
2019 SS-00333	2024/11/18	6	F1-ICWBL-89	0.004	0.004	0.035	—



瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m <sup>3</sup> )	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
2019 SS-00340 /	2024/11/18 /	6 /	F1-ICWBL-89 /	0.004 /	0.004 /	0.29 /	—
2019 SS-00298 /	2024/11/18	6	F1-ICWBL-89	0.004	0.004	0.064 /	—
2018 FU-00007 /	2024/11/18	6	F1-ICWBL-89	0.004	0.004	0.044 /	—
2019 SS-00023 /	2024/11/19 /	6 /	F1-ICWBL-56 /	0.004 /	0.004 /	0.085 /	—
2019 FU-00226G /	2024/11/19	6	F1-ICWBL-56	0.004	0.004	0.16 /	—
2020 SS-00322 /	2024/11/19	6	F1-ICWBL-56	0.004	0.004	0.51 /	—
2019 SS-00049 /	2024/11/19	6	F1-ICWBL-56	0.004	0.004	0.13 /	—
2019 FU-00264 /	2024/11/19	6	F1-ICWBL-56	0.004	0.004	0.018 /	—
2019 FU-00262 /	2024/11/19	6	F1-ICWBL-56	0.004	0.004	0.064 /	—
2019 FU-00277 /	2024/11/19	6	F1-ICWBL-56	0.004	0.004	0.031 /	—
2019 FU-00166 /	2024/11/19	6	F1-ICWBL-56	0.004	0.004	0.083 /	—
2019 FU-00162 /	2024/11/19	6	F1-ICWBL-56	0.004	0.004	0.023 /	—
2019 FU-00253 /	2024/11/19	6	F1-ICWBL-56	0.004	0.004	0.047 /	—
2019 FU-00270 /	2024/11/19 /	6 /	F1-ICWBL-89 /	0.004 /	0.004 /	0.062 /	—
2019 FU-00268 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.41 /	—
2019 FU-00261 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.038 /	—
S7 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.33 /	—
S11 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.78 /	—
S6 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.93 /	—
2020 ZK-04720 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.49 /	—
2019 FU-00159 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.031 /	—
2020 ZK-04722 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.95 /	—
2019 FU-00160 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.037 /	—
2019 FU-00156 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.026 /	—
2020 ZK-04718 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.50 /	—
2018 FU-00039 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.008 /	—
2018 FU-00031 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.16 /	—
2020 ZK-04719 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.58 /	—
2019 FU-00271 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.051 /	—
2018 FU-00029 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.016 /	—
2020 ZK-04721 /	2024/11/19	6	F1-ICWBL-89	0.004	0.004	0.48 /	—
2019 FU-00238 /	2024/11/20 /	6 /	F1-ICWBL-89 /	0.004 /	0.004 /	0.66 /	—
2019 FU-00158 /	2024/11/20	6	F1-ICWBL-89	0.004	0.004	0.037 /	—
2018 FU-00034 /	2024/11/20	6	F1-ICWBL-89	0.004	0.004	0.047 /	—
2018 FU-00026 /	2024/11/20	6	F1-ICWBL-89	0.004	0.004	0.009 /	—
2018 FU-00138 /	2024/11/20	6	F1-ICWBL-89	0.004	0.004	0.005 /	—
2018 FU-00023 /	2024/11/20	6	F1-ICWBL-89	0.004	0.004	0.063 /	—



瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
2020 ZK-04710 ✓	2024/11/20 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.71 ✓	—
2018 ZK-01451 ✓	2024/11/20	6	F1-ICWBL-89	0.004	0.004	0.025 ✓	—
2018 FU-00036 ✓	2024/11/20	6	F1-ICWBL-89	0.004	0.004	0.012 ✓	—
2019 ZK-02356 ✓	2024/11/20	6	F1-ICWBL-89	0.004	0.004	0.83 ✓	—
ZK-01106 ✓	2024/11/22 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.070 ✓	—
S10 ✓	2024/11/22	6	F1-ICWBL-56	0.005	0.005	0.22 ✓	—
2020 ZK-04709 ✓	2024/11/22	6	F1-ICWBL-56	0.005	0.005	0.48 ✓	—
2020 ZK-04711 ✓	2024/11/22	6	F1-ICWBL-56	0.005	0.005	0.48 ✓	—
2019 SS-00260 ✓	2024/11/22	6	F1-ICWBL-56	0.005	0.005	0.46 ✓	—
2021 SS-40390 ✓	2024/11/22	6	F1-ICWBL-56	0.005	0.005	0.55 ✓	—
2019 SS-00056 ✓	2024/11/22	6	F1-ICWBL-56	0.005	0.005	0.68 ✓	—
2021 SS-40397 ✓	2024/11/22	6	F1-ICWBL-56	0.005	0.005	0.65 ✓	—
2021 SS-40446 ✓	2024/11/22	6	F1-ICWBL-56	0.005	0.005	0.45 ✓	—
2021 SS-40472 ✓	2024/11/22	6	F1-ICWBL-56	0.005	0.005	0.48 ✓	—
2019 SS-00152 ✓	2024/11/22	6	F1-ICWBL-56	0.005	0.005	0.25 ✓	—
2021 SS-40193 ✓	2024/11/23 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.75 ✓	—
2022 SK-00476 ✓	2024/11/23	6	F1-ICWBL-56	0.005	0.005	0.42 ✓	—
2021 SS-40382 ✓	2024/11/23	6	F1-ICWBL-56	0.005	0.005	0.35 ✓	—
2021 SS-40396 ✓	2024/11/23	6	F1-ICWBL-56	0.005	0.005	0.37 ✓	—
2021 SS-40441 ✓	2024/11/23	6	F1-ICWBL-56	0.005	0.005	0.66 ✓	—
2021 SS-40399 ✓	2024/11/23	6	F1-ICWBL-56	0.005	0.005	0.37 ✓	—
2021 SS-40447 ✓	2024/11/23	6	F1-ICWBL-56	0.005	0.005	0.30 ✓	—
2021 SS-40389 ✓	2024/11/23	6	F1-ICWBL-56	0.005	0.005	0.41 ✓	—
2021 SS-40469 ✓	2024/11/23	6	F1-ICWBL-56	0.005	0.005	0.65 ✓	—
2022 SK-01036 ✓	2024/11/23	6	F1-ICWBL-56	0.005	0.005	0.41 ✓	—
2021 SS-40468 ✓	2024/11/25 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.57 ✓	—
2021 SS-40465 ✓	2024/11/25	6	F1-ICWBL-56	0.005	0.005	0.30 ✓	—
2021 SS-40392 ✓	2024/11/25	6	F1-ICWBL-56	0.005	0.005	0.58 ✓	—
2021 SS-40470 ✓	2024/11/25	6	F1-ICWBL-56	0.005	0.005	0.56 ✓	—
2021 SS-40393 ✓	2024/11/25	6	F1-ICWBL-56	0.005	0.005	0.64 ✓	—
2021 SS-40395 ✓	2024/11/25	6	F1-ICWBL-56	0.005	0.005	0.47 ✓	—
2021 SS-40466 ✓	2024/11/25	6	F1-ICWBL-56	0.005	0.005	0.47 ✓	—
2021 SS-40454 ✓	2024/11/25	6	F1-ICWBL-56	0.005	0.005	0.49 ✓	—
2021 SS-40406 ✓	2024/11/25	6	F1-ICWBL-56	0.005	0.005	0.46 ✓	—
2021 SS-40453 ✓	2024/11/25	6	F1-ICWBL-56	0.005	0.005	0.74 ✓	—
2019 ZK-03044 ✓	2024/11/25 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.005 ✓	—
S085 ✓	2024/11/25	6	F1-ICWBL-89	0.004	0.004	0.48 ✓	—



瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
TB-180 ✓	2024/11/25 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.005 ✓	—
HP-00002 ✓	2024/11/25	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
TB-034 ✓	2024/11/25	6	F1-ICWBL-89	0.004	0.004	0.10 ✓	—
TB-142 ✓	2024/11/25	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
2020 ZK-03377 ✓	2024/11/25	6	F1-ICWBL-89	0.004	0.004	0.014 ✓	—
TB-112 ✓	2024/11/25	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
KM-00377 ✓	2024/11/25	6	F1-ICWBL-89	0.004	0.004	0.45 ✓	—
S055 ✓	2024/11/25	6	F1-ICWBL-89	0.004	0.004	0.14 ✓	—
2019 ZK-03217 ✓	2024/11/25	6	F1-ICWBL-89	0.004	0.004	0.006 ✓	—
2022 SK-01035 ✓	2024/11/26 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.32 ✓	—
2021 SS-40384 ✓	2024/11/26	6	F1-ICWBL-56	0.005	0.005	0.40 ✓	—
2020 ZK-03340 ✓	2024/11/26	6	F1-ICWBL-56	0.005	0.005	0.26 ✓	—
2020 ZK-03435 ✓	2024/11/26	6	F1-ICWBL-56	0.005	0.005	0.41 ✓	—
2020 SS-00087 ✓	2024/11/26	6	F1-ICWBL-56	0.005	0.005	0.49 ✓	—
2021 SS-10031 ✓	2024/11/26	6	F1-ICWBL-56	0.005	0.005	0.51 ✓	—
2021 SS-40400 ✓	2024/11/26	6	F1-ICWBL-56	0.005	0.005	0.61 ✓	—
2020 SS-00257 ✓	2024/11/26	6	F1-ICWBL-56	0.005	0.005	0.41 ✓	—
2021 SK-00282 ✓	2024/11/26	6	F1-ICWBL-56	0.005	0.005	0.46 ✓	—
2020 ZK-03336 ✓	2024/11/26	6	F1-ICWBL-56	0.005	0.005	0.48 ✓	—
2020 ZK-03562 ✓	2024/11/26 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.17 ✓	—
2019 ZK-03303 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
2020 ZK-03325 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	0.032 ✓	—
2020 ZK-03556 ✓	2024/11/26 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.21 ✓	—
2019 ZK-03156 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
2020 ZK-03519 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	0.037 ✓	—
2020 ZK-03642 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	0.009 ✓	—
2020 ZK-03636 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	0.010 ✓	—
2019 ZK-03212 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
2019 ZK-03248 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
2021 SS-30042 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	0.093 ✓	—
2021 FU-00127 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	0.74 ✓	—
2021 ZK-05254 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	1.85 ✓	—
2021 FU-00173 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	1.14 ✓	—
2021 ZK-04960 ✓	2024/11/26	6	F1-ICWBL-89	0.004	0.004	0.34 ✓	—
2020 SS-00088 ✓	2024/11/27 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.54 ✓	—
2020 ZK-03770 ✓	2024/11/27	6	F1-ICWBL-56	0.005	0.005	0.20 ✓	—
2020 ZK-03365 ✓	2024/11/27	6	F1-ICWBL-56	0.005	0.005	0.12 ✓	—



瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m <sup>3</sup> )	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
2021 ZK-05259 ✓	2024/11/27 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.67 ✓	—
2019 SS-00098 ✓	2024/11/27	6	F1-ICWBL-56	0.005	0.005	0.095 ✓	—
2019 SS-00446 ✓	2024/11/27	6	F1-ICWBL-56	0.005	0.005	0.075 ✓	—
2021 ZK-04947 ✓	2024/11/27	6	F1-ICWBL-56	0.005	0.005	0.31 ✓	—
2021 SS-00170 ✓	2024/11/27	6	F1-ICWBL-56	0.005	0.005	0.76 ✓	—
2020 ZK-03727 ✓	2024/11/27	6	F1-ICWBL-56	0.005	0.005	0.26 ✓	—
2020 SS-00224 ✓	2024/11/27	6	F1-ICWBL-56	0.005	0.005	0.34 ✓	—
2019 SS-00013 ✓	2024/11/27 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.14 ✓	—
2019 FU-00138 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.13 ✓	—
2020 ZK-03345 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.25 ✓	—
2022 SK-00786 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.62 ✓	—
2020 ZK-03514 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.23 ✓	—
2022 FU-00189 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	1.07 ✓	—
2021 SS-40405 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	1.20 ✓	—
2022 SK-00720 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.38 ✓	—
2019 SS-00106 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.36 ✓	—
2019 SS-00268 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.21 ✓	—
2019 FU-00275G ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.27 ✓	—
2019 SS-00221 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.021 ✓	—
2019 SS-00103 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.076 ✓	—
2019 SS-00423 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.055 ✓	—
2022 FU-00076 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.90 ✓	—
2019 FU-00024 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.051 ✓	—
2019 SS-00055 ✓	2024/11/27	6	F1-ICWBL-89	0.004	0.004	0.47 ✓	—
2019 ZK-02418 ✓	2024/11/28 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.48 ✓	—
2019 SS-00294 ✓	2024/11/28	6	F1-ICWBL-56	0.005	0.005	0.20 ✓	—
2019 SS-00058 ✓	2024/11/28	6	F1-ICWBL-56	0.005	0.005	0.093 ✓	—
2019 SS-00238 ✓	2024/11/28	6	F1-ICWBL-56	0.005	0.005	0.060 ✓	—
2019 SS-00027 ✓	2024/11/28	6	F1-ICWBL-56	0.005	0.005	0.22 ✓	—
2019 SS-00156 ✓	2024/11/28	6	F1-ICWBL-56	0.005	0.005	0.33 ✓	—
2022 FU-00167 ✓	2024/11/28	6	F1-ICWBL-56	0.005	0.005	0.54 ✓	—
ZK-00039 ✓	2024/11/28	6	F1-ICWBL-56	0.005	0.005	0.21 ✓	—
2019 ZK-02816 ✓	2024/11/28	6	F1-ICWBL-56	0.005	0.005	0.35 ✓	—
2019 ZK-02339 ✓	2024/11/28	6	F1-ICWBL-56	0.005	0.005	0.13 ✓	—
2021 SS-40447 ✓	2024/11/29 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.30 ✓	—
2019 FU-00272 ✓	2024/11/29 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.014 ✓	—
2019 ZK-02412 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.19 ✓	—

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m <sup>3</sup> )	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
2019 SS-00154 ✓	2024/11/29 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.12 ✓	—
2019 FU-00258 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.013 ✓	—
2019 FU-00155 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.008 ✓	—
2018 FU-00027 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.019 ✓	—
2019 FU-00266 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.027 ✓	—
2019 SS-00024 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.18 ✓	—
2019 FU-00263 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.019 ✓	—
2018 FU-00015 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.028 ✓	—
2019 FU-00196 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.060 ✓	—
2019 FU-00266G ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.64 ✓	—
2018 FU-00010 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.020 ✓	—
2019 SS-00590 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	1.01 ✓	—
2019 ZK-02840 ✓	2024/11/29	6	F1-ICWBL-89	0.004	0.004	0.18 ✓	—
2019 FU-00274G ✓	2024/11/30 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.098 ✓	—
2019 FU-00267 ✓	2024/11/30	6	F1-ICWBL-56	0.005	0.005	0.020 ✓	—
2019 FU-00170 ✓	2024/11/30	6	F1-ICWBL-56	0.005	0.005	0.26 ✓	—
2019 SS-00441 ✓	2024/11/30	6	F1-ICWBL-56	0.005	0.005	0.25 ✓	—
2019 SS-00448 ✓	2024/11/30	6	F1-ICWBL-56	0.005	0.005	0.33 ✓	—