

GM	メンバー

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2022 CT-00279	2025/8/1	6	F1-ICWBL-258	0.004	0.004	0.004	-
2022 CT-00172	2025/8/1	6	F1-ICWBL-258	0.004	0.004	0.004	-
2022 SK-00330	2025/8/4	6	F1-ICWBL-258	0.004	0.004	0.004	-
2022 SK-00361	2025/8/4	6	F1-ICWBL-258	0.004	0.004	0.004	-
2022 CT-00261	2025/8/4	6	F1-ICWBL-258	0.004	0.004	0.004	-
2022 SK-00342	2025/8/4	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-02692	2025/8/4	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-02659	2025/8/4	6	F1-ICWBL-258	0.004	0.004	0.004	-
TB-299	2025/8/4	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03160	2025/8/4	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-40057	2025/8/4	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 ZK-04845	2025/8/4	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 FU-00160	2025/8/5	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-02941	2025/8/5	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-40001	2025/8/5	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-40276	2025/8/5	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-40033	2025/8/5	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-10356	2025/8/5	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-10506	2025/8/5	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04156	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04179	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-40006	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-10635	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03112	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04189	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-10239	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.026	-
2020 ZK-04153	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 FU-00068	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.004	-
KM-00032	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04172	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 ZK-05014	2025/8/6	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03174	2025/8/7	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03158	2025/8/7	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-02960	2025/8/7	6	F1-ICWBL-258	0.004	0.004	0.023	-
2021 SS-10212	2025/8/7	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-00174	2025/8/7	6	F1-ICWBL-258	0.004	0.004	0.004	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2020 ZK-04170	2025/8/7	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 CT-00036	2025/8/7	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-10554	2025/8/7	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03080	2025/8/7	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-40055	2025/8/7	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 ZK-04842	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 FU-00205	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 FU-00172	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.023	-
2019 ZK-02985	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03159	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03083	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-02958	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-02675	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03079	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03296	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-40072	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03362	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03357	2025/8/8	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SK-00085	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SK-00088	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03164	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 ZK-05043	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04368	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03171	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03016	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
ZK-00251	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04151	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04169	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-02975	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04085	2025/8/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 FU-00112	2025/8/12	6	F1-ICWBL-240	0.004	0.004	0.005	-
2019 ZK-02559	2025/8/12	6	F1-ICWBL-240	0.004	0.004	0.019	-
2019 ZK-02502	2025/8/12	6	F1-ICWBL-240	0.004	0.004	0.017	-
2020 ZK-03554	2025/8/12	6	F1-ICWBL-240	0.004	0.004	0.021	-
2019 NS-00036	2025/8/13	6	F1-ICWBL-240	0.004	0.004	0.004	-
2019 FU-00152	2025/8/13	6	F1-ICWBL-240	0.004	0.004	0.019	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 ZK-02453	2025/8/13	6	F1-ICWBL-240	0.004	0.004	0.038	-
2019 ZK-02742	2025/8/13	6	F1-ICWBL-240	0.004	0.004	0.005	-
2019 FU-00090	2025/8/13	6	F1-ICWBL-240	0.004	0.004	0.026	-
2019 FU-00084	2025/8/13	6	F1-ICWBL-240	0.004	0.004	0.069	-
2018 ZK-01476	2025/8/13	6	F1-ICWBL-240	0.004	0.004	0.011	-
2019 ZK-02898	2025/8/13	6	F1-ICWBL-240	0.004	0.004	0.006	-
2019 ZK-02723	2025/8/13	6	F1-ICWBL-240	0.004	0.004	0.063	-
2019 SS-00088	2025/8/13	6	F1-ICWBL-240	0.004	0.004	0.025	-
2019 NS-00832	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04117	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04171	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 NS-00879	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 NS-00908	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04184	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04180	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 SS-00013	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04140	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 NS-00825	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2022 SS-00439	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 SS-40017	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04188	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
TB-248	2025/8/13	6	F1-ICWBL-258	0.004	0.004	0.004	-
S062	2025/8/19	6	F1-ICWBL-258	0.004	0.004	0.27	-
ZK-00613	2025/8/19	6	F1-ICWBL-258	0.004	0.004	0.004	-
2018 ZK-01797	2025/8/19	6	F1-ICWBL-258	0.004	0.004	0.19	-
S085	2025/8/19	6	F1-ICWBL-258	0.004	0.004	0.58	-
TB-180	2025/8/19	6	F1-ICWBL-258	0.004	0.004	0.005	-
TB-034	2025/8/19	6	F1-ICWBL-258	0.004	0.004	0.12	-
HP-00002	2025/8/19	6	F1-ICWBL-258	0.004	0.004	0.004	-
TB-234	2025/8/20	6	F1-ICWBL-258	0.004	0.004	0.004	-
TB-067	2025/8/20	6	F1-ICWBL-258	0.004	0.004	0.004	-
ZK-00266	2025/8/20	6	F1-ICWBL-258	0.004	0.004	0.013	-
ZK-00810	2025/8/20	6	F1-ICWBL-258	0.004	0.004	0.007	-
TB-112	2025/8/20	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03217	2025/8/20	6	F1-ICWBL-258	0.004	0.004	0.004	-
TB-142	2025/8/20	6	F1-ICWBL-258	0.004	0.004	0.004	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2020 ZK-03377	2025/8/20	6	F1-ICWBL-258	0.004	0.004	0.018	-
2019 ZK-03248	2025/8/20	6	F1-ICWBL-258	0.004	0.004	0.004	-
ZK-00701	2025/8/21	6	F1-ICWBL-240	0.004	0.004	0.006	-
KM-10089	2025/8/21	6	F1-ICWBL-240	0.004	0.004	0.018	-
2020 ZK-03638	2025/8/21	6	F1-ICWBL-240	0.004	0.004	0.040	-
2019 NS-00247	2025/8/21	6	F1-ICWBL-240	0.004	0.004	0.006	-
2020 ZK-03575	2025/8/21	6	F1-ICWBL-240	0.004	0.004	0.063	-
2019 ZK-02733	2025/8/21	6	F1-ICWBL-240	0.004	0.004	0.008	-
2019 FU-00080	2025/8/21	6	F1-ICWBL-240	0.004	0.004	0.006	-
2019 ZK-03212	2025/8/21	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03156	2025/8/21	6	F1-ICWBL-258	0.004	0.004	0.004	-
S055	2025/8/21	6	F1-ICWBL-258	0.004	0.004	0.15	-
2020 ZK-03636	2025/8/21	6	F1-ICWBL-258	0.004	0.004	0.010	-
2020 ZK-03642	2025/8/21	6	F1-ICWBL-258	0.004	0.004	0.011	-
2020 ZK-03519	2025/8/21	6	F1-ICWBL-258	0.004	0.004	0.044	-
2020 ZK-03556	2025/8/21	6	F1-ICWBL-258	0.004	0.004	0.22	-
2019 ZK-03139	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.064	-
2019 ZK-02449	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.007	-
TB-130	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.047	-
ZK-00450	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.008	-
2019 ZK-02627	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.019	-
2019 ZK-02274	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.010	-
2019 ZK-02277	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.006	-
2019 ZK-02596	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.010	-
2019 ZK-02600	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.008	-
2019 FU-00147	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.010	-
2019 ZK-02598	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.010	-
ZK-01184	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.011	-
ZK-00644	2025/8/22	6	F1-ICWBL-240	0.004	0.004	0.023	-
ZK-00761	2025/8/22	6	F1-ICWBL-258	0.004	0.004	0.023	-
ZK-00960	2025/8/22	6	F1-ICWBL-258	0.004	0.004	0.028	-
ZK-00700	2025/8/22	6	F1-ICWBL-258	0.004	0.004	0.046	-
ZK-00733	2025/8/22	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03562	2025/8/22	6	F1-ICWBL-258	0.004	0.004	0.19	-
2019 ZK-03303	2025/8/22	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03692	2025/8/25	6	F1-ICWBL-240	0.004	0.004	0.060	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 SS-00272	2025/8/25	6	F1-ICWBL-240	0.004	0.004	0.030	-
2019 NS-00322	2025/8/25	6	F1-ICWBL-240	0.004	0.004	0.006	-
2020 FU-00235	2025/8/25	6	F1-ICWBL-240	0.004	0.004	0.098	-
2019 SS-00209	2025/8/25	6	F1-ICWBL-240	0.004	0.004	0.043	-
2020 ZK-03535	2025/8/25	6	F1-ICWBL-240	0.004	0.004	0.081	-
2019 ZK-02615	2025/8/25	6	F1-ICWBL-240	0.004	0.004	0.007	-
2019 ZK-02795	2025/8/25	6	F1-ICWBL-240	0.004	0.004	0.019	-
2019 SS-00487	2025/8/25	6	F1-ICWBL-240	0.004	0.004	0.006	-
2019 ZK-02729	2025/8/26	6	F1-ICWBL-258	0.004	0.004	0.033	-
2018 FU-00074	2025/8/26	6	F1-ICWBL-258	0.004	0.004	0.025	-
2019 ZK-02870	2025/8/26	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03693	2025/8/26	6	F1-ICWBL-258	0.004	0.004	0.066	-
2019 FU-00374	2025/8/26	6	F1-ICWBL-258	0.004	0.004	0.011	-
ZK-00445	2025/8/26	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 ZK-04835	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 NS-00889	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04174	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04217	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04165	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 NS-00839	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 NS-00815	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 NS-00895	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 ZK-04781	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
2021 ZK-04733	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-04295	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03573	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.049	-
2019 ZK-02284	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.004	-
ZK-01061	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.078	-
ZK-01085	2025/8/28	6	F1-ICWBL-258	0.004	0.004	0.048	-
2019 NS-00062	2025/8/29	6	F1-ICWBL-240	0.003	0.003	0.004	-
2019 ZK-02513	2025/8/29	6	F1-ICWBL-240	0.003	0.003	0.020	-
2019 FU-00189G	2025/8/29	6	F1-ICWBL-240	0.003	0.003	0.008	-
2019 NS-00314	2025/8/29	6	F1-ICWBL-240	0.003	0.003	0.004	-
2020 FU-00206	2025/8/29	6	F1-ICWBL-240	0.003	0.003	0.008	-
ZK-01075	2025/8/29	6	F1-ICWBL-240	0.003	0.003	0.010	-
2018 ZK-01837	2025/8/29	6	F1-ICWBL-240	0.003	0.003	0.041	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 ZK-02817	2025/8/29	6	F1-ICWBL-240	0.003	0.003	0.007	-