1. Radiation concentration estimates for each tank area

Estimates for each tank area will no longer be shown, since actual radiation concentration measurements are released.

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

(as of March 31, 2025)

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

B Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	1.26E+00	<4.28E-01	6.86E-01	2.71E+00	<2.99E+00	9.23E+03	5.21E+01	1.25E+06	1.55E+01	5.77E+00	2.03E+04	<7.77E-02	313.51	313.52
A5	4.82E-01	<2.97E-01	6.56E-01	1.99E+00	<1.53E+00	2.49E+03	5.39E+01	1.27E+06	1.45E+01	5.92E+00	5.91E+03	<6.00E-02	89.16	89.17
B1	<1.25E-01	<1.37E-01	4.26E-01	<4.48E-01	<1.20E+00	1.15E+00	<2.32E-01	6.42E+05	2.36E+01	<1.68E+00	1.09E+01	<5.69E-02	0.08	0.10
B2	<2.15E-01	<2.13E-01	4.59E-01	<4.26E-01	<1.05E+00	<4.71E-01	1.54E-01	6.13E+05	1.84E+01	<4.79E-01	7.13E+00	<6.28E-02	0.05	0.06
B3	<1.17E-01	<1.63E-01	3.64E-01	<4.43E-01	<1.18E+00	<4.62E-01	1.16E-01	6.11E+05	1.99E+01	<4.30E-01	6.37E+00	<6.28E-02	0.05	0.06
B4	<1.26E-01	<1.37E-01	2.25E-01	<3.98E-01	<1.20E+00	9.92E-01	1.42E-01	6.12E+05	2.83E+01	<4.30E-01	1.16E+01	<6.79E-02	0.07	0.08
B5	<1.16E-01	<1.56E-01	3.65E-01	<3.14E-01	<1.11E+00	4.06E+00	<2.32E-01	6.72E+05	3.18E+01	<1.68E+00	1.79E+01	<5.69E-02	0.18	0.20
C1	1.61E+00	<3.35E-01	5.17E-01	1.88E+00	<1.49E+00	1.74E+03	4.49E+01	1.02E+06	1.02E+01	4.57E+00	3.85E+03	<9.32E-02	63.10	63.11
D1	3.03E-01	<1.56E-01	<1.78E-01	<4.98E-01	<1.28E+00	1.19E+00	6.57E-01	4.89E+05	3.83E+00	<1.28E+00	8.01E+00	<9.32E-02	0.13	0.14
D2	1.08E+00	<4.66E-01	5.91E-01	2.36E+00	<3.06E+00	6.10E+03	4.23E+01	1.12E+06	9.48E+00	4.89E+00	1.42E+04	<8.35E-02	208.13	208.13
D3	9.19E-01	<3.78E-01	4.94E-01	2.48E+00	<2.70E+00	5.92E+03	4.80E+01	1.06E+06	1.13E+01	5.13E+00	1.37E+04	<8.35E-02	202.78	202.79
D4	1.50E+00	<1.55E+00	<1.18E+00	4.88E+00	<1.21E+01	9.26E+03	4.79E+01	1.13E+06	1.29E+01	4.97E+00	2.02E+04	<8.35E-02	314.06	314.07
D5	2.78E+00	<1.96E+00	<1.34E+00	<6.16E+00	<1.75E+01	1.12E+04	4.68E+01	1.21E+06	1.63E+01	5.22E+00	2.44E+04	<7.77E-02	378.79	378.80
D6	2.16E+00	<4.98E-01	4.27E-01	2.77E+00	<3.59E+00	1.71E+04	4.65E+01	1.32E+06	1.45E+01	5.47E+00	4.04E+04	<7.77E-02	573.57	573.59
D7	2.98E+00	<6.97E-01	4.26E-01	4.78E+00	<4.63E+00	2.26E+04	4.49E+01	1.47E+06	1.44E+01	5.92E+00	5.28E+04	<7.77E-02	757.76	757.77
D8	1.93E+00	<6.05E-01	3.79E-01	1.77E+00	<4.19E+00	1.42E+04	3.49E+01	1.17E+06	1.16E+01	4.28E+00	3.02E+04	<7.97E-02	478.63	478.64
D9	2.13E+00	<4.81E-01	6.52E-01	3.00E+00	<3.36E+00	1.42E+04	4.62E+01	1.27E+06	1.35E+01	5.12E+00	3.27E+04	<7.97E-02	479.54	479.55
E1	3.92E-01	<2.09E-01	4.81E-01	2.19E+00	<1.40E+00	4.57E+02	4.64E+01	1.02E+06	9.95E+00	4.46E+00	1.04E+03	<9.03E-02	20.41	20.42
E6	9.66E-01	<2.32E-01	4.57E-01	2.42E+00	<2.33E+00	7.36E+03	4.11E+01	1.18E+06	1.25E+01	4.78E+00	1.56E+04	<9.03E-02	250.01	250.02

※ primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

B South Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	<2.35E-01	<2.05E-01	<1.86E-01	<7.20E-01	1.82E+00	3.82E+00	9.11E-01	4.80E+05	5.40E+00	<1.28E+00	8.70E+00	<9.03E-02	0.25	0.26
A2	<1.17E-01	<1.43E-01	4.01E-01	<3.81E-01	<1.08E+00	<4.09E-01	5.04E-01	4.04E+05	4.85E+00	<7.19E-01	6.31E+00	<5.36E-02	0.09	0.09
A3	<1.19E-01	<1.89E-01	6.01E-01	<3.75E-01	<1.21E+00	<3.83E-01	1.37E+00	3.36E+05	9.37E+00	<7.19E-01	5.16E+00	<5.36E-02	0.18	0.19
A4	<1.28E-01	<1.58E-01	4.75E-01	<4.93E-01	<9.65E-01	<3.93E-01	1.28E+00	3.38E+05	1.01E+01	<7.19E-01	4.05E+00	<5.36E-02	0.17	0.18
A5	3.86E-01	<1.82E-01	7.75E-01	<4.00E-01	<1.27E+00	3.55E+00	2.63E+00	3.24E+05	1.28E+01	<1.28E+00	7.33E+00	<9.03E-02	0.43	0.44
A6	<1.24E-01	<1.34E-01	4.90E-01	<4.07E-01	<1.17E+00	<4.90E-01	1.20E+00	3.44E+05	8.96E+00	<7.19E-01	6.45E+00	<5.36E-02	0.17	0.17
A7	<1.26E-01	<1.37E-01	3.27E-01	<3.94E-01	<1.33E+00	<4.50E-01	6.86E-01	4.02E+05	6.57E+00	<7.19E-01	3.91E+00	<5.36E-02	0.11	0.11

※ primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G1 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	1.86E-01	<1.48E-01	2.60E-01	<3.90E-01	<1.12E+00	<4.51E-01	1.21E-01	3.04E+05	3.06E+00	<3.93E-01	6.31E+00	<6.00E-02	0.05	0.05
A2	<1.49E-01	<1.23E-01	1.71E-01	<4.09E-01	<1.21E+00	<4.77E-01	<1.40E-01	3.83E+05	5.15E+00	<3.93E-01	5.18E+00	<6.00E-02	0.05	0.05
A3	<1.66E-01	<2.88E-01	2.67E-01	4.78E-01	<1.18E+00	<4.01E-01	1.57E-01	4.14E+05	4.77E+00	<3.93E-01	5.13E+00	<5.36E-02	0.05	0.05
A4	<1.56E-01	<3.57E-01	2.29E-01	<4.29E-01	<1.06E+00	<3.98E-01	1.22E-01	4.11E+05	6.60E+00	<3.93E-01	5.51E+00	<5.36E-02	0.05	0.05
A5	<1.39E-01	<1.49E-01	3.24E-01	<4.58E-01	<1.16E+00	<4.23E-01	1.81E-01	4.12E+05	6.44E+00	<3.93E-01	4.23E+00	<4.97E-02	0.05	0.06
A6	<1.64E-01	<2.18E-01	4.36E-01	<4.10E-01	<1.41E+00	<4.27E-01	1.30E-01	4.21E+05	1.16E+01	<3.93E-01	4.42E+00	<4.97E-02	0.05	0.06
A7	<1.64E-01	<1.80E-01	3.15E-01	<4.93E-01	<1.35E+00	<4.76E-01	1.07E-01	4.21E+05	1.25E+01	<3.93E-01	7.60E+00	<5.69E-02	0.05	0.05
A8	<1.84E-01	<1.63E-01	3.89E-01	<4.65E-01	<1.26E+00	<4.68E-01	1.15E-01	4.32E+05	1.20E+01	<3.93E-01	3.77E+00	<5.69E-02	0.05	0.05
A9	<1.52E-01	<1.29E-01	2.09E-01	<4.81E-01	<1.26E+00	<4.65E-01	<1.84E-01	4.34E+05	1.19E+01	<5.88E-01	3.78E+00	<4.97E-02	0.05	0.06
A10	<1.57E-01	<1.52E-01	3.40E-01	<4.63E-01	<1.04E+00	<4.79E-01	1.93E-01	4.22E+05	5.58E+00	<5.88E-01	5.30E+00	<4.97E-02	0.05	0.06
A11	<1.30E-01	<1.40E-01	1.86E-01	<4.46E-01	<1.15E+00	<3.86E-01	<1.84E-01	4.16E+05	7.90E+00	<5.88E-01	6.56E+00	<5.69E-02	0.05	0.05
A12	<1.47E-01	<1.55E-01	2.94E-01	<3.91E-01	<1.10E+00	<4.28E-01	<1.84E-01	3.82E+05	5.41E+00	<5.88E-01	4.58E+00	<5.69E-02	0.05	0.06
A13	<1.49E-01	<1.54E-01	2.71E-01	<3.95E-01	<1.03E+00	<4.66E-01	<1.84E-01	4.12E+05	1.03E+01	<5.88E-01	6.47E+00	<6.54E-02	0.05	0.06
A14	<1.42E-01	<1.80E-01	2.47E-01	<3.91E-01	<1.15E+00	<4.16E-01	<1.84E-01	4.26E+05	5.67E+00	<5.88E-01	5.43E+00	<6.54E-02	0.05	0.06
A15	<1.32E-01	<1.98E-01	3.11E-01	<4.33E-01	<1.10E+00	<4.24E-01	<1.84E-01	4.28E+05	7.94E+00	<5.88E-01	6.56E+00	<5.36E-02	0.05	0.06

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G1 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
B1	<1.16E-01	<1.49E-01	2.45E-01	<4.18E-01	<1.15E+00	<4.68E-01	2.01E-01	4.98E+05	1.28E+01	<7.97E-01	<5.59E+00	<5.65E-02	0.05	0.06
B2	<1.49E-01	<1.61E-01	<1.63E-01	<4.11E-01	<9.35E-01	<3.55E-01	<2.07E-01	4.76E+05	1.02E+01	<4.49E-01	6.77E+00	<6.00E-02	0.05	0.06
B3	<1.37E-01	<1.45E-01	3.84E-01	<4.63E-01	<1.23E+00	<4.28E-01	<2.07E-01	4.92E+05	5.53E+00	<4.49E-01	8.28E+00	<6.00E-02	0.06	0.06
B4	<1.35E-01	<1.63E-01	3.29E-01	<4.99E-01	<1.79E+00	<3.78E-01	<2.07E-01	5.09E+05	1.42E+01	<4.49E-01	8.80E+00	<6.00E-02	0.06	0.07
B5	<1.39E-01	<1.96E-01	2.83E-01	<3.90E-01	<1.07E+00	<3.88E-01	2.02E-01	5.34E+05	1.53E+01	<4.49E-01	5.81E+00	<5.69E-02	0.05	0.06
B6	<1.34E-01	<1.17E-01	3.50E-01	<4.14E-01	<1.19E+00	<3.76E-01	1.52E-01	5.82E+05	7.63E+00	<4.49E-01	6.94E+00	<5.69E-02	0.05	0.05
B7	<1.30E-01	<2.87E-01	3.31E-01	<4.28E-01	<1.18E+00	<3.71E-01	1.11E-01	5.75E+05	1.17E+01	<4.49E-01	5.48E+00	<6.28E-02	0.04	0.05
B8	<1.24E-01	<1.36E-01	3.57E-01	<3.93E-01	<1.19E+00	<3.88E-01	8.17E-02	5.35E+05	1.41E+01	<4.65E-01	6.70E+00	<6.28E-02	0.04	0.05
B9	<1.34E-01	<1.45E-01	3.03E-01	<4.11E-01	<1.10E+00	<3.70E-01	4.77E-02	5.02E+05	1.18E+01	<4.65E-01	6.88E+00	<6.54E-02	0.03	0.04
B10	<1.38E-01	<2.02E-01	1.79E-01	<3.85E-01	<1.12E+00	<4.18E-01	5.76E-02	4.80E+05	1.41E+01	<4.65E-01	6.51E+00	<6.54E-02	0.04	0.05
B11	<1.21E-01	<3.42E-01	2.68E-01	<3.93E-01	<1.02E+00	<4.20E-01	5.27E-01	5.68E+05	1.64E+01	<4.79E-01	6.19E+00	<5.36E-02	0.09	0.10
B12	<1.22E-01	<1.21E-01	2.86E-01	<3.78E-01	<1.15E+00	<4.10E-01	4.13E-01	5.81E+05	1.83E+01	<4.79E-01	7.60E+00	<5.36E-02	0.08	0.09
B13	<1.40E-01	<1.63E-01	3.81E-01	<4.60E-01	<1.17E+00	<4.94E-01	4.44E-01	5.78E+05	1.86E+01	<4.79E-01	7.55E+00	<5.36E-02	0.08	0.09
B14	<1.30E-01	<1.67E-01	3.86E-01	<4.34E-01	<1.10E+00	<4.00E-01	<4.35E-01	5.65E+05	2.13E+01	<7.17E-01	6.06E+00	<5.10E-02	0.08	0.09

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G1 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
C1	<2.43E-01	<2.28E-01	3.15E-01	<7.67E-01	<2.15E+00	<4.73E-01	<7.74E-02	3.92E+05	1.22E+01	<2.41E-01	<7.22E+00	<7.57E-02	0.05	0.06
C2	<1.40E-01	<1.58E-01	2.30E-01	<4.07E-01	<1.31E+00	<4.39E-01	2.91E-01	4.25E+05	8.69E+00	<5.88E-01	6.03E+00	<6.79E-02	0.07	0.07
C3	<1.26E-01	<1.42E-01	5.90E-01	<4.18E-01	<1.10E+00	<4.03E-01	3.03E-01	5.12E+05	1.35E+01	<5.88E-01	6.31E+00	<6.79E-02	0.07	0.07
C4	<1.48E-01	<1.51E-01	7.92E-01	<4.47E-01	<1.37E+00	<4.49E-01	2.47E-01	6.08E+05	1.53E+01	<4.49E-01	7.85E+00	<6.00E-02	0.06	0.07
C5	<2.54E-01	<2.03E-01	8.19E-01	<5.26E-01	<1.58E+00	<3.60E-01	1.36E-01	6.64E+05	1.93E+01	<2.41E-01	<6.77E+00	<7.57E-02	0.05	0.06
C6	<1.30E-01	<1.38E-01	4.45E-01	<4.26E-01	<1.22E+00	<4.12E-01	3.89E-01	5.56E+05	1.75E+01	<4.79E-01	8.21E+00	<5.36E-02	0.08	0.08
C7	<1.48E-01	<1.58E-01	4.50E-01	<3.75E-01	<1.07E+00	<4.61E-01	3.50E-01	5.27E+05	3.45E+00	<4.79E-01	6.69E+00	<5.69E-02	0.07	0.07
C8	<1.38E-01	<1.37E-01	4.76E-01	<3.78E-01	<1.16E+00	<4.73E-01	3.03E-01	5.29E+05	1.08E+01	<4.79E-01	8.38E+00	<5.69E-02	0.07	0.07
C9	<1.41E-01	<1.51E-01	4.43E-01	<4.40E-01	<9.79E-01	<4.67E-01	<4.35E-01	5.66E+05	1.86E+01	<7.17E-01	9.65E+00	<6.29E-02	0.08	0.09
C10	<1.38E-01	<1.55E-01	3.81E-01	<4.61E-01	<1.47E+00	<3.79E-01	9.70E-02	5.85E+05	1.16E+01	<4.79E-01	8.88E+00	<5.36E-02	0.04	0.05
C11	<1.34E-01	<2.88E-01	3.80E-01	<3.82E-01	<1.09E+00	<4.02E-01	9.99E-02	5.87E+05	7.53E+00	<4.79E-01	8.35E+00	<5.36E-02	0.04	0.05
C12	<1.26E-01	<1.20E-01	3.47E-01	<4.01E-01	<1.21E+00	<3.91E-01	8.41E-02	5.95E+05	1.61E+01	<4.79E-01	6.69E+00	<5.64E-02	0.04	0.05
C13	<1.30E-01	<1.42E-01	3.42E-01	<4.37E-01	<1.49E+00	<4.30E-01	5.97E-02	5.99E+05	1.03E+01	<4.79E-01	5.56E+00	<5.64E-02	0.04	0.05

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G1 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
D1	<1.26E-01	<1.66E-01	2.35E-01	<4.57E-01	<1.15E+00	<3.90E-01	2.02E-01	3.56E+05	5.55E+00	<5.29E-01	5.03E+00	<6.00E-02	0.05	0.06
D2	<1.28E-01	<2.18E-01	5.01E-01	<3.95E-01	<1.19E+00	<3.88E-01	1.49E-01	3.86E+05	9.03E+00	<5.29E-01	5.03E+00	<6.00E-02	0.05	0.05
D3	<1.46E-01	<1.52E-01	4.12E-01	<4.21E-01	<1.06E+00	<3.94E-01	7.83E-02	4.05E+05	8.76E+00	<4.76E-01	4.97E+00	<5.64E-02	0.04	0.04
D4	<1.30E-01	<1.51E-01	3.24E-01	<4.51E-01	<1.30E+00	<3.79E-01	<4.64E-02	4.17E+05	9.16E+00	<4.76E-01	6.65E+00	<5.64E-02	0.04	0.04
D5	<1.32E-01	<2.14E-01	3.70E-01	4.26E-01	<1.06E+00	<4.85E-01	2.66E-01	4.78E+05	1.09E+01	<4.54E-01	5.11E+00	<5.64E-02	0.06	0.07
D6	<1.50E-01	<1.62E-01	2.94E-01	<4.88E-01	<1.22E+00	<3.59E-01	2.78E-01	5.07E+05	1.01E+01	<4.54E-01	5.38E+00	<5.64E-02	0.06	0.07
D7	<1.36E-01	<1.36E-01	3.24E-01	<3.96E-01	<1.15E+00	<3.78E-01	3.50E-01	4.98E+05	1.04E+01	<4.54E-01	4.94E+00	<4.97E-02	0.07	0.07
D8	<1.31E-01	<1.57E-01	4.78E-01	<3.87E-01	<9.89E-01	<4.97E-01	3.67E-01	5.20E+05	1.10E+01	<4.54E-01	7.99E+00	<4.97E-02	0.07	0.08
D9	<1.30E-01	<1.43E-01	3.12E-01	<4.54E-01	<1.05E+00	8.10E-01	2.95E-01	5.29E+05	4.05E+00	<4.54E-01	8.43E+00	<4.97E-02	0.08	0.08
D10	<1.38E-01	<1.74E-01	3.88E-01	<3.59E-01	<1.12E+00	6.61E-01	3.29E-01	5.40E+05	8.57E+00	<4.54E-01	7.36E+00	<4.97E-02	0.08	0.08
D11	<1.38E-01	<1.53E-01	4.48E-01	<4.33E-01	<1.16E+00	<4.78E-01	3.20E-01	5.25E+05	1.18E+01	<4.54E-01	6.06E+00	<6.32E-02	0.07	0.08
D12	<1.25E-01	<1.27E-01	4.33E-01	<4.09E-01	<1.24E+00	<4.49E-01	3.95E-01	5.13E+05	1.21E+01	<4.54E-01	7.04E+00	<6.32E-02	0.08	0.08

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G1 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
E1	<1.40E-01	<2.08E-01	6.13E-01	<4.28E-01	<1.24E+00	1.91E+00	2.48E-01	2.69E+05	4.35E+00	<3.21E-01	8.66E+00	<5.69E-02	0.11	0.11
E2	<1.40E-01	<1.78E-01	7.67E-01	<4.46E-01	<1.26E+00	1.04E+00	2.38E-01	2.98E+05	8.12E+00	<3.21E-01	6.86E+00	<5.69E-02	0.08	0.09
E3	1.54E-01	<2.92E-01	6.92E-01	4.20E-01	<1.02E+00	1.00E+00	2.17E-01	3.90E+05	8.43E+00	<3.21E-01	6.14E+00	<4.97E-02	0.08	0.08
E4	1.58E-01	<2.89E-01	6.04E-01	<3.81E-01	<1.16E+00	7.82E-01	1.64E-01	5.03E+05	1.64E+01	<3.21E-01	8.37E+00	<4.97E-02	0.07	0.07
E5	<1.51E-01	<2.79E-01	7.25E-01	<4.05E-01	<1.42E+00	4.76E-01	1.17E-01	5.86E+05	1.95E+01	<3.21E-01	8.12E+00	<6.00E-02	0.05	0.06
E6	3.43E-01	<1.73E-01	8.30E-01	<3.98E-01	<1.16E+00	<4.40E-01	1.23E-01	6.54E+05	8.38E+00	<3.21E-01	9.83E+00	<6.00E-02	0.05	0.06
E7	1.47E-01	<1.31E-01	7.74E-01	<4.20E-01	<1.13E+00	<5.09E-01	1.00E-01	6.85E+05	9.74E+00	<3.93E-01	9.49E+00	<6.00E-02	0.05	0.05
E8	<1.59E-01	<1.62E-01	7.56E-01	<4.38E-01	<1.13E+00	7.30E-01	1.35E-01	6.74E+05	2.68E+01	<3.93E-01	7.41E+00	<6.00E-02	0.06	0.07
E9	1.84E-01	<2.29E-01	7.73E-01	<4.11E-01	<1.30E+00	5.29E-01	1.22E-01	6.13E+05	2.34E+01	<3.93E-01	8.45E+00	<6.00E-02	0.05	0.07
E10	1.52E-01	<1.70E-01	6.72E-01	<4.38E-01	<1.24E+00	7.20E-01	2.40E-01	5.03E+05	1.95E+01	<3.93E-01	6.74E+00	<4.97E-02	0.07	0.08
E11	<1.40E-01	<2.17E-01	8.18E-01	5.20E-01	<1.22E+00	1.02E+00	2.94E-01	3.99E+05	1.35E+01	<3.93E-01	7.02E+00	<4.97E-02	0.09	0.10
E12	<1.56E-01	<1.89E-01	6.82E-01	<4.43E-01	<1.22E+00	1.11E+00	2.38E-01	3.45E+05	1.63E+01	<3.93E-01	8.51E+00	<4.97E-02	0.08	0.09

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G1 South Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	<5.95E-02	<1.33E-01	6.57E-01	3.90E-01	2.62E+00	<2.45E-01	2.97E+00	4.26E+05	—	—	9.76E+00	—	0.37	—
A5	1.38E-01	<7.02E-02	1.62E+00	6.49E-01	<7.97E-01	2.54E-01	1.12E+01	6.25E+05	—	—	3.38E+01	—	1.28	—
A5※2	3.42E-01	<1.89E-01	1.28E+00	<4.78E-01	<1.38E+00	<5.03E-01	7.64E+00	5.75E+05	8.05E+01	<1.20E+00	2.63E+01	—	0.89	0.94
B1	5.41E-01	1.69E-01	7.33E-01	6.70E-01	1.53E+00	9.54E+00	4.62E+00	7.93E+05	—	—	6.31E+01	—	0.86	—
B1※2	4.40E-01	<1.74E-01	6.34E-01	5.06E-01	<1.29E+00	2.38E+00	3.04E+00	6.33E+05	9.60E+01	5.61E+00	3.51E+01	<6.28E-02	0.44	0.50
B2	4.31E-01	<1.61E-01	4.86E-01	<4.61E-01	<1.21E+00	5.67E-01	1.74E+00	7.75E+05	1.36E+02	1.99E+00	3.36E+01	<6.79E-02	0.23	0.30
B3	2.93E-01	<2.22E-01	4.19E-01	4.07E-01	<1.07E+00	8.33E-01	2.12E+00	7.70E+05	1.25E+02	2.34E+00	2.81E+01	<6.79E-02	0.28	0.35
B4	1.95E-01	<2.08E-01	4.28E-01	4.04E-01	<1.03E+00	1.05E+00	2.18E+00	5.68E+05	6.35E+01	4.72E+00	2.08E+01	<5.36E-02	0.30	0.33
B6	<1.60E-01	<1.43E-01	4.52E-01	<4.25E-01	<1.04E+00	7.70E-01	2.13E+00	6.73E+05	8.34E+01	3.24E+00	2.45E+01	<5.36E-02	0.28	0.32
B7	2.13E-01	<1.33E-01	8.06E-01	5.99E-01	1.50E+00	6.18E-01	3.76E+00	7.62E+05	—	—	2.99E+01	—	0.46	—
B7	1.82E-01	<1.41E-01	4.01E-01	<4.28E-01	<1.23E+00	8.31E-01	2.26E+00	6.01E+05	6.93E+01	3.66E+00	2.14E+01	<4.97E-02	0.30	0.34
C1	6.35E-02	<8.11E-02	6.85E-01	4.48E-01	<7.81E-01	2.22E+01	1.32E+01	1.60E+06	—	—	1.22E+02	—	2.22	—
C6	<6.48E-02	<1.03E-01	7.39E-01	4.13E-01	1.05E+00	9.01E-02	5.41E+00	3.21E+05	—	—	1.09E+01	—	0.62	—
B5	2.64E+00	<4.16E-01	6.18E-01	3.79E+00	<2.99E+00	1.85E+04	4.30E+01	2.20E+06	2.27E+01	6.63E+00	3.77E+04	<9.32E-02	621.19	621.20

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Concentrations of Carbon-14 and Technetium-99 which affect the concentration of Gross β were additionally measured.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G3 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	<7.23E-02	<1.05E-01	5.86E-01	2.50E+00	<1.01E+00	<2.85E-01	4.11E+01	8.45E+05	—	—	1.38E+01	—	4.59	—
B1	<5.85E-02	<6.46E-02	9.70E-02	1.07E+00	<7.66E-01	7.59E-02	2.36E+01	6.55E+05	—	—	1.50E+01	—	2.63	—
C1	4.21E-01	<7.13E-02	2.83E-01	1.72E+00	1.92E+00	1.10E+01	3.78E+01	1.41E+06	—	—	6.10E+01	—	4.59	—
D1	9.26E+00	<1.68E+00	1.24E+01	1.67E+01	<1.06E+01	2.28E+03	1.85E+00	2.80E+05	9.55E+00	<5.24E-01	5.62E+03	—	76.43	76.43

G4 North Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	4.67E-01	<1.54E-01	4.51E-01	<4.04E-01	<1.02E+00	9.42E+00	1.39E-01	3.53E+05	1.90E+01	<5.68E-01	2.22E+01	<6.45E-02	0.35	0.36
A2	2.55E-01	<1.71E-01	3.62E-01	<4.71E-01	<1.08E+00	5.05E+00	4.47E-01	3.12E+05	1.38E+01	<4.94E-01	1.42E+01	<6.45E-02	0.24	0.24
A3	1.90E-01	<1.60E-01	4.16E-01	<4.28E-01	<1.24E+00	4.60E+00	3.38E-01	3.11E+05	1.65E+01	<4.94E-01	1.23E+01	<6.45E-02	0.21	0.22
B1	<1.47E-01	<1.45E-01	2.86E-01	4.63E-01	<1.08E+00	1.76E+00	8.33E-01	2.61E+05	1.58E+01	<4.94E-01	9.54E+00	<6.39E-02	0.17	0.18
B2	2.47E-01	<1.35E-01	3.59E-01	<3.86E-01	<1.10E+00	<5.74E-01	1.16E+00	1.84E+05	1.64E+01	<5.68E-01	5.92E+00	<6.45E-02	0.17	0.18
B3	2.33E-01	<1.32E-01	3.78E-01	<3.67E-01	<9.88E-01	2.38E+00	7.90E-01	2.72E+05	1.64E+01	<4.94E-01	1.01E+01	<6.39E-02	0.18	0.19

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6
4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G4 South Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1※2	—	—	—	—	—	—	—	—	—	—	—	—	—	—
A2※2	—	—	—	—	—	—	—	—	—	—	—	—	—	—
A3※2	—	—	—	—	—	—	—	—	—	—	—	—	—	—
A4※2	—	—	—	—	—	—	—	—	—	—	—	—	—	—
A5※2	—	—	—	—	—	—	—	—	—	—	—	—	—	—
A6※2	—	—	—	—	—	—	—	—	—	—	—	—	—	—
A7※2	—	—	—	—	—	—	—	—	—	—	—	—	—	—
A8※2	—	—	—	—	—	—	—	—	—	—	—	—	—	—
B1	<1.28E-01	<2.20E-01	1.79E-01	<4.00E-01	<1.22E+00	<5.15E-01	<1.06E-01	3.71E+05	7.94E+00	<3.44E-01	<7.99E+00	<6.28E-02	0.05	0.05
B2	<1.48E-01	<3.97E-01	2.93E-01	<4.52E-01	<1.29E+00	<5.83E-01	<7.38E-02	3.70E+05	9.81E+00	<3.44E-01	<7.99E+00	<6.28E-02	0.05	0.06
B3	1.35E-01	<2.05E-01	4.05E-01	<3.99E-01	<1.21E+00	5.39E-01	<7.38E-02	3.88E+05	7.65E+00	<3.44E-01	1.00E+01	<6.00E-02	0.05	0.05
B4	1.92E-01	<1.65E-01	3.92E-01	<4.58E-01	<1.19E+00	<4.95E-01	<7.38E-02	4.21E+05	1.08E+01	<3.44E-01	6.74E+00	<6.00E-02	0.04	0.05
B5	4.11E-01	<1.39E-01	4.16E-01	<4.72E-01	<1.16E+00	6.15E-01	<7.38E-02	4.65E+05	1.09E+01	<3.47E-01	<6.38E+00	<5.64E-02	0.05	0.06
B6	4.82E-01	<1.28E-01	5.18E-01	<4.42E-01	<1.12E+00	7.14E-01	3.05E-01	5.10E+05	1.21E+01	<3.47E-01	6.51E+00	<5.64E-02	0.08	0.09
B7	7.30E-01	<1.77E-01	5.95E-01	<4.73E-01	<1.21E+00	<6.53E-01	1.74E-01	5.35E+05	1.18E+01	<3.47E-01	7.79E+00	<5.24E-02	0.07	0.07
B8	6.08E-01	<1.38E-01	4.98E-01	<4.62E-01	<1.19E+00	1.41E+00	1.87E-01	5.39E+05	1.94E+01	<3.47E-01	1.02E+01	<5.24E-02	0.09	0.10
B9	8.16E-01	<1.60E-01	3.85E-01	<4.75E-01	<1.30E+00	1.54E+00	2.17E-01	5.16E+05	2.10E+01	<3.47E-01	1.16E+01	<4.97E-02	0.10	0.11
B10	9.77E-01	<1.53E-01	5.20E-01	<4.38E-01	<1.25E+00	2.45E+00	2.23E-01	5.03E+05	1.80E+01	<3.47E-01	1.16E+01	<4.97E-02	0.14	0.14

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Radiation concentration data for this group will no longer be released due to the discharge of stored water.

【Reference】Value notation for radioactive concentrations, etc.

(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6

4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G4 South Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
C1※2	<1.36E-01	<1.49E-01	4.44E-01	<3.53E-01	<1.12E+00	<4.42E-01	3.91E-01	2.15E+05	3.50E+01	3.53E-01	8.66E+00	<6.07E-02	0.08	0.09
C6※2	<1.50E-01	<1.39E-01	3.40E-01	<4.30E-01	<1.15E+00	<4.20E-01	3.00E-01	2.50E+05	2.44E+01	7.45E-01	8.57E+00	<6.07E-02	0.07	0.08

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 ALPS treated water was transferred to this area after discharging stored water.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6
4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G5 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	5.14E-01	<1.37E-01	7.11E-01	5.07E-01	<1.17E+00	8.18E+00	1.71E-01	2.99E+05	3.38E+01	<3.49E-01	2.88E+01	<6.45E-02	0.32	0.33
A1	2.19E-01	<1.58E-01	4.47E-01	<7.04E-01	<1.41E+00	5.17E-01	1.09E+00	2.47E+05	4.21E+01	<3.47E-01	6.81E+00	<5.47E-02	0.16	0.18
A2	2.14E-01	<1.35E-01	5.59E-01	<4.27E-01	<1.23E+00	2.46E+00	4.37E-01	2.83E+05	3.89E+01	<3.64E-01	1.16E+01	<7.12E-02	0.15	0.17
A3	3.57E-01	<1.63E-01	4.80E-01	<4.34E-01	<1.26E+00	2.26E+00	3.63E-01	2.85E+05	3.40E+01	<3.64E-01	1.46E+01	<7.12E-02	0.14	0.16
A4	<1.32E-01	<1.27E-01	3.74E-01	<4.15E-01	<1.04E+00	1.52E+00	1.75E-01	3.21E+05	2.15E+01	<3.49E-01	1.15E+01	<6.45E-02	0.09	0.10
A4	2.71E-01	<1.65E-01	5.72E-01	<4.18E-01	<1.13E+00	2.65E+00	6.60E-01	3.02E+05	3.11E+01	<3.47E-01	1.02E+01	<6.29E-02	0.18	0.20
B1	2.22E-01	<1.48E-01	6.58E-01	<5.27E-01	<1.33E+00	<4.42E-01	2.21E-01	2.31E+05	4.18E+01	<3.64E-01	1.25E+01	<5.63E-02	0.06	0.08
B2	2.13E-01	<1.51E-01	8.11E-01	<4.43E-01	<1.25E+00	<4.37E-01	3.07E-01	2.26E+05	4.98E+01	<5.82E-01	1.40E+01	<6.07E-02	0.07	0.10
B3	2.52E-01	<1.67E-01	4.00E-01	5.29E-01	<1.25E+00	6.71E-01	2.61E-01	2.46E+05	4.35E+01	<5.82E-01	1.24E+01	<6.07E-02	0.07	0.09
B4	3.47E-01	<1.55E-01	5.52E-01	<6.17E-01	<1.42E+00	9.32E-01	2.72E-01	2.64E+05	4.03E+01	<3.64E-01	1.21E+01	<5.63E-02	0.09	0.11
C1	1.58E-01	<1.51E-01	6.15E-01	<4.84E-01	<1.16E+00	<4.69E-01	3.86E-01	2.18E+05	4.46E+01	<3.64E-01	8.10E+00	<6.07E-02	0.08	0.10
C2	4.27E-01	<1.33E-01	5.61E-01	<3.98E-01	<1.10E+00	<4.76E-01	6.35E-01	2.22E+05	4.38E+01	<5.82E-01	1.97E+01	<6.07E-02	0.11	0.13
C3	3.16E-01	<1.48E-01	6.02E-01	<4.31E-01	<1.14E+00	<4.25E-01	1.54E+00	2.33E+05	4.00E+01	<3.64E-01	1.02E+01	<6.07E-02	0.21	0.23
D1	1.79E-01	<1.88E-01	6.12E-01	<6.69E-01	<1.30E+00	<4.94E-01	1.33E-01	3.03E+05	2.61E+01	<3.49E-01	7.82E+00	<7.50E-02	0.05	0.07
D2	<1.43E-01	<1.45E-01	3.81E-01	<3.64E-01	<1.02E+00	6.66E-01	2.08E-01	3.25E+05	2.79E+01	<3.47E-01	9.77E+00	<6.29E-02	0.06	0.08
D3	<1.56E-01	<1.67E-01	3.93E-01	<6.05E-01	<1.50E+00	8.76E-01	3.05E-01	3.47E+05	3.92E+01	<3.49E-01	1.49E+01	<7.50E-02	0.09	0.11
E1	3.83E-01	<1.39E-01	5.78E-01	<4.06E-01	<1.14E+00	<4.53E-01	1.96E-01	2.21E+05	4.07E+01	<5.82E-01	1.23E+01	<5.63E-02	0.06	0.08
E2	2.28E-01	<1.57E-01	7.34E-01	4.45E-01	<1.25E+00	<4.69E-01	3.88E-01	2.18E+05	3.64E+01	<4.42E-01	1.43E+01	<7.16E-02	0.08	0.10
E3	<1.53E-01	<1.77E-01	5.27E-01	<4.18E-01	<1.22E+00	<4.35E-01	4.43E-01	2.18E+05	4.02E+01	<5.82E-01	1.04E+01	<5.63E-02	0.08	0.10

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G6 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	4.42E-01	<3.17E-01	9.20E-01	<6.63E-01	<1.93E+00	1.47E+00	<3.51E-01	8.88E+05	3.77E+01	<1.38E+00	8.47E+00	<9.03E-02	0.12	0.14
A2	4.44E-01	<2.20E-01	8.52E-01	<4.01E-01	<1.30E+00	<5.11E-01	<2.88E-01	8.01E+05	5.11E+01	<7.19E-01	1.17E+01	<5.36E-02	0.08	0.10
A3	5.43E-01	<2.70E-01	8.22E-01	4.69E-01	<1.24E+00	6.36E-01	<2.88E-01	8.58E+05	5.90E+01	<7.19E-01	1.81E+01	<5.36E-02	0.08	0.11
A4	5.97E-01	<1.22E-01	7.28E-01	<4.54E-01	<1.27E+00	8.47E-01	<2.88E-01	9.12E+05	7.81E+01	<4.01E-01	1.40E+01	<6.00E-02	0.09	0.13
A5	6.25E-01	<2.08E-01	4.99E-01	<4.38E-01	<1.21E+00	1.13E+00	<2.88E-01	9.62E+05	9.13E+01	<4.01E-01	2.01E+01	<6.00E-02	0.10	0.14
A6	6.56E-01	<1.31E-01	4.93E-01	<4.30E-01	<1.21E+00	2.31E+00	<2.88E-01	9.90E+05	9.03E+01	<4.01E-01	2.00E+01	<6.00E-02	0.13	0.18
A7	6.84E-01	<1.66E-01	4.14E-01	<4.78E-01	<1.34E+00	4.45E+00	<2.88E-01	1.02E+06	9.68E+01	<4.01E-01	3.53E+01	<6.89E-02	0.21	0.26
A8	5.60E-01	<1.86E-01	4.38E-01	<4.40E-01	<1.12E+00	6.07E+00	<2.88E-01	1.04E+06	1.01E+02	<4.01E-01	3.70E+01	<6.89E-02	0.26	0.31
A9※2	7.35E-01	<3.45E-01	7.06E-01	1.06E+00	<2.11E+00	8.91E+00	3.15E-01	1.14E+06	1.27E+02	<4.64E-01	4.93E+01	<8.87E-02	0.37	0.44
B1	<2.29E-01	<1.58E-01	9.39E-01	<4.66E-01	<1.30E+00	<4.45E-01	1.77E+00	1.19E+06	5.12E+01	<1.28E+00	2.20E+01	<9.32E-02	0.24	0.26
B2	<1.36E-01	<1.33E-01	8.91E-01	<4.10E-01	<1.18E+00	<3.61E-01	1.05E+00	9.39E+05	4.46E+01	<5.59E-01	6.70E+00	<6.00E-02	0.15	0.17
B3	<1.45E-01	<1.43E-01	1.04E+00	<4.10E-01	<1.34E+00	<3.31E-01	1.34E+00	9.48E+05	3.69E+01	<5.59E-01	1.12E+01	<6.00E-02	0.18	0.20
B4	<1.42E-01	<1.85E-01	9.64E-01	<4.64E-01	<1.24E+00	<3.30E-01	1.48E+00	9.56E+05	4.57E+01	<5.59E-01	1.12E+01	<5.64E-02	0.20	0.22
B5	<1.52E-01	<1.74E-01	1.31E+00	<4.66E-01	<1.37E+00	<3.01E-01	1.62E+00	9.56E+05	7.79E+01	<5.59E-01	2.11E+01	<5.64E-02	0.21	0.25
B6	2.17E-01	<2.76E-01	1.67E+00	<4.37E-01	<1.23E+00	5.49E-01	1.89E+00	1.11E+06	1.19E+02	<1.28E+00	3.11E+01	<9.32E-02	0.26	0.32
B7	<1.41E-01	<2.02E-01	1.07E+00	<4.17E-01	<1.24E+00	<3.69E-01	1.76E+00	9.33E+05	7.27E+01	<5.59E-01	2.31E+01	<6.00E-02	0.23	0.27
B8	<1.60E-01	<1.57E-01	1.18E+00	<4.92E-01	<1.45E+00	<3.61E-01	1.50E+00	9.70E+05	5.44E+01	<5.59E-01	1.70E+01	<6.00E-02	0.20	0.23
B9	<1.52E-01	<1.43E-01	7.36E-01	<4.04E-01	<1.20E+00	<3.65E-01	1.32E+00	8.90E+05	2.82E+01	<5.59E-01	9.25E+00	<4.97E-02	0.18	0.19
B10	<1.31E-01	<1.44E-01	9.02E-01	<3.99E-01	<1.18E+00	<3.44E-01	1.01E+00	9.15E+05	1.94E+01	<5.59E-01	6.80E+00	<4.97E-02	0.14	0.15
C1	<2.26E-01	<2.01E-01	3.59E-01	<7.01E-01	<1.79E+00	1.06E+00	<3.51E-01	7.48E+05	2.62E+01	<1.38E+00	1.08E+01	<9.03E-02	0.10	0.12
C2	<1.22E-01	<1.29E-01	3.20E-01	<3.84E-01	<1.26E+00	<4.36E-01	2.27E-01	6.92E+05	2.55E+01	<4.01E-01	7.60E+00	<5.69E-02	0.06	0.07

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Reflects the results of reanalysis.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G6 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
C3	<1.24E-01	<1.49E-01	3.72E-01	<4.20E-01	<1.14E+00	<4.55E-01	4.71E-01	7.24E+05	3.30E+01	<4.01E-01	1.17E+01	<5.69E-02	0.09	0.10
C4	<1.53E-01	<1.53E-01	2.96E-01	<4.04E-01	<1.28E+00	<4.46E-01	7.13E-01	7.28E+05	3.61E+01	<4.01E-01	1.10E+01	<5.69E-02	0.11	0.13
C5	<1.34E-01	<1.39E-01	3.47E-01	<4.43E-01	<1.24E+00	<4.50E-01	1.11E+00	7.39E+05	3.77E+01	<4.01E-01	1.33E+01	<5.69E-02	0.16	0.18
C6	<1.30E-01	<1.48E-01	4.37E-01	<4.23E-01	<1.24E+00	<3.74E-01	7.88E-01	7.44E+05	3.82E+01	4.72E-01	1.09E+01	<6.89E-02	0.12	0.14
C7	<1.44E-01	<1.24E-01	3.36E-01	<4.10E-01	<1.38E+00	<4.06E-01	3.54E-01	7.27E+05	3.37E+01	<4.01E-01	6.75E+00	<6.89E-02	0.07	0.09
C8	<1.08E-01	<1.65E-01	3.60E-01	<4.45E-01	<1.38E+00	<4.06E-01	1.43E+00	7.47E+05	3.33E+01	4.16E-01	1.37E+01	<6.89E-02	0.19	0.21
C9	<1.40E-01	<1.47E-01	4.19E-01	<3.93E-01	<1.24E+00	<5.25E-01	1.87E+00	7.00E+05	2.85E+01	<6.93E-01	8.76E+00	<6.89E-02	0.24	0.26
C10	<2.56E-01	<1.84E-01	3.56E-01	<7.21E-01	<1.71E+00	1.90E+00	2.64E+00	7.28E+05	2.55E+01	<1.38E+00	1.26E+01	<9.03E-02	0.38	0.40
D1	<1.27E-01	<1.42E-01	4.74E-01	<4.32E-01	<1.35E+00	2.24E+00	<2.32E-01	6.37E+05	2.39E+01	<1.68E+00	9.65E+00	<6.00E-02	0.12	0.13
D2	<1.35E-01	<1.22E-01	3.56E-01	<4.13E-01	<1.02E+00	<3.57E-01	5.68E-01	6.61E+05	3.23E+01	<5.78E-01	1.24E+01	<5.36E-02	0.09	0.11
D3	<1.28E-01	<1.92E-01	2.72E-01	4.90E-01	<1.11E+00	<3.40E-01	7.56E-01	7.32E+05	3.25E+01	<5.78E-01	1.22E+01	<5.36E-02	0.11	0.13
D4	<1.28E-01	<1.44E-01	2.78E-01	<4.47E-01	<1.13E+00	<3.31E-01	8.35E-01	8.16E+05	5.20E+01	<5.09E-01	1.45E+01	<5.36E-02	0.12	0.15
D5	<1.33E-01	<1.40E-01	4.13E-01	<4.07E-01	<1.10E+00	<3.24E-01	1.21E+00	8.56E+05	5.00E+01	<5.09E-01	1.35E+01	<5.36E-02	0.16	0.19
D6	<1.48E-01	<2.22E-01	4.31E-01	7.42E-01	<1.34E+00	1.21E+00	1.34E+00	9.35E+05	4.79E+01	<1.68E+00	2.19E+01	<6.00E-02	0.21	0.24
D7	<1.39E-01	<1.23E-01	3.88E-01	<4.72E-01	<1.21E+00	<3.59E-01	1.67E+00	8.54E+05	3.90E+01	<5.09E-01	1.28E+01	<6.62E-02	0.22	0.24
D8	<1.43E-01	<1.45E-01	3.41E-01	<4.43E-01	<1.23E+00	<3.61E-01	1.64E+00	8.46E+05	4.76E+01	<5.09E-01	1.21E+01	<6.62E-02	0.21	0.24
D9	<1.48E-01	<3.17E-01	4.39E-01	<6.04E-01	<1.38E+00	<3.96E-01	1.21E+00	8.08E+05	4.14E+01	<5.78E-01	1.77E+01	<6.32E-02	0.17	0.19

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6
4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

G7 Area

Group	Radiation concentration for each nuclide									Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Gross β [Bq/L]	
B1	4.87E-01	<2.86E-01	5.40E-01	1.04E+02	<8.86E-01	2.24E+00	2.17E+01	5.24E+05	1.37E+02	2.63

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

H1 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	4.62E+00	5.03E-01	9.35E-01	1.78E+01	2.19E+00	1.68E+00	3.75E+01	9.06E+05	—	—	7.56E+01	—	4.33	—
C1	3.36E-01	<1.38E-01	6.92E-01	<4.30E-01	<1.29E+00	<4.48E-01	8.12E-02	2.47E+05	—	—	1.10E+01	—	0.05	—
C2	2.11E-01	<1.45E-01	4.37E-01	<4.44E-01	<1.20E+00	<4.46E-01	1.94E-01	2.39E+05	5.40E+01	<4.04E-01	1.25E+01	<7.16E-02	0.06	0.08
C3	2.12E-01	<1.43E-01	4.03E-01	<4.18E-01	<1.19E+00	7.57E-01	2.34E-01	2.90E+05	4.70E+01	<4.04E-01	1.43E+01	<7.16E-02	0.07	0.09
C4	<1.44E-01	<1.52E-01	2.27E-01	5.36E-01	<1.21E+00	2.03E+00	1.94E-01	3.64E+05	4.88E+01	<5.86E-01	1.20E+01	<7.16E-02	0.11	0.13
C5	2.03E-01	<1.39E-01	3.16E-01	<3.84E-01	<9.96E-01	1.71E+00	1.96E-01	3.45E+05	4.16E+01	<5.86E-01	8.29E+00	<7.16E-02	0.10	0.12
C6	<1.26E-01	<1.62E-01	2.92E-01	<4.57E-01	<1.07E+00	2.38E+00	2.07E-01	3.87E+05	3.42E+01	<5.86E-01	1.52E+01	<7.16E-02	0.12	0.14
C7	1.82E-01	<1.35E-01	2.83E-01	<4.24E-01	<1.25E+00	2.16E+00	1.64E-01	3.76E+05	—	—	1.33E+01	—	0.11	—
C9	1.45E-01	<1.52E-01	3.21E-01	<3.81E-01	<1.09E+00	1.64E+00	2.12E-01	3.50E+05	3.68E+01	<5.86E-01	1.31E+01	<7.16E-02	0.10	0.11
C10	1.89E-01	<1.45E-01	3.36E-01	<4.07E-01	<9.89E-01	9.84E-01	1.93E-01	3.24E+05	4.15E+01	<5.86E-01	1.31E+01	<7.16E-02	0.07	0.09
C11	2.99E-01	<1.33E-01	3.75E-01	<4.07E-01	<1.06E+00	7.50E-01	1.89E-01	2.85E+05	4.88E+01	<5.86E-01	1.12E+01	<7.16E-02	0.06	0.09
E1※2	<6.98E-02	<8.60E-02	2.25E+00	1.41E+00	2.13E+00	1.41E+01	1.99E+01	4.70E+05	—	—	5.05E+01	—	2.71	—
G5※2	1.05E-01	<1.02E-01	1.21E+00	8.26E-01	8.49E-01	8.55E+00	6.89E+00	5.28E+05	—	—	3.14E+01	—	1.07	—

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 ALPS treated water was additionally transferred to this area after measuring the radiation concentration. Above data were measured before the additional transfer.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6
4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

H1 East Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	1.05E+00	<1.55E-01	5.52E-01	<4.39E-01	<1.28E+00	8.25E-01	6.13E+00	2.21E+05	—	—	1.14E+01	—	0.74	—
A1※2	4.96E-01	<2.07E-01	9.12E-01	<4.47E-01	<1.15E+00	4.42E+00	3.84E+00	1.94E+05	1.42E+01	<1.02E+00	1.32E+01	<5.36E-02	0.60	0.61
A4	7.16E-01	<1.83E-01	7.10E-01	<4.80E-01	<1.23E+00	6.87E-01	5.65E+00	2.64E+05	—	—	1.89E+01	—	0.68	—
A7	7.32E-01	<2.66E-01	6.05E-01	<4.13E-01	1.96E+00	7.83E-01	5.19E+00	2.71E+05	—	—	1.91E+01	—	0.64	—
B1	5.35E-01	<2.68E-01	4.12E-01	<4.18E-01	<1.29E+00	4.12E-01	4.71E+00	2.33E+05	—	—	1.02E+01	—	0.56	—
B3	6.58E-01	<3.02E-01	7.89E-01	<4.36E-01	<1.46E+00	7.15E-01	5.34E+00	2.52E+05	—	—	1.56E+01	—	0.65	—
B5	8.22E-01	<1.46E-01	6.84E-01	<5.49E-01	<1.23E+00	9.06E-01	5.72E+00	2.64E+05	—	—	1.84E+01	—	0.69	—
B7	6.02E-01	<2.18E-01	7.54E-01	<4.40E-01	<1.19E+00	9.67E-01	5.59E+00	2.68E+05	—	—	1.45E+01	—	0.68	—
C1	6.82E-01	<1.61E-01	4.39E-01	<4.67E-01	<1.27E+00	3.05E-01	7.01E+00	1.90E+05	—	—	8.20E+00	—	0.82	—
C3	7.33E-01	<1.48E-01	8.03E-01	<4.72E-01	<1.34E+00	5.56E-01	5.24E+00	2.40E+05	—	—	1.86E+01	—	0.63	—
C6	6.87E-01	<2.18E-01	1.03E+00	5.34E-01	<1.24E+00	1.56E-01	3.99E+00	2.62E+05	—	—	1.73E+01	—	0.48	—
C8	5.83E-01	<1.19E-01	9.61E-01	<4.18E-01	<1.20E+00	1.44E-01	3.98E+00	2.56E+05	—	—	1.74E+01	—	0.47	—
C8※2	4.67E-01	<2.15E-01	8.59E-01	<6.45E-01	<1.95E+00	<5.11E-01	2.80E+00	2.40E+05	1.51E+01	1.49E+01	2.15E+01	—	0.36	0.38

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Concentrations of Carbon-14 and Technetium-99 which affect the concentration of Gross β were additionally measured.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6
4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

H 2 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	1.03E-01	<1.82E-01	3.78E-01	6.75E-01	<9.73E-01	4.64E-01	8.33E+00	1.07E+06	—	—	2.46E+01	—	0.96	—
A1※2	<2.46E-01	<4.27E-01	2.30E-01	<6.57E-01	<1.69E+00	6.17E+00	5.23E+00	9.40E+05	1.08E+02	<9.58E-01	4.21E+01	—	0.82	0.87
A5	1.90E-01	<1.78E-01	5.72E-01	5.83E-01	<1.00E+00	<7.19E-02	3.72E+00	2.76E+05	—	—	6.59E+00	—	0.43	—
B1	3.11E-01	<2.22E-01	1.62E+00	1.05E+00	7.70E+00	3.25E-01	9.09E+00	3.42E+05	—	—	2.11E+01	—	1.11	—
B1※2	2.91E-01	<2.95E-01	1.17E+00	<4.57E-01	1.85E+00	3.32E+00	5.85E+00	2.95E+05	2.22E+01	1.26E+01	2.62E+01	<5.36E-02	0.79	0.82
B4	3.74E-01	<1.20E-01	5.53E-01	6.32E-01	<9.44E-01	1.14E-01	1.39E+00	1.96E+05	—	—	6.12E+00	—	0.18	—
C1	1.06E+00	<1.58E-01	5.87E-01	7.23E-01	<9.29E-01	<5.93E-02	6.90E+00	6.41E+05	—	—	1.54E+01	—	0.80	—
C1※2	8.72E-01	<2.17E-01	2.68E-01	<4.39E-01	<1.31E+00	2.47E+00	6.25E+00	5.57E+05	5.93E+01	<1.23E+00	1.96E+01	<5.36E-02	0.81	0.84
C2	1.04E+00	2.34E-01	5.46E-01	5.40E-01	<7.57E-01	<2.28E-01	5.22E+00	4.62E+05	—	—	1.56E+01	—	0.61	—
C4	4.94E-01	<2.05E-01	6.32E-01	7.17E-01	<9.37E-01	<5.60E-02	5.46E+00	3.65E+05	—	—	1.00E+01	—	0.63	—
D1	3.56E-01	<1.48E-01	6.40E-01	6.82E-01	7.72E+00	<8.42E-02	2.82E+00	5.04E+05	—	—	1.23E+01	—	0.40	—
D1※2	4.46E-01	<2.64E-01	4.17E-01	<4.19E-01	<1.22E+00	2.84E+00	2.69E+00	4.41E+05	1.40E+01	<1.23E+00	1.04E+01	<6.54E-02	0.42	0.43
D2	3.35E-01	<2.30E-01	5.45E-01	<4.52E-01	<1.16E+00	<4.96E-01	3.08E+00	3.28E+05	1.73E+01	<3.69E-01	8.10E+00	<5.76E-02	0.38	0.39
D3	3.14E-01	<1.26E-01	8.76E-01	6.02E-01	6.50E+00	2.25E-01	4.51E+00	4.54E+05	—	—	1.61E+01	—	0.58	—
D3	3.17E-01	<1.40E-01	4.12E-01	<4.50E-01	<1.24E+00	<4.88E-01	4.06E+00	3.30E+05	2.32E+01	<5.18E-01	7.92E+00	<5.76E-02	0.49	0.50
D4	3.27E-01	<1.37E-01	4.51E-01	<4.31E-01	<1.10E+00	<5.12E-01	3.84E+00	3.30E+05	1.97E+01	<3.69E-01	9.35E+00	<5.96E-02	0.46	0.47

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Concentrations of Carbon-14 and Technetium-99 which affect the concentration of Gross β were additionally measured.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6
4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

H 2 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
E1	3.71E-01	<1.78E-01	5.41E-01	8.12E-01	1.84E+00	1.75E-01	4.67E+00	5.46E+05	—	—	1.62E+01	—	0.55	—
E1※2	3.37E-01	<1.94E-01	2.15E-01	5.02E-01	<1.22E+00	1.96E+00	4.21E+00	4.62E+05	1.66E+01	1.81E+01	1.91E+01	<6.54E-02	0.55	0.58
E4	2.25E-01	<1.42E-01	1.23E+00	9.47E-01	2.06E+00	3.23E-01	6.19E+00	4.25E+05	—	—	1.14E+01	—	0.73	—
F1	5.02E-01	<1.27E-01	5.14E-01	7.10E-01	<1.04E+00	<6.39E-02	2.24E+01	7.58E+05	—	—	2.68E+01	—	2.52	—
G5	5.31E-01	1.50E-01	6.20E-01	5.77E-01	<9.29E-01	<5.45E-02	5.47E+00	3.59E+05	—	—	7.40E+00	—	0.63	—
J1	4.45E-01	<1.28E-01	9.50E-01	8.10E-01	3.63E+00	<6.36E-02	3.81E+00	4.97E+05	—	—	1.91E+01	—	0.47	—
J1※2	5.07E-01	<1.78E-01	5.58E-01	5.21E-01	<1.34E+00	2.11E+00	2.51E+00	4.38E+05	3.88E+01	1.22E+01	2.46E+01	<6.54E-02	0.37	0.41
J2	3.35E-01	<1.34E-01	4.24E-01	<4.16E-01	<1.12E+00	<3.97E-01	2.36E+00	2.92E+05	1.94E+01	5.90E+00	1.16E+01	<6.28E-02	0.30	0.31
J3	3.96E-01	<1.27E-01	1.05E+00	6.84E-01	<9.45E-01	6.25E-02	2.16E+00	3.69E+05	—	—	1.04E+01	—	0.26	—
J3	3.25E-01	<2.47E-01	5.60E-01	<4.04E-01	<1.18E+00	<4.22E-01	2.24E+00	2.72E+05	1.80E+01	2.40E+00	6.02E+00	<6.28E-02	0.29	0.30
J4	3.98E-01	<1.48E-01	5.41E-01	<4.04E-01	<1.10E+00	<4.29E-01	2.57E+00	2.82E+05	1.59E+01	2.65E+00	9.35E+00	<6.28E-02	0.32	0.33
J5	2.45E-01	<1.27E-01	5.21E-01	<4.49E-01	<1.22E+00	<4.39E-01	2.44E+00	2.85E+05	1.78E+01	5.74E+00	1.15E+01	<6.28E-02	0.31	0.32
K4	2.70E-01	<1.90E-01	9.15E-01	9.24E-01	2.32E+00	9.67E-02	3.03E+00	5.12E+05	—	—	1.84E+01	—	0.38	—
L1	1.35E-01	<1.33E-01	7.92E-01	5.83E-01	<9.45E-01	1.66E-01	1.35E+01	1.26E+06	—	—	2.72E+01	—	1.52	—

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Concentrations of Carbon-14 and Technetium-99 which affect the concentration of Gross β were additionally measured.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6
4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

H3 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	<2.46E-01	<1.85E-01	6.08E-01	<4.63E-01	<1.24E+00	5.34E+00	<1.92E-01	1.25E+06	1.04E+02	<5.24E-01	3.21E+01	<8.72E-02	0.22	0.27
A2	2.45E-01	<1.34E-01	6.08E-01	<4.43E-01	<1.16E+00	4.47E-01	7.24E-01	9.12E+05	6.98E+01	<5.78E-01	1.89E+01	<4.97E-02	0.12	0.15
A3	2.88E-01	<3.03E-01	9.02E-01	<3.81E-01	<1.21E+00	<4.27E-01	7.89E-01	7.36E+05	6.73E+01	<5.78E-01	1.87E+01	<4.97E-02	0.13	0.16
A4	3.49E-01	<1.54E-01	1.10E+00	<4.34E-01	<1.38E+00	6.37E-01	1.10E+00	6.23E+05	5.81E+01	<5.78E-01	1.96E+01	<6.00E-02	0.17	0.20
A5	4.10E-01	<1.51E-01	1.42E+00	<3.96E-01	<1.37E+00	9.06E-01	1.33E+00	5.71E+05	5.42E+01	<5.78E-01	1.81E+01	<6.00E-02	0.21	0.23
B1	2.45E-01	<1.54E-01	6.37E-01	<3.78E-01	<9.75E-01	4.36E-01	4.63E-01	1.06E+06	1.03E+02	<5.78E-01	2.93E+01	<5.36E-02	0.08	0.14
B2	<1.57E-01	<1.59E-01	9.17E-01	<4.23E-01	<1.30E+00	<3.56E-01	7.34E-01	8.52E+05	8.92E+01	<5.59E-01	3.07E+01	<5.36E-02	0.12	0.16
B3	2.35E-01	<1.52E-01	1.28E+00	<4.55E-01	<1.22E+00	6.15E-01	1.34E+00	7.30E+05	7.73E+01	<5.59E-01	1.98E+01	<6.32E-02	0.19	0.23
B4	4.64E-01	<1.79E-01	1.71E+00	<4.82E-01	<1.15E+00	7.31E-01	1.62E+00	6.26E+05	6.73E+01	<5.59E-01	1.89E+01	<6.32E-02	0.23	0.27
B5	4.40E-01	<2.67E-01	1.71E+00	<3.93E-01	<1.18E+00	2.28E+00	1.37E+00	6.50E+05	6.12E+01	<5.24E-01	2.98E+01	<8.72E-02	0.26	0.29

H4 North Area

A1	4.55E-01	<1.52E-01	9.90E-01	7.08E-01	8.76E+00	7.31E-02	1.78E+01	5.58E+05	—	—	3.97E+01	—	2.08	—
A6	3.37E-01	<1.68E-01	4.62E-01	6.53E-01	5.77E+00	1.91E-01	1.77E+00	7.14E+05	—	—	4.07E+01	—	0.27	—
A7	5.92E-01	<1.25E-01	4.36E-01	6.50E-01	<9.37E-01	<6.04E-02	6.06E+00	5.52E+05	—	—	1.60E+01	—	0.70	—
B1	2.40E-01	<1.90E-01	1.11E+00	5.74E-01	<1.03E+00	<5.88E-02	1.47E+01	1.20E+06	—	—	2.49E+01	—	1.66	—
C1	<8.87E-02	<1.22E-01	3.64E-01	7.09E-01	1.26E+00	<5.27E-02	6.37E+00	1.25E+06	—	—	1.87E+01	—	0.73	—
C1※2	<2.42E-01	<1.46E-01	1.62E+00	<4.60E-01	<1.37E+00	<4.21E-01	1.01E+00	9.86E+05	6.72E+01	<1.20E+00	2.59E+01	—	0.15	0.19
C5	1.41E+00	1.44E-01	3.17E-01	6.56E-01	<9.38E-01	<6.68E-02	6.74E+00	6.03E+05	—	—	2.13E+01	—	0.78	—
D1	1.68E-01	<1.25E-01	5.52E-01	4.68E-01	<1.04E+00	6.22E+00	1.01E+01	1.25E+06	—	—	4.33E+01	—	1.35	—
D4	3.38E-01	<1.88E-01	4.97E-01	5.26E-01	<9.28E-01	4.39E+00	1.61E+01	6.55E+05	—	—	2.76E+01	—	1.95	—

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Concentrations of Carbon-14 and Technetium-99 which affect the concentration of Gross β were additionally measured.

【Reference】Value notation for radioactive concentrations, etc.

(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6

4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

H4 South Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	<9.03E-02	<1.35E-01	1.96E+00	7.96E-01	1.98E+00	1.50E-01	1.49E+01	9.72E+05	—	—	1.82E+01	—	1.70	—
A11	<9.01E-02	<1.54E-01	1.11E+00	6.85E-01	<1.11E+00	2.65E-01	7.29E+00	1.18E+06	—	—	2.44E+01	—	0.84	—
B1	3.97E-01	<2.05E-01	2.12E+00	<4.74E-01	<1.46E+00	8.12E-01	8.00E-01	1.11E+06	1.02E+02	<1.20E+00	2.63E+01	<7.35E-02	0.15	0.20
B2	<1.57E-01	<2.33E-01	7.86E-01	<4.14E-01	<1.26E+00	6.77E-01	9.34E-01	8.81E+05	6.59E+01	<4.30E-01	2.84E+01	<6.79E-02	0.15	0.18
B3	<1.47E-01	<1.67E-01	8.26E-01	<4.22E-01	<1.05E+00	<4.35E-01	1.08E+00	8.50E+05	6.44E+01	<4.30E-01	1.96E+01	<6.32E-02	0.15	0.19
B4	1.82E-01	<2.98E-01	7.73E-01	<4.11E-01	<1.28E+00	<5.30E-01	1.16E+00	8.93E+05	5.67E+01	<4.30E-01	2.12E+01	<6.32E-02	0.17	0.20
B5	<1.30E-01	<1.36E-01	6.22E-01	<4.58E-01	<1.31E+00	<3.80E-01	1.32E+00	8.89E+05	6.86E+01	<4.30E-01	1.84E+01	<6.28E-02	0.18	0.21
B6	4.44E-01	<1.55E-01	7.04E-01	<4.29E-01	<1.21E+00	<3.97E-01	1.30E+00	1.05E+06	7.63E+01	<1.20E+00	2.24E+01	<9.11E-02	0.18	0.22
B7	<2.40E-01	<1.68E-01	7.03E-01	5.58E-01	<1.20E+00	<3.90E-01	1.70E+01	1.73E+06	2.15E+02	<1.20E+00	6.18E+01	<9.11E-02	1.92	2.03
B9	<1.50E-01	<1.27E-01	9.95E-01	<4.11E-01	<1.18E+00	<4.71E-01	1.34E+00	9.14E+05	4.28E+01	<4.30E-01	2.43E+01	<6.28E-02	0.19	0.21
C1	9.81E-02	<9.79E-02	3.46E-01	2.51E-01	1.05E+00	<6.58E-02	3.24E+00	2.28E+05	—	—	<4.32E+00	—	0.38	—
D1	1.68E-01	<1.07E-01	6.39E-01	4.02E-01	3.42E+00	2.35E-01	3.06E+00	7.89E+05	—	—	2.94E+01	—	0.39	—
D1	<1.44E-01	<1.56E-01	3.88E-01	<3.96E-01	<1.03E+00	4.44E-01	2.75E+00	6.21E+05	7.07E+01	8.13E-01	2.17E+01	<5.24E-02	0.34	0.37
D2	<1.42E-01	<1.44E-01	3.13E-01	<4.09E-01	<1.05E+00	<4.54E-01	3.96E+00	3.71E+05	3.45E+01	1.01E+00	1.12E+01	<5.24E-02	0.47	0.49
D3	1.29E-01	<1.41E-01	2.92E-01	<4.02E-01	<1.24E+00	<4.36E-01	4.15E+00	3.17E+05	2.92E+01	<4.69E-01	1.13E+01	<6.32E-02	0.49	0.51
D4	<1.48E-01	<1.25E-01	2.92E-01	<3.93E-01	<1.12E+00	<4.31E-01	3.09E+00	3.45E+05	3.00E+01	5.05E-01	1.13E+01	<6.32E-02	0.37	0.39
D5	2.15E-01	<1.34E-01	3.08E-01	<4.33E-01	<1.14E+00	<4.25E-01	3.14E+00	3.22E+05	3.15E+01	6.21E-01	8.47E+00	<6.00E-02	0.38	0.40
D6	2.79E-01	<1.55E-01	2.85E-01	<3.83E-01	<7.89E-01	<4.56E-01	2.68E+00	3.37E+05	3.39E+01	1.50E+00	1.04E+01	<7.15E-02	0.33	0.35
D7	3.14E-01	<1.58E-01	4.68E-01	3.64E-01	1.27E+00	1.45E-01	3.20E+00	5.51E+05	—	—	1.89E+01	—	0.38	—
D7※2	3.13E-01	<1.81E-01	4.88E-01	<4.78E-01	<1.38E+00	6.90E-01	2.22E+00	4.28E+05	3.97E+01	<9.58E-01	1.05E+01	—	0.29	0.31
D7	3.12E-01	<1.41E-01	2.51E-01	<4.03E-01	<1.10E+00	<4.21E-01	2.30E+00	3.41E+05	3.87E+01	1.55E+00	9.73E+00	<7.15E-02	0.29	0.31

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Concentrations of Carbon-14 and Technetium-99 which affect the concentration of Gross β were additionally measured.

【Reference】Value notation for radioactive concentrations, etc.

(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6

4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

H4 South Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
D8	8.18E-02	<1.01E-01	1.57E+00	8.16E-01	2.34E+00	2.08E-01	1.38E+01	1.30E+06	—	—	4.86E+01	—	1.57	—
D8※2	<2.03E-01	<2.14E-01	1.31E+00	<8.07E-01	<1.35E+00	<4.03E-01	1.25E+01	1.18E+06	1.39E+02	<9.58E-01	3.48E+01	—	1.43	1.50
D10	3.04E-01	<1.53E-01	3.00E-01	<3.59E-01	<1.10E+00	<4.26E-01	3.06E+00	3.36E+05	2.94E+01	1.42E+00	7.55E+00	<6.00E-02	0.37	0.39
E1	6.71E+00	<1.14E+00	<9.45E-01	<2.32E+00	<7.52E+00	3.12E+00	2.21E+00	7.67E+05	3.44E+01	<1.20E+00	3.50E+01	<7.35E-02	0.53	0.54

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Concentrations of Carbon-14 and Technetium-99 which affect the concentration of Gross β were additionally measured.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

H5 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	<2.37E-01	<4.07E-01	1.24E+00	1.43E+00	1.84E+00	<3.40E-01	2.04E+00	1.17E+06	8.29E+01	<1.28E+00	1.79E+01	<9.32E-02	0.27	0.32
A2	<1.42E-01	<2.71E-01	7.43E-01	<4.57E-01	<1.23E+00	<4.24E-01	1.65E+00	9.39E+05	6.07E+01	<4.01E-01	1.38E+01	<6.89E-02	0.22	0.25
A3	<1.30E-01	<3.32E-01	8.44E-01	6.21E-01	<1.21E+00	<3.87E-01	1.79E+00	8.45E+05	6.39E+01	<4.01E-01	1.27E+01	<6.89E-02	0.24	0.27
A4	<1.28E-01	<1.53E-01	7.13E-01	<4.54E-01	<1.32E+00	1.18E+00	2.01E+00	8.73E+05	7.04E+01	<4.01E-01	1.66E+01	<6.28E-02	0.28	0.32
A5	<1.30E-01	<2.34E-01	7.60E-01	<3.88E-01	<1.34E+00	<4.41E-01	2.25E+00	8.21E+05	7.31E+01	<4.01E-01	1.80E+01	<6.28E-02	0.29	0.32
A6	<1.19E-01	<2.60E-01	8.45E-01	<4.26E-01	<1.44E+00	<3.87E-01	2.58E+00	6.99E+05	6.73E+01	<4.01E-01	1.47E+01	<6.28E-02	0.32	0.36
A7	<1.53E-01	<1.70E-01	7.31E-01	<4.45E-01	<1.19E+00	<4.29E-01	2.76E+00	5.95E+05	5.35E+01	<4.01E-01	1.59E+01	<6.28E-02	0.34	0.37
A8	<1.52E-01	<1.60E-01	6.89E-01	<4.44E-01	<1.03E+00	<4.03E-01	2.80E+00	5.41E+05	5.24E+01	<4.01E-01	1.64E+01	<6.62E-02	0.34	0.37
A9	1.96E-01	<1.37E-01	6.96E-01	<3.89E-01	<1.20E+00	<4.03E-01	2.96E+00	5.17E+05	4.90E+01	<4.01E-01	1.38E+01	<6.62E-02	0.36	0.39
A10	<1.30E-01	<1.43E-01	6.32E-01	<5.08E-01	<1.15E+00	<4.56E-01	2.72E+00	5.09E+05	4.91E+01	4.19E-01	1.86E+01	<6.62E-02	0.34	0.36
A11	<1.38E-01	<1.40E-01	7.69E-01	<4.19E-01	<1.32E+00	<4.36E-01	2.90E+00	5.02E+05	4.80E+01	<4.01E-01	1.40E+01	<6.62E-02	0.36	0.38
A12	<2.26E-01	<1.43E-01	6.65E-01	<4.59E-01	<1.28E+00	<4.06E-01	2.82E+00	5.48E+05	5.30E+01	<5.24E-01	1.51E+01	<7.68E-02	0.35	0.37
B1	<2.27E-01	<2.43E-01	1.32E+00	3.35E+00	<1.40E+00	<3.94E-01	2.23E+00	7.80E+05	2.98E+01	<1.28E+00	2.15E+01	<9.32E-02	0.29	0.31
B2	<1.48E-01	<2.20E-01	1.17E+00	2.07E+00	<1.18E+00	<4.29E-01	1.79E+00	7.98E+05	6.92E+01	<4.46E-01	1.60E+01	<5.64E-02	0.24	0.27
B3	<1.46E-01	<2.46E-01	9.14E-01	1.57E+00	<1.41E+00	<4.19E-01	2.04E+00	8.93E+05	7.17E+01	<4.46E-01	1.79E+01	<5.64E-02	0.27	0.30
B4	<1.38E-01	<2.26E-01	8.33E-01	9.29E-01	<1.36E+00	<4.13E-01	2.12E+00	9.75E+05	8.36E+01	<7.19E-01	1.52E+01	<5.64E-02	0.27	0.32
B5	<1.34E-01	<2.39E-01	8.08E-01	6.49E-01	<1.34E+00	<4.54E-01	2.18E+00	9.94E+05	8.85E+01	<7.19E-01	1.98E+01	<5.64E-02	0.28	0.33
B6	<1.40E-01	<2.23E-01	8.50E-01	<4.90E-01	<1.27E+00	<4.10E-01	2.06E+00	9.56E+05	8.43E+01	<7.19E-01	1.97E+01	<6.62E-02	0.27	0.31
B7	<1.38E-01	<1.41E-01	6.82E-01	<4.36E-01	<1.24E+00	<4.27E-01	1.88E+00	8.72E+05	7.37E+01	<7.19E-01	1.40E+01	<6.62E-02	0.24	0.28
B8	<1.36E-01	<1.62E-01	5.83E-01	<4.25E-01	<1.38E+00	<4.11E-01	1.87E+00	7.48E+05	6.72E+01	<7.19E-01	1.75E+01	<6.62E-02	0.24	0.28
B9	<1.46E-01	<1.50E-01	6.98E-01	<3.99E-01	<1.21E+00	<3.98E-01	2.01E+00	6.86E+05	6.75E+01	<7.19E-01	1.36E+01	<6.62E-02	0.26	0.29

※ primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

H5 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
B10	<1.34E-01	<2.26E-01	6.24E-01	<3.89E-01	<1.35E+00	<4.09E-01	2.09E+00	6.35E+05	6.26E+01	<7.19E-01	1.66E+01	<5.36E-02	0.27	0.30
B11	<2.02E-01	<1.17E-01	6.77E-01	<3.95E-01	<1.23E+00	4.14E-01	2.32E+00	6.68E+05	5.87E+01	<5.24E-01	1.92E+01	<7.68E-02	0.29	0.32
C1	<2.03E-01	<2.88E-01	1.51E+00	6.98E-01	1.15E+00	<4.07E-01	2.24E+00	7.10E+05	4.73E+01	<5.24E-01	1.35E+01	<9.32E-02	0.29	0.31
C7	<2.33E-01	<1.79E-01	1.56E+00	<7.17E-01	<1.91E+00	<4.41E-01	5.07E+00	7.70E+05	7.81E+01	<5.24E-01	2.36E+01	<9.32E-02	0.61	0.65

H6(Ⅰ) Area

A1	2.43E+00	<1.64E+00	<3.01E+00	<4.46E+00	<1.44E+01	8.42E-01	1.10E+00	1.52E+06	1.19E+02	<1.28E+00	3.89E+01	<9.32E-02	0.37	0.43
A5	4.26E+01	2.63E+00	<1.05E+00	<3.90E+00	<9.49E+00	2.12E+01	1.00E+00	1.19E+06	9.47E+01	<1.28E+00	9.82E+01	<9.32E-02	1.44	1.49
B1	7.04E-01	<1.33E-01	2.91E+00	<4.15E-01	<1.28E+00	1.06E+00	2.33E+00	1.34E+06	1.22E+02	5.66E+00	3.85E+01	<9.32E-02	0.33	0.40
B5	2.77E+01	<1.27E+00	<9.45E-01	<3.54E+00	<8.60E+00	8.90E+00	2.00E+00	1.06E+06	1.16E+02	3.17E+01	1.03E+02	<9.32E-02	0.94	1.03

※ primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6
4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

H6(Ⅱ) Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	<2.28E-01	<2.42E-01	1.27E+00	<4.60E-01	<1.32E+00	1.20E+00	3.72E+00	1.32E+06	1.07E+02	<5.24E-01	3.05E+01	<9.87E-02	0.48	0.53
A2	<1.32E-01	<2.25E-01	9.45E-01	<4.25E-01	<1.10E+00	4.40E+00	3.32E+00	1.06E+06	1.03E+02	<4.23E-01	3.62E+01	<6.28E-02	0.54	0.59
A3	<1.36E-01	<1.59E-01	9.46E-01	<4.09E-01	<1.31E+00	6.94E+00	2.29E+00	8.21E+05	7.07E+01	<4.23E-01	2.59E+01	<6.28E-02	0.51	0.54
A4	<1.39E-01	<1.41E-01	9.74E-01	<3.99E-01	<1.30E+00	6.61E+00	1.72E+00	5.83E+05	4.80E+01	<4.23E-01	2.73E+01	<6.32E-02	0.43	0.46
A5	<2.44E-01	<1.71E-01	1.17E+00	<4.67E-01	<1.49E+00	9.30E+00	1.19E+00	8.95E+05	6.68E+01	<5.24E-01	4.03E+01	<8.05E-02	0.47	0.50
A6	<1.24E-01	<1.94E-01	9.95E-01	<3.63E-01	<1.23E+00	9.25E+00	1.17E+00	9.45E+05	8.90E+01	<4.23E-01	4.63E+01	<6.32E-02	0.46	0.51
A7	<1.45E-01	<1.40E-01	1.12E+00	<4.34E-01	<1.12E+00	7.97E+00	1.75E+00	1.03E+06	9.72E+01	<4.23E-01	4.12E+01	<6.28E-02	0.48	0.53
A8	<1.30E-01	<2.22E-01	1.08E+00	<3.77E-01	<1.34E+00	5.03E+00	2.93E+00	1.09E+06	9.78E+01	<4.23E-01	3.62E+01	<6.28E-02	0.52	0.57
A9	<1.35E-01	<1.45E-01	1.05E+00	<4.35E-01	<1.29E+00	6.42E+00	2.06E+00	8.17E+05	7.46E+01	<4.23E-01	3.30E+01	<7.85E-02	0.47	0.50
B1	<2.11E-01	<1.79E-01	6.49E-01	5.10E-01	<1.21E+00	<3.81E-01	2.31E+00	4.49E+05	1.07E+01	<5.24E-01	<5.43E+00	<9.87E-02	0.29	0.30
B5	<2.43E-01	<2.24E-01	1.64E+00	1.80E+00	1.83E+00	<4.00E-01	5.04E+00	9.33E+05	3.24E+01	<5.24E-01	1.65E+01	<8.05E-02	0.61	0.62
C1※2	3.32E-01	<1.67E-01	1.08E+00	<5.25E-01	<1.37E+00	4.22E-01	2.60E-01	8.39E+05	3.39E+01	<4.64E-01	6.51E+00	<8.87E-02	0.07	0.09
C2	2.62E-01	<1.73E-01	6.49E-01	<4.29E-01	<1.31E+00	4.79E-01	2.11E-01	9.10E+05	3.82E+01	<5.78E-01	1.24E+01	<7.02E-02	0.06	0.08
C3	4.19E-01	<2.20E-01	1.06E+00	<6.89E-01	<1.90E+00	5.14E+00	<3.51E-01	1.07E+06	5.74E+01	<1.38E+00	2.29E+01	<9.03E-02	0.24	0.27
C4	3.10E-01	<1.61E-01	6.86E-01	<4.38E-01	<1.13E+00	<3.88E-01	6.96E-01	9.47E+05	4.92E+01	<5.78E-01	1.20E+01	<6.32E-02	0.11	0.14
C5	3.08E-01	<1.57E-01	7.85E-01	<4.07E-01	<1.22E+00	3.36E-01	4.66E-01	9.35E+05	5.70E+01	<5.78E-01	1.60E+01	<6.32E-02	0.09	0.11
C6	1.65E-01	<2.80E-01	8.11E-01	<3.83E-01	<1.09E+00	<3.65E-01	3.97E-01	9.36E+05	4.20E+01	<5.78E-01	1.33E+01	<5.69E-02	0.08	0.10
C7	2.48E-01	<1.40E-01	6.38E-01	<4.89E-01	<1.42E+00	<4.20E-01	3.97E-01	8.94E+05	3.81E+01	<5.78E-01	1.37E+01	<5.69E-02	0.08	0.10

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Reflects the results of reanalysis.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

J1 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	8.13E+01	6.67E+00	4.83E+01	2.98E+01	1.02E+01	3.05E+04	6.66E+00	3.48E+05	—	—	6.72E+04	—	1017.80	—
C1	8.29E+02	6.80E+01	4.97E+01	1.65E+02	4.81E+01	1.13E+05	2.89E+01	1.13E+06	—	—	2.21E+05	—	3791.16	—
D1	<7.39E-01	<9.23E-01	6.44E-01	2.71E+01	1.58E+02	4.33E+05	3.47E+01	7.10E+05	—	—	9.54E+05	—	14442.15	—
E1	2.08E-01	<2.62E-01	6.30E-01	8.74E+01	<1.08E+00	3.17E+01	1.78E+01	4.25E+05	—	—	1.93E+02	—	3.17	—
E1	<1.24E-01	<2.73E-01	1.91E-01	<4.45E-01	<1.12E+00	5.61E+00	7.73E-02	4.76E+05	3.96E+01	<5.78E-01	2.68E+01	<5.55E-02	0.21	0.23
E2	<1.32E-01	<1.49E-01	2.69E-01	5.64E-01	<1.04E+00	7.72E-01	1.62E-01	4.29E+05	6.17E+01	<4.04E-01	1.83E+01	<7.50E-02	0.06	0.09
E3	1.05E-01	<1.23E-01	1.57E-01	<4.66E-01	<1.27E+00	9.24E-01	2.74E-01	3.98E+05	7.36E+01	<4.04E-01	1.90E+01	<7.50E-02	0.08	0.12
E4	1.94E-01	<1.65E-01	2.18E-01	<4.12E-01	<1.31E+00	1.35E+00	5.27E-01	4.06E+05	7.54E+01	<4.04E-01	2.46E+01	<7.50E-02	0.12	0.16
E5	3.08E-01	<2.50E-01	3.84E-01	<3.88E-01	<9.21E-01	3.04E+00	6.10E-01	4.07E+05	7.76E+01	<5.78E-01	2.64E+01	<5.55E-02	0.19	0.23
E6	1.31E-01	<1.41E-01	2.86E-01	5.52E-01	<1.18E+00	3.42E+00	4.34E-01	4.10E+05	7.25E+01	<4.04E-01	3.11E+01	<7.50E-02	0.18	0.22
E7	1.40E-01	<1.66E-01	2.12E-01	<4.22E-01	<9.89E-01	1.19E+00	3.01E-01	4.22E+05	6.95E+01	<4.04E-01	2.96E+01	<7.50E-02	0.09	0.12
E8	<1.39E-01	<1.33E-01	<1.65E-01	4.20E-01	<1.17E+00	1.08E+00	1.35E-01	4.27E+05	6.02E+01	<4.04E-01	2.07E+01	<7.50E-02	0.07	0.10
F1	1.05E-01	<2.63E-01	5.03E-01	8.01E+01	<8.93E-01	3.43E+02	2.57E+01	4.75E+05	—	—	9.95E+02	—	14.41	—
G1	6.09E+01	5.25E+00	4.13E+01	4.89E+01	1.85E+00	4.55E+03	1.20E+00	2.57E+05	—	—	1.35E+04	—	152.98	—
H1	6.46E-01	<1.10E-01	9.06E-02	8.68E+00	<8.87E-01	4.11E-01	2.80E+01	7.47E+05	—	—	2.77E+01	—	3.15	—
K4	9.64E-01	<5.16E-01	5.09E-01	4.08E+01	4.13E+01	8.94E+04	1.95E+00	1.62E+06	—	—	1.71E+05	—	2981.37	—
L1	3.30E-01	<1.69E-01	7.63E-01	2.39E+01	<9.22E-01	2.53E+00	1.21E+01	3.94E+05	—	—	6.20E+01	—	1.48	—
M1	2.72E-01	<2.93E-01	8.49E-01	1.05E+02	<9.46E-01	1.76E+01	1.38E+01	3.92E+05	—	—	1.82E+02	—	2.27	—
N1	1.15E+00	1.07E-01	6.71E-01	2.20E-01	<8.05E-01	2.50E-01	1.96E+00	2.86E+05	—	—	7.65E+00	—	0.25	—
N1※2	1.32E+00	<1.29E-01	4.29E-01	<4.48E-01	<1.30E+00	2.04E+00	2.16E+00	2.59E+05	1.45E+01	<1.23E+00	1.25E+01	<6.28E-02	0.34	0.35

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Concentrations of Carbon-14 and Technetium-99 which affect the concentration of Gross β were additionally measured.

【Reference】Value notation for radioactive concentrations, etc.

(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6

4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

J2 Area

Group	Radiation concentration for each nuclide									Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Gross β [Bq/L]	
A1※2	1.17E+01	1.15E+00	1.02E+00	1.45E+00	1.47E+00	2.93E-01	5.91E+00	3.14E+05	2.42E+01	0.84
C1※2	1.36E+00	<1.41E-01	3.03E-01	1.09E+01	8.45E-01	3.48E+00	1.15E+01	1.03E+06	3.81E+01	1.43
E1※2	1.10E+00	<1.97E-01	3.28E-01	4.74E+01	1.28E+00	9.01E+00	4.62E+01	9.07E+05	9.53E+01	5.52
G1※2	5.72E-01	<1.51E-01	4.48E-01	2.25E+01	1.58E+00	3.70E+01	3.84E+01	1.03E+06	1.86E+02	5.56
K1※2	2.16E+00	3.57E-01	2.04E-01	6.56E+00	1.34E+00	4.52E+01	1.48E+01	7.93E+05	1.59E+02	3.20
M1※2	2.20E+01	1.84E+00	1.08E+00	1.27E+00	2.03E+00	3.33E-01	8.96E+00	4.68E+05	4.07E+01	1.31

J3 Area

A1※2	2.43E-01	<1.46E-01	1.86E-01	3.61E+00	<7.87E-01	4.19E+00	6.27E+00	6.26E+05	2.46E+01	0.86
B1※2	1.49E+00	<1.58E-01	8.61E-01	3.65E+00	9.15E-01	5.98E-01	1.62E+01	4.30E+05	1.56E+01	1.85
C1※2	2.01E+00	<2.57E-01	4.75E-01	3.33E+01	1.46E+00	1.77E+00	4.49E+01	1.08E+06	6.96E+01	5.14
E1※2	1.04E+00	2.56E-01	4.46E-01	3.86E-01	<9.55E-01	3.16E-01	7.53E+00	3.05E+05	1.00E+01	0.88

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 ALPS treated water was additionally transferred to this area after measuring the radiation concentration. Above data were measured before the additional transfer.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

J4 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	6.02E+00	6.44E-01	3.89E-01	1.08E+01	<9.08E-01	2.19E+01	7.72E+00	6.84E+05	—	—	9.51E+01	—	1.69	—
B1	2.23E+00	2.40E-01	4.13E-01	3.85E+00	2.02E+00	1.43E+00	7.44E+00	1.62E+06	—	—	1.85E+01	—	0.93	—
C1	1.23E+00	1.85E-01	1.38E-01	2.73E+00	<7.88E-01	4.15E+00	2.50E+00	6.24E+05	—	—	2.00E+01	—	0.44	—
C1※2	1.20E+00	<2.00E-01	<1.54E-01	1.15E+00	<1.21E+00	1.24E+01	2.23E+00	6.04E+05	5.81E+00	<1.02E+00	2.47E+01	<6.00E-02	0.69	0.69
D1	2.92E+00	3.16E-01	4.47E-01	9.34E+00	2.42E+00	1.41E+03	3.36E+01	1.24E+06	—	—	3.65E+03	—	50.68	—
E1	2.37E+00	<1.68E-01	1.06E+01	1.21E+01	<1.04E+00	5.97E+02	8.48E+00	1.15E+06	—	—	1.39E+03	—	20.94	—
F1	2.58E+00	1.84E-01	5.68E+00	1.52E+01	1.35E+00	1.40E+03	8.68E+00	4.36E+05	—	—	2.31E+03	—	47.79	—
G1	3.50E-01	<1.62E-01	1.62E+00	2.03E+00	1.35E+00	6.70E+01	8.49E+00	4.02E+05	—	—	1.93E+02	—	3.21	—
H1	3.24E+00	2.45E-01	3.97E+00	1.70E+01	<9.31E-01	1.81E+03	5.87E+00	3.81E+05	—	—	2.60E+03	—	60.98	—
K1	3.38E+00	<1.66E-01	7.08E+00	2.03E+01	1.43E+00	1.82E+03	5.72E+00	4.07E+05	—	—	2.99E+03	—	61.38	—
L※3	—	—	—	—	—	—	—	—	—	—	—	—	—	—

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Concentrations of Carbon-14 and Technetium-99 which affect the concentration of Gross β were additionally measured.

※3 Radiation concentration data for this group will no longer be released due to the discharge of stored water.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6
4.16E + 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

J5 Area

Group	Radiation concentration for each nuclide									Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Gross β [Bq/L]	
A1	3.96E-01	<1.15E-01	1.70E-01	8.98E+00	8.54E-01	9.63E+01	3.02E+01	9.05E+05	2.91E+02	6.59
B1	3.63E-01	<1.39E-01	2.15E-01	1.43E+01	<9.59E-01	7.15E+01	3.41E+01	8.67E+05	2.45E+02	6.20
C1	4.80E-01	<1.42E-01	4.05E-01	1.53E+01	9.56E-01	4.17E+01	5.62E+01	8.24E+05	1.72E+02	7.68
D1	5.31E-01	<1.39E-01	5.30E-01	1.87E+01	<7.69E-01	2.86E+01	5.25E+01	8.23E+05	1.24E+02	6.83
E1	1.10E+00	<1.89E-01	6.45E-01	3.50E+01	9.57E-01	1.52E+00	1.68E+01	2.75E+05	5.97E+01	1.99

J6 Area

A1※2	6.96E-01	<1.19E-01	2.13E-01	8.96E+00	<7.52E-01	1.12E+02	1.62E+01	9.13E+05	3.46E+02	5.57
B1※2	4.24E+00	3.48E-01	5.35E-01	3.45E+00	1.29E+00	7.08E-01	5.92E+00	1.21E+06	1.88E+01	0.75
C1※2	1.04E+00	2.26E-01	4.61E-01	8.17E-01	<8.85E-01	2.41E+00	6.74E+00	3.63E+05	2.20E+01	0.86
D1※2	3.13E+00	2.33E-01	6.63E-01	5.75E+00	2.00E+00	1.12E+00	8.05E+00	1.40E+06	3.48E+01	1.00
E1※2	2.39E+00	<2.50E-01	6.34E-01	2.38E+01	1.82E+00	1.50E+00	1.48E+01	1.41E+06	4.46E+01	1.78

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 ALPS treated water was additionally transferred to this area after measuring the radiation concentration. Above data were measured before the additional transfer.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

J7 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1 ave.※2	5.72E-01	1.13E-01	9.33E-01	7.57E-01	8.26E-01	5.44E-01	3.60E+00	4.42E+05	—	—	1.16E+01	—	0.44	—
A1 upper※3	6.31E-01	<9.84E-02	9.67E-01	7.23E-01	<7.97E-01	4.56E-01	3.63E+00	4.58E+05	—	—	1.11E+01	—	0.44	—
A1 middle※3	5.87E-01	<1.39E-01	1.01E+00	8.45E-01	9.25E-01	5.83E-01	3.81E+00	4.62E+05	—	—	1.25E+01	—	0.47	—
A1 lower※3	4.96E-01	1.01E-01	8.23E-01	7.04E-01	<7.58E-01	5.94E-01	3.36E+00	4.07E+05	—	—	1.13E+01	—	0.41	—
A1※4	8.06E-01	<1.33E-01	3.32E-01	<4.09E-01	<1.18E+00	4.85E+00	3.21E+00	3.61E+05	1.39E+01	<1.02E+00	1.37E+01	<5.36E-02	0.54	0.55
A6 ave.※2	1.49E+00	2.21E-01	8.86E-01	8.69E-01	8.22E-01	2.16E+00	6.02E+00	3.21E+05	—	—	1.88E+01	—	0.78	—
A6 upper※3	1.36E+00	2.50E-01	1.10E+00	9.47E-01	<7.66E-01	1.53E+00	6.09E+00	3.17E+05	—	—	1.79E+01	—	0.76	—
A6 middle※3	1.47E+00	2.39E-01	1.12E+00	1.07E+00	8.40E-01	1.72E+00	5.90E+00	3.17E+05	—	—	1.89E+01	—	0.75	—
A6 lower※3	1.65E+00	1.74E-01	4.40E-01	5.93E-01	8.61E-01	3.23E+00	6.08E+00	3.30E+05	—	—	1.96E+01	—	0.82	—

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)
※2 Average of the upper, middle and lower levels
※3 ALPS treated water was additionally transferred to this area after measuring the radiation concentration. Above data were measured before the additional transfer.
※4 Concentrations of Carbon-14 and Technetium-99 which affect the concentration of Gross β were additionally measured.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

J7 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A7 ave.※2	2.05E-01	1.45E-01	2.85E+00	8.80E-01	1.69E+00	3.82E-01	5.96E+00	3.02E+05	—	—	1.38E+01	—	0.71	—
A7 upper※3	2.00E-01	<1.57E-01	3.79E+00	1.20E+00	2.25E+00	4.00E-01	7.11E+00	2.72E+05	—	—	1.39E+01	—	0.85	—
A7 middle※3	1.51E-01	<1.10E-01	3.38E+00	8.07E-01	1.87E+00	<3.24E-01	6.71E+00	2.83E+05	—	—	1.53E+01	—	0.80	—
A7 lower※3	2.65E-01	<1.69E-01	1.39E+00	6.33E-01	9.66E-01	4.23E-01	4.07E+00	3.51E+05	—	—	1.20E+01	—	0.49	—
B1 ave.※2	2.17E-01	1.17E-01	2.96E+00	1.03E+00	1.49E+00	5.69E-01	7.98E+00	3.05E+05	—	—	1.41E+01	—	0.94	—
B1 upper※3	1.03E-01	<1.10E-01	3.95E+00	1.21E+00	1.87E+00	6.81E-01	1.09E+01	2.95E+05	—	—	1.62E+01	—	1.27	—
B1 middle※3	1.52E-01	<1.34E-01	3.72E+00	1.09E+00	1.85E+00	7.02E-01	9.89E+00	2.95E+05	—	—	1.33E+01	—	1.16	—
B1 lower※3	3.95E-01	<1.05E-01	1.21E+00	8.03E-01	<7.32E-01	<3.23E-01	3.16E+00	3.26E+05	—	—	1.29E+01	—	0.38	—
B6 upper	3.38E-01	<1.07E-01	3.10E+00	7.72E-01	1.80E+00	3.53E-01	6.98E+00	2.91E+05	—	—	1.28E+01	—	0.83	—
B6 middle	3.81E-01	<1.16E-01	3.07E+00	9.32E-01	1.59E+00	3.48E-01	6.83E+00	2.93E+05	—	—	1.35E+01	—	0.81	—
B6 lower	3.44E-01	1.67E-01	1.68E+00	6.25E-01	1.20E+00	3.78E-01	4.83E+00	3.20E+05	—	—	1.45E+01	—	0.58	—

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)
※2 Average of the upper, middle and lower levels
※3 ALPS treated water was additionally transferred to this area after measuring the radiation concentration. Above data were measured before the additional transfer.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

J7 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
D1 upper	4.49E-01	<1.48E-01	8.25E-01	4.67E-01	<8.22E-01	<7.32E-02	3.03E+00	2.86E+05	—	—	1.62E+01	—	0.36	—
D1 middle	4.61E-01	<9.69E-02	8.44E-01	3.20E-01	<7.68E-01	<7.18E-02	2.91E+00	2.88E+05	—	—	1.59E+01	—	0.35	—
D1 lower	3.91E-01	<1.07E-01	1.05E+00	4.59E-01	<7.30E-01	7.85E-02	3.58E+00	2.89E+05	—	—	1.50E+01	—	0.42	—
D1※2	<2.47E-01	<2.45E-01	9.49E-01	<4.54E-01	<1.40E+00	7.46E-01	2.79E+00	2.72E+05	1.72E+01	4.36E+00	1.05E+01	—	0.36	0.37
D5 upper	2.54E-01	<1.41E-01	2.33E+00	9.23E-01	1.27E+00	3.55E-01	4.24E+00	3.28E+05	—	—	1.57E+01	—	0.51	—
D5 middle	2.35E-01	1.77E-01	2.37E+00	8.40E-01	<7.94E-01	3.23E-01	4.13E+00	3.24E+05	—	—	1.75E+01	—	0.50	—
D5 lower	3.86E-01	<1.26E-01	2.30E+00	9.56E-01	9.74E-01	3.69E-01	3.95E+00	3.18E+05	—	—	1.57E+01	—	0.48	—
E1 upper	5.97E-01	1.40E-01	6.59E-01	6.05E-01	<7.37E-01	5.54E-01	2.73E+00	2.69E+05	—	—	1.19E+01	—	0.34	—
E1 middle	6.61E-01	<9.84E-02	6.18E-01	3.79E-01	<8.12E-01	5.09E-01	2.70E+00	2.66E+05	—	—	1.33E+01	—	0.34	—
E1 lower	5.81E-01	<9.30E-02	5.90E-01	5.12E-01	<8.73E-01	5.05E-01	2.55E+00	2.73E+05	—	—	1.17E+01	—	0.32	—
E6 upper	1.90E+00	3.21E-01	4.73E-01	3.45E+00	<8.37E-01	5.28E+00	6.11E+00	3.76E+05	—	—	3.34E+01	—	0.90	—
E6 middle	1.95E+00	2.78E-01	5.21E-01	3.38E+00	<8.05E-01	5.63E+00	6.43E+00	3.76E+05	—	—	3.34E+01	—	0.94	—
E6 lower	1.91E+00	<1.31E-01	5.47E-01	3.44E+00	<9.53E-01	5.33E+00	6.18E+00	3.75E+05	—	—	3.20E+01	—	0.90	—

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Concentrations of Carbon-14 and Technetium-99 which affect the concentration of Gross β were additionally measured.

【Reference】Value notation for radioactive concentrations, etc.

(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6

4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

J8 Area

Group	Radiation concentration for each nuclide									Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Gross β [Bq/L]	
A1	1.38E+00	<1.74E-01	4.57E-01	<5.78E-01	<1.31E+00	1.82E+00	4.59E+00	2.64E+05	1.34E+01	0.60
A4	7.44E-01	<1.91E-01	5.52E-01	<4.95E-01	<1.26E+00	8.27E+00	6.47E+00	2.59E+05	2.25E+01	1.02
A5	8.09E-01	<2.22E-01	5.49E-01	6.95E-01	1.74E+00	5.43E+00	6.31E+00	2.72E+05	2.35E+01	0.92
B1	1.22E+00	<2.18E-01	7.18E-01	<6.26E-01	<1.38E+00	3.45E+00	5.41E+00	2.71E+05	1.92E+01	0.75
B3	6.91E-01	<1.77E-01	5.18E-01	4.61E-01	1.34E+00	6.89E+00	6.30E+00	2.67E+05	2.80E+01	0.96

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

J9 Area※

※ Radiation concentration data for this area will no longer be released due to the discharge of stored water.

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

K1 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	1.65E+00	<1.49E-01	2.08E-01	<4.13E-01	<1.32E+00	<4.42E-01	2.22E-01	2.19E+05	1.62E+01	<5.09E-01	6.11E+00	<6.45E-02	0.07	0.08
A2	7.94E-01	<1.26E-01	2.82E-01	<4.51E-01	<1.07E+00	5.88E-01	1.86E-01	2.23E+05	1.77E+01	<5.09E-01	6.39E+00	<6.45E-02	0.06	0.07
A3	4.49E-01	<1.45E-01	4.42E-01	<4.19E-01	<1.07E+00	5.46E-01	1.56E-01	2.27E+05	2.10E+01	<5.09E-01	7.50E+00	<5.47E-02	0.06	0.07
A4	2.33E-01	<1.51E-01	4.92E-01	<4.49E-01	<1.20E+00	1.08E+00	1.79E-01	2.25E+05	2.72E+01	<5.09E-01	6.67E+00	<5.47E-02	0.08	0.09
A5	2.11E-01	<1.43E-01	5.62E-01	4.32E-01	<1.06E+00	8.73E-01	1.97E-01	2.23E+05	2.87E+01	<5.09E-01	1.08E+01	<5.63E-02	0.07	0.08
B1※2	2.56E-01	<2.42E-01	8.32E-01	3.42E+00	<1.31E+00	2.97E+02	4.95E+00	4.34E+05	2.53E+00	<1.23E+00	6.78E+02	<6.28E-02	10.46	10.47
B1	1.73E+00	<1.08E-01	<1.43E-01	<4.00E-01	<1.18E+00	<4.44E-01	1.71E-01	2.14E+05	1.68E+01	<3.34E-01	8.29E+00	<6.80E-02	0.07	0.08
B2	1.36E+00	<1.27E-01	2.17E-01	<4.11E-01	<1.07E+00	4.48E-01	1.95E-01	2.13E+05	1.77E+01	<5.09E-01	5.67E+00	<5.47E-02	0.07	0.08
B3	6.20E-01	<1.10E-01	3.23E-01	<4.97E-01	<1.09E+00	5.51E-01	1.85E-01	2.15E+05	1.88E+01	<5.09E-01	5.95E+00	<5.47E-02	0.06	0.07
B4	3.23E-01	<1.35E-01	2.86E-01	<3.59E-01	<1.06E+00	1.01E+00	1.37E-01	2.28E+05	2.41E+01	<5.09E-01	6.51E+00	<6.80E-02	0.07	0.08
B5	2.16E-01	<1.31E-01	4.70E-01	<4.08E-01	<1.29E+00	1.32E+00	1.75E-01	2.31E+05	2.54E+01	<5.09E-01	7.24E+00	<6.80E-02	0.08	0.10
B6	2.27E-01	<1.56E-01	4.65E-01	<4.03E-01	<1.08E+00	7.39E-01	1.89E-01	2.26E+05	3.04E+01	<5.09E-01	1.25E+01	<5.63E-02	0.06	0.08
B7	2.88E-01	<1.57E-01	6.03E-01	<4.74E-01	<1.18E+00	1.01E+00	1.87E-01	2.19E+05	3.04E+01	<3.34E-01	8.94E+00	<6.80E-02	0.08	0.09

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Stored water was transferred in order to secure fresh water after radiation concentration was measured, and ALPS treated water was re-stored. Above data were measured before the water transfer.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6
4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

TEPCO

K3 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1※2	2.21E-01	<1.67E-01	1.01E+00	4.71E-01	<1.29E+00	<4.28E-01	3.13E-01	2.34E+05	3.17E+01	1.15E+00	9.04E+00	<6.80E-02	0.07	0.09
A2※2	1.46E-01	<1.46E-01	8.44E-01	<4.43E-01	<1.21E+00	<4.73E-01	2.47E-01	2.31E+05	3.40E+01	1.18E+00	5.68E+00	<6.80E-02	0.06	0.08
A3※2	<1.45E-01	<1.22E-01	8.33E-01	<4.22E-01	<1.21E+00	<4.45E-01	2.53E-01	2.23E+05	3.81E+01	9.69E-01	7.17E+00	<7.50E-02	0.06	0.08
A4※2	1.62E-01	<1.59E-01	6.27E-01	<4.29E-01	<1.31E+00	<4.38E-01	3.32E-01	2.29E+05	4.34E+01	6.28E-01	7.64E+00	<5.63E-02	0.07	0.10
A5※2	<1.35E-01	<1.48E-01	5.14E-01	3.98E-01	<9.43E-01	<3.92E-01	4.77E-01	2.33E+05	4.43E+01	1.16E+00	9.03E+00	<6.45E-02	0.08	0.11
A6※2	1.60E-01	<1.58E-01	5.83E-01	<4.42E-01	<1.30E+00	<4.42E-01	5.76E-01	2.38E+05	4.19E+01	1.85E+00	1.31E+01	<5.93E-02	0.10	0.12
B1※2	1.53E-01	<1.44E-01	3.77E-01	<4.29E-01	<1.21E+00	<4.07E-01	1.10E-01	2.41E+05	2.68E+01	<3.36E-01	9.63E+00	<6.80E-02	0.04	0.06
B2※2	<1.45E-01	<1.68E-01	9.39E-01	<3.90E-01	<9.72E-01	<4.09E-01	2.93E-01	2.28E+05	3.30E+01	1.28E+00	8.30E+00	<6.80E-02	0.07	0.08
B3※2	<1.46E-01	<1.44E-01	7.31E-01	<4.39E-01	<1.12E+00	<4.33E-01	2.52E-01	2.24E+05	3.41E+01	1.07E+00	8.80E+00	<7.50E-02	0.06	0.08
B4※2	1.62E-01	<1.78E-01	6.75E-01	<4.08E-01	<1.08E+00	<4.20E-01	4.82E-01	2.26E+05	3.50E+01	1.04E+00	1.07E+01	<5.63E-02	0.09	0.11
B5※2	<1.38E-01	<1.48E-01	6.96E-01	4.74E-01	<1.21E+00	<4.12E-01	3.47E-01	2.28E+05	4.75E+01	7.59E-01	8.90E+00	<6.45E-02	0.07	0.10
B6※2	1.99E-01	<1.70E-01	7.18E-01	<6.22E-01	<1.49E+00	<3.99E-01	9.44E-01	2.32E+05	3.42E+01	2.75E+00	1.35E+01	<5.93E-02	0.14	0.16

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 ALPS treated water was transferred to this area after discharging stored water.

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

2. Actual radiation concentration measurements for each tank group (except for repurposed tanks)

K4 Area※

※ Radiation concentration data for this area will no longer be released due to the discharge of stored water.

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

3. Actual radiation concentration measurements for each tank group (repurposed tanks)

(as of March 31, 2025)

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved.
無断複製・転載禁止 東京電力ホールディングス株式会社

3. Actual radiation concentration measurements for each tank group (repurposed tanks)

TEPCO

G3 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
D8	4.00E+00	<2.47E-01	5.65E-01	<4.78E-01	<1.16E+00	7.63E+01	2.43E-01	2.13E+05	4.49E+01	<5.30E-01	1.60E+02	<6.79E-02	2.63	2.66
G1	3.58E-01	<1.61E-01	1.61E-01	<4.55E-01	<1.18E+00	3.48E+00	3.68E-01	2.21E+05	1.08E+02	<5.30E-01	3.70E+01	<6.79E-02	0.18	0.23
E1	9.13E-01	<3.08E-01	5.61E-01	<4.34E-01	<1.22E+00	9.75E+00	6.59E-01	4.38E+05	1.32E+02	<2.99E-01	4.74E+01	<4.83E-02	0.43	0.50
E10	2.40E+00	<3.17E-01	3.64E-01	<4.72E-01	<1.22E+00	5.24E+01	8.44E-02	2.43E+05	7.96E+01	<2.99E-01	1.08E+02	<4.83E-02	1.80	1.84
F1	5.91E-01	<1.99E-01	3.80E-01	4.09E-01	<1.09E+00	8.90E+00	3.33E-01	3.65E+05	7.13E+01	<4.76E-01	3.28E+01	<6.00E-02	0.36	0.39
F6	2.40E+00	<2.00E-01	7.57E-01	5.02E-01	<1.41E+00	2.99E+01	3.84E-01	4.28E+05	1.42E+02	<4.76E-01	8.28E+01	<6.00E-02	1.09	1.16
H1	2.05E+00	<1.95E-01	6.96E-01	6.27E-01	<1.22E+00	2.64E+02	<2.39E-01	7.00E+05	1.41E+01	<1.08E+00	5.40E+02	<6.00E-02	8.88	8.88
H4	4.01E+01	2.18E+00	4.62E+00	1.69E+00	<2.54E+00	3.38E+03	3.26E-01	4.97E+05	1.43E+01	<1.08E+00	7.25E+03	<6.00E-02	113.17	113.18

H8 Area

A3	1.56E+02	2.56E+00	6.85E+01	1.01E+01	<6.06E+00	9.28E+02	1.13E+01	1.44E+06	2.55E+01	3.16E+00	1.85E+03	<6.35E-02	34.39	34.40
A4	3.23E+01	<5.61E-01	4.03E+01	4.97E+00	<3.79E+00	6.53E+02	1.12E+01	1.34E+06	2.45E+01	3.60E+00	1.32E+03	<6.35E-02	23.61	23.62
B2	9.50E+01	1.89E+00	4.75E+00	2.81E+01	<3.37E+00	1.36E+03	1.06E+01	1.41E+06	2.15E+01	4.58E+00	3.09E+03	<6.35E-02	47.75	47.77
B4	1.34E+01	2.69E-01	1.03E+00	2.97E+00	<1.88E+00	1.13E+03	1.23E+01	1.24E+06	2.40E+01	5.42E+00	2.38E+03	<6.35E-02	39.21	39.23
B9	8.24E+01	1.27E+00	2.80E+00	3.93E+00	<4.23E+00	4.01E+03	1.25E+01	1.50E+06	2.99E+01	3.67E+00	8.29E+03	<6.35E-02	136.06	136.08

J1 Area

B1	2.02E+01	<5.03E-01	7.74E+00	1.69E+01	<3.01E+00	1.38E+04	2.86E+01	4.47E+05	5.66E+00	8.57E+00	2.85E+04	<5.64E-02	464.5	464.51
B6	1.81E+00	<3.14E-01	3.19E+00	4.61E+00	<2.10E+00	6.54E+03	3.49E+01	5.27E+05	4.16E+00	3.68E+00	1.26E+04	<5.64E-02	221.78	221.78

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16×10^{1} = 41.6
4.16E - 01 = 4.16×10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

3. Actual radiation concentration measurements for each tank group (repurposed tanks)

TEPCO

K1 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
C1	<1.38E-01	<1.55E-01	1.31E+00	<4.02E-01	<1.09E+00	<4.01E-01	3.63E-01	1.97E+05	4.39E+01	3.26E+00	1.30E+01	<7.42E-02	0.08	0.10
C2	1.30E-01	<1.31E-01	7.13E-01	<3.47E-01	<1.09E+00	<4.20E-01	1.37E-01	1.96E+05	3.33E+01	9.69E-01	1.18E+01	<6.80E-02	0.05	0.07
C3	<1.14E-01	<1.37E-01	6.56E-01	3.86E-01	<1.10E+00	<4.14E-01	1.36E-01	2.00E+05	2.50E+01	9.08E-01	9.64E+00	<6.80E-02	0.05	0.06
C4	2.30E-01	<1.32E-01	7.66E-01	4.27E-01	<1.30E+00	<4.29E-01	1.54E-01	1.97E+05	2.47E+01	9.29E-01	9.33E+00	<5.77E-02	0.05	0.07
C5	2.28E-01	<1.39E-01	8.49E-01	<4.19E-01	<1.18E+00	5.06E-01	1.85E-01	2.04E+05	1.60E+01	8.54E-01	8.84E+00	<5.77E-02	0.06	0.07
C6	2.53E-01	<1.37E-01	4.32E-01	<4.34E-01	<1.16E+00	5.86E-01	1.16E-01	2.04E+05	1.37E+01	4.59E-01	7.50E+00	<6.07E-02	0.05	0.06
D1	<1.37E-01	<1.38E-01	5.04E-01	<3.62E-01	<9.88E-01	<3.87E-01	1.75E-01	2.06E+05	2.14E+01	9.89E-01	6.94E+00	<7.42E-02	0.05	0.06
D2	3.05E-01	<1.49E-01	5.83E-01	<3.93E-01	<1.02E+00	<4.62E-01	1.51E-01	2.05E+05	1.91E+01	7.55E-01	5.79E+00	<7.42E-02	0.05	0.06
D3	3.76E-01	<1.23E-01	4.04E-01	<3.78E-01	<1.32E+00	<4.04E-01	1.13E-01	2.03E+05	1.16E+01	3.66E-01	6.56E+00	<6.07E-02	0.05	0.05
D4	3.56E-01	<1.35E-01	3.68E-01	<3.79E-01	<1.30E+00	9.03E-01	<6.15E-02	2.00E+05	1.24E+01	<2.01E-01	7.41E+00	<7.42E-02	0.06	0.06

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

【Reference】Value notation for radioactive concentrations, etc.
(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6
4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社

3. Actual radiation concentration measurements for each tank group (repurposed tanks)

TEPCO

K2 Area

Group	Radiation concentration for each nuclide												Sum of the ratios to regulatory concentration limits (primary 7 nuclides※) [-]	Sum of the ratios to regulatory concentration limits (primary 7 nuclides※ +C-14 +T-99) [-]
	Cesium-137 Regulatory concentration limit **9.00E+01** [Bq/L]	Cesium-134 Regulatory concentration limit **6.00E+01** [Bq/L]	Cobalt-60 Regulatory concentration limit **2.00E+02** [Bq/L]	Antimony-125 Regulatory concentration limit **8.00E+02** [Bq/L]	Ruthenium-106 Regulatory concentration limit **1.00E+02** [Bq/L]	Strontium-90 Regulatory concentration limit **3.00E+01** [Bq/L]	Indine-129 Regulatory concentration limit **9.00E+00** [Bq/L]	Tritium-3 Regulatory concentration limit **6.00E+04** [Bq/L]	Carbon-14 Regulatory concentration limit **2.00E+03** [Bq/L]	Technetium-99 Regulatory concentration limit **1.00E+03** [Bq/L]	Gross β [Bq/L]	Gross α [Bq/L]		
A1	5.81E-01	<1.36E-01	5.19E-01	<4.12E-01	<1.18E+00	6.56E-01	7.09E-02	3.03E+05	8.71E+00	<5.09E-01	6.45E+00	<7.15E-02	0.05	0.06
A7	2.23E-01	<2.91E-01	1.01E+00	7.79E-01	<1.16E+00	3.98E+01	1.71E-01	2.76E+05	6.51E+00	<5.09E-01	1.04E+02	<7.15E-02	1.37	1.38
B1	7.72E-01	<2.51E-01	1.20E+00	7.32E-01	<1.81E+00	5.77E+01	3.16E+00	2.98E+05	2.86E+01	<8.31E-01	2.16E+02	<7.97E-02	2.31	2.33
B6	4.68E-01	<4.55E-01	5.53E-01	2.28E+00	<2.57E+00	2.95E+01	3.77E-01	6.90E+05	1.88E+01	<8.31E-01	1.88E+02	<7.97E-02	1.07	1.08
B7	2.89E-01	<4.64E-01	1.96E+00	1.24E+01	<2.17E+00	5.30E+02	1.25E+00	5.69E+05	1.23E+01	<7.97E-01	1.21E+03	<7.13E-02	17.85	17.86
C1※2	<2.15E-01	<2.26E-01	1.47E-01	8.17E-01	<1.16E+00	<4.21E-01	<7.74E-02	4.64E+05	1.05E+01	<2.41E-01	<6.45E+00	<6.89E-02	0.04	0.05
C7	<2.55E-01	<3.18E-01	1.05E+00	1.09E+01	<1.48E+00	5.19E+02	6.58E-01	4.21E+05	1.02E+01	<2.41E-01	1.11E+03	<6.89E-02	17.41	17.42
D1※2	2.41E-01	<1.45E-01	8.64E-01	<4.86E-01	<1.22E+00	<3.98E-01	5.21E-01	4.41E+05	9.74E+00	<7.97E-01	5.81E+00	<7.13E-02	0.09	0.10

※1 primary 7 nuclides (Cesium-137, Cesium-134, Cobalt-60, Antimony-125, Ruthenium-106, Strontium-90 and Iodine-129)

※2 Treated water tanks connected to repurposed tanks

【Reference】Value notation for radioactive concentrations, etc.

(e.g.) 4.16E + 01 = 4.16 x 10^{1} = 41.6

4.16E - 01 = 4.16 x 10^{-1} = 0.416

©Tokyo Electric Power Company Holdings, Inc. All Rights Reserved. 無断複製・転載禁止 東京電力ホールディングス株式会社