

# Application for approval to amend the Implementation Plan Regarding the Handling of ALPS Treated Water [Overview]



November 14, 2022  
Tokyo Electric Power Company Holdings, Inc.

- Following the Japanese government's Basic Policy announced in April 2021, TEPCO had been reviewed the details of the design and operation of ALPS treated water dilution/discharge facility and related facilities. In December 2021, TEPCO submitted the "Application Documents for Approval to Amend the Implementation Plan for Fukushima Daiichi Nuclear Power Station Specified Nuclear Facility" for the basic design of ALPS treated water dilution/discharge facility and related facilities to the Nuclear Regulation Authority (NRA), and on July 22, 2022, these application documents were approved by the NRA.
- Today, on November 14<sup>th</sup>, we submitted the "Application Documents for Approval to Amend the Implementation Plan for Fukushima Daiichi Nuclear Power Station Specified Nuclear Facility" to the NRA, with additional details/revisions on the organizational structure for operating, maintaining, and managing the ALPS treated water dilution/discharge facilities, nuclides to be measured/assessed to confirm that the ALPS treated water meets the discharge criteria before it is discharged into the sea, and the radiological environmental impact assessment results given the changes to the nuclides to be measured/assessed.
- We will continue to do our utmost to increase the understanding of people of Fukushima and domestic and international community regarding the handling of ALPS treated water as part of the decommissioning work, by focusing on our efforts to disseminate information based on scientific evidence to parties within and outside Japan in an easy-to-understand manner and taking every opportunity to listen to the concerns and opinions of the public and explain our approach and response.
- Furthermore, we will also work to build trust of people within and outside Japan, by disclosing the construction status of ALPS treated water dilution/discharge facilities, etc. as appropriate and responding sincerely to safety confirmation by municipalities and reviews by the International Atomic Energy Agency (IAEA) to secure objectivity and transparency.

# 1-1. Overview of the Implementation Plan

## Partial revised points and contents to the implementation plan

Slide No.

### Chapter III Security at the specified nuclear facility

#### Part 1 / Part 2 Operations related to security

Reflected changes in operation structure after the ALPS treated water dilution/discharge facility starts operation

5

#### Part 3 Supplementary explanation regarding security

Selection of nuclides subject to measurement and assessment in order to confirm before discharging ALPS treated water into the sea that the ALPS treated water meets the discharge criteria (Sum of ratios of the concentration of each radionuclide to the regulatory concentration of each is less than one)

6~14

### Reference material

#### Response based on the “Basic Policy on handling of ALPS Treated Water at the Tokyo Electric Power Company Holdings’ Fukushima Daiichi Nuclear Power Station”

Radiological Environmental Impact Assessment report regarding the discharge of ALPS treated water into the sea (construction stage)

Attachment  
3


# 2-1. Objective and ALPS Treated Water dilution/discharge facility and related facilities

## Objective

Water which radioactive nuclides has been removed using ALPS until the radionuclide concentration is at a sufficiently low concentration, will be diluted with seawater and discharged into the sea after confirming that the water meets the regulatory requirements (water with the sum of ratios of legally required concentrations, excluding tritium, less than 1).

## Facility overview

In the measurement/confirmation facility, once the radionuclides in the water in the measurement/confirmation tank are uniformly dispersed, samples are taken and analyzed to confirm the water meets regulatory standards. The ALPS treated water is then transferred to the seawater pipe header using the transfer facility and mixed with the seawater taken from the Unit 5 intake channel using the dilution facility until the tritium concentration is below 1,500 Bq/L. This is then discharged using the discharge facility. At the discharge facility, the water will be discharged from the outlet 1km off the coast.




# 2-2. Overview of ALPS treated water dilution/discharge facility and related facilities

Remain the original



Source: Developed by Tokyo Electric Power Company Holdings, Inc. based on the map developed by the Geospatial Information Authority of Japan (electronic territory web) <https://maps.gsi.go.jp/#13/37.422730/141.044970/&base=std&ls=std&disp=1&vs=c1j0h0k0l0u0t0z0r0s0m0f1>



\*Area where common fishery rights are not set

**Secondary treatment facility (newly installed reverse osmosis membrane facility)**


Secondary treatment of treated water to be re-purified (sum of the ratios of nuclides, excluding tritium, is between 1 and 10)

**Secondary treatment facility (ALPS)**

Secondary treatment of Treated water to be re-purified (sum of the ratios of nuclides, excluding tritium, is 1 or higher)

**Measurement/confirmation facility (K4 tank group)**

Comprised of three sets of tank groups each with the role of receiving, measurement/confirmation, and discharge. In the measurement/confirmation stage, water that has been made homogenized through circulation and agitating is sampled and analyzed (approx. 10,000m<sup>3</sup> × 3 groups)



Use the differential head equivalent to the loss in the discharge tunnel (difference between the water surface in the downstream storage and the sea surface) to discharge water naturally.

## 3-1. Major changes : organizational structure

- The ALPS Treated Water Program Department will continue to be in charge of planning and managing the project of facilities related to the discharge into the sea even after the ALPS treated water dilution/discharge facilities start operation. The Implementation Plan was updated to clarify the specific departments that would be in charge of maintenance management and operation management of equipment.

<u>Organization</u>	<u>Operations related to security (Updated)</u> <span style="color: red;">Red letters</span> : Updated areas
<b>ALPS Treated Water Program Department</b>	Development of plans, management and operation methods for facilities related to sea discharge and the <span style="color: red;"><u>operation plans of ALPS treated water dilution/discharge facilities</u></span>
<b>Water Treatment Team, Operation Dept., Construction, Operation, and Maintenance Center</b>	Operation management of contaminated water treatment facilities, buildings for storing stagnant water, ALPS, subdrain and other water treatment facilities, and the <span style="color: red;"><u>ALPS treated water dilution/discharge facilities</u></span>
<b>Storage Facilities G, Mechanical Engineering Dept., Construction, Operation, and Maintenance Center</b>	Maintenance management of civil engineering equipment in contaminated water treatment facilities (storage facilities) and <span style="color: red;"><u>mechanical equipment in ALPS treated water dilution/discharge facilities</u></span> Construction, installation, and maintenance management of contaminated water treatment facilities (ancillary facilities to storage facilities), and rainwater treatment facilities
<b>Water Treatment Instrumentation G, Electrical, Instrumentation and Control Dept., Center for Construction, Operation, and Maintenance</b>	Construction, installation, and maintenance management of instrumentation for contaminated water treatment facilities, buildings storing stagnant water, ALPS, subdrain and other water treatment facilities, oil treatment facilities, facilities to intake water inside the Unit 3 primary containment vessel, <span style="color: red;"><u>ALPS treated water dilution/ discharge facilities</u></span>

The department in charge of works other than the above is as described in the current, approved version of the Implementation Plan. The following Groups will work on each of the tasks as appropriate.


- E.g.)
- Maintenance management of electrical equipment: Electrical Equipment Maintenance G, Electrical, Instrumentation and Control Dept., Construction, Operation, and Maintenance Center
  - Maintenance management of civil engineering equipment: Civil Engineering Equipment G, Civil Engineering Dept., Construction, Operation, and Maintenance Center
  - Maintenance management of construction equipment: Construction Equipment Maintenance G, Construction Dept., Construction, Operation, and Maintenance Center
  - ALPS treated water analysis: Analysis and Assessment G, Radiation/Environment Dept., Emergency Preparedness/Radiation Control Center

## 3-2. Major changes : selection of nuclides to be measured and assessed

Remain the original (partly updated)

TEPCO

- Approach to selecting nuclides that could impact dose assessment in ALPS treated water
  - The existing approved Implementation Plan stated “the policy for **selecting nuclides subject to measurement and assessment with rigorous verification** to ensure that the **ALPS treated water meets the discharge criteria after it has been diluted before discharge** (sum of the ratios of the concentration of each radionuclide to the regulatory concentration of each, excluding tritium, in the ALPS treated water is less than 1) based on the knowledge in Japan on decommissioning and disposal facilities”. We have described our approach to the selection of nuclides based on the results of the verification this time.



Overview of the discussions of the selection of nuclides to be measured and assessed



### 3-3. Results of the additional nuclide analysis

- In the verification, analysis results in the past were assessed and additional analysis was conducted to see if the nuclides garnering attention in the research on decommissioning and burial facilities exist in significant quantities in the stagnant water, Sr removed water, ALPS treated water, etc.
- Results of this verification showed that **the nuclides (including α nuclides) garnering attention in the research on decommissioning and burial facilities were not detected in the ALPS treated water.\***

※ : Below or equal to the 1/100 of the regulatory concentration and below the detection limit ; Uranium was detected in very small amounts of natural uranium in the environment

Nuclides measured in the past							Source : the 9th ALPS Treated Water Review Meeting materials						
Fission products: 56 nuclides							Corrosion products: 6 nuclides			Nuclides other than those on the left: 2 nuclides			
Rb-86 Rubidium	Sr-89 Strontium	Sr-90 Strontium	Y-90 Yttrium	Y-91 Yttrium	Nb-95 Niobium	Tc-99 Technetium	Mn-54 Manganese	H-3 Tritium			C-14 Carbon		
Ru-103 Ruthenium	Ru-106 Ruthenium	Rh-103m Rhodium	Rh-106 Rhodium	Ag-110m Silver	Cd-113m Cadmium	Cd-115m Cadmium	Fe-59 Iron	Nuclides other than the 64 nuclides: 20 nuclides					
Sn-119m Tin	Sn-123 Tin	Sn-126 Tin	Sb-124 Antimony	Sb-125 Antimony	Te-123m Tellurium	Te-125m Tellurium	Co-58 Cobalt	Cl-36 Chlorine	Ca-41 Calcium	Ni-59 Nickel			
Te-127 Tellurium	Te-127m Tellurium	Te-129 Tellurium	Te-129m Tellurium	I-129 Iodine	Cs-134 Cesium	Cs-135 Cesium	Co-60 Cobalt	Se-79 Selenium	Nb-94 Niobium	Mo-99 Molybdenum			
Cs-136 Cesium	Cs-137 Cesium	Ba-137m Barium	Ba-140 Barium	Ce-141 Cerium	Ce-144 Cerium	Pr-144 Praseodymium	Ni-63 Nickel	Tc-99m Technetium	Te-132 Tellurium	I-131 Iodine			
Pr-144m Praseodymium	Pm-146 Promethium	Pm-147 Promethium	Pm-148 Promethium	Pm-148m Promethium	Sm-151 Samarium	Eu-152 Europium	Zn-65 Zinc	I-132 Iodine	La-140 Lanthanum	U-233 Uranium			
Eu-154 Europium	Eu-155 Europium	Gd-153 Gadolinium	Tb-160 Terbium	Pu-238 Plutonium	Pu-239 Plutonium	Pu-240 Plutonium							
Pu-241 Plutonium	Am-241 Americium	Am-242m Americium	Am-243 Americium	Cm-242 Curium	Cm-243 Curium	Cm-244 Curium							
										U-234 Uranium	U-235 Uranium	U-236 Uranium	
										U-238 Uranium	Np-237 Neptunium	Pu-242 Plutonium	
										Cm-245 Curium	Cm-246 Curium		

Nuclides selected based on the existing knowledge and additionally analyzed in this study this time (in addition to the nuclides below, alpha nuclides that could exist in significant quantities in stagnant water, Sr removed water, and ALPS treated water, etc. were also analyzed).

<b>Fe-55</b> Iron	<b>Ni-59</b> Nickel	<b>Nb-93m</b> Niobium	<b>Mo-93</b> Molybdenum	<b>Sn-121m</b> Tin	<b>Cl-36</b> Chlorine	<b>Ca-41</b> Calcium	<b>Zr-93</b> Zirconium	<b>Ba-133</b> Barium	<b>Se-79</b> Selenium	<b>Pd-107</b> Palladium
----------------------	------------------------	--------------------------	----------------------------	-----------------------	--------------------------	-------------------------	---------------------------	-------------------------	--------------------------	----------------------------




# 【Reference】 Approach to selecting nuclides to be measured and assessed

Newly added

TEPCO

- In the ALPS treated water etc., there is no discrepancy that would suggest the presence of radionuclides other than the current 64 nuclides between total beta measurements and the sum of analysis results for radioactive concentration of 7 major nuclides\* plus carbon-14 and technetium-99. Total alpha also remained undetectable.  
※ Major 7 nuclides : Cesium-134, Cesium-137, Strontium-90, Iodine-129, Cobalt-60, Antimony-125, Ruthenium-106 that were found in significant concentrations compared to the regulatory concentration limits in the analysis of the 62 nuclides in treated water conducted in the past.
- In addition to the above, as shown in the previous slide, results of individual analyses on nuclides other than the current 64 nuclides, that are garnering attention in decommissioning and burial facilities research, demonstrate that these nuclides did not exist in significant concentrations in ALPS treated water.
- Through these efforts, we were able to verify again that the ALPS nuclide removal function was performing as expected, and the nuclides that could exist in significant concentrations were the major 7 nuclides, Carbon-14, and Technetium-99.

- Nevertheless, based on the discussions at previous review meetings related ALPS treated water and comments from the NRA and the IAEA, **nuclides to be measured and assessed are selected with a perspective of confirming, just in case, that nuclides that are significantly present or possibly present in significant concentrations in stagnant water, Sr removed water, etc. have been removed to meet the discharge criteria in the ALPS treated water to be discharged into the sea.**




# 3-4. Selection of nuclides to be measured and assessed through inventory assessment

Newly added



- The nuclides to be measured and assessed were selected using the following process.
- Regarding the following process, first, the nuclides that can realistically exist are selected considering the half-life of the nuclides based on the findings pointed by the IAEA and the NRA. Next, we conduct another desk study assuming<sup>※</sup> that all of the radioactive materials have been transferred to the ALPS treated water storage tanks. Furthermore, the assessment is based on the actual measured data of contaminated water and the properties of nuclides that we have accumulated over the past 12 years.

※ Assumption based on the fact that contaminated water has been continuously treated and stored in the tanks over the 12 years since the earthquake.



## 3-5. Selected nuclides to be measured and assessed

- 30 nuclides in the table below and tritium are the nuclides to be measured and assessed in discharging the ALPS treated water into the sea, selected using the selection flow on the previous slide.
- These changes to the nuclides to be measured and assessed (4 nuclides were added and 37 removed from selection) will be reviewed by the NRA and the IAEA.

### 【Nuclides to be measured and assessed (30 nuclides)】

Before, during and after the discharge of ALPS treated water into the sea, we will confirm that the following nuclides meets the discharge criteria (sum of the ratios of the concentration of each radionuclide to the regulatory concentration of each is less than one).

※ In addition to the nuclides in the table below, tritium will be also measured.

<b>C-14</b> Carbon	<b>Y-90</b> Yttrium	<b>I-129</b> Iodine	<b>Eu-154</b> Europium	<b>Pu-239</b> Plutonium
<b>Mn-54</b> Manganese	<b>Tc-99</b> Technetium	<b>Cs-134</b> Cesium	<b>Eu-155</b> Europium	<b>Pu-240</b> Plutonium
<b>Co-60</b> Cobalt	<b>Ru-106</b> Ruthenium	<b>Cs-137</b> Cesium	<b>U-234</b> Uranium	<b>Pu-241</b> Plutonium
<b>Ni-63</b> Nickel	<b>Cd-113m</b> Cadmium	<b>Ce-144</b> Cerium	<b>U-238</b> Uranium	<b>Am-241</b> Americium
<b>Se-79</b> Selenium	<b>Sb-125</b> Antimony	<b>Pm-147</b> Promethium	<b>Np-237</b> Neptunium	<b>Cm-243</b> Curium
<b>Sr-90</b> Strontium	<b>Te-125m</b> Tellurium	<b>Sm-151</b> Samarium	<b>Pu-238</b> Plutonium	<b>Cm-244</b> Curium



Nuclides added to be on the conservative side based on the selection flow

# 3-6. Periodic confirmation of nuclides to be measured and assessed

- Although the nuclides to be measured and assessed on the previous page were selected after confirming the past analysis results, there is a possibility that the situation may change depending on the progress of future decommissioning work.
- If significant quantities of nuclides other than those to be measured and assessed (hereinafter referred to as "other nuclides") are found, the nuclides to be measured and assessed will be re-evaluated. Decay of radionuclides will be also reflected in the selection following process.
- These details will also be discussed during the future review by the NRA.

## 【 Confirmation at each release 】

Confirm that other nuclides in significant quantities are not found by measuring  $\gamma$ -rays with Ge semiconductor detectors, total alpha, and total beta.

## 【 Confirmation of trend of radioactive concentration in contaminated water 】

Confirm that the radioactive concentration of contaminated water after the central radioactive waste treatment facility is below or equal to the concentration confirmed in the past.

## 【 Research and analysis 】

In the research and analysis, if an event of concern is found in the above confirmation, we will research the presence of other nuclides. Even if there is no concern, we will research the presence of other nuclides by confirming that nuclides to be monitored in significant quantities are not found once a year in Sr removed water.

## ○ Nuclides to be monitored (6 nuclides)

Nuclides not detected in significant quantities in past analysis of contaminated and treated water but to be continuously confirmed.

<b>Cl-36</b> Chlorine	<b>Fe-55</b> Iron	<b>Nb-93m</b> Niobium	<b>Nb-94</b> Niobium	<b>Mo-93</b> Molybdenum	<b>Ba-133</b> Barium
--------------------------	----------------------	--------------------------	-------------------------	----------------------------	-------------------------

# [Reference] Comparison with nuclides to be removed with ALPS (62 nuclides) and carbon-14

Newly added



- The nuclides that have been changed in this method are as follows.
- In previous measurements, (a) there is no discrepancy that would suggest the presence of Selenium-79 in total beta analysis of ALPS treated water, (b) Uranium-234, Uranium-238, and Neptunium-237 have not been detected by total alpha analysis in ALPS treated water, and (c) in this additional analysis, these nuclides were not detected. From the foregoing, these nuclides are not considered to be present in significant concentrations in ALPS treated water, though they will be measured and assessed voluntarily just in case.
- Among the nuclides subject to be removed by ALPS, **there is no possibility that the 37 nuclides that were not selected are present in the contaminated water. However, we will voluntarily measure them and confirm that their concentrations are below the detection limit prior to the discharge.**

## Nuclides to be measured and assessed : 30 Nuclides (=26+4)

※ In addition to the nuclides in the table below, tritium will be also measured.

<b>C-14</b> Carbon	<b>Tc-99</b> Technetium	<b>Cs-137</b> Cesium	<b>U-238</b> Uranium	<b>Cm-243</b> Curium
<b>Mn-54</b> Manganese	<b>Ru-106</b> Ruthenium	<b>Ce-144</b> Cerium	<b>Np-237</b> Neptunium	<b>Cm-244</b> Curium
<b>Co-60</b> Cobalt	<b>Cd-113m</b> Cadmium	<b>Pm-147</b> Promethium	<b>Pu-238</b> Plutonium	
<b>Ni-63</b> Nickel	<b>Sb-125</b> Antimony	<b>Sm-151</b> Samarium	<b>Pu-239</b> Plutonium	
<b>Se-79</b> Selenium	<b>Te-125m</b> Tellurium	<b>Eu-154</b> Europium	<b>Pu-240</b> Plutonium	
<b>Sr-90</b> Strontium	<b>I-129</b> Iodine	<b>Eu-155</b> Europium	<b>Pu-241</b> Plutonium	
<b>Y-90</b> Yttrium	<b>Cs-134</b> Cesium	<b>U-234</b> Uranium	<b>Am-241</b> Americium	

■ : Nuclides added to be on the conservative side based on the selection flow (4 nuclides)

## Nuclides excluded from those to be measured and assessed among the nuclides to be removed with ALPS : 37 nuclides (=13+10+14)

<b>Fe-59</b> Iron	<b>Te-129m</b> Tellurium	<b>Co-58</b> Cobalt	<b>Te-123m</b> Tellurium	<b>Zn-65</b> Zinc	<b>Rh-106</b> Rhodium
<b>Rb-86</b> Rubidium	<b>Cs-136</b> Cesium	<b>Y-91</b> Yttrium	<b>Te-127</b> Tellurium	<b>Ag-110m</b> Silver	<b>Cs-135</b> Cesium
<b>Sr-89</b> Strontium	<b>Ba-140</b> Barium	<b>Nb-95</b> Niobium	<b>Te-127m</b> Tellurium	<b>Sn-119m</b> Tin	<b>Ba-137m</b> Barium
<b>Ru-103</b> Ruthenium	<b>Ce-141</b> Cerium	<b>Sn-123</b> Tin	<b>Gd-153</b> Gadolinium	<b>Sn-126</b> Tin	<b>Pm-146</b> Promethium
<b>Rh-103m</b> Ruthenium	<b>Pm-148</b> Promethium	<b>Sb-124</b> Antimony	<b>Tb-160</b> Terbium	<b>Pr-144</b> Praseodymium	<b>Eu-152</b> Europium
<b>Cd-115m</b> Cadmium	<b>Pm-148m</b> Promethium			<b>Pr-144m</b> Praseodymium	<b>Am-242m</b> Americium
<b>Te-129</b> Tellurium				<b>Cm-242</b> Curium	<b>Am-243</b> Americium

■ : Nuclides whose inventory volume decreased and excluded from selection in step 1 (13 nuclides)

■ : Nuclides whose inventory volume decreased and excluded from selection in step 3 (10 nuclides)

■ : Nuclides excluded from selection in step 4 as a result of reviewing the state of transition to contaminated water from nuclear reactors, etc. according to the actual situation. (14 nuclides)

All nuclides  
Half-life less  
than 1 year

# [Reference] Major issues in selecting nuclides to be Measured and assessed

Major issues in selecting nuclides to be measured/evaluated are as follows:

- The reason why the criteria for exclusion from the selection on the selection flow is 1/100 of the regulatory concentration of each nuclide

This criterion was established based on the assumption that the dose impact caused by the release of ALPS treated water into the sea is sufficiently small.

Example of procedure 3 (Evaluation of transfer of all the amount to ALPS treated water, etc. storage tanks)

$$\text{Concentration of nuclide } i = \frac{\text{Inventory amount of nuclide } i \text{ (Bq)}}{\text{Stored amount of ALPS treated water, etc. (m}^3\text{)}} < \text{Regulatory concentration of nuclide } i \times 0.01 \text{ (Bq/m}^3\text{)}$$

1.33 million m<sup>3</sup> (estimated) as of Mar. 2023

In Procedure 3, we evaluate the assumption that all the inventory generated in the reactor core has been transferred to the storage amount of ALPS treated water etc. to be stored as of March 2023. Considering the situation of the PCV internal investigation, etc. so far, we believe that it is a very conservative setting\* that the entire amount of the generated inventory has been transferred to the tanks.

※The setting that the entire amount of the generated inventory was transferred to the tanks has more than 100 times more conservativeness in the concentration evaluation compared with the sampling results of contaminated water so far.

Example of procedure 4 and 5 (Concentration evaluation of contaminated water, Actual concentration of contaminated water)

In procedures 4 and 5, the concentration of contaminated water is assessed, and even if the figure is 1/100 of regulatory concentration at that point, the impact on the sum of ratios of the concentration of each radionuclide to the regulatory concentration, which is one and the discharge criteria, is small enough considering the subsequent removal with ALPS.

※ Nuclides to be removed by ALPS are set to target nuclides exceeding 1/100 of the regulatory standard concentration in contaminated water as in this section



It has the ability to remove 62 radioactive nuclides excluding tritium to below the regulatory standard concentration.

※ Having also the ability to remove particulate radionuclides and nuclides with similar properties such as isotopes of nuclides targeted for removal

## 3-7. Summary of the selection of nuclides to be measured and assessed other than tritium

Newly added

TEPCO

- Based on the discussions at previous review meetings related to the ALPS treated water, first IAEA review report, and the requirements from the Fukushima Prefecture Technical Discussion Committee Report, TEPCO reverified thoroughly the nuclides to be confirmed before ALPS treated water is diluted and discharged into the environment.
- TEPCO has continued to measure radioactive materials in ALPS treated water. We confirm that nuclides other than the major 7 nuclides\*, Carbon-14, and Technetium-99 do not exist in significant concentrations in ALPS treated water by total beta and total alpha measurements. Furthermore, additional analysis of nuclides selected based on existing knowledge detected no new nuclides (including alpha nuclides) in ALPS treated water.
- Given the above, regarding the nuclides to be measured and assessed before ALPS treated water is diluted and discharged, we selected 30 nuclides considering the nuclides may exist in significant concentrations in contaminated water before purified and treated by ALPS regardless of whether they are in the ALPS treated water or not.
- Among the 62 nuclides subject to be removed by ALPS, there is no possibility that the 37 nuclides that were not selected for measurement and assessment this time are significantly present in the contaminated water. However, we will voluntarily measure them and confirm that their concentrations are below the detection limit prior to the discharge from the viewpoint of suppressing adverse impacts of reputation.

※ Major 7 nuclides : Cesium-134, Cesium-137, Strontium-90, Iodine-129, Cobalt-60, Antimony-125, Ruthenium-106 that were found in significant concentrations compared to the regulatory concentration limits in the analysis of the 62 nuclides in treated water conducted in the past.