

June 22, 2012

Tokyo Electric Power Station

Kashiwazaki-Kariwa Nuclear Power Station







(2) Watertight doors at the Reactor Building, etc. Adopting watertight doors at the Reactor Building, Turbine Building and Heat Exchanger Building prevents the equipments and facilities in the building from being flooded.

3. Strengthening the Heat Removal/Cooling Functions

(7) Equipments/Materials storage built on high ground for emergency

The equipments/materials storage is built on high ground to allow access to necessary equipments and materials in case of Tsunami emergencies.

(2) Additional deployment of air-cooled gas turbine power supply cars

Large capacity gas turbine power supply cars are additionally deployed to secure power supply allowing the stable operation of residual heat removal pumps in the case of station blackouts.

(3) Installation of emergency high-voltage switchboards and the permanent cables in the Reactor Building By installing emergency high-voltage switchboards

and permanent cables in the Reactor Building, stable power supply to facilities such as the residual heat removal system pumps can be secured at station blackouts.




(6) Strengthening the environment monitoring equipments

In order to be well prepared for information gathering in case of emergencies, additional monitoring cars are deployed to allow continuous radiation dose measurements in the surrounding area of the power station.




Seawall Construction


The construction of the seawalls started in November 2011. Seawalls (15m above sea level) are being built along Unit 1-4 (Arahama side) and Unit 5-7 (Ominato side). Along with an observation deck, these constructions that surround the entire power station will prevent Tsunami from flowing into the power station site. In consideration of the ground heights, the seawalls built along Unit 1-4 are made of reinforced concrete and those built along Unit 5-7 are made of improved soil.



Seawall Construction









Progress Status of Seawall Construction





Seawalls along Unit 1-4 (Arahama side)

Foundation pile construction: Approx. 460 piles installed as of the end of May 2012 The entire seawalls construction: Approx. 30% completed as of the end of May 2012



Progress Status of Seawall Construction





Seawalls along Unit 5-7 (Ominato side)

Embankment construction using cement improved soil: Approx. 80% completed as of the end of May 2012



Outline of the Freshwater Reservoir and the Water Transfer Pipes

Freshwater Reservoir


- -Freshwater transfer from the reservoir to the tank is done based on gravity flow requiring no power, in order to allow water transfer even in the case of station blackouts.
- -The freshwater reservoir must be built on the flat ground at approx. 45m above sea level to prevent impact from Tsunami.
- -In order to secure necessary amount of freshwater even after an earthquake, a drilling operation is done on the ground and an embankment using cement improved soil is built. An impermeable liner is installed on the inner surface of the freshwater reservoir to prevent water leak in the case of an earthquake. The reservoir height is set high enough to secure necessary amount of freshwater, taking into account the overflow due to the sloshing phenomenon at the time of an earthquake.
- -The capacity of the freshwater reservoir is approx. 20,000m³ which is equivalent to the freshwater storage amount in the existing tank. With the new reservoir, the stored freshwater amount is increased twice as much.


Water Transfer Pipes

- -"Pressure-resistant/abrasion-resistant hose" with flexible structure design is used, to be able to withstand earthquakes and minimize the impact of earthquakes.
- -The water transfer line has a double structure allowing the pressure-resistant/abrasion-resistant hose inside to be protected even when the outer layer is damaged.



Freshwater Reservoir





Water transfer pipe

Freshwater reservoir

Size: 64m (Length) x 120m (Width) x 6.5m (Depth)


The maximum water depth: 4.8m

Capacity: Approx. 20,000m³ (Effective capacity:18,000m³)

Water transfer pipe

Material: Abrasion-resistant rubber (Approx. 8.5mm thick)

Inside diameter: Approx. 150mm



Freshwater reservoir (A-A Cross section)



Progress Status of Freshwater Reservoir Construction




Drilling operation




Freshwater reservoir (Full view)

Underground Gas Oil Tank

- -For backup power supply line for emergency, the permanent cable is installed between the emergency high voltage switchboard at the transformer building and the emergency high voltage switchboard of each unit.
- -Permanent cable is installed between the air-cooled gas turbine power supply car and the emergency high voltage switchboard at the transformer building. -Underground gas oil tank is installed to allow stable
- fuel supply to the air-cooled gas turbine power supply car.



Tanker



Installation of the Underground Gas Oil Tank and Air-cooled Gas Turbine Power Supply Cars




Underground gas oil tank installation completed



2 air-cooled gas turbine power supply cars have been deployed

Progress Status of Tsunami Protection Countermeasure Implementation at Kashiwazaki-Kariwa Nuclear Power Station

As of June 21, 2012



Progress Status of Tsunami Protection Countermeasure Implementation at Kashiwazaki-Kariwa Nuclear Power Station

As of June 21, 2012

	As of June 21, 201.						
Countermeasure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6	Unit 7
Seawall Construction	Under construction				Under construction		
Preventing the Buildings from Being Flooded							
(1) Seawall/Flood barrier panels installation	Completed	Under construction	Under construction	Under construction	No opening under 16m above sea level		
(2) Watertight doors at the Reactor Building, etc.	Completed	Under design	Under design	Under design	Completed	Completed	Completed
Strengthening the Heat Removal/Cooling Functions							
(1) Water source installation	Under construction						
(2) Additional deployment of air-cooled gas turbine generator trucks	Completed						
(3)-1 Installation of emergency high-voltage switchboards	Completed						
(3)-2 Installation of permanent cables in the Reactor Building	Completed	Completed	Completed	Completed	Completed	Completed	Completed
(4) Installation of alternative underwater pumps and alternative seawater heat exchanger facility	Completed	Under design	Under design	Under design	Completed	Will be deployed at the next inspection	Completed
(5) Top vent system installation at the Reactor Building	Completed	Under design	Under design	Under design	Completed	Completed	Completed
(6) Strengthening the environment monitoring equipments, additional deployment of monitoring cars	Completed						
(7) Equipments/materials storage built on high ground for emergency	Under design						
: Under design/preparation			: Under construc	tion		: Completed	

^{*}We will continue implementing necessary Tsunami protection countermeasures to further enhance the reliability of nuclear power station.