

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/1 0:00	5	23	15	14	17	37	115	97
2011/7/1 0:10	5	23	15	14	17	37	115	97
2011/7/1 0:20	5	23	15	14	17	37	115	97
2011/7/1 0:30	5	23	15	14	17	37	115	97
2011/7/1 0:40	5	23	15	14	17	37	115	97
2011/7/1 0:50	5	23	15	14	17	37	115	97
2011/7/1 1:00	5	23	15	14	17	37	115	97
2011/7/1 1:10	5	23	15	14	17	37	115	97
2011/7/1 1:20	5	23	15	14	17	37	115	97
2011/7/1 1:30	5	23	15	14	17	37	115	97
2011/7/1 1:40	5	23	15	14	17	37	115	97
2011/7/1 1:50	5	23	15	14	17	37	115	97
2011/7/1 2:00	5	23	15	14	17	37	115	97
2011/7/1 2:10	5	23	15	14	17	37	115	97
2011/7/1 2:20	5	23	15	14	17	37	115	97
2011/7/1 2:30	5	23	15	14	17	37	115	97
2011/7/1 2:40	5	23	15	14	17	37	115	97
2011/7/1 2:50	5	23	15	14	17	37	115	97
2011/7/1 3:00	5	23	15	14	17	37	115	97
2011/7/1 3:10	5	23	15	14	17	37	115	97
2011/7/1 3:20	5	23	15	14	17	37	115	97
2011/7/1 3:30	5	23	15	14	17	37	115	97
2011/7/1 3:40	5	23	15	14	17	37	115	97
2011/7/1 3:50	5	23	15	14	17	37	115	97
2011/7/1 4:00	5	23	15	14	17	37	115	97
2011/7/1 4:10	5	23	15	14	17	37	115	97
2011/7/1 4:20	5	23	15	14	17	37	115	97
2011/7/1 4:30	5	23	15	14	17	37	115	97
2011/7/1 4:40	5	23	15	14	17	37	115	97
2011/7/1 4:50	5	23	15	14	17	37	115	97
2011/7/1 5:00	5	23	15	14	17	37	115	97
2011/7/1 5:10	5	23	15	14	17	37	115	97
2011/7/1 5:20	5	23	15	14	17	37	115	97
2011/7/1 5:30	5	23	15	14	17	37	115	97
2011/7/1 5:40	5	23	15	14	17	37	115	97
2011/7/1 5:50	5	23	15	14	17	37	115	97
2011/7/1 6:00	5	23	15	14	17	37	115	97

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/1 6:10	5	23	15	14	17	37	115	97
2011/7/1 6:20	5	23	15	14	17	37	115	97
2011/7/1 6:30	5	23	15	14	17	37	115	97
2011/7/1 6:40	5	23	15	14	17	37	115	97
2011/7/1 6:50	5	23	15	14	17	37	115	97
2011/7/1 7:00	5	23	15	14	17	37	115	97
2011/7/1 7:10	5	23	15	14	17	37	115	97
2011/7/1 7:20	5	23	15	14	17	37	115	97
2011/7/1 7:30	5	23	15	14	17	37	115	97
2011/7/1 7:40	5	23	15	14	17	37	115	97
2011/7/1 7:50	5	23	15	14	17	37	115	97
2011/7/1 8:00	5	23	15	14	17	37	115	97
2011/7/1 8:10	5	23	15	14	17	37	115	97
2011/7/1 8:20	5	23	15	14	17	37	115	97
2011/7/1 8:30	5	23	15	14	17	37	115	97
2011/7/1 8:40	5	23	15	14	17	37	115	97
2011/7/1 8:50	5	23	15	14	17	37	115	97
2011/7/1 9:00	5	24	15	14	17	37	115	97
2011/7/1 9:10	5	24	15	14	17	37	115	97
2011/7/1 9:20	5	24	15	14	17	37	115	97
2011/7/1 9:30	5	24	15	14	17	37	115	96
2011/7/1 9:40	5	24	15	14	17	37	115	97
2011/7/1 9:50	5	24	15	14	17	37	115	97
2011/7/1 10:00	5	24	15	14	17	37	114	97
2011/7/1 10:10	5	24	15	14	17	37	115	97
2011/7/1 10:20	5	24	15	14	17	37	115	97
2011/7/1 10:30	5	24	15	14	17	38	115	97
2011/7/1 10:40	5	24	15	14	17	38	115	97
2011/7/1 10:50	5	24	15	14	17	38	115	97
2011/7/1 11:00	5	24	15	14	17	38	115	97
2011/7/1 11:10	5	24	15	14	17	38	115	97
2011/7/1 11:20	5	24	15	14	17	38	115	97
2011/7/1 11:30	5	24	15	14	17	38	115	97
2011/7/1 11:40	5	24	15	14	17	38	115	97
2011/7/1 11:50	5	24	15	14	17	38	115	97
2011/7/1 12:00	5	24	15	14	17	38	115	97
2011/7/1 12:10	5	24	15	14	17	38	115	97

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/1 12:20	5	24	15	14	17	38	115	97
2011/7/1 12:30	5	24	15	14	17	38	115	97
2011/7/1 12:40	5	24	15	14	17	38	115	97
2011/7/1 12:50	5	24	15	14	17	38	115	97
2011/7/1 13:00	5	24	15	14	17	38	115	97
2011/7/1 13:10	5	24	15	14	17	38	115	97
2011/7/1 13:20	5	24	15	14	17	38	116	96
2011/7/1 13:30	5	24	15	14	17	38	116	97
2011/7/1 13:40	5	24	15	14	17	37	115	97
2011/7/1 13:50	5	24	15	14	17	37	115	96
2011/7/1 14:00	5	24	15	14	17	37	115	96
2011/7/1 14:10	5	24	15	14	17	37	115	96
2011/7/1 14:20	5	24	15	14	17	37	115	96
2011/7/1 14:30	5	24	15	14	17	37	115	96
2011/7/1 14:40	5	24	15	14	17	37	115	96
2011/7/1 14:50	5	24	15	14	17	37	115	96
2011/7/1 15:00	5	24	15	14	17	37	115	97
2011/7/1 15:10	5	24	15	14	17	37	115	97
2011/7/1 15:20	5	24	15	14	17	37	115	97
2011/7/1 15:30	5	24	15	14	17	37	115	97
2011/7/1 15:40	5	24	15	14	17	37	115	97
2011/7/1 15:50	5	24	15	14	17	37	115	97
2011/7/1 16:00	5	24	15	14	17	37	115	97
2011/7/1 16:10	5	24	15	14	17	37	115	97
2011/7/1 16:20	5	24	15	14	17	37	115	97
2011/7/1 16:30	5	24	15	14	17	37	115	97
2011/7/1 16:40	5	24	15	14	17	37	115	97
2011/7/1 16:50	5	24	15	14	17	37	115	97
2011/7/1 17:00	5	24	15	14	17	37	115	97
2011/7/1 17:10	5	24	15	14	17	37	115	97
2011/7/1 17:20	5	24	15	14	17	37	115	97
2011/7/1 17:30	5	24	15	14	17	37	115	97
2011/7/1 17:40	5	24	15	14	17	37	115	97
2011/7/1 17:50	5	24	15	14	17	37	115	97
2011/7/1 18:00	5	24	15	14	17	37	115	97
2011/7/1 18:10	5	24	15	14	17	37	115	97
2011/7/1 18:20	5	24	15	14	17	37	115	97

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/1 18:30	5	24	15	14	17	37	115	97
2011/7/1 18:40	5	24	15	14	17	37	115	97
2011/7/1 18:50	5	24	15	14	17	37	115	97
2011/7/1 19:00	5	24	15	14	17	37	115	97
2011/7/1 19:10	5	24	15	14	17	37	115	97
2011/7/1 19:20	5	24	15	14	17	37	115	97
2011/7/1 19:30	5	24	15	14	17	37	115	97
2011/7/1 19:40	5	24	15	14	17	37	115	97
2011/7/1 19:50	5	24	15	14	17	37	115	97
2011/7/1 20:00	5	24	15	14	17	37	115	97
2011/7/1 20:10	5	24	15	14	17	37	115	97
2011/7/1 20:20	5	24	15	14	17	37	115	97
2011/7/1 20:30	5	24	15	14	17	37	115	97
2011/7/1 20:40	5	24	15	14	17	37	115	97
2011/7/1 20:50	5	24	15	14	17	37	115	97
2011/7/1 21:00	5	24	15	14	17	37	115	97
2011/7/1 21:10	5	24	15	14	17	37	115	97
2011/7/1 21:20	5	24	15	14	17	37	115	97
2011/7/1 21:30	5	24	15	14	17	37	115	97
2011/7/1 21:40	5	24	15	14	17	37	115	97
2011/7/1 21:50	5	24	15	14	17	37	115	97
2011/7/1 22:00	5	24	15	14	17	37	115	97
2011/7/1 22:10	5	24	15	14	17	37	115	97
2011/7/1 22:20	5	24	15	14	17	37	115	97
2011/7/1 22:30	5	24	15	14	17	37	115	97
2011/7/1 22:40	5	24	15	14	17	37	115	97
2011/7/1 22:50	5	24	15	14	17	37	115	97
2011/7/1 23:00	5	24	15	14	17	37	115	97
2011/7/1 23:10	5	24	15	14	17	37	115	97
2011/7/1 23:20	5	24	15	14	17	37	115	97
2011/7/1 23:30	5	24	15	14	17	37	115	97
2011/7/1 23:40	5	24	15	14	17	37	115	97
2011/7/1 23:50	5	24	15	14	17	37	115	97

Fixed point Monitoring Status by Temporary Monitoring Post at Fukushima Daiichi Nuclear Power Station

Date	Radiation Dose Rate (μ Sv/h) At the Main Buiding	Radiation Dose Rate (μ Sv/h) At the Main Gate	Radiation Dose Rate (μ Sv/h) At the West Gate
2011/7/1 0:00	334	35	13
2011/7/1 0:30	334	35	13
2011/7/1 1:00	334	34	13
2011/7/1 1:30	336	34	13
2011/7/1 2:00	336	35	13
2011/7/1 2:30	334	34	13
2011/7/1 3:00	336	35	13
2011/7/1 3:30	337	35	13
2011/7/1 4:00	336	35	13
2011/7/1 4:30	336	34	13
2011/7/1 5:00	337	34	13
2011/7/1 5:30	336	34	13
2011/7/1 6:00	336	34	13
2011/7/1 6:30	338	34	13
2011/7/1 7:00	338	34	13
2011/7/1 7:30	339	35	13
2011/7/1 8:00	338	35	13
2011/7/1 8:30	338	35	13
2011/7/1 9:00	339	35	13
2011/7/1 9:30	336	35	13
2011/7/1 10:00	336	35	13
2011/7/1 10:30	334	35	13
2011/7/1 11:00	333	35	13
2011/7/1 11:30	335	35	13
2011/7/1 12:00	333	35	13
2011/7/1 12:30	333	35	13
2011/7/1 13:00	333	35	13
2011/7/1 13:30	333	35	13
2011/7/1 14:00	333	35	13
2011/7/1 14:30	330	34	13
2011/7/1 15:00	332	35	13
2011/7/1 15:30	333	35	13
2011/7/1 16:00	334	35	13
2011/7/1 16:30	334	35	13
2011/7/1 17:00	332	35	13
2011/7/1 17:30	333	35	13
2011/7/1 18:00	330	34	13
2011/7/1 18:30	334	35	13
2011/7/1 19:00	332	35	13
2011/7/1 19:30	337	34	13
2011/7/1 20:00	337	35	14
2011/7/1 20:30	338	35	13
2011/7/1 21:00	336	35	13
2011/7/1 21:30	338	35	13
2011/7/1 22:00	336	35	13
2011/7/1 22:30	339	35	13
2011/7/1 23:00	337	35	13
2011/7/1 23:30	338	35	13

Monitoring data by a monitoring car* at Fukushima Daiichi Nuclear Power Station (μ Sv/h)

* The data from monitoring car may deficit as the vehicle may change monitoring point.

*The data at this point may be missed since samplings are conducted at other points during the nitrogen injection to the Unit 2 reactor containment vessel. (planned from June 28 to July 12)

Measuring Point	Measurement Date	γ Ray	Neutron Ray	Weather	Wind Direction	Wind Velocity (m/s)
Main Gate	2011/7/1 0:00	28.2	<0.01	Rain	E	1.2
Main Gate	2011/7/1 0:10	28.2	<0.01	Rain	S	1.3
Main Gate	2011/7/1 0:20	28.2	<0.01	Rain	S	0.7
Main Gate	2011/7/1 0:30	28.1	<0.01	Cloudy	W	1.0
Main Gate	2011/7/1 0:40	28.2	<0.01	Cloudy	SE	1.2
Main Gate	2011/7/1 0:50	28.2	<0.01	Cloudy	S	1.3
Main Gate	2011/7/1 1:00	28.1	<0.01	Cloudy	WNW	0.8
Main Gate	2011/7/1 1:10	28.3	<0.01	Cloudy	NW	1.5
Main Gate	2011/7/1 1:20	28.4	<0.01	Cloudy	NW	2.3
Main Gate	2011/7/1 1:30	28.3	<0.01	Cloudy	NW	2.1
Main Gate	2011/7/1 1:40	28.3	<0.01	Cloudy	NNW	1.8
Main Gate	2011/7/1 1:50	28.3	<0.01	Cloudy	N	1.5
Main Gate	2011/7/1 2:00	28.3	<0.01	Cloudy	NNE	1.3
Main Gate	2011/7/1 2:10	28.3	<0.01	Cloudy	NNW	1.2
Main Gate	2011/7/1 2:20	28.3	<0.01	Cloudy	NW	0.9
Main Gate	2011/7/1 2:30	28.2	<0.01	Cloudy	WSW	0.8
Main Gate	2011/7/1 2:40	28.3	<0.01	Cloudy	NNE	0.5
Main Gate	2011/7/1 2:50	28.3	<0.01	Cloudy	NE	0.7
Main Gate	2011/7/1 3:00	28.2	<0.01	Cloudy	NNW	0.7
Main Gate	2011/7/1 3:10	28.3	<0.01	Cloudy	N	1.0
Main Gate	2011/7/1 3:20	28.3	<0.01	Cloudy	SE	0.8
Main Gate	2011/7/1 3:30	28.2	<0.01	Cloudy	SE	1.1
Main Gate	2011/7/1 3:40	28.2	<0.01	Cloudy	NNE	1.0
Main Gate	2011/7/1 3:50	28.2	<0.01	Cloudy	N	0.8
Main Gate	2011/7/1 4:00	28.1	<0.01	Cloudy	NE	1.0
Main Gate	2011/7/1 4:10	28.3	<0.01	Cloudy	S	1.0
Main Gate	2011/7/1 4:20	28.2	<0.01	Cloudy	S	1.1
Main Gate	2011/7/1 4:30	28.2	<0.01	Cloudy	SSW	1.1
Main Gate	2011/7/1 4:40	28.1	<0.01	Cloudy	SE	0.6
Main Gate	2011/7/1 4:50	28.3	<0.01	Cloudy	SE	0.6
Main Gate	2011/7/1 5:00	28.1	<0.01	Cloudy	ESE	0.9
Main Gate	2011/7/1 5:10	28.2	<0.01	Cloudy	E	0.8
Main Gate	2011/7/1 5:20	28.3	<0.01	Cloudy	E	0.8
Main Gate	2011/7/1 5:30	28.1	<0.01	Cloudy	SE	1.2
Main Gate	2011/7/1 5:40	28.2	<0.01	Cloudy	SE	1.0
Main Gate	2011/7/1 5:50	28.1	<0.01	Cloudy	SE	1.1
Main Gate	2011/7/1 6:00	28.3	<0.01	Fine	ESE	0.6
Main Gate	2011/7/1 6:10	28.3	<0.01	Fine	ESE	1.0
Main Gate	2011/7/1 6:20	28.2	<0.01	Fine	NE	0.9
Main Gate	2011/7/1 6:30	28.3	<0.01	Fine	WNW	1.0
Main Gate	2011/7/1 6:40	28.3	<0.01	Fine	ENE	0.9
Main Gate	2011/7/1 6:50	27.9	<0.01	Fine	ENE	0.7
Main Gate	2011/7/1 7:00	28.3	<0.01	Fine	W	0.9
Main Gate	2011/7/1 7:10	28.3	<0.01	Fine	N	1.1
Main Gate	2011/7/1 7:20	28.1	<0.01	Fine	E	1.0
Main Gate	2011/7/1 7:30	28.4	<0.01	Fine	NNE	0.8
Main Gate	2011/7/1 7:40	28.4	<0.01	Fine	N	0.9
Main Gate	2011/7/1 7:50	28.3	<0.01	Fine	NNE	0.8
Main Gate	2011/7/1 8:00	28.4	<0.01	Fine	E	1.4
Main Gate	2011/7/1 8:10	28.3	<0.01	Fine	SE	1.5
Main Gate	2011/7/1 8:20	28.3	<0.01	Fine	N	1.8
Main Gate	2011/7/1 8:30	28.3	<0.01	Fine	ESE	1.2
Main Gate	2011/7/1 8:40	28.3	<0.01	Fine	E	1.5
Main Gate	2011/7/1 8:50	28.3	<0.01	Fine	ESE	1.4
Main Gate	2011/7/1 9:00	28.2	<0.01	Fine	E	1.9
Main Gate	2011/7/1 9:10	28.2	<0.01	Fine	SE	1.4
Main Gate	2011/7/1 9:20	28.3	<0.01	Fine	SE	1.2
Main Gate	2011/7/1 9:30	28.1	<0.01	Fine	E	1.0
Main Gate	2011/7/1 9:40	28.3	<0.01	Fine	ESE	1.5
Main Gate	2011/7/1 9:50	28.3	<0.01	Fine	ESE	1.3
Main Gate	2011/7/1 10:00	28.3	<0.01	Fine	S	1.6
Main Gate	2011/7/1 10:10	28.2	<0.01	Fine	SE	1.8
Main Gate	2011/7/1 10:20	28.2	<0.01	Fine	SW	1.5
Main Gate	2011/7/1 10:30	28.1	<0.01	Fine	SW	1.7
Main Gate	2011/7/1 10:40	28.2	<0.01	Fine	SE	1.2
Main Gate	2011/7/1 10:50	28.2	<0.01	Fine	SSE	2.5
Main Gate	2011/7/1 11:00	28.0	<0.01	Fine	SE	2.3
Main Gate	2011/7/1 11:10	27.8	<0.01	Fine	SE	2.3
Main Gate	2011/7/1 11:20	27.8	<0.01	Fine	SE	1.9
West Gate	2011/7/1 11:30	13.8	<0.01	Fine	E	2.1
West Gate	2011/7/1 11:40	13.7	<0.01	Fine	E	2.0

Measuring Point	Measurement Date	γ Ray	Neutron Ray	Weather	Wind Direction	Wind Velocity (m/s)
West Gate	2011/7/1 11:50	13.8	<0.01	Fine	SW	1.5
Main Gate	2011/7/1 12:00	28.0	<0.01	Fine	SSE	3.3
Main Gate	2011/7/1 12:10	28.1	<0.01	Fine	S	2.2
Main Gate	2011/7/1 12:20	28.2	<0.01	Cloudy	SSE	2.2
Main Gate	2011/7/1 12:30	28.1	<0.01	Cloudy	S	1.9
Main Gate	2011/7/1 12:40	27.8	<0.01	Fine	S	1.9
Main Gate	2011/7/1 12:50	28.3	<0.01	Fine	S	2.1
Main Gate	2011/7/1 13:00	28.1	<0.01	Fine	S	2.3
Main Gate	2011/7/1 13:10	28.4	<0.01	Cloudy	S	2.6
Main Gate	2011/7/1 13:20	28.2	<0.01	Cloudy	S	1.8
Main Gate	2011/7/1 13:30	28.7	<0.01	Rain	S	1.9
Main Gate	2011/7/1 13:40	27.9	<0.01	Rain	S	1.4
Main Gate	2011/7/1 13:50	28.2	<0.01	Rain	S	1.8
Main Gate	2011/7/1 14:00	28.3	<0.01	Cloudy	S	1.6
Main Gate	2011/7/1 14:10	28.3	<0.01	Cloudy	SSW	1.6
Main Gate	2011/7/1 14:20	28.3	<0.01	Cloudy	E	1.2
Main Gate	2011/7/1 14:30	28.0	<0.01	Fine	S	1.2
Main Gate	2011/7/1 14:40	28.3	<0.01	Fine	SSE	1.5
Main Gate	2011/7/1 14:50	28.2	<0.01	Cloudy	S	1.8
Main Gate	2011/7/1 15:00	28.1	<0.01	Fine	S	1.6
Main Gate	2011/7/1 15:10	28.4	<0.01	Fine	SE	1.8
Main Gate	2011/7/1 15:20	28.2	<0.01	Fine	SE	1.8
Main Gate	2011/7/1 15:30	28.1	<0.01	Fine	SE	1.4
Main Gate	2011/7/1 15:40	28.3	<0.01	Fine	S	1.7
Main Gate	2011/7/1 15:50	28.2	<0.01	Fine	S	1.7
Main Gate	2011/7/1 16:00	28.1	<0.01	Fine	S	2.0
Main Gate	2011/7/1 16:10	28.3	<0.01	Fine	S	2.3
Main Gate	2011/7/1 16:20	28.5	<0.01	Fine	SE	1.6
Main Gate	2011/7/1 16:30	28.0	<0.01	Fine	SE	2.0
Main Gate	2011/7/1 16:40	28.3	<0.01	Fine	S	1.8
Main Gate	2011/7/1 16:50	28.3	<0.01	Fine	SE	1.6
Main Gate	2011/7/1 17:00	28.3	<0.01	Fine	S	1.9
Main Gate	2011/7/1 17:10	28.7	<0.01	Fine	S	2.1
Main Gate	2011/7/1 17:20	28.3	<0.01	Fine	S	2.3
Main Gate	2011/7/1 17:30	28.3	<0.01	Fine	SE	2.4
Main Gate	2011/7/1 17:40	28.4	<0.01	Fine	S	2.0
Main Gate	2011/7/1 17:50	28.4	<0.01	Fine	S	2.2
Main Gate	2011/7/1 18:00	28.5	<0.01	Fine	S	2.2
Main Gate	2011/7/1 18:10	28.4	<0.01	Fine	SE	2.4
Main Gate	2011/7/1 18:20	28.5	<0.01	Fine	S	2.2
Main Gate	2011/7/1 18:30	28.5	<0.01	Fine	SSE	2.2
Main Gate	2011/7/1 18:40	28.5	<0.01	Fine	S	1.9
Main Gate	2011/7/1 18:50	28.4	<0.01	Fine	S	1.9
Main Gate	2011/7/1 19:00	28.5	<0.01	Fine	S	2.1
Main Gate	2011/7/1 19:10	28.4	<0.01	Fine	SSW	1.5
Main Gate	2011/7/1 19:20	28.5	<0.01	Fine	S	1.3
Main Gate	2011/7/1 19:30	28.5	<0.01	Fine	SSE	1.3
Main Gate	2011/7/1 19:40	28.5	<0.01	Fine	S	1.5
Main Gate	2011/7/1 19:50	28.5	<0.01	Fine	SE	1.2
Main Gate	2011/7/1 20:00	28.5	<0.01	Fine	SSE	0.8
Main Gate	2011/7/1 20:10	28.4	<0.01	Fine	SW	0.8
Main Gate	2011/7/1 20:20	28.5	<0.01	Fine	SSE	0.6
Main Gate	2011/7/1 20:30	28.4	<0.01	Fine	S	0.7
Main Gate	2011/7/1 20:40	28.5	<0.01	Fine	SSE	1.1
Main Gate	2011/7/1 20:50	28.5	<0.01	Fine	SW	1.2
Main Gate	2011/7/1 21:00	28.5	<0.01	Fine	S	0.9
Main Gate	2011/7/1 21:10	28.5	<0.01	Fine	SSW	0.7
Main Gate	2011/7/1 21:20	28.4	<0.01	Fine	S	0.9
Main Gate	2011/7/1 21:30	28.5	<0.01	Fine	SSE	1.4
Main Gate	2011/7/1 21:40	28.5	<0.01	Fine	SSE	1.1
Main Gate	2011/7/1 21:50	28.5	<0.01	Fine	SSW	1.0
Main Gate	2011/7/1 22:00	28.5	<0.01	Fine	NNE	0.9
Main Gate	2011/7/1 22:10	28.5	<0.01	Fine	S	0.6
Main Gate	2011/7/1 22:20	28.4	<0.01	Fine	W	1.1
Main Gate	2011/7/1 22:30	28.2	<0.01	Fine	SSW	0.8
Main Gate	2011/7/1 22:40	28.2	<0.01	Fine	W	0.6
Main Gate	2011/7/1 22:50	28.2	<0.01	Fine	S	0.4
Main Gate	2011/7/1 23:00	28.2	<0.01	Fine	SW	0.5
Main Gate	2011/7/1 23:10	28.2	<0.01	Fine	SW	0.4
Main Gate	2011/7/1 23:20	28.2	<0.01	Fine	SW	0.4
Main Gate	2011/7/1 23:30	28.2	<0.01	Fine	S	0.4
Main Gate	2011/7/1 23:40	28.1	<0.01	Fine	NNW	0.7
Main Gate	2011/7/1 23:50	28.2	<0.01	Fine	WNW	0.7

Fukushima Daiichi Nuclear Power Plant

2011/7/1
as of 23:50

周辺監視区域 : supervised outside area
敷地境界 : site boundary

