

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/4 0:00	5	24	15	14	17	37	115	96
2011/7/4 0:10	5	24	15	14	17	37	115	96
2011/7/4 0:20	5	24	15	14	17	37	115	96
2011/7/4 0:30	5	24	15	14	17	37	115	96
2011/7/4 0:40	5	24	15	14	17	37	115	96
2011/7/4 0:50	5	24	15	14	17	37	115	96
2011/7/4 1:00	5	24	15	14	17	37	115	96
2011/7/4 1:10	5	24	15	14	17	37	115	96
2011/7/4 1:20	5	24	15	14	17	37	115	96
2011/7/4 1:30	5	24	15	14	17	37	115	96
2011/7/4 1:40	5	24	15	14	17	37	115	96
2011/7/4 1:50	5	24	15	14	17	37	115	96
2011/7/4 2:00	5	24	15	14	17	37	115	96
2011/7/4 2:10	5	24	15	14	17	37	115	96
2011/7/4 2:20	5	24	15	14	17	37	115	96
2011/7/4 2:30	5	24	15	14	17	37	115	96
2011/7/4 2:40	5	24	15	14	17	37	115	96
2011/7/4 2:50	5	24	15	14	17	37	115	96
2011/7/4 3:00	5	24	15	14	17	37	115	96
2011/7/4 3:10	5	24	15	14	17	37	115	96
2011/7/4 3:20	5	24	15	14	17	37	115	96
2011/7/4 3:30	5	24	15	14	17	37	115	96
2011/7/4 3:40	5	24	15	14	17	37	115	96
2011/7/4 3:50	5	24	15	14	17	37	115	96
2011/7/4 4:00	5	24	15	14	17	37	115	96
2011/7/4 4:10	5	24	15	14	17	37	115	96
2011/7/4 4:20	5	24	15	14	17	37	115	96
2011/7/4 4:30	5	24	15	14	17	37	115	96
2011/7/4 4:40	5	24	15	14	17	37	115	96
2011/7/4 4:50	5	24	15	14	17	37	115	96
2011/7/4 5:00	5	24	15	14	17	37	115	96
2011/7/4 5:10	5	24	15	14	17	37	115	96
2011/7/4 5:20	5	24	15	14	17	37	115	96
2011/7/4 5:30	5	24	15	14	17	37	115	96
2011/7/4 5:40	5	24	15	14	17	37	115	96
2011/7/4 5:50	5	24	15	14	17	37	115	96
2011/7/4 6:00	5	24	15	14	17	37	115	96

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/4 6:10	5	24	15	14	17	37	115	96
2011/7/4 6:20	5	24	15	14	17	37	115	96
2011/7/4 6:30	5	24	15	14	17	37	115	96
2011/7/4 6:40	5	24	15	14	17	37	115	96
2011/7/4 6:50	5	24	15	14	17	37	115	96
2011/7/4 7:00	5	24	15	14	17	37	115	96
2011/7/4 7:10	5	24	15	14	17	37	115	96
2011/7/4 7:20	5	24	15	14	17	37	115	96
2011/7/4 7:30	5	24	15	14	17	38	115	96
2011/7/4 7:40	5	24	15	14	17	38	115	97
2011/7/4 7:50	5	24	15	14	17	38	115	97
2011/7/4 8:00	5	24	15	14	17	38	115	97
2011/7/4 8:10	5	24	15	14	17	38	115	97
2011/7/4 8:20	5	24	15	14	17	38	115	97
2011/7/4 8:30	5	24	15	14	17	38	115	97
2011/7/4 8:40	5	24	15	14	17	38	115	97
2011/7/4 8:50	5	24	15	14	17	38	115	97
2011/7/4 9:00	5	24	15	14	17	38	115	97
2011/7/4 9:10	5	24	15	14	17	38	115	97
2011/7/4 9:20	5	24	15	14	17	38	115	97
2011/7/4 9:30	5	24	15	14	17	38	115	97
2011/7/4 9:40	5	24	15	14	17	38	115	97
2011/7/4 9:50	5	24	15	14	17	38	115	97
2011/7/4 10:00	5	24	15	14	17	38	115	97
2011/7/4 10:10	5	24	15	14	17	38	115	97
2011/7/4 10:20	5	24	15	14	17	38	115	97
2011/7/4 10:30	5	24	15	14	17	38	116	97
2011/7/4 10:40	5	24	15	14	17	38	116	97
2011/7/4 10:50	5	24	15	14	17	38	116	97
2011/7/4 11:00	5	24	15	14	17	38	116	97
2011/7/4 11:10	5	24	15	14	17	38	116	97
2011/7/4 11:20	5	24	15	14	17	38	116	97
2011/7/4 11:30	5	24	15	14	17	38	116	97
2011/7/4 11:40	5	24	15	14	17	38	116	97
2011/7/4 11:50	5	24	15	14	17	38	116	97
2011/7/4 12:00	5	24	15	14	17	38	116	97
2011/7/4 12:10	5	24	15	14	17	38	116	97

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/4 12:20	5	24	15	14	17	38	116	97
2011/7/4 12:30	5	24	15	14	17	38	116	97
2011/7/4 12:40	5	24	15	14	17	38	116	97
2011/7/4 12:50	5	24	15	14	17	38	116	96
2011/7/4 13:00	5	24	15	14	17	38	116	96
2011/7/4 13:10	5	24	15	14	17	38	116	96
2011/7/4 13:20	5	24	15	14	17	38	116	96
2011/7/4 13:30	5	24	15	14	17	38	116	96
2011/7/4 13:40	5	24	15	14	17	38	116	96
2011/7/4 13:50	5	24	15	14	17	38	116	96
2011/7/4 14:00	5	24	15	14	17	38	116	96
2011/7/4 14:10	5	24	15	14	17	38	116	96
2011/7/4 14:20	5	24	15	14	17	38	116	97
2011/7/4 14:30	5	24	15	14	17	38	116	97
2011/7/4 14:40	5	24	15	14	17	38	116	97
2011/7/4 14:50	5	24	15	14	17	38	116	97
2011/7/4 15:00	5	24	15	14	17	38	116	97
2011/7/4 15:10	5	24	15	14	17	38	116	97
2011/7/4 15:20	5	24	15	14	17	38	116	97
2011/7/4 15:30	5	24	15	14	17	38	116	97
2011/7/4 15:40	5	24	15	14	17	38	116	97
2011/7/4 15:50	5	24	15	14	17	38	116	97
2011/7/4 16:00	5	24	15	14	17	38	116	97
2011/7/4 16:10	5	24	15	14	17	38	116	97
2011/7/4 16:20	5	24	15	14	17	38	116	97
2011/7/4 16:30	5	24	15	14	17	38	116	96
2011/7/4 16:40	5	24	15	14	17	38	116	97
2011/7/4 16:50	5	24	15	14	17	38	116	97
2011/7/4 17:00	5	24	15	14	17	38	116	97
2011/7/4 17:10	5	24	15	14	17	38	116	97
2011/7/4 17:20	5	24	15	14	17	38	116	97
2011/7/4 17:30	5	24	15	14	17	38	116	97
2011/7/4 17:40	5	24	15	14	17	38	116	97
2011/7/4 17:50	5	24	15	14	17	38	116	97
2011/7/4 18:00	5	24	15	14	17	38	116	97
2011/7/4 18:10	5	24	15	14	17	38	116	97
2011/7/4 18:20	5	24	15	14	17	38	116	97

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/4 18:30	5	24	15	14	17	38	116	97
2011/7/4 18:40	5	24	15	14	17	38	116	97
2011/7/4 18:50	5	24	15	14	17	38	116	97
2011/7/4 19:00	5	23	15	14	17	38	116	97
2011/7/4 19:10	5	23	15	14	17	38	116	97
2011/7/4 19:20	5	23	15	14	17	38	116	96
2011/7/4 19:30	5	23	15	14	17	37	116	96
2011/7/4 19:40	5	23	15	14	17	37	115	95
2011/7/4 19:50	5	23	15	14	17	37	115	94
2011/7/4 20:00	5	23	15	14	17	37	115	94
2011/7/4 20:10	5	23	15	14	17	37	115	94
2011/7/4 20:20	5	23	15	14	17	37	115	94
2011/7/4 20:30	5	23	15	14	17	37	115	94
2011/7/4 20:40	5	23	15	14	17	37	115	94
2011/7/4 20:50	5	23	15	14	17	37	115	94
2011/7/4 21:00	5	23	15	14	17	37	114	94
2011/7/4 21:10	5	23	15	14	17	37	114	93
2011/7/4 21:20	5	23	15	14	17	37	113	93
2011/7/4 21:30	5	23	14	14	17	36	113	92
2011/7/4 21:40	5	23	14	14	17	36	112	92
2011/7/4 21:50	5	23	15	14	17	36	113	92
2011/7/4 22:00	5	23	15	14	17	36	113	92
2011/7/4 22:10	5	23	15	14	17	36	113	92
2011/7/4 22:20	5	23	15	14	17	36	112	92
2011/7/4 22:30	5	23	15	14	17	36	112	92
2011/7/4 22:40	5	23	15	14	17	36	112	93
2011/7/4 22:50	5	23	15	14	17	37	112	93
2011/7/4 23:00	5	23	15	14	17	37	113	94
2011/7/4 23:10	5	23	15	14	17	37	113	94
2011/7/4 23:20	5	23	15	14	17	37	113	94
2011/7/4 23:30	5	23	15	14	17	37	113	94
2011/7/4 23:40	5	23	15	14	17	37	113	94
2011/7/4 23:50	5	23	15	14	17	37	113	94

Fixed point Monitoring Status by Temporary Monitoring Post at Fukushima Daiichi Nuclear Power Station

Date	Radiation Dose Rate (μ Sv/h) At the Main Buiding	Radiation Dose Rate (μ Sv/h) At the Main Gate	Radiation Dose Rate (μ Sv/h) At the West Gate
2011/7/4 0:00	341	35	13
2011/7/4 0:30	342	35	13
2011/7/4 1:00	340	35	13
2011/7/4 1:30	338	35	13
2011/7/4 2:00	340	35	13
2011/7/4 2:30	340	35	13
2011/7/4 3:00	341	35	13
2011/7/4 3:30	339	35	13
2011/7/4 4:00	341	35	13
2011/7/4 4:30	338	35	13
2011/7/4 5:00	340	35	13
2011/7/4 5:30	340	35	13
2011/7/4 6:00	340	35	14
2011/7/4 6:30	339	35	13
2011/7/4 7:00	340	35	13
2011/7/4 7:30	339	35	14
2011/7/4 8:00	340	35	13
2011/7/4 8:30	338	35	13
2011/7/4 9:00	337	35	13
2011/7/4 9:30	338	35	13
2011/7/4 10:00	337	35	13
2011/7/4 10:30	335	35	13
2011/7/4 11:00	338	35	13
2011/7/4 11:30	336	35	13
2011/7/4 12:00	338	35	13
2011/7/4 12:30	338	35	13
2011/7/4 13:00	338	35	13
2011/7/4 13:30	336	35	13
2011/7/4 14:00	336	35	13
2011/7/4 14:30	334	35	13
2011/7/4 15:00	333	35	13
2011/7/4 15:30	331	35	13
2011/7/4 16:00	333	35	13
2011/7/4 16:30	332	35	13
2011/7/4 17:00	329	35	13
2011/7/4 17:30	328	35	13
2011/7/4 18:00	326	35	13
2011/7/4 18:30	329	35	13
2011/7/4 19:00	325	34	13
2011/7/4 19:30	322	34	13
2011/7/4 20:00	323	33	13
2011/7/4 20:30	325	33	13
2011/7/4 21:00	321	33	13
2011/7/4 21:30	325	32	12
2011/7/4 22:00	326	33	13
2011/7/4 22:30	327	33	13
2011/7/4 23:00	329	33	13
2011/7/4 23:30	329	33	13

Monitoring data by a monitoring car* at Fukushima Daiichi Nuclear Power Station (μ Sv/h)

* The data from monitoring car may deficit as the vehicle may change monitoring point.

Measuring Point	Measurement Date	γ Ray	Neutron Ray	Weather	Wind Direction	Wind Velocity (m/s)	
Main Gate	2011/7/4 0:00	28.2	<0.01	Cloudy	WNW	1.3	
Main Gate	2011/7/4 0:10	28.1	<0.01	Cloudy	S	1.1	
Main Gate	2011/7/4 0:20	28.2	<0.01	Cloudy	SE	1.2	
Main Gate	2011/7/4 0:30	28.3	<0.01	Cloudy	S	1.1	
Main Gate	2011/7/4 0:40	28.2	<0.01	Cloudy	S	1.4	
Main Gate	2011/7/4 0:50	28.2	<0.01	Cloudy	S	1.3	
Main Gate	2011/7/4 1:00	28.2	<0.01	Cloudy	SSE	1.1	
Main Gate	2011/7/4 1:10	28.1	<0.01	Cloudy	S	1.0	
Main Gate	2011/7/4 1:20	28.2	<0.01	Cloudy	SSE	0.8	
Main Gate	2011/7/4 1:30	28.2	<0.01	Cloudy	SSE	0.6	
Main Gate	2011/7/4 1:40	28.3	<0.01	Cloudy	SE	1.7	
Main Gate	2011/7/4 1:50	28.2	<0.01	Cloudy	SSE	1.2	
Main Gate	2011/7/4 2:00	28.1	<0.01	Cloudy	SE	1.1	
Main Gate	2011/7/4 2:10	28.2	<0.01	Cloudy	S	1.1	
Main Gate	2011/7/4 2:20	28.3	<0.01	Cloudy	SE	1.0	
Main Gate	2011/7/4 2:30	28.0	<0.01	Cloudy	S	1.0	
Main Gate	2011/7/4 2:40	28.1	<0.01	Cloudy	SE	0.7	
Main Gate	2011/7/4 2:50	28.1	<0.01	Cloudy	SE	1.6	
Main Gate	2011/7/4 3:00	28.3	<0.01	Cloudy	S	1.6	
Main Gate	2011/7/4 3:10	28.2	<0.01	Cloudy	SE	1.4	
Main Gate	2011/7/4 3:20	28.5	<0.01	Cloudy	S	1.1	
Main Gate	2011/7/4 3:30	28.5	<0.01	Cloudy	S	0.9	
Main Gate	2011/7/4 3:40	28.4	<0.01	Cloudy	S	0.6	
Main Gate	2011/7/4 3:50	28.4	<0.01	Cloudy	S	1.2	
Main Gate	2011/7/4 4:00	28.5	<0.01	Cloudy	SSE	0.9	
Main Gate	2011/7/4 4:10	28.4	<0.01	Cloudy	SSE	1.4	
Main Gate	2011/7/4 4:20	28.3	<0.01	Cloudy	SE	1.4	
Main Gate	2011/7/4 4:30	28.4	<0.01	Cloudy	S	0.8	
Main Gate	2011/7/4 4:40	28.5	<0.01	Cloudy	SE	0.9	
Main Gate	2011/7/4 4:50	28.5	<0.01	Cloudy	SE	1.1	
Main Gate	2011/7/4 5:00	28.5	<0.01	Cloudy	SSE	1.1	
Main Gate	2011/7/4 5:10	28.2	<0.01	Cloudy	SSE	1.2	
Main Gate	2011/7/4 5:20	28.2	<0.01	Cloudy	SE	0.8	
Main Gate	2011/7/4 5:30	28.1	<0.01	Cloudy	SE	1.3	
Main Gate	2011/7/4 5:40	28.3	<0.01	Cloudy	SSE	1.3	
Main Gate	2011/7/4 5:50	28.2	<0.01	Cloudy	SE	1.3	
Main Gate	2011/7/4 6:00	28.4	<0.01	Cloudy	SSE	1.3	
Main Gate	2011/7/4 6:10	28.2	<0.01	Cloudy	SE	1.3	
Main Gate	2011/7/4 6:20	28.3	<0.01	Cloudy	SE	1.6	
Main Gate	2011/7/4 6:30	28.4	<0.01	Cloudy	SE	1.5	
Main Gate	2011/7/4 6:40	28.3	<0.01	Cloudy	SSW	1.4	
Main Gate	2011/7/4 6:50	28.3	<0.01	Cloudy	SSE	1.6	
Main Gate	2011/7/4 7:00	28.3	<0.01	Cloudy	SSE	1.4	
Main Gate	2011/7/4 7:10	28.2	<0.01	Cloudy	SSE	1.7	
Main Gate	2011/7/4 7:20	28.3	<0.01	Cloudy	S	2.1	
Main Gate	2011/7/4 7:30	28.2	<0.01	Cloudy	SSE	1.9	
Main Gate	2011/7/4 7:40	28.3	<0.01	Cloudy	SE	1.7	
Main Gate	2011/7/4 7:50	28.3	<0.01	Cloudy	S	2.2	
Main Gate	2011/7/4 8:00	28.3	<0.01	Cloudy	S	2.3	
Main Gate	2011/7/4 8:10	28.3	<0.01	Cloudy	SSE	2.0	
Main Gate	2011/7/4 8:20	28.4	<0.01	Cloudy	S	2.2	
Main Gate	2011/7/4 8:30	28.4	<0.01	Cloudy	S	1.7	
Main Gate	2011/7/4 8:40	28.4	<0.01	Cloudy	SSE	1.8	
Main Gate	2011/7/4 8:50	28.4	<0.01	Cloudy	SSE	2.7	
Main Gate	2011/7/4 9:00	28.2	<0.01	Cloudy	S	2.9	
Main Gate	2011/7/4 9:10	28.2	<0.01	Cloudy	S	2.3	
Main Gate	2011/7/4 9:20	28.3	<0.01	Cloudy	S	2.5	
-	2011/7/4 9:30	The data at this point was missed since samplings were conducted at other points during the nitrogen injection to the Unit 2 reactor containment vessel.					
-	2011/7/4 9:40						
-	2011/7/4 9:50						
West Gate	2011/7/4 10:00	13.9	<0.01	Cloudy	E	2.5	
West Gate	2011/7/4 10:10	13.9	<0.01	Cloudy	E	1.4	
West Gate	2011/7/4 10:20	13.3	<0.01	Cloudy	E	1.5	
West Gate	2011/7/4 10:30	13.9	<0.01	Cloudy	E	1.1	
West Gate	2011/7/4 10:40	13.9	<0.01	Cloudy	ENE	1.1	
West Gate	2011/7/4 10:50	13.9	<0.01	Cloudy	ENE	0.5	
West Gate	2011/7/4 11:00	14.0	<0.01	Cloudy	ESE	0.8	
West Gate	2011/7/4 11:10	14.0	<0.01	Cloudy	SW	1.0	
West Gate	2011/7/4 11:20	14.1	<0.01	Cloudy	S	1.3	
West Gate	2011/7/4 11:30	14.1	<0.01	Cloudy	SW	0.9	
West Gate	2011/7/4 11:40	14.0	<0.01	Cloudy	W	1.2	

Measuring Point	Measurement Date	γ Ray	Neutron Ray	Weather	Wind Direction	Wind Velocity (m/s)
West Gate	2011/7/4 11:50	14.0	<0.01	Cloudy	SW	1.4
West Gate	2011/7/4 12:00	14.1	<0.01	Cloudy	W	1.6
West Gate	2011/7/4 12:10	14.1	<0.01	Fine	W	1.4
West Gate	2011/7/4 12:20	14.1	<0.01	Fine	E	1.2
West Gate	2011/7/4 12:30	14.0	<0.01	Fine	N	1.0
West Gate	2011/7/4 12:40	14.1	<0.01	Fine	NW	1.2
West Gate	2011/7/4 12:50	14.1	<0.01	Fine	W	1.9
West Gate	2011/7/4 13:00	14.2	<0.01	Fine	WSW	1.6
West Gate	2011/7/4 13:10	14.1	<0.01	Cloudy	WNW	1.3
West Gate	2011/7/4 13:20	14.1	<0.01	Cloudy	SW	0.8
West Gate	2011/7/4 13:30	14.1	<0.01	Cloudy	NNE	1.2
West Gate	2011/7/4 13:40	14.1	<0.01	Cloudy	WNW	1.2
West Gate	2011/7/4 13:50	14.1	<0.01	Cloudy	SW	1.4
West Gate	2011/7/4 14:00	14.2	<0.01	Cloudy	NW	0.9
West Gate	2011/7/4 14:10	14.2	<0.01	Cloudy	W	1.0
West Gate	2011/7/4 14:20	14.3	<0.01	Cloudy	WNW	1.1
West Gate	2011/7/4 14:30	14.2	<0.01	Fine	SW	0.9
West Gate	2011/7/4 14:40	14.3	<0.01	Fine	S	0.6
West Gate	2011/7/4 14:50	14.1	<0.01	Fine	E	0.6
West Gate	2011/7/4 15:00	14.1	<0.01	Fine	E	1.5
West Gate	2011/7/4 15:10	14.2	<0.01	Fine	E	1.7
West Gate	2011/7/4 15:20	14.3	<0.01	Fine	E	1.9
West Gate	2011/7/4 15:30	14.3	<0.01	Fine	E	1.2
West Gate	2011/7/4 15:40	14.3	<0.01	Fine	ENE	1.0
West Gate	2011/7/4 15:50	14.2	<0.01	Fine	SE	1.1
West Gate	2011/7/4 16:00	14.2	<0.01	Fine	E	1.3
West Gate	2011/7/4 16:10	14.3	<0.01	Fine	E	1.2
West Gate	2011/7/4 16:20	14.3	<0.01	Fine	ENE	1.1
West Gate	2011/7/4 16:30	14.3	<0.01	Fine	SE	1.0
West Gate	2011/7/4 16:40	14.2	<0.01	Fine	E	1.6
West Gate	2011/7/4 16:50	14.3	<0.01	Fine	ESE	1.7
West Gate	2011/7/4 17:00	14.2	<0.01	Fine	ESE	1.7
West Gate	2011/7/4 17:10	14.2	<0.01	Fine	E	1.2
West Gate	2011/7/4 17:20	14.3	<0.01	Fine	E	1.0
West Gate	2011/7/4 17:30	14.2	<0.01	Fine	E	0.7
West Gate	2011/7/4 17:40	14.2	<0.01	Fine	ESE	1.3
West Gate	2011/7/4 17:50	14.2	<0.01	Fine	SE	0.8
West Gate	2011/7/4 18:00	14.2	<0.01	Fine	E	0.9
West Gate	2011/7/4 18:10	14.2	<0.01	Fine	SE	0.3
West Gate	2011/7/4 18:20	14.2	<0.01	Fine	SW	0.5
West Gate	2011/7/4 18:30	14.2	<0.01	Fine	W	0.6
West Gate	2011/7/4 18:40	14.2	<0.01	Fine	W	0.7
West Gate	2011/7/4 18:50	14.0	<0.01	Rain	N	2.9
West Gate	2011/7/4 19:00	14.1	<0.01	Rain	W	1.4
West Gate	2011/7/4 19:10	14.0	<0.01	Rain	WNW	0.9
West Gate	2011/7/4 19:20	14.1	<0.01	Rain	NE	0.7
West Gate	2011/7/4 19:30	14.1	<0.01	Cloudy	W	0.9
West Gate	2011/7/4 19:40	14.0	<0.01	Rain	NW	0.7
West Gate	2011/7/4 19:50	13.9	<0.01	Rain	NNW	0.7
West Gate	2011/7/4 20:00	13.9	<0.01	Rain	N	0.8
West Gate	2011/7/4 20:10	13.9	<0.01	Rain	NW	1.0
West Gate	2011/7/4 20:20	14.0	<0.01	Rain	N	0.7
West Gate	2011/7/4 20:30	13.9	<0.01	Rain	NW	0.4
West Gate	2011/7/4 20:40	13.9	<0.01	Rain	N	0.4
West Gate	2011/7/4 20:50	13.9	<0.01	Rain	E	0.3
West Gate	2011/7/4 21:00	13.9	<0.01	Rain	E	0.7
West Gate	2011/7/4 21:10	13.9	<0.01	Rain	NNE	0.8
West Gate	2011/7/4 21:20	13.9	<0.01	Rain	E	0.6
West Gate	2011/7/4 21:30	13.8	<0.01	Rain	W	0.4
West Gate	2011/7/4 21:40	13.8	<0.01	Rain	NW	0.5
West Gate	2011/7/4 21:50	13.9	<0.01	Rain	SW	0.3
West Gate	2011/7/4 22:00	13.8	<0.01	Rain	E	0.6
West Gate	2011/7/4 22:10	13.8	<0.01	Rain	NNE	0.5
West Gate	2011/7/4 22:20	13.8	<0.01	Rain	N	0.5
West Gate	2011/7/4 22:30	13.9	<0.01	Rain	E	0.5
West Gate	2011/7/4 22:40	13.8	<0.01	Cloudy	E	0.6
West Gate	2011/7/4 22:50	13.8	<0.01	Cloudy	ESE	1.2
West Gate	2011/7/4 23:00	13.8	<0.01	Cloudy	ENE	0.8
West Gate	2011/7/4 23:10	13.8	<0.01	Cloudy	NE	0.6
West Gate	2011/7/4 23:20	13.8	<0.01	Cloudy	ENE	0.4
West Gate	2011/7/4 23:30	13.9	<0.01	Cloudy	NE	0.4
West Gate	2011/7/4 23:40	13.9	<0.01	Cloudy	E	0.6
West Gate	2011/7/4 23:50	13.8	<0.01	Cloudy	NE	2.0

Fukushima Daiichi Nuclear Power Plant

2011/7/4
as of 23:50

周辺監視区域 : supervised outside area
敷地境界 : site boundary

