

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/11 19:30 | | | | | | | | | | | |
| 3/11 19:37 | | | | | | | | | | | |
| 3/11 20:00 | | | | | | | | | | | |
| 3/11 20:07 | | | 6.900 | | | | | | | | |
| 3/11 20:30 | | | | | | | | | | | |
| 3/11 21:00 | | | | | | | | | | | |
| 3/11 21:30 | 450 | | | | | | | | | | |
| 3/11 22:00 | 550 | | | | | | | | | | |
| 3/11 22:10 | 550 | | | | | | | | | | |
| 3/11 22:20 | 590 | | | | | | | | | | |
| 3/11 22:30 | | | | | | | | | | | |
| 3/11 22:35 | 590 | | | | | | | | | | |
| 3/11 22:47 | 590 | | | | | | | | | | |
| 3/11 23:05 | 590 | | | | | | | | | | |
| 3/11 23:24 | 590 | | | | | | | | | | |
| 3/11 23:30 | | | | | | | | | | | |
| 3/12 0:30 | 1300 | | | | | | | | | | |
| 3/12 0:45 | 1300 | | | | | | | | | | |
| 3/12 1:00 | 1300 | | | | | | | | | | |
| 3/12 1:05 | | | | | 0.600 | | | | | | |
| 3/12 1:25 | 1300 | | | | | | | | | | |
| 3/12 1:40 | 1300 | | | | | | | | | | |
| 3/12 1:55 | 1300 | 530 | | | | | | | | | |
| 3/12 2:10 | 1300 | 500 | | | | | | | | | |
| 3/12 2:30 | 1300 | 500 | | | 0.840 | | | | | | |
| 3/12 2:45 | | | 0.800 | | 0.840 | | | | | | |
| 3/12 2:50 | | 500 | | | | | | | | | |
| 3/12 3:05 | 1300 | 500 | | | | | | | | | |
| 3/12 3:30 | 1300 | | | | | | | | | | |
| 3/12 3:55 | 1300 | 500 | | | | | | | | | |
| 3/12 4:19 | 1300 | 500 | | | 0.780 | 0.790 | | | | | |
| 3/12 4:35 | 1300 | 500 | | | 0.770 | 0.770 | | | | | |
| 3/12 4:55 | 1300 | 500 | | | | | | | | | |
| 3/12 5:20 | 1300 | 500 | | | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/12 5:30 | 1300 | 500 | | | | | | | | | |
| 3/12 5:55 | 1300 | 500 | | | | | | | | | |
| 3/12 6:00 | 1300 | 500 | | | 0.740 | | | | | | |
| 3/12 6:05 | | | | | 0.740 | | | | | | |
| 3/12 6:30 | 1300 | 550 | | | 0.790 | 0.780 | | | | | |
| 3/12 6:47 | 1200 | 400 | | | 0.770 | 0.770 | | | | | |
| 3/12 7:00 | 900 | 300 | | | | | | | | | |
| 3/12 7:01 | | | | | 0.760 | 0.760 | | | | | |
| 3/12 7:15 | 700 | 250 | | | | | | | | | |
| 3/12 7:17 | | | | | 0.760 | 0.760 | | | | | |
| 3/12 7:30 | 100 | 200 | | | 0.760 | 0.760 | | | | | |
| 3/12 7:40 | | | | | 0.755 | | | | | | |
| 3/12 7:55 | 50 | -100 | | | 0.755 | 0.755 | | | | | |
| 3/12 8:03 | 50 | -100 | | | 0.755 | 0.755 | | | | | |
| 3/12 8:10 | 0 | -200 | | | | | | | | | |
| 3/12 8:15 | | | | | 0.750 | 0.750 | | | | | |
| 3/12 8:20 | -50 | -300 | | | | | | | | | |
| 3/12 8:22 | 0 | -300 | | | | | | | | | |
| 3/12 8:23 | | | | | 0.750 | 0.750 | | | | | |
| 3/12 8:30 | 0 | -400 | | | | | | | | | |
| 3/12 8:36 | | | | | 0.750 | | | | | | |
| 3/12 8:39 | -50 | -500 | | | | | | | | | |
| 3/12 8:49 | -300 | -550 | | | 0.740 | 0.740 | | | | | |
| 3/12 8:56 | -375 | -600 | | | | | | | | | |
| 3/12 9:00 | -500 | -650 | | | | | | | | | |
| 3/12 9:02 | | | | | 0.740 | 0.740 | | | | | |
| 3/12 9:10 | -425 | -650 | | | | | | | | | |
| 3/12 9:20 | -425 | -700 | | | 0.740 | 0.740 | | | | | |
| 3/12 9:25 | -450 | -700 | | | 0.740 | 0.740 | | | | | |
| 3/12 9:45 | -450 | -700 | | | 0.740 | 0.740 | | | | | |
| 3/12 9:52 | -500 | -700 | | | 0.740 | 0.740 | | | | | |
| 3/12 10:04 | -500 | -700 | | | | | | | | | |
| 3/12 10:19 | | | | | 0.750 | | | | | | |
| 3/12 10:20 | | | | | 0.750 | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/12 10:27 | | | | | 0.750 | | | | | | |
| 3/12 10:33 | -500 | -700 | | | | | | | | | |
| 3/12 10:38 | -550 | -700 | | | 0.740 | 0.740 | | | | | |
| 3/12 10:47 | -550 | -700 | | | 0.740 | 0.740 | | | | | |
| 3/12 10:52 | -600 | -750 | | | 0.750 | 0.750 | | | | | |
| 3/12 11:00 | -700 | -800 | | | 0.750 | 0.750 | | | | | |
| 3/12 11:10 | -800 | -800 | | | | | | | | | |
| 3/12 11:20 | -900 | -800 | | | 0.750 | 0.750 | | | | | |
| 3/12 11:30 | -1100 | -900 | | | 0.750 | 0.750 | | | | | |
| 3/12 11:41 | -1250 | -1000 | | | 0.750 | 0.750 | | | | | |
| 3/12 11:52 | -1350 | -1100 | | | 0.750 | 0.740 | | | | | |
| 3/12 12:05 | -1500 | -1400 | | | 0.750 | 0.740 | | | | | |
| 3/12 12:12 | -1550 | -1450 | | | 0.750 | 0.740 | | | | | |
| 3/12 12:35 | -1700 | -1450 | | | 0.750 | 0.750 | | | | | |
| 3/12 12:45 | -1700 | -1450 | | | 0.750 | 0.745 | | | | | |
| 3/12 12:55 | -1700 | -1500 | | | 0.750 | 0.745 | | | | | |
| 3/12 13:05 | -1700 | -1500 | | | 0.750 | 0.745 | | | | | |
| 3/12 13:14 | -1700 | -1550 | | | 0.750 | 0.745 | | | | | |
| 3/12 13:26 | -1700 | -1550 | | | 0.755 | 0.745 | | | | | |
| 3/12 13:38 | -1700 | -1550 | | | 0.755 | 0.745 | | | | | |
| 3/12 13:48 | -1700 | -1650 | | | 0.755 | 0.745 | | | | | |
| 3/12 13:52 | -1700 | -1650 | | | 0.755 | 0.744 | | | | | |
| 3/12 13:58 | -1700 | -1650 | | | 0.755 | 0.744 | | | | | |
| 3/12 14:05 | -1700 | -1650 | | | 0.735 | 0.735 | | | | | |
| 3/12 14:10 | -1700 | -1650 | | | 0.730 | 0.730 | | | | | |
| 3/12 14:18 | -1700 | -1600 | | | 0.725 | 0.725 | | | | | |
| 3/12 14:20 | -1700 | -1600 | | | 0.710 | 0.710 | | | | | |
| 3/12 14:25 | -1700 | -1600 | | | 0.690 | 0.690 | | | | | |
| 3/12 14:30 | -1700 | -1600 | | | 0.670 | | | | | | |
| 3/12 14:35 | -1700 | -1600 | | | 0.640 | 0.640 | | | | | |
| 3/12 14:40 | -1700 | -1650 | | | 0.620 | 0.620 | | | | | |
| 3/12 14:41 | -1700 | -1650 | | | 0.610 | 0.610 | | | | | |
| 3/12 14:50 | -1700 | -1600 | | | 0.580 | 0.580 | | | | | |
| 3/12 14:52 | -1700 | -1650 | | | 0.570 | 0.570 | | | | | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/12 14:54 | -1700 | -1650 | | | 0.565 | 0.565 | | | | | |
| 3/12 14:56 | -1700 | -1650 | | | 0.555 | 0.555 | | | | | |
| 3/12 14:58 | -1700 | -1650 | | | 0.550 | 0.550 | | | | | |
| 3/12 15:00 | | | | | 0.540 | 0.540 | | | | | |
| 3/12 15:02 | | | | | 0.535 | 0.535 | | | | | |
| 3/12 15:04 | -1700 | -1650 | | | 0.530 | 0.530 | | | | | |
| 3/12 15:06 | -1700 | -1650 | | | 0.525 | 0.525 | | | | | |
| 3/12 15:08 | -1700 | -1650 | | | 0.525 | 0.525 | | | | | |
| 3/12 15:10 | -1700 | -1650 | | | 0.520 | 0.515 | | | | | |
| 3/12 15:12 | -1700 | -1650 | | | 0.520 | 0.515 | | | | | |
| 3/12 15:14 | -1700 | -1650 | | | 0.525 | 0.520 | | | | | |
| 3/12 15:18 | -1700 | -1650 | | | 0.525 | 0.520 | | | | | |
| 3/12 15:20 | -1700 | -1650 | | | 0.530 | 0.520 | | | | | |
| 3/12 15:22 | -1700 | -1650 | | | 0.535 | 0.520 | | | | | |
| 3/12 15:26 | -1700 | -1650 | | | 0.535 | 0.520 | | | | | |
| 3/12 15:28 | -1700 | -1650 | | | 0.540 | 0.525 | | | | | |
| 3/12 15:30 | -1700 | -1650 | | | 0.540 | 0.525 | | | | | |
| 3/12 15:35 | -1700 | -1650 | | | 0.540 | 0.525 | | | | | |
| 3/12 15:37 | -1700 | -1650 | | | | | | | | | |
| 3/12 16:10 | -1700 | -1650 | | | | | | | | | |
| 3/12 16:31 | -1700 | -1650 | | | | | | | | | |
| 3/12 16:45 | -1700 | -1700 | | | | | | | | | |
| 3/12 17:00 | -1700 | -1700 | | | | | | | | | |
| 3/12 17:30 | -1700 | -1700 | | | | | | | | | |
| 3/12 18:00 | -1700 | -1700 | | | | | | | | | |
| 3/12 20:08 | | -1700 | | 0.370 | | | | | | | |
| 3/12 20:20 | | | | 0.367 | | | | | | | |
| 3/12 20:30 | | -1600 | | 0.367 | | | | | | | |
| 3/12 21:00 | | -1750 | | 0.360 | | | | | | | |
| 3/12 21:30 | | -1700 | | 0.355 | | | | | | | |
| 3/12 22:00 | | -1700 | | 0.355 | | | | | | | |
| 3/12 22:20 | | -1700 | | 0.353 | | | | | | | |
| 3/12 23:00 | | -1750 | | 0.358 | | | | | | | |
| 3/12 23:30 | | -1750 | | 0.368 | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/13 0:00 | | -1750 | | 0.368 | | | | | | | |
| 3/13 0:30 | | -1750 | | 0.378 | | | | | | | |
| 3/13 1:00 | | -1700 | | 0.375 | | | | | | | |
| 3/13 2:00 | | -1700 | | 0.375 | | | | | | | |
| 3/13 3:00 | | -1700 | | 0.373 | | | | | | | |
| 3/13 4:00 | | -1700 | | 0.248 | | | | | | | |
| 3/13 5:00 | | -1700 | 0.389 | | | | | | | | |
| 3/13 5:30 | | -1700 | 0.389 | | | | | | | | |
| 3/13 6:00 | | -1700 | 0.389 | | | | | | | | |
| 3/13 6:30 | | -1700 | 0.389 | | | | | | | | |
| 3/13 7:00 | | -1700 | 0.394 | | | | | | | | |
| 3/13 7:30 | | -1700 | 0.392 | | | | | | | | |
| 3/13 8:00 | | -1700 | 0.392 | | | | | | | | |
| 3/13 8:20 | | -1700 | 0.396 | | | | | | | | |
| 3/13 8:55 | | -1700 | 0.398 | | | | | | | | |
| 3/13 9:25 | | -1700 | 0.392 | | | | | | | | |
| 3/13 9:55 | | -1700 | 0.392 | | | | | | | | |
| 3/13 10:35 | | -1750 | 0.402 | | | | | | | | |
| 3/13 10:55 | | -1700 | 0.398 | | | | | | | | |
| 3/13 11:25 | | -1700 | 0.404 | | | | | | | | |
| 3/13 11:55 | | -1700 | 0.405 | | | | | | | | |
| 3/13 12:20 | | -1700 | 0.405 | | | | | | | | |
| 3/13 12:40 | | -1700 | 0.405 | | | | | | | | |
| 3/13 13:00 | | -1700 | 0.408 | | | | | | | | |
| 3/13 13:37 | | | | | 0.595 | 0.590 | | | | | |
| 3/13 14:00 | | | | | 0.595 | 0.590 | | | | | |
| 3/13 14:10 | | -1700 | 0.413 | | | | | | | | |
| 3/13 14:30 | | -1700 | | 0.415 | 0.600 | 0.600 | | | | | |
| 3/13 14:45 | | -1700 | | 0.415 | 0.600 | 0.600 | | | | | |
| 3/13 15:00 | | -1700 | 0.415 | | 0.600 | 0.600 | | | | | |
| 3/13 15:15 | | -1700 | | 0.418 | 0.605 | 0.600 | | | | | |
| 3/13 15:30 | | -1700 | | 0.418 | 0.605 | 0.600 | | | | | |
| 3/13 15:45 | | -1700 | | 0.420 | 0.605 | 0.600 | | | | | |
| 3/13 16:00 | | -1700 | 0.420 | | 0.605 | 0.600 | | | | | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/13 16:15 | | -1700 | 0.420 | | 0.605 | 0.600 | | | | | |
| 3/13 16:30 | | -1700 | 0.420 | | 0.605 | 0.600 | | | | | |
| 3/13 16:45 | | -1700 | 0.422 | | 0.605 | 0.600 | | | | | |
| 3/13 17:00 | | -1700 | 0.423 | | 0.605 | 0.600 | | | | | |
| 3/13 17:15 | | -1700 | 0.418 | | 0.605 | 0.600 | | | | | |
| 3/13 17:30 | | -1700 | 0.415 | | 0.600 | 0.600 | | | | | |
| 3/13 18:00 | | -1700 | 0.415 | | 0.600 | 0.600 | | | | | |
| 3/13 18:20 | | -1700 | 0.408 | | 0.590 | 0.590 | | | | | |
| 3/13 18:40 | | -1700 | 0.403 | | 0.590 | 0.585 | | | | | |
| 3/13 19:00 | | -1750 | 0.398 | | 0.580 | 0.580 | | | | | |
| 3/13 19:30 | | -1750 | 0.393 | | 0.575 | 0.570 | | | | | |
| 3/13 19:45 | | -1750 | 0.388 | | 0.570 | 0.570 | | | | | |
| 3/13 20:00 | | -1750 | 0.388 | | 0.570 | 0.565 | | | | | |
| 3/13 20:15 | | -1750 | 0.382 | | 0.560 | 0.560 | | | | | |
| 3/13 20:30 | | -1750 | 0.383 | | 0.560 | 0.560 | | | | | |
| 3/13 20:45 | | -1750 | 0.378 | | 0.550 | 0.550 | | | | | |
| 3/13 21:00 | | -1750 | 0.382 | | 0.550 | 0.550 | | | | | |
| 3/13 21:15 | | -1750 | 0.380 | | 0.550 | 0.550 | | | | | |
| 3/13 21:30 | | -1750 | 0.380 | | 0.550 | 0.550 | | | | | |
| 3/13 21:45 | | -1700 | | | 0.550 | 0.550 | | | | | |
| 3/13 22:00 | | -1700 | | | 0.540 | 0.540 | | | | | |
| 3/13 22:15 | | -1750 | 0.370 | | 0.540 | 0.540 | | | | | |
| 3/13 22:30 | | -1750 | 0.030 | 0.368 | 0.540 | 0.540 | | | | | |
| 3/13 22:45 | | -1750 | 0.028 | 0.365 | 0.540 | 0.530 | | | | | |
| 3/13 23:00 | | -1750 | 0.062 | 0.366 | 0.540 | 0.530 | | | | | |
| 3/13 23:15 | | -1750 | 0.068 | 0.360 | 0.530 | 0.530 | | | | | |
| 3/13 23:30 | | -1750 | 0.056 | 0.360 | 0.530 | 0.530 | | | | | |
| 3/14 0:00 | | -1700 | 0.156 | 0.356 | 0.520 | 0.520 | | | | | |
| 3/14 0:15 | | -1700 | 0.072 | 0.356 | 0.520 | 0.520 | | | | | |
| 3/14 0:30 | | -1700 | 0.070 | 0.356 | 0.520 | 0.520 | | | | | |
| 3/14 0:45 | | -1700 | 0.106 | 0.356 | 0.520 | 0.520 | | | | | |
| 3/14 1:00 | | -1700 | 0.056 | 0.350 | 0.515 | 0.510 | | | | | |
| 3/14 1:15 | | -1700 | 0.150 | 0.350 | | | | | | | |
| 3/14 1:30 | | -1750 | 0.050 | 0.350 | 0.515 | 0.510 | | | | | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/14 1:45 | | -1750 | 0.040 | 0.350 | 0.515 | 0.505 | | | | | |
| 3/14 2:00 | | -1700 | 0.040 | 0.350 | 0.510 | 0.505 | | | | | |
| 3/14 2:15 | | -1700 | 0.040 | 0.346 | 0.510 | 0.505 | | | | | |
| 3/14 2:30 | | -1700 | 0.036 | 0.342 | 0.505 | 0.500 | | | | | |
| 3/14 2:45 | | -1700 | 0.032 | 0.340 | 0.505 | 0.500 | | | | | |
| 3/14 3:00 | | -1700 | 0.032 | 0.340 | 0.505 | 0.500 | | | | | |
| 3/14 3:15 | | -1700 | 0.032 | 0.340 | 0.500 | 0.500 | | | | | |
| 3/14 3:30 | | -1700 | 0.032 | 0.340 | 0.500 | 0.495 | | | | | |
| 3/14 3:45 | | -1700 | 0.032 | 0.338 | 0.500 | 0.495 | | | | | |
| 3/14 4:00 | | -1700 | 0.032 | 0.338 | 0.495 | 0.490 | | | | | |
| 3/14 4:15 | | -1700 | 0.030 | 0.328 | 0.495 | 0.490 | | | | | |
| 3/14 4:30 | | -1700 | 0.030 | 0.328 | 0.495 | 0.490 | | | | | |
| 3/14 4:45 | | -1700 | 0.038 | 0.332 | 0.490 | 0.485 | | | | | |
| 3/14 5:00 | -1700 | -1700 | 0.030 | 0.326 | 0.485 | 0.480 | | | | | |
| 3/14 5:15 | -1700 | -1700 | 0.030 | 0.326 | 0.485 | 0.480 | | | | | |
| 3/14 5:30 | -1750 | -1750 | 0.030 | 0.326 | 0.480 | 0.480 | | | | | |
| 3/14 5:45 | -1750 | -1750 | 0.030 | 0.323 | 0.480 | 0.475 | | | | | |
| 3/14 6:00 | -1750 | -1750 | 0.030 | 0.326 | 0.480 | 0.475 | 1.64E+02 | | 2.66E+01 | | |
| 3/14 6:15 | -1750 | -1750 | 0.030 | 0.318 | 0.480 | 0.475 | | | | | |
| 3/14 6:30 | -1750 | -1750 | 0.036 | 0.320 | 0.475 | 0.470 | 1.62E+02 | | 2.66E+01 | | |
| 3/14 6:45 | -1750 | -1750 | 0.030 | 0.316 | 0.475 | 0.470 | | | | | |
| 3/14 7:00 | -1750 | -1750 | 0.036 | 0.318 | 0.470 | 0.467 | 1.61E+02 | | 2.65E+01 | | |
| 3/14 7:15 | -1750 | -1750 | 0.038 | 0.318 | 0.465 | 0.460 | | | | | |
| 3/14 7:30 | -1750 | -1750 | 0.038 | 0.316 | 0.465 | 0.460 | 1.60E+02 | | 2.65E+01 | | |
| 3/14 7:45 | | | | | | | 1.60E+02 | | 2.65E+01 | | |
| 3/14 8:00 | -1750 | -1750 | 0.038 | 0.316 | 0.460 | 0.455 | 1.60E+02 | | 2.65E+01 | | |
| 3/14 8:15 | | | | | | | 1.57E+02 | | 2.65E+01 | | |
| 3/14 8:30 | -1800 | -1750 | 0.038 | 0.312 | 0.460 | 0.455 | 1.52E+02 | | 2.65E+01 | | |
| 3/14 8:45 | -1800 | -1750 | | | | | 1.49E+02 | | 2.65E+01 | | |
| 3/14 9:00 | -1800 | -1750 | 0.036 | 0.306 | 0.450 | 0.445 | 1.45E+02 | | 2.65E+01 | | |
| 3/14 9:35 | -1800 | -1750 | 0.040 | 0.306 | 0.450 | 0.445 | 1.41E+02 | | 2.65E+01 | | |
| 3/14 9:45 | -1800 | -1750 | 0.040 | 0.306 | 0.450 | 0.445 | 1.40E+02 | | 2.65E+01 | | |
| 3/14 10:00 | -1800 | -1750 | 0.042 | 0.310 | 0.445 | 0.440 | 1.39E+02 | | 2.65E+01 | | |
| 3/14 10:15 | -1800 | -1750 | | | | | 1.37E+02 | | 2.65E+01 | | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/14 10:30 | -1800 | -1750 | 0.038 | 0.306 | 0.440 | 0.435 | 1.35E+02 | | 2.65E+01 | | |
| 3/14 10:45 | -1800 | -1750 | | | | | 1.33E+02 | | 2.65E+01 | | |
| 3/14 11:00 | | | 0.038 | 0.306 | | | | | | | |
| 3/14 12:00 | -1800 | -1750 | 0.040 | 0.306 | | | 1.23E+02 | | 2.64E+01 | | |
| 3/14 12:30 | -1800 | -1750 | 0.040 | 0.306 | | | 1.18E+02 | | 2.64E+01 | | |
| 3/14 14:45 | -1800 | -1750 | 0.046 | 0.300 | | | 9.80E+01 | | 2.62E+01 | | |
| 3/14 15:00 | -1800 | -1750 | 0.046 | 0.298 | | | 9.48E+01 | | 2.62E+01 | | |
| 3/14 15:30 | -1750 | -1750 | 0.048 | 0.300 | | | 9.17E+01 | | 2.62E+01 | | |
| 3/14 16:00 | -1750 | -1750 | 0.052 | 0.300 | | | 8.97E+01 | | 2.62E+01 | | |
| 3/14 19:15 | -1750 | -1750 | 0.062 | 0.272 | | | 7.88E+01 | | 2.59E+01 | | |
| 3/14 21:00 | -1750 | -1750 | 0.060 | 0.270 | | | 6.56E+01 | | 2.57E+01 | | |
| 3/14 22:00 | -1700 | -1700 | 0.057 | 0.260 | | | 6.10E+01 | | 2.56E+01 | | |
| 3/15 2:30 | -1700 | -1700 | | | | | | | | | |
| 3/15 3:00 | -1700 | -1700 | 0.068 | 0.248 | | | 5.73E+01 | | 2.46E+01 | | |
| 3/15 4:00 | -1750 | -1750 | 0.068 | 0.240 | | | 6.27E+01 | | 2.47E+01 | | |
| 3/15 5:00 | -1750 | | 0.066 | 0.240 | | | 7.74E+01 | | 2.47E+01 | | |
| 3/15 11:25 | -1700 | -1700 | 0.078 | 0.206 | | | 8.70E+01 | | 2.42E+01 | | |
| 3/15 11:42 | -1700 | -1700 | 0.080 | 0.206 | | | 8.58E+01 | | 2.41E+01 | | |
| 3/15 11:58 | -1700 | -1700 | 0.079 | 0.202 | | | 8.44E+01 | | 2.41E+01 | | |
| 3/15 13:00 | -1700 | -1700 | 0.076 | 0.206 | | | 8.19E+01 | | 2.41E+01 | | |
| 3/15 15:25 | -1800 | -1750 | 0.082 | 0.195 | | | 1.04E+02 | | 2.37E+01 | | |
| 3/15 16:10 | -1800 | -1750 | 0.090 | 0.200 | | | 9.75E+01 | | 2.36E+01 | | |
| 3/15 18:43 | -1800 | -1800 | 0.188 | | | | 6.89E+01 | | 2.33E+01 | | |
| 3/16 1:24 | -1750 | -1750 | 0.180 | 0.096 | | | 3.84E+01 | | 2.31E+01 | | |
| 3/16 1:44 | -1750 | | 0.092 | 0.176 | | | 3.50E+01 | | 2.36E+01 | | |
| 3/16 1:54 | -1750 | -1750 | 0.092 | 0.176 | | | 3.44E+01 | | 2.33E+01 | | |
| 3/16 5:00 | -1800 | -1750 | 0.096 | 0.178 | | | 7.92E+00 | | 2.42E+01 | | |
| 3/16 5:15 | -1800 | -1750 | 0.098 | 0.180 | | | 4.15E+00 | | 2.42E+01 | | |
| 3/16 5:35 | -1800 | -1750 | 0.100 | 0.180 | | | 9.81E+01 | | 3.64E+01 | | |
| 3/16 6:55 | -1800 | -1750 | 0.186 | 0.186 | | | | | | | |
| 3/16 12:35 | -1750 | -1750 | 0.230 | 0.190 | | | | | | | |
| 3/16 15:30 | -1750 | -1750 | 0.232 | 0.188 | | | | 1.85E+01 | | 2.20E+01 | |
| 3/16 20:00 | -1800 | -1800 | 0.228 | 0.188 | | | | 3.70E-03 | | 2.27E+01 | |
| 3/16 20:20 | -1800 | -1800 | 0.228 | 0.188 | | | | 3.70E-03 | | 2.27E+01 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/16 23:50 | -1800 | -1750 | 0.238 | 0.188 | | | | 3.05E-03 | | 2.29E+01 | |
| 3/17 3:10 | -1750 | -1750 | 0.220 | 0.172 | | | | 3.09E-03 | | 2.40E+01 | |
| 3/17 6:00 | -1750 | -1750 | 0.206 | 0.168 | | | | 3.15E-03 | | 1.38E+01 | |
| 3/17 11:00 | -1800 | -1800 | 0.192 | 0.160 | | | | 3.60E-03 | | 2.38E+01 | |
| 3/17 11:15 | -1800 | -1800 | 0.192 | 0.160 | | | | 2.70E-03 | | 3.08E+01 | |
| 3/17 11:30 | -1800 | -1800 | 0.192 | 0.160 | | | | 4.10E-03 | | 3.15E+01 | |
| 3/17 12:50 | -1700 | -1750 | 0.206 | 0.160 | | | | 4.10E-03 | | 3.16E+01 | |
| 3/17 21:40 | -1700 | | 0.192 | 0.168 | | | | 3.23E-03 | | 4.82E+01 | |
| 3/17 21:50 | -1700 | | 0.192 | 0.168 | | | | 4.15E-03 | | 4.81E+01 | |
| 3/18 2:20 | -1700 | | 0.186 | 0.158 | | | | 2.65E-03 | | 4.78E+01 | |
| 3/18 2:50 | -1700 | | 0.182 | 0.158 | | | | 3.80E-03 | | 4.77E+01 | |
| 3/18 7:40 | -1700 | | 0.190 | 0.162 | | | | 3.50E-03 | | 4.70E+01 | |
| 3/18 7:55 | -1700 | | 0.188 | 0.162 | | | | 3.75E-03 | | 4.69E+01 | |
| 3/18 9:40 | -1750 | -1700 | 0.192 | 0.160 | | | | 2.75E-03 | | 4.67E+01 | |
| 3/18 16:00 | -1700 | -1800 | 0.212 | 0.170 | 0.180 | 0.160 | | 3.56E-03 | | 4.60E+01 | |
| 3/18 20:55 | -1750 | -1800 | 0.212 | 0.162 | 0.180 | 0.160 | | 2.97E-03 | | 4.54E+01 | |
| 3/18 21:10 | -1750 | -1800 | 0.216 | 0.168 | 0.180 | 0.160 | | 4.00E-03 | | 4.53E+01 | |
| 3/19 2:40 | -1700 | -1700 | 0.228 | 0.172 | 0.180 | 0.165 | | 3.55E-03 | | 4.46E+01 | |
| 3/19 3:30 | -1750 | -1750 | 0.228 | 0.172 | 0.180 | 0.165 | | 2.63E-03 | | 1.45E+01 | |
| 3/19 7:10 | -1700 | -1700 | 0.222 | 0.170 | 0.180 | 0.170 | | 2.33E-03 | | 4.40E+01 | |
| 3/19 11:00 | -1800 | -1700 | 0.218 | 0.168 | 0.180 | 0.170 | | 2.32E-03 | | 4.35E+01 | |
| 3/19 16:30 | -1750 | -1750 | 0.228 | 0.178 | 0.180 | 0.170 | | 3.67E+01 | | 4.29E+01 | |
| 3/19 16:45 | -1750 | -1750 | 0.228 | 0.178 | 0.180 | 0.170 | | 3.60E+01 | | 4.28E+01 | |
| 3/19 16:50 | -1750 | -1750 | 0.228 | 0.178 | 0.180 | 0.170 | | 3.60E+01 | | 4.28E+01 | |
| 3/19 19:00 | -1750 | -1700 | 0.232 | 0.180 | 0.170 | 0.165 | | 3.35E+01 | | 4.26E+01 | |
| 3/19 22:30 | -1750 | -1750 | 0.228 | 0.182 | 0.180 | 0.170 | | 2.49E+01 | | 4.21E+01 | |
| 3/20 0:00 | -1750 | -1750 | 0.228 | 0.186 | 0.180 | 0.170 | | 1.89E+01 | | 4.19E+01 | |
| 3/20 4:50 | -1750 | -1750 | 0.226 | 0.180 | 0.180 | 0.170 | | 1.20E+01 | | 4.13E+01 | |
| 3/20 5:00 | -1750 | -1750 | 0.226 | 0.180 | 0.180 | 0.170 | | 1.11E+01 | | 4.12E+01 | |
| 3/20 10:00 | -1750 | -1750 | 0.226 | 0.182 | 0.170 | 0.160 | 3.83E+00 | | | 4.07E+01 | |
| 3/20 11:00 | -1750 | -1750 | 0.216 | 0.178 | 0.170 | 0.160 | | 2.76E+01 | | 4.05E+01 | |
| 3/20 15:00 | -1700 | -1750 | 0.208 | 0.176 | 0.170 | 0.160 | | 1.20E+01 | | 4.00E+01 | |
| 3/20 22:00 | -1750 | -1800 | 0.216 | 0.178 | 0.160 | 0.160 | | 4.80E+01 | | 3.91E+01 | |
| 3/21 3:00 | -1750 | -1800 | 0.216 | 0.176 | 0.160 | 0.160 | | 4.66E+01 | | 3.85E+01 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/21 8:00 | -1750 | -1750 | 0.218 | 0.182 | 0.160 | 0.160 | | 4.71E+01 | | 3.79E+01 | |
| 3/21 13:30 | -1750 | -1750 | 0.218 | 0.188 | 0.160 | 0.155 | | 4.75E+01 | | 3.74E+01 | |
| 3/21 14:00 | -1750 | -1750 | 0.220 | 0.190 | 0.160 | 0.155 | | 4.76E+01 | | 3.73E+01 | |
| 3/21 14:25 | -1750 | -1750 | 0.220 | 0.190 | 0.160 | 0.155 | | 4.76E+01 | | 3.73E+01 | |
| 3/22 0:15 | -1750 | -1700 | 0.218 | 0.190 | 0.160 | 0.155 | | 4.77E+01 | | 3.62E+01 | |
| 3/22 5:00 | -1750 | -1700 | 0.232 | 0.200 | 0.160 | 0.155 | | 4.80E+01 | | 3.56E+01 | |
| 3/22 6:00 | -1750 | -1700 | 0.218 | 0.186 | 0.160 | 0.155 | | 4.80E+01 | | 3.55E+01 | |
| 3/22 10:30 | -1800 | -1750 | 0.250 | 0.228 | 0.175 | 0.155 | | 4.79E+01 | | 3.49E+01 | |
| 3/22 11:20 | -1800 | -1750 | 0.252 | 0.228 | 0.175 | 0.155 | | 4.78E+01 | | 3.49E+01 | |
| 3/22 15:30 | -1800 | -1750 | 0.240 | 0.188 | 0.180 | 0.160 | | 4.65E+01 | | 3.40E+01 | |
| 3/22 17:00 | -1800 | -1750 | 0.242 | 0.212 | 0.180 | 0.160 | | 4.68E+01 | | 3.40E+01 | |
| 3/22 18:00 | -1750 | -1750 | 0.242 | 0.212 | 0.180 | 0.160 | | 4.64E+01 | | 3.40E+01 | |
| 3/22 23:00 | -1750 | -1750 | 0.246 | 0.218 | 0.185 | 0.160 | | 4.71E+01 | | 3.36E+01 | |
| 3/23 4:00 | -1750 | -1750 | 0.336 | 0.300 | 0.260 | 0.240 | | 4.60E+01 | | 3.16E+01 | |
| 3/23 9:00 | -1750 | -1750 | 0.376 | 0.342 | 0.305 | 0.285 | | 4.88E+01 | | 3.06E+01 | |
| 3/23 9:30 | -1750 | -1750 | 0.412 | 0.368 | 0.310 | 0.290 | | | | | |
| 3/23 10:00 | -1750 | -1750 | 0.388 | 0.358 | 0.320 | 0.295 | | | | | |
| 3/23 10:30 | -1750 | -1750 | 0.390 | 0.358 | 0.320 | 0.295 | | | | | |
| 3/23 11:00 | -1750 | -1750 | 0.396 | 0.360 | 0.325 | 0.300 | | | | | |
| 3/23 11:30 | -1750 | -1750 | 0.400 | 0.366 | 0.320 | 0.300 | | | | | |
| 3/23 12:00 | -1750 | -1750 | 0.396 | 0.356 | 0.320 | 0.300 | | | | | |
| 3/23 12:30 | -1750 | -1750 | 0.392 | 0.362 | 0.325 | 0.305 | | | | | |
| 3/23 13:00 | -1750 | -1750 | 0.400 | 0.366 | 0.330 | 0.305 | | | | | |
| 3/23 13:30 | -1750 | -1700 | 0.400 | 0.370 | 0.330 | 0.310 | | | | | |
| 3/23 14:00 | -1700 | -1700 | 0.418 | 0.398 | 0.345 | 0.320 | | 4.80E+01 | | 2.98E+01 | |
| 3/23 14:20 | -1700 | -1700 | 0.390 | 0.430 | 0.340 | 0.320 | | 4.80E+01 | | 2.99E+01 | |
| 3/23 14:30 | -1700 | -1700 | 0.428 | 0.390 | 0.340 | 0.320 | | | | | |
| 3/23 15:00 | -1700 | -1700 | 0.416 | 0.380 | 0.345 | 0.325 | | | | | |
| 3/23 15:30 | -1700 | -1700 | 0.416 | 0.378 | 0.345 | 0.330 | | | | | |
| 3/23 16:00 | -1750 | -1700 | 0.422 | 0.398 | 0.360 | 0.330 | | | | | |
| 3/23 18:09 | -1740 | -1670 | 0.483 | | 0.347 | 0.339 | | | | | |
| 3/23 19:32 | -1740 | -1680 | 0.490 | | 0.360 | 0.346 | | | | | |
| 3/23 20:21 | -1740 | -1660 | 0.492 | | 0.354 | 0.347 | | | | | |
| 3/23 21:00 | -1700 | -1650 | 0.440 | 0.416 | 0.375 | 0.355 | | 3.12E+01 | | 2.88E+01 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/23 23:00 | -1750 | -1750 | 0.466 | 0.440 | 0.380 | 0.365 | | | | | |
| 3/24 1:00 | -1700 | -1700 | 0.456 | 0.430 | 0.385 | 0.370 | | 4.39E+01 | | 2.79E+01 | |
| 3/24 5:00 | -1700 | -1700 | 0.472 | 0.446 | 0.400 | 0.390 | | 4.37E+01 | | 2.71E+01 | |
| 3/24 7:00 | -1700 | -1700 | 0.480 | 0.450 | 0.400 | 0.390 | | 4.37E+01 | | 2.71E+01 | |
| 3/24 9:00 | -1700 | -1700 | 0.496 | 0.466 | 0.400 | 0.400 | | 4.41E+01 | | 2.67E+01 | |
| 3/24 11:00 | -1700 | -1700 | 0.480 | 0.446 | 0.400 | 0.395 | | 4.35E+01 | | 2.63E+01 | |
| 3/24 13:00 | -1700 | -1650 | 0.470 | 0.430 | 0.390 | 0.382 | | 4.24E+01 | | 2.61E+01 | |
| 3/24 17:00 | -1650 | -1650 | 0.488 | 0.408 | 0.355 | 0.355 | | 4.09E+01 | | 2.58E+01 | |
| 3/24 20:00 | -1700 | -1650 | 0.430 | 0.402 | 0.345 | 0.340 | | 4.05E+01 | | 2.56E+01 | |
| 3/24 21:45 | -1700 | -1650 | 0.420 | 0.388 | 0.330 | 0.325 | | 4.13E+01 | | 2.55E+01 | |
| 3/24 22:00 | -1700 | -1650 | 0.422 | 0.388 | 0.325 | 0.325 | | 4.16E+01 | | 2.55E+01 | |
| 3/25 0:00 | -1700 | -1650 | 0.416 | 0.388 | 0.325 | 0.320 | | 4.16E+01 | | 2.54E+01 | |
| 3/25 2:00 | -1700 | -1650 | 0.418 | 0.398 | 0.325 | 0.315 | | 4.11E+01 | | 2.54E+01 | |
| 3/25 6:00 | -1700 | -1650 | 0.406 | 0.390 | 0.310 | 0.305 | | 4.00E+01 | | 2.51E+01 | |
| 3/25 10:00 | -1650 | -1650 | 0.388 | 0.388 | 0.295 | 0.290 | | 3.89E+01 | | 2.49E+01 | |
| 3/25 14:00 | -1650 | -1600 | 0.380 | 0.388 | 0.280 | 0.280 | | 3.78E+01 | | 2.47E+01 | |
| 3/25 15:45 | -1650 | -1600 | 0.376 | 0.382 | 0.275 | 0.275 | | 3.78E+01 | | 2.47E+01 | |
| 3/25 16:00 | -1650 | -1600 | 0.378 | 0.382 | 0.275 | 0.275 | | 3.72E+01 | | 2.46E+01 | |
| 3/25 16:30 | -1650 | -1600 | 0.380 | 0.380 | 0.275 | 0.275 | | 3.71E+01 | | 2.45E+01 | |
| 3/25 18:30 | -1650 | -1600 | 0.376 | 0.376 | 0.275 | 0.275 | | 3.67E+01 | | 2.44E+01 | |
| 3/25 23:00 | -1650 | -1600 | 0.388 | 0.392 | 0.275 | 0.275 | | 3.60E+01 | | 2.42E+01 | |
| 3/26 5:00 | -1650 | -1600 | 0.392 | 0.400 | 0.270 | 0.270 | | 3.53E+01 | | 2.38E+01 | |
| 3/26 9:30 | -1650 | -1600 | 0.418 | 0.400 | 0.270 | 0.270 | | 3.51E+01 | | 2.36E+01 | |
| 3/26 11:30 | -1650 | -1600 | 0.418 | 0.392 | 0.275 | 0.275 | | 3.57E+01 | | 2.35E+01 | |
| 3/26 12:00 | -1650 | -1600 | 0.396 | 0.420 | 0.275 | 0.275 | | 3.57E+01 | | 2.35E+01 | |
| 3/26 13:00 | -1650 | -1600 | 0.390 | 0.422 | 0.275 | 0.275 | | 3.54E+01 | | 2.34E+01 | |
| 3/26 17:30 | -1650 | -1650 | 0.388 | 0.416 | 0.275 | 0.275 | | 3.63E+01 | | 2.31E+01 | |
| 3/26 21:00 | -1650 | -1650 | 0.406 | 0.432 | 0.270 | 0.270 | | 3.47E+01 | | 2.29E+01 | |
| 3/27 1:00 | -1650 | -1650 | 0.406 | 0.440 | 0.265 | 0.265 | | 3.41E+01 | | 2.27E+01 | |
| 3/27 5:00 | -1650 | -1600 | 0.412 | 0.452 | 0.270 | 0.270 | | 3.40E+01 | | 2.25E+01 | |
| 3/27 9:00 | -1650 | -1600 | 0.416 | 0.462 | 0.270 | 0.270 | | 3.46E+01 | | 2.22E+01 | |
| 3/27 15:30 | -1650 | -1650 | 0.412 | 0.476 | 0.270 | 0.270 | | 3.36E+01 | | 2.19E+01 | |
| 3/27 16:20 | -1650 | -1650 | 0.410 | 0.482 | 0.265 | 0.270 | | 3.36E+01 | | 2.18E+01 | |
| 3/27 22:00 | -1650 | -1650 | 0.412 | 0.492 | 0.265 | 0.270 | | 3.36E+01 | | 2.16E+01 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/28 0:00 | -1650 | -1600 | 0.416 | 0.490 | 0.270 | 0.270 | | 3.36E+01 | | 2.15E+01 | |
| 3/28 3:00 | -1700 | -1650 | 0.418 | 0.492 | 0.270 | 0.270 | | 3.38E+01 | | 2.13E+01 | |
| 3/28 7:00 | -1700 | -1650 | 0.420 | 0.506 | 0.270 | 0.270 | | 3.37E+01 | | 2.11E+01 | |
| 3/28 12:30 | -1700 | -1650 | 0.418 | 0.502 | 0.270 | 0.270 | | 3.39E+01 | | 2.08E+01 | |
| 3/28 17:30 | -1650 | -1650 | 0.422 | 0.528 | 0.280 | 0.280 | | 3.39E+01 | | 2.06E+01 | |
| 3/28 21:00 | -1700 | -1700 | 0.430 | 0.530 | 0.290 | 0.290 | | 3.40E+01 | | 2.04E+01 | |
| 3/28 21:20 | -1700 | -1700 | 0.428 | 0.536 | 0.290 | 0.290 | | 3.39E+01 | | 2.04E+01 | |
| 3/28 21:40 | -1700 | -1700 | 0.424 | 0.536 | 0.290 | 0.290 | | | | | |
| 3/28 22:00 | -1700 | -1700 | 0.432 | 0.539 | 0.290 | 0.290 | | 3.40E+01 | | 2.03E+01 | |
| 3/28 22:20 | -1700 | -1700 | 0.432 | 0.536 | 0.290 | 0.290 | | | | | |
| 3/29 1:00 | -1500 | -1650 | 0.438 | 0.556 | 0.290 | 0.290 | | 3.38E+01 | | 2.02E+01 | |
| 3/29 4:00 | -1600 | -1600 | 0.436 | 0.558 | 0.285 | 0.285 | | 3.60E+01 | | 2.00E+01 | |
| 3/29 7:00 | -1650 | -1700 | 0.430 | 0.552 | 0.275 | 0.275 | | 3.77E+01 | | 1.99E+01 | |
| 3/29 8:30 | -1650 | -1650 | 0.430 | 0.552 | 0.275 | | | | | | |
| 3/29 8:35 | -1650 | -1650 | 0.430 | 0.552 | 0.275 | | | | | | |
| 3/29 8:45 | -1650 | -1650 | 0.426 | 0.550 | 0.275 | 0.275 | | 4.01E+01 | | 1.98E+01 | |
| 3/29 9:10 | -1650 | -1650 | 0.428 | 0.550 | 0.275 | 0.275 | | 3.37E+01 | | 1.98E+01 | |
| 3/29 9:40 | -1650 | -1650 | 0.426 | 0.546 | 0.275 | 0.275 | | 3.94E+01 | | 1.98E+01 | |
| 3/29 13:00 | -1650 | -1600 | 0.412 | 0.546 | 0.265 | 0.265 | | 3.38E+01 | | 1.97E+01 | |
| 3/29 16:00 | -1650 | -1600 | 0.408 | 0.546 | 0.265 | 0.265 | | 3.36E+01 | | 1.96E+01 | |
| 3/29 19:00 | -1650 | -1650 | 0.398 | 0.536 | 0.250 | 0.250 | | 3.48E+01 | | 1.94E+01 | |
| 3/29 22:00 | -1650 | -1650 | 0.392 | 0.536 | 0.245 | 0.250 | | 3.94E+01 | | 1.93E+01 | |
| 3/30 1:00 | -1600 | -1600 | 0.400 | 0.546 | 0.240 | 0.240 | | 3.97E+01 | | 1.92E+01 | |
| 3/30 4:00 | -1600 | -1600 | 0.392 | 0.542 | 0.235 | 0.235 | | 3.32E+01 | | 1.91E+01 | |
| 3/30 7:00 | -1600 | -1600 | 0.380 | 0.538 | 0.235 | 0.235 | | 3.71E+01 | | 1.90E+01 | |
| 3/30 10:00 | -1600 | -1600 | 0.376 | 0.536 | 0.230 | 0.230 | | 4.06E+01 | | 1.89E+01 | |
| 3/30 13:00 | -1600 | -1600 | 0.378 | 0.546 | 0.230 | 0.230 | | 3.77E+01 | | 1.82E+01 | |
| 3/30 16:00 | -1600 | -1600 | 0.366 | 0.538 | 0.230 | 0.230 | | 4.00E+01 | | 1.85E+01 | |
| 3/30 18:00 | -1600 | -1600 | 0.366 | 0.538 | 0.225 | 0.225 | | 4.07E+01 | | 1.85E+01 | |
| 3/30 20:00 | -1600 | -1600 | 0.362 | 0.548 | 0.220 | 0.220 | | 4.01E+01 | | 1.85E+01 | |
| 3/30 22:00 | -1650 | -1650 | 0.372 | 0.562 | 0.220 | 0.220 | | 4.00E+01 | | 1.84E+01 | |
| 3/31 0:00 | -1600 | -1600 | 0.362 | 0.552 | 0.220 | 0.220 | | 4.12E+01 | | 1.83E+01 | |
| 3/31 2:00 | -1600 | -1600 | 0.362 | 0.552 | 0.210 | 0.210 | | 4.23E+01 | | 1.83E+01 | |
| 3/31 4:00 | -1650 | -1650 | 0.370 | 0.568 | 0.210 | 0.210 | | 4.17E+01 | | 1.82E+01 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 3/31 6:00 | -1650 | -1650 | 0.368 | 0.568 | 0.210 | 0.210 | | 3.82E+01 | | 1.81E+01 | |
| 3/31 8:00 | -1650 | -1650 | 0.366 | 0.550 | 0.210 | 0.210 | | 3.42E+01 | | 1.80E+01 | |
| 3/31 10:00 | -1600 | -1600 | 0.358 | 0.566 | 0.210 | 0.210 | | 4.23E+01 | | 1.80E+01 | |
| 3/31 12:00 | -1600 | -1650 | 0.366 | 0.562 | 0.210 | 0.205 | | 4.12E+01 | | 1.72E+01 | |
| 3/31 13:00 | -1600 | -1550 | 0.356 | 0.552 | 0.205 | 0.205 | | 4.12E+01 | | 1.72E+01 | |
| 3/31 14:00 | -1600 | -1550 | 0.352 | 0.552 | 0.205 | 0.205 | | 3.44E+01 | | 1.76E+01 | |
| 3/31 16:00 | -1600 | -1550 | 0.350 | 0.552 | 0.190 | 0.190 | | 4.35E+01 | | 1.77E+01 | |
| 3/31 18:00 | -1600 | -1600 | 0.340 | 0.548 | 0.180 | 0.180 | | 4.10E+01 | | 1.77E+01 | |
| 3/31 20:00 | -1650 | -1650 | 0.336 | 0.538 | 0.180 | 0.180 | | 4.25E+01 | | 1.76E+01 | |
| 3/31 22:00 | -1650 | -1650 | 0.340 | 0.546 | 0.180 | 0.180 | | 4.29E+01 | | 1.76E+01 | |
| 4/1 0:00 | -1650 | -1650 | 0.326 | 0.536 | 0.175 | 0.175 | | 4.39E+01 | | 1.75E+01 | |
| 4/1 2:00 | -1600 | -1600 | 0.328 | 0.546 | 0.175 | 0.175 | | 3.87E+01 | | 1.75E+01 | |
| 4/1 4:00 | -1650 | -1600 | 0.336 | 0.558 | 0.170 | 0.175 | | 4.24E+01 | | 1.74E+01 | |
| 4/1 6:00 | -1600 | -1600 | 0.326 | 0.550 | 0.170 | 0.170 | | 4.43E+01 | | 1.74E+01 | |
| 4/1 8:00 | -1650 | -1650 | 0.322 | 0.552 | 0.165 | 0.170 | | 4.25E+01 | | 1.73E+01 | |
| 4/1 10:00 | -1650 | -1650 | 0.328 | 0.552 | 0.165 | 0.165 | | 4.30E+01 | | 1.72E+01 | |
| 4/1 12:00 | -1650 | -1600 | 0.320 | 0.550 | 0.165 | 0.165 | | 4.09E+01 | | 1.72E+01 | |
| 4/1 16:00 | -1600 | -1600 | 0.326 | 0.550 | 0.160 | 0.160 | | 4.42E+01 | | 1.69E+01 | |
| 4/1 16:30 | -1600 | -1600 | 0.326 | 0.564 | 0.160 | 0.160 | | 4.30E+01 | | 1.70E+01 | |
| 4/1 17:00 | -1600 | -1600 | 0.326 | 0.560 | 0.160 | 0.160 | | 4.38E+01 | | 1.70E+01 | |
| 4/1 20:00 | -1600 | -1600 | 0.316 | 0.556 | 0.160 | 0.160 | | 4.29E+01 | | 1.69E+01 | |
| 4/2 0:30 | -1600 | -1600 | 0.310 | 0.566 | 0.160 | 0.160 | | 4.10E+01 | | 1.67E+01 | |
| 4/2 4:00 | -1600 | -1600 | 0.320 | 0.578 | 0.160 | 0.160 | | 4.55E+01 | | 1.65E+01 | |
| 4/2 8:00 | -1650 | -1600 | 0.326 | 0.582 | 0.160 | 0.160 | | 4.42E+01 | | 1.62E+01 | |
| 4/2 12:00 | -1650 | -1650 | 0.322 | 0.590 | 0.155 | 0.155 | | 4.51E+01 | | 1.60E+01 | |
| 4/2 16:30 | -1650 | -1650 | 0.316 | 0.598 | 0.155 | 0.155 | | 3.63E+01 | | 1.57E+01 | |
| 4/2 20:00 | -1650 | -1650 | 0.326 | 0.598 | 0.155 | 0.155 | | 3.38E+01 | | 1.55E+01 | |
| 4/2 20:37 | -1650 | -1650 | 0.328 | 0.598 | 0.155 | 0.155 | | | | | |
| 4/2 20:47 | -1650 | -1650 | 0.328 | 0.600 | 0.155 | 0.160 | | | | | |
| 4/2 21:07 | -1650 | -1650 | 0.326 | 0.598 | 0.155 | 0.160 | | 3.19E+01 | | 1.56E+01 | |
| 4/2 23:00 | -1650 | -1650 | 0.322 | 0.590 | 0.155 | 0.160 | | 3.75E+01 | | 1.55E+01 | |
| 4/3 3:00 | -1650 | -1650 | 0.322 | 0.602 | 0.155 | 0.160 | | 3.18E+01 | | 1.53E+01 | |
| 4/3 7:00 | -1650 | -1600 | 0.328 | 0.608 | 0.155 | 0.160 | | 4.74E+01 | | 1.50E+01 | |
| 4/3 9:00 | -1650 | -1650 | 0.326 | 0.608 | 0.155 | 0.155 | | 4.46E+01 | | 1.49E+01 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|-----------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 4/3 10:52 | -1650 | -1650 | 0.330 | 0.612 | 0.155 | 0.155 | | | | | |
| 4/3 11:02 | | | 0.330 | 0.618 | 0.155 | 0.155 | | | | | |
| 4/3 11:07 | -1650 | -1650 | 0.328 | 0.616 | 0.155 | 0.155 | | | | | |
| 4/3 11:12 | -1650 | -1650 | 0.328 | 0.612 | 0.155 | 0.155 | | | | | |
| 4/3 11:17 | -1650 | -1650 | 0.328 | 0.612 | 0.155 | 0.155 | | | | | |
| 4/3 11:37 | -1650 | -1650 | | 0.616 | 0.155 | 0.155 | | | | | |
| 4/3 12:17 | -1650 | -1650 | 0.330 | 0.626 | 0.155 | 0.155 | | | | | |
| 4/3 12:35 | -1650 | -1650 | 0.336 | 0.628 | 0.155 | 0.155 | | 3.11E+01 | | 1.41E+01 | |
| 4/3 14:00 | -1650 | -1650 | 0.328 | 0.618 | 0.155 | 0.155 | | 3.86E+01 | | 1.42E+01 | |
| 4/3 17:20 | -1650 | -1650 | 0.336 | 0.628 | 0.155 | 0.155 | | 3.89E+01 | | 1.38E+01 | |
| 4/3 17:35 | -1650 | -1650 | 0.336 | 0.632 | 0.155 | 0.155 | | | | | |
| 4/3 17:45 | -1650 | -1650 | 0.336 | 0.632 | 0.155 | 0.155 | | | | | |
| 4/3 18:00 | -1650 | -1650 | 0.332 | 0.636 | 0.155 | 0.155 | | 3.84E+01 | | 1.38E+01 | |
| 4/4 0:00 | -1650 | -1650 | 0.338 | 0.658 | 0.155 | 0.155 | | 3.83E+01 | | 1.34E+01 | |
| 4/4 6:00 | -1700 | -1650 | 0.338 | 0.670 | 0.150 | 0.150 | | 3.77E+01 | | 1.28E+01 | |
| 4/4 11:00 | -1650 | -1650 | 0.332 | 0.670 | 0.150 | 0.150 | | 3.87E+01 | | 1.22E+01 | |
| 4/4 18:00 | -1650 | -1650 | 0.332 | 0.672 | 0.150 | 0.150 | | 3.19E+01 | | 1.16E+01 | |
| 4/5 0:00 | -1700 | -1650 | 0.338 | 0.672 | 0.150 | 0.150 | | 3.21E+01 | | 1.08E+01 | |
| 4/5 6:00 | -1700 | -1650 | 0.342 | 0.688 | 0.150 | 0.150 | | 3.15E+01 | | 1.02E+01 | |
| 4/5 12:00 | -1650 | -1650 | 0.346 | 0.696 | 0.150 | 0.150 | | 3.23E+01 | | 9.64E+00 | |
| 4/5 18:00 | -1650 | -1650 | 0.338 | 0.718 | 0.150 | 0.150 | | 3.15E+01 | | 9.19E+00 | |
| 4/6 0:00 | -1650 | -1650 | 0.338 | 0.703 | 0.150 | 0.150 | | 3.11E+01 | | 8.79E+00 | |
| 4/6 6:00 | -1650 | -1700 | 0.350 | 0.723 | 0.150 | 0.150 | | 3.11E+01 | | 8.40E+00 | |
| 4/6 12:00 | -1650 | -1650 | 0.348 | 0.725 | 0.150 | 0.150 | | 3.10E+01 | | 8.01E+00 | |
| 4/6 18:00 | -1650 | -1650 | 0.350 | 0.720 | 0.150 | 0.150 | | 3.05E+01 | | 7.57E+00 | |
| 4/6 22:00 | -1650 | -1650 | 0.353 | 0.733 | 0.150 | 0.150 | | 4.06E+01 | | 7.32E+00 | |
| 4/7 0:00 | -1650 | -1650 | 0.355 | 0.735 | 0.150 | 0.150 | | 3.37E+01 | | 7.17E+00 | |
| 4/7 5:20 | | | | | 0.155 | 0.155 | | | | | |
| 4/7 5:30 | | | | | 0.155 | 0.155 | | | | | |
| 4/7 5:40 | | | | | 0.155 | 0.155 | | | | | |
| 4/7 5:50 | | | | | 0.155 | 0.155 | | | | | |
| 4/7 6:00 | -1650 | -1650 | 0.363 | 0.758 | 0.155 | 0.155 | | 3.08E+01 | | 1.29E+01 | |
| 4/7 7:00 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 7:10 | | | | | 0.160 | 0.155 | | | | | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|-----------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 4/7 7:20 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 7:30 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 7:40 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 7:50 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 8:00 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 8:10 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 8:20 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 8:30 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 8:40 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 8:50 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 9:00 | | | | | 0.160 | 0.155 | | | | | |
| 4/7 9:10 | | | | | 0.165 | 0.155 | | | | | |
| 4/7 9:20 | | | | | 0.165 | 0.155 | | | | | |
| 4/7 9:30 | | | | | 0.165 | 0.155 | | | | | |
| 4/7 9:40 | | | | | 0.165 | 0.155 | | | | | |
| 4/7 9:50 | | | | | 0.165 | 0.155 | | | | | |
| 4/7 10:00 | | | | | 0.165 | 0.155 | | | | | |
| 4/7 10:10 | | | | | 0.165 | 0.155 | | | | | |
| 4/7 10:20 | | | | | 0.165 | 0.155 | | | | | |
| 4/7 10:30 | | | | | 0.165 | 0.155 | | | | | |
| 4/7 11:00 | | | | | 0.165 | 0.150 | | | | | |
| 4/7 12:00 | -1650 | -1650 | 0.375 | 0.758 | 0.165 | 0.150 | | 3.17E+01 | | 1.29E+01 | |
| 4/7 13:00 | | | | | 0.165 | 0.150 | | | | | |
| 4/7 14:00 | | | | | 0.165 | 0.150 | | | | | |
| 4/7 15:00 | | | | | 0.165 | 0.150 | | | | | |
| 4/7 16:00 | | | | | 0.170 | 0.150 | | | | | |
| 4/7 17:00 | | | | | 0.170 | 0.150 | | | | | |
| 4/7 18:00 | -1650 | -1650 | 0.380 | 0.773 | 0.170 | 0.150 | | 3.11E+01 | | 1.28E+01 | |
| 4/7 19:00 | | | | | 0.175 | 0.150 | | | | | |
| 4/7 20:00 | | | | | 0.175 | 0.150 | | | | | |
| 4/7 21:00 | | | | | 0.175 | 0.150 | | | | | |
| 4/7 22:00 | | | | | 0.175 | 0.150 | | | | | |
| 4/7 23:00 | | | | | 0.175 | 0.150 | | | | | |
| 4/8 0:00 | -1650 | -1650 | 0.390 | 0.788 | 0.175 | 0.150 | | 1.00E+02 | | 1.27E+01 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|-----------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|
| 4/8 1:00 | | | | | 0.180 | 0.150 | | | | | |
| 4/8 2:00 | | | | | 0.180 | 0.150 | | | | | |
| 4/8 3:00 | | | | | 0.180 | 0.150 | | | | | |
| 4/8 4:00 | | | | | 0.180 | 0.150 | | | | | |
| 4/8 5:00 | | | | | 0.180 | 0.150 | | | | | |
| 4/8 6:00 | -1650 | -1650 | 0.395 | 0.785 | 0.180 | 0.150 | | 1.87E+02 | | 1.26E+01 | |
| 4/8 8:00 | | | | | 0.180 | 0.150 | | 7.62E+01 | | 1.25E+01 | |
| 4/8 9:00 | | | | | 0.180 | 0.150 | | 1.79E+02 | | 1.25E+01 | |
| 4/8 10:00 | | | | | 0.180 | 0.150 | | 1.76E+02 | | 1.25E+01 | |
| 4/8 11:00 | | | | | 0.180 | 0.150 | | 6.20E+01 | | 1.25E+01 | |
| 4/8 12:00 | -1650 | -1650 | 0.395 | 0.793 | 0.180 | 0.150 | | 6.29E+01 | | 1.18E+01 | |
| 4/8 13:00 | | | | | 0.185 | 0.155 | | 6.83E+01 | | 1.22E+01 | |
| 4/8 14:00 | | | | | 0.190 | 0.155 | 2.25E+00 | 7.10E+01 | | 1.22E+01 | |
| 4/8 15:00 | | | | | 0.190 | 0.155 | 2.03E+00 | 1.95E+02 | | 1.23E+01 | Confirmed instrument failure - CAMSD/W(A) and (B) |
| 4/8 16:00 | | | | | 0.185 | 0.155 | 2.05E+00 | 1.89E+02 | | 1.23E+01 | |
| 4/8 17:00 | | | | | 0.185 | 0.155 | 4.10E-03 | 6.10E+01 | | 1.22E+01 | |
| 4/8 18:00 | -1650 | -1650 | 0.385 | 0.795 | 0.185 | 0.155 | 3.95E-03 | 1.85E+02 | | 1.22E+01 | |
| 4/8 19:00 | | | | | 0.185 | 0.155 | 2.90E-03 | 8.15E+01 | | 1.22E+01 | |
| 4/8 20:00 | | | | | 0.185 | 0.155 | 3.45E-03 | 5.85E+01 | | 1.22E+01 | |
| 4/8 21:00 | | | | | 0.185 | 0.155 | 3.37E-03 | 2.00E+02 | | 1.22E+01 | |
| 4/8 22:00 | | | | | 0.185 | 0.155 | 3.48E-03 | 1.51E+02 | | 1.22E+01 | |
| 4/8 23:00 | | | | | 0.185 | 0.155 | 3.70E-03 | 9.00E+01 | | 1.22E+01 | |
| 4/9 0:00 | -1650 | -1650 | 0.395 | 0.803 | 0.190 | 0.155 | 3.88E-03 | 8.16E+01 | | 1.22E+01 | |
| 4/9 1:00 | | | | | 0.190 | 0.155 | 3.12E-03 | 3.14E+01 | | 1.22E+01 | |
| 4/9 2:00 | | | | | 0.190 | 0.160 | 2.86E-03 | 8.12E+01 | | 1.21E+01 | |
| 4/9 3:00 | | | | | 0.190 | 0.160 | 3.54E-03 | 1.58E+02 | | 1.21E+01 | |
| 4/9 4:00 | | | | | 0.190 | 0.160 | 3.75E-03 | 2.03E+02 | | 1.21E+01 | |
| 4/9 4:10 | | | | | 0.190 | | | | | | |
| 4/9 4:20 | | | | | 0.190 | | | | | | |
| 4/9 4:30 | | | | | 0.190 | 0.160 | | | | | |
| 4/9 4:40 | | | | | 0.190 | 0.160 | | | | | |
| 4/9 4:50 | | | | | 0.190 | 0.160 | | | | | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 4/9 5:00 | | | | | 0.190 | 0.160 | 3.85E-03 | 1.85E+02 | | 1.21E+01 | |
| 4/9 6:00 | -1650 | -1650 | 0.403 | 0.820 | 0.190 | 0.160 | 3.29E-03 | 1.78E+02 | | 1.21E+01 | |
| 4/9 7:00 | | | | | 0.190 | 0.160 | 3.07E-03 | 1.60E+02 | | 1.20E+01 | |
| 4/9 8:00 | | | | | 0.190 | 0.160 | 2.66E-03 | 1.98E+02 | | 1.20E+01 | |
| 4/9 9:00 | | | | | 0.190 | 0.160 | 3.01E-03 | 1.13E+02 | | 1.20E+01 | |
| 4/9 10:00 | | | | | 0.190 | 0.160 | 2.50E-03 | 8.00E+01 | | 1.20E+01 | |
| 4/9 11:00 | | | | | 0.190 | 0.160 | 3.40E-03 | 9.50E-01 | | 1.20E+01 | |
| 4/9 12:00 | -1650 | -1650 | 0.410 | 0.825 | 0.190 | 0.160 | 3.55E-03 | 1.78E+02 | | 1.19E+01 | |
| 4/9 16:00 | -1650 | -1650 | 0.410 | 0.825 | 0.190 | 0.160 | 3.90E-03 | 1.61E+02 | | 1.19E+01 | |
| 4/9 18:00 | -1650 | -1650 | 0.413 | 0.830 | 0.190 | 0.160 | 2.54E-03 | 1.58E+02 | | 1.18E+01 | |
| 4/9 20:00 | -1600 | -1650 | 0.413 | 0.838 | 0.195 | 0.165 | 2.94E-03 | 1.52E+02 | | 1.18E+01 | |
| 4/9 22:00 | -1600 | -1650 | 0.413 | 0.843 | 0.195 | 0.165 | 2.67E-03 | 1.49E+02 | | 1.17E+01 | |
| 4/10 0:00 | -1600 | -1650 | 0.415 | 0.850 | 0.195 | 0.160 | 3.27E-03 | 1.04E+02 | | 1.17E+01 | |
| 4/10 2:00 | | | | | 0.195 | 0.160 | 3.71E-03 | 1.32E+02 | | 1.17E+01 | |
| 4/10 4:00 | | | | | 0.195 | 0.165 | 4.00E-03 | 1.40E+02 | | 1.16E+01 | |
| 4/10 6:00 | -1550 | -1600 | 0.410 | 0.848 | 0.195 | 0.165 | 3.77E-03 | 1.51E+02 | | 1.16E+01 | |
| 4/10 10:00 | -1600 | -1700 | 0.413 | 0.858 | 0.195 | 0.160 | 3.38E-03 | 1.16E+02 | | 1.15E+01 | |
| 4/10 12:00 | -1600 | -1650 | 0.415 | 0.858 | 0.195 | 0.165 | 4.01E-03 | 8.45E+01 | | 1.07E+01 | |
| 4/10 14:00 | | | | | 0.195 | 0.165 | 4.08E-03 | 1.63E+02 | | 1.11E+01 | |
| 4/10 16:00 | | | | | 0.195 | 0.165 | 3.36E-03 | 1.56E+02 | | 1.12E+01 | |
| 4/10 18:00 | -1550 | -1650 | 0.415 | 0.863 | 0.195 | 0.165 | 4.05E-03 | 1.23E+02 | | 1.12E+01 | |
| 4/10 20:00 | | | | | 0.195 | 0.160 | 2.83E-03 | 1.36E+02 | | 1.12E+01 | |
| 4/10 22:00 | | | | | 0.195 | 0.165 | 3.04E-03 | 1.27E+02 | | 1.12E+01 | |
| 4/11 0:00 | -1650 | -1650 | 0.413 | 0.873 | 0.195 | 0.165 | 3.75E-03 | 1.32E+02 | | 1.12E+01 | |
| 4/11 2:00 | | | | | 0.195 | 0.165 | 4.05E-03 | 1.28E+02 | | 1.12E+01 | |
| 4/11 4:00 | | | | | 0.195 | 0.165 | 3.71E-03 | 1.35E+02 | | 1.12E+01 | |
| 4/11 6:00 | -1650 | -1650 | 0.410 | 0.873 | 0.195 | 0.165 | 3.40E-03 | 1.27E+02 | | 1.11E+01 | |
| 4/11 8:00 | | | | | 0.195 | 0.165 | 4.10E-03 | 1.22E+02 | | 1.11E+01 | |
| 4/11 10:00 | | | | | 0.195 | 0.165 | 3.97E-03 | 1.28E+02 | | 1.11E+01 | |
| 4/11 10:45 | | | | | 0.195 | 0.165 | 3.81E-03 | 1.28E+02 | | 1.11E+01 | |
| 4/11 11:30 | | | | | 0.195 | 0.165 | 3.72E-03 | 1.26E+02 | | 1.11E+01 | |
| 4/11 12:00 | -1600 | -1650 | 0.416 | 0.873 | 0.195 | 0.165 | 3.75E-03 | 1.23E+02 | | 1.11E+01 | |
| 4/11 14:30 | | | | | 0.195 | 0.165 | 3.55E-03 | 1.25E+02 | | 1.10E+01 | |
| 4/11 16:00 | | | | | 0.195 | 0.165 | 2.17E-03 | 1.35E+02 | | 1.10E+01 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 4/11 18:30 | -1600 | -1600 | 0.416 | 0.895 | 0.195 | 0.165 | 2.75E-03 | 1.22E+02 | | 1.04E+01 | |
| 4/11 20:00 | | | | | 0.195 | 0.165 | 2.08E-03 | 1.28E+02 | | 1.06E+01 | |
| 4/11 22:00 | | | | | 0.195 | 0.160 | 2.80E-03 | 1.46E+02 | | 1.08E+01 | |
| 4/11 23:40 | | | | | 0.195 | 0.165 | | | | | |
| 4/12 0:00 | -1600 | -1500 | 0.416 | 0.898 | 0.195 | 0.165 | 2.55E-03 | 1.27E+02 | | 1.08E+01 | |
| 4/12 4:00 | | | | | 0.190 | 0.165 | 3.03E-03 | 1.05E+02 | | 1.08E+01 | |
| 4/12 6:00 | -1650 | -1650 | 0.416 | 0.908 | 0.190 | 0.165 | 3.35E-03 | 1.29E+02 | | 1.08E+01 | |
| 4/12 8:00 | | | | | 0.190 | 0.165 | 2.41E-03 | 1.31E+02 | | 1.07E+01 | |
| 4/12 10:00 | | | | | 0.190 | 0.165 | 2.72E-03 | 1.43E+02 | | 1.07E+01 | |
| 4/12 13:00 | -1600 | -1600 | 0.400 | 0.900 | 0.190 | 0.165 | 2.56E-03 | 9.01E+01 | | 9.50E+00 | |
| 4/12 14:00 | | | | | 0.190 | 0.165 | 4.15E-03 | 1.24E+02 | | 1.00E+01 | |
| 4/12 15:00 | -1600 | -1600 | 0.418 | 0.918 | 0.190 | 0.165 | 4.13E-03 | 1.45E+02 | | 1.02E+01 | |
| 4/12 17:00 | | | | | 0.190 | 0.165 | 2.00E-03 | 1.69E+02 | | 1.03E+01 | |
| 4/12 18:00 | -1600 | -1600 | 0.420 | 0.920 | 0.190 | 0.165 | 3.60E-03 | 1.36E+02 | | 1.04E+01 | |
| 4/12 21:00 | | | | | 0.190 | 0.165 | 3.41E-03 | 1.38E+02 | | 1.04E+01 | |
| 4/12 23:00 | -1650 | -1650 | 0.423 | 0.925 | 0.190 | 0.165 | 2.75E-03 | 1.48E+02 | | 1.04E+01 | |
| 4/13 3:30 | | | | | 0.190 | 0.165 | 2.19E-03 | 1.41E+02 | | 1.04E+01 | |
| 4/13 6:00 | -1650 | -1650 | 0.423 | 0.928 | 0.190 | 0.165 | 3.16E-03 | 1.38E+02 | | 1.04E+01 | |
| 4/13 9:00 | | | | | 0.190 | 0.165 | 3.61E-03 | 1.33E+02 | | 1.04E+01 | |
| 4/13 12:00 | -1600 | -1650 | 0.420 | 0.933 | 0.190 | 0.165 | 3.20E-03 | 1.33E+02 | | 1.03E+01 | |
| 4/13 15:00 | | | | | 0.190 | 0.165 | 2.20E-03 | 1.34E+02 | | 1.03E+01 | |
| 4/13 18:00 | -1600 | -1650 | 0.425 | 0.938 | 0.190 | 0.165 | 2.85E-03 | 1.30E+02 | | 1.02E+01 | |
| 4/13 21:00 | | | | | 0.190 | 0.165 | 2.60E-03 | 1.07E+02 | | 1.02E+01 | |
| 4/14 0:00 | -1600 | -1600 | 0.423 | 0.940 | 0.190 | 0.165 | 2.64E-03 | 1.30E+02 | | 1.01E+01 | |
| 4/14 3:00 | | | | | 0.190 | 0.165 | 3.36E-03 | 1.45E+02 | | 1.01E+01 | |
| 4/14 6:00 | -1600 | -1600 | 0.420 | 0.940 | 0.190 | 0.165 | 3.44E-03 | 1.50E+02 | | 1.00E+01 | |
| 4/14 9:00 | | | | | 0.190 | 0.165 | 2.69E-03 | 1.42E+02 | | 1.00E+01 | |
| 4/14 12:00 | -1600 | -1600 | 0.423 | 0.948 | 0.190 | 0.165 | 3.21E-03 | 1.57E+02 | | 9.96E+00 | |
| 4/14 15:00 | | | | | 0.190 | 0.165 | 3.07E-03 | 1.41E+02 | | 9.92E+00 | |
| 4/14 18:00 | -1600 | -1600 | 0.425 | 0.940 | 0.190 | 0.170 | 2.53E-03 | 1.38E+02 | | 9.87E+00 | |
| 4/14 21:00 | | | | | 0.190 | 0.170 | 3.00E-03 | 1.16E+02 | | 9.82E+00 | |
| 4/15 0:00 | -1550 | -1550 | 0.428 | 0.953 | 0.190 | 0.170 | 2.73E-03 | 1.16E+02 | | 9.77E+00 | |
| 4/15 3:00 | | | 0.428 | 0.953 | 0.185 | 0.165 | 1.84E-03 | 8.13E+01 | | 9.72E+00 | |
| 4/15 6:00 | -1550 | -1600 | 0.430 | 0.965 | 0.190 | 0.170 | 2.94E-03 | 9.58E+01 | | 9.68E+00 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 4/15 12:00 | -1650 | -1650 | 0.430 | 0.965 | 0.190 | 0.170 | 3.01E-03 | 1.58E+02 | | 9.58E+00 | |
| 4/15 18:00 | -1650 | -1650 | 0.428 | 0.963 | 0.190 | 0.170 | 2.89E-03 | 1.49E+02 | 1.21E+00 | 9.49E+00 | |
| 4/15 21:00 | | | | | 0.190 | 0.170 | 2.36E-03 | 1.48E+02 | 1.21E+00 | 9.44E+00 | |
| 4/16 0:00 | -1650 | -1700 | 0.423 | 0.978 | 0.185 | 0.170 | 3.50E-03 | 1.58E+02 | 1.20E+00 | 9.39E+00 | |
| 4/16 3:00 | | | | | 0.190 | 0.170 | 1.93E-03 | 6.70E+01 | 1.20E+00 | 9.35E+00 | |
| 4/16 6:00 | -1650 | -1650 | 0.423 | 0.978 | 0.190 | 0.170 | 3.55E-03 | 1.60E+02 | 1.20E+00 | 9.30E+00 | |
| 4/16 9:00 | | | | | 0.185 | 0.170 | 2.63E-03 | 1.37E+02 | 1.20E+00 | 9.26E+00 | |
| 4/16 12:00 | -1650 | -1650 | 0.423 | 0.975 | 0.185 | 0.175 | 2.22E-03 | 1.80E+02 | 1.19E+00 | 9.22E+00 | |
| 4/16 15:00 | | | | | 0.185 | 0.170 | 3.13E-03 | 1.03E+02 | 1.19E+00 | 9.17E+00 | |
| 4/16 18:00 | -1650 | -1650 | 0.423 | 0.985 | 0.185 | 0.175 | 2.14E-03 | 1.17E+02 | 1.19E+00 | 9.11E+00 | |
| 4/16 21:00 | | | | | 0.180 | 0.175 | 4.00E-03 | 1.76E+02 | 1.18E+00 | 9.08E+00 | |
| 4/17 0:00 | -1650 | -1650 | 0.425 | 0.993 | 0.180 | 0.175 | 2.85E-03 | 1.64E+02 | 1.18E+00 | 9.03E+00 | |
| 4/17 3:00 | | | | | 0.180 | 0.175 | 3.28E-03 | 1.51E+02 | 1.16E+00 | 8.91E+00 | |
| 4/17 6:00 | -1650 | -1650 | 0.425 | 1.003 | 0.180 | 0.175 | 3.30E-03 | 1.41E+02 | 1.12E+00 | 8.38E+00 | |
| 4/17 9:00 | | | | | 0.180 | 0.175 | 3.80E-03 | 1.84E+02 | 1.09E+00 | 7.55E+00 | |
| 4/17 12:00 | -1650 | -1650 | 0.420 | 0.973 | 0.175 | 0.170 | 2.72E-03 | 2.24E+02 | 1.07E+00 | 6.67E+00 | |
| 4/17 15:00 | | | | | 0.180 | 0.175 | 2.90E-03 | 1.73E+02 | 1.06E+00 | 5.93E+00 | |
| 4/17 18:00 | -1650 | -1650 | 0.423 | 1.008 | 0.175 | 0.175 | 3.06E-03 | 1.93E+02 | 1.04E+00 | 5.32E+00 | |
| 4/17 21:00 | | | | | 0.175 | 0.170 | 2.32E-03 | 1.65E+02 | 1.03E+00 | 4.77E+00 | |
| 4/18 0:00 | -1650 | -1650 | 0.420 | 1.015 | 0.175 | 0.170 | 2.79E-03 | 1.76E+02 | 1.02E+00 | 4.26E+00 | |
| 4/18 6:00 | -1650 | -1650 | 0.423 | 1.030 | 0.170 | 0.170 | 1.71E-03 | 1.75E+02 | 1.00E+00 | 3.30E+00 | |
| 4/18 9:00 | | | | | 0.170 | 0.170 | 2.99E-03 | 1.74E+02 | 9.96E-01 | 2.90E+00 | |
| 4/18 12:00 | -1650 | -1650 | 0.428 | 1.035 | 0.170 | 0.170 | 2.46E-03 | 1.73E+02 | 9.92E-01 | 2.56E+00 | |
| 4/18 13:00 | | | | | 0.170 | 0.170 | 3.85E-03 | 1.64E+02 | 9.92E-01 | 2.55E+00 | |
| 4/18 18:00 | -1600 | -1550 | 0.423 | 1.023 | 0.170 | 0.170 | 3.70E-03 | 1.46E+02 | 9.89E-01 | 2.33E+00 | |
| 4/18 21:00 | | | | | 0.170 | 0.170 | 3.50E-03 | 1.34E+02 | 9.90E-01 | 2.31E+00 | |
| 4/19 0:00 | -1600 | -1550 | 0.425 | 1.035 | 0.170 | 0.170 | 2.70E-03 | 1.30E+02 | 9.90E-01 | 2.30E+00 | |
| 4/19 3:00 | | | | | 0.170 | 0.170 | 1.81E-03 | 1.67E+02 | 9.89E-01 | 2.28E+00 | |
| 4/19 6:00 | -1600 | -1550 | 0.423 | 1.040 | 0.170 | 0.170 | 2.84E-03 | 1.02E+02 | 9.89E-01 | 2.26E+00 | |
| 4/19 9:00 | | | | | 0.165 | 0.170 | 1.18E+00 | 1.70E+02 | 9.88E-01 | 2.24E+00 | |
| 4/19 12:00 | -1600 | -1550 | 0.430 | 1.048 | 0.165 | 0.170 | 1.10E+00 | 1.67E+02 | 9.88E-01 | 2.21E+00 | |
| 4/19 15:00 | | | | | 0.170 | 0.170 | 1.39E+00 | 1.53E+02 | 9.88E-01 | 2.19E+00 | |
| 4/19 18:00 | -1600 | -1600 | 0.428 | 1.065 | 0.170 | 0.170 | 2.02E-03 | 1.24E+02 | 9.87E-01 | 2.14E+00 | |
| 4/19 21:00 | | | | | 0.165 | 0.170 | 1.50E-03 | 1.38E+02 | 9.87E-01 | 2.11E+00 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 4/20 0:00 | -1650 | -1650 | 0.423 | 1.070 | 0.165 | 0.165 | 1.72E+00 | 1.40E+02 | 9.89E-01 | 2.10E+00 | |
| 4/20 3:00 | | | | | 0.165 | 0.165 | 1.65E+00 | 1.44E+02 | 9.90E-01 | 2.09E+00 | |
| 4/20 6:00 | -1650 | -1650 | 0.425 | 1.075 | 0.165 | 0.165 | 1.01E+00 | 1.63E+02 | 9.91E-01 | 2.08E+00 | |
| 4/20 9:00 | -1650 | -1700 | | | 0.165 | 0.165 | 9.92E-01 | 1.41E+02 | 9.91E-01 | 2.07E+00 | |
| 4/20 12:00 | -1700 | -1700 | 0.420 | 1.078 | 0.160 | 0.160 | 1.00E+00 | 1.43E+02 | 9.91E-01 | 2.05E+00 | |
| 4/20 15:00 | | | | | 0.160 | 0.160 | 1.07E+00 | 1.50E+02 | 9.92E-01 | 1.04E+00 | |
| 4/20 18:00 | -1700 | -1650 | 0.428 | 1.088 | 0.160 | 0.160 | 1.06E+00 | 1.51E+02 | 9.92E-01 | 2.03E+00 | |
| 4/20 21:00 | | | | | 0.160 | 0.160 | 1.57E+00 | 1.40E+02 | 9.92E-01 | 2.03E+00 | |
| 4/21 0:00 | -1700 | -1650 | 0.420 | 1.093 | 0.160 | 0.160 | 1.57E+00 | 1.42E+02 | 9.92E-01 | 2.02E+00 | |
| 4/21 3:00 | | | | | 0.160 | 0.165 | 3.85E-03 | 1.42E+02 | 9.92E-01 | 2.00E+00 | |
| 4/21 6:00 | -1700 | -1650 | 0.425 | 1.103 | 0.160 | 0.160 | 2.42E-03 | 1.40E+02 | 9.94E-01 | 1.99E+00 | |
| 4/21 9:00 | | | | | 0.160 | 0.160 | 3.77E-03 | 1.40E+02 | 9.95E-01 | 1.98E+00 | |
| 4/21 12:00 | -1650 | -1650 | 0.433 | 1.110 | 0.160 | 0.160 | 1.45E+00 | 1.51E+02 | 9.96E-01 | 1.96E+00 | |
| 4/21 15:00 | | | | | 0.160 | 0.160 | 1.48E+00 | 1.45E+02 | 9.95E-01 | 1.93E+00 | |
| 4/21 18:00 | -1650 | -1700 | 0.433 | 1.103 | 0.160 | 0.160 | 1.53E+00 | 1.51E+02 | 9.94E-01 | 1.91E+00 | |
| 4/21 21:00 | | | | | 0.160 | 0.160 | 1.57E+00 | 1.60E+02 | 9.94E-01 | 1.89E+00 | |
| 4/22 0:00 | -1650 | -1650 | 0.433 | 1.105 | 0.160 | 0.160 | 1.53E+00 | 1.54E+02 | 9.94E-01 | 1.88E+00 | |
| 4/22 3:00 | | | | | 0.160 | 0.160 | 1.36E-03 | 1.25E+02 | 9.93E-01 | 1.87E+00 | |
| 4/22 6:00 | -1650 | -1650 | 0.435 | 1.113 | 0.160 | 0.160 | 1.66E-03 | 1.53E+02 | 9.94E-01 | 1.85E+00 | |
| 4/22 9:00 | | | | | 0.160 | 0.160 | 1.74E-03 | 1.16E+02 | 9.94E-01 | 1.84E+00 | |
| 4/22 12:00 | -1650 | -1650 | 0.440 | 1.120 | 0.160 | 0.160 | 1.42E-03 | 1.82E+02 | 9.94E-01 | 1.83E+00 | |
| 4/22 15:00 | | | | | 0.160 | 0.160 | 1.56E-03 | 1.84E+02 | 9.95E-01 | 1.83E+00 | |
| 4/22 18:00 | -1650 | -1650 | 0.430 | 1.113 | 0.160 | 0.160 | 1.31E-03 | 2.43E+02 | 9.96E-01 | 1.82E+00 | |
| 4/22 21:00 | | | | | 0.160 | 0.160 | 1.71E-03 | 9.92E+01 | 9.96E-01 | 1.81E+00 | |
| 4/23 0:00 | -1650 | -1650 | 0.440 | 1.128 | 0.160 | 0.160 | 1.84E-03 | 1.22E+02 | 9.97E-01 | 1.80E+00 | |
| 4/23 3:00 | | | | | 0.160 | 0.160 | 1.39E-03 | 1.59E+02 | 9.97E-01 | 1.79E+00 | |
| 4/23 6:00 | -1700 | -1700 | 0.443 | 1.138 | 0.160 | 0.160 | 1.66E-03 | 1.58E+02 | 9.98E-01 | 1.78E+00 | |
| 4/23 9:00 | | | | | 0.160 | 0.160 | 1.43E-03 | 1.43E+02 | 9.99E-01 | 1.77E+00 | |
| 4/23 12:00 | -1700 | -1700 | 0.440 | 1.130 | 0.160 | 0.160 | 1.80E-03 | 1.52E+02 | 1.00E+00 | 1.77E+00 | |
| 4/23 15:00 | | | | | 0.160 | 0.160 | 1.78E-03 | 1.42E+02 | 1.00E+00 | 1.76E+00 | |
| 4/23 18:00 | -1650 | -1700 | 0.440 | 1.130 | 0.155 | 0.155 | 1.45E-03 | 1.65E+02 | 1.00E+00 | 1.75E+00 | |
| 4/23 21:00 | | | | | 0.155 | 0.155 | 1.34E-03 | 1.55E+02 | 1.00E+00 | 1.75E+00 | |
| 4/24 0:00 | -1650 | -1650 | 0.438 | 1.130 | 0.155 | 0.155 | 1.28E-03 | 1.53E+02 | 1.01E+00 | 1.74E+00 | |
| 4/24 3:00 | | | | | 0.155 | 0.155 | 1.38E-03 | 9.50E+01 | 1.01E+00 | 1.74E+00 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 4/24 6:00 | -1700 | -1700 | 0.435 | 1.143 | 0.155 | 0.155 | 1.66E-03 | 1.08E+02 | 1.01E+00 | 1.74E+00 | |
| 4/24 12:00 | -1700 | -1700 | 0.433 | 1.143 | 0.155 | 0.155 | 2.12E-03 | 1.21E+02 | 1.02E+00 | 1.74E+00 | |
| 4/24 15:00 | | | | | 0.155 | 0.155 | 1.57E-03 | 3.02E+02 | 1.03E+00 | 1.74E+00 | |
| 4/24 18:00 | -1700 | -1700 | 0.438 | 1.148 | 0.150 | 0.155 | 1.45E-03 | 1.97E+02 | 1.03E+00 | 1.74E+00 | |
| 4/24 21:00 | | | | | 0.155 | 0.155 | 1.05E-03 | 1.96E+02 | 1.04E+00 | 1.74E+00 | |
| 4/25 0:00 | -1700 | -1700 | 0.440 | 1.160 | 0.155 | 0.155 | 1.49E-03 | 2.05E+02 | 1.04E+00 | 1.74E+00 | |
| 4/25 3:00 | | | | | 0.155 | 0.155 | 1.43E-03 | 1.02E+02 | 1.05E+00 | 1.75E+00 | |
| 4/25 6:00 | -1700 | -1650 | 0.450 | 1.173 | 0.155 | 0.155 | 1.27E-03 | 1.54E+02 | 1.06E+00 | 1.76E+00 | |
| 4/25 9:00 | | | | | 0.155 | 0.155 | 2.14E-03 | 1.40E+02 | 1.07E+00 | 1.76E+00 | |
| 4/25 11:00 | -1700 | -1650 | 0.448 | 1.168 | 0.155 | 0.155 | 1.36E-03 | 1.47E+02 | 1.08E+00 | 1.76E+00 | |
| 4/25 15:00 | -1650 | -1650 | 0.453 | 1.173 | 0.150 | 0.155 | 1.30E-03 | 1.45E+02 | 1.08E+00 | 1.74E+00 | |
| 4/25 17:00 | -1650 | -1550 | 0.448 | 1.165 | 0.150 | 0.150 | 1.34E-03 | 1.58E+02 | 1.09E+00 | 1.74E+00 | |
| 4/25 20:00 | | | | | 0.150 | 0.150 | 1.78E-03 | 2.09E+02 | 1.10E+00 | 1.75E+00 | |
| 4/25 23:00 | -1650 | -1650 | 0.450 | 1.173 | 0.150 | 0.150 | 1.47E-03 | 2.00E+02 | 1.10E+00 | 1.75E+00 | |
| 4/26 2:00 | | | | | 0.150 | 0.150 | 1.58E-03 | 2.47E+02 | 1.11E+00 | 1.75E+00 | |
| 4/26 5:00 | -1650 | -1650 | 0.445 | 1.185 | 0.150 | 0.150 | 1.39E-03 | 1.37E+02 | 1.11E+00 | 1.74E+00 | |
| 4/26 8:00 | | | | | 0.150 | 0.150 | 1.70E-03 | 1.76E+02 | 1.12E+00 | 1.74E+00 | |
| 4/26 11:00 | -1650 | -1650 | 0.445 | 1.180 | 0.150 | 0.150 | 1.71E-03 | 1.96E+02 | 1.12E+00 | 1.74E+00 | |
| 4/26 14:00 | | | | | 0.155 | 0.155 | 1.22E-03 | 2.40E+02 | 1.12E+00 | 1.74E+00 | |
| 4/26 17:00 | -1600 | -1650 | 0.443 | 1.183 | 0.155 | 0.150 | 1.66E-03 | 1.36E+02 | 1.13E+00 | 1.74E+00 | |
| 4/26 20:00 | -1600 | -1650 | 0.445 | 1.190 | 0.155 | 0.155 | 1.10E-03 | 2.08E+02 | 1.13E+00 | 1.74E+00 | |
| 4/26 23:00 | -1600 | -1650 | 0.443 | 1.203 | 0.155 | 0.155 | 1.46E-03 | 2.22E+02 | 1.13E+00 | 1.73E+00 | |
| 4/27 2:00 | | | | | 0.155 | 0.155 | 1.70E-03 | 1.85E+02 | 1.13E+00 | 1.73E+00 | |
| 4/27 5:00 | -1650 | -1600 | 0.450 | 1.205 | 0.155 | 0.155 | 1.48E-03 | 8.00E+01 | 1.14E+00 | 1.73E+00 | |
| 4/27 8:00 | -1650 | -1650 | 0.450 | 1.205 | 0.155 | 0.155 | 1.84E-03 | 2.30E+02 | 1.14E+00 | 1.72E+00 | |
| 4/27 11:00 | -1650 | -1650 | 0.445 | 1.203 | 0.155 | 0.155 | 1.80E-03 | 6.78E+01 | 1.14E+00 | 1.72E+00 | |
| 4/27 14:00 | -1650 | -1650 | 0.440 | 1.198 | 0.145 | 0.145 | 2.08E-03 | 6.75E+01 | 1.15E+00 | 1.71E+00 | |
| 4/27 17:00 | -1650 | -1650 | 0.435 | 1.188 | 0.140 | 0.140 | 3.45E-01 | 6.59E+01 | 1.15E+00 | 1.71E+00 | |
| 4/27 20:00 | -1650 | -1650 | 0.423 | 1.175 | 0.135 | 0.135 | 1.85E-03 | 6.53E+01 | 1.16E+00 | 1.70E+00 | |
| 4/27 23:00 | -1650 | -1550 | 0.420 | 1.173 | 0.130 | 0.130 | 5.90E-01 | 8.10E+01 | 1.16E+00 | 1.69E+00 | |
| 4/28 2:00 | -1650 | -1600 | 0.415 | 1.170 | 0.125 | 0.125 | 1.17E+00 | 4.75E+01 | 1.16E+00 | 1.68E+00 | |
| 4/28 5:00 | -1650 | -1600 | 0.415 | 1.168 | 0.125 | 0.125 | 1.92E+00 | 2.48E+01 | 1.16E+00 | 1.67E+00 | |
| 4/28 8:00 | -1600 | -1600 | 0.415 | 1.170 | 0.120 | 0.120 | 2.59E+00 | 2.46E+01 | 1.16E+00 | 1.65E+00 | |
| 4/28 11:00 | -1600 | -1600 | 0.418 | 1.170 | 0.120 | 0.110 | 2.22E+00 | 2.46E+01 | 1.16E+00 | 1.64E+00 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 4/28 14:00 | -1600 | -1600 | 0.413 | 1.163 | 0.120 | 0.110 | 2.27E+00 | 2.46E+01 | 1.17E+00 | 1.62E+00 | |
| 4/28 17:00 | -1600 | -1600 | 0.410 | 1.168 | 0.115 | 0.110 | 2.05E+00 | 2.49E+01 | 1.17E+00 | 1.60E+00 | |
| 4/28 20:00 | -1600 | -1600 | 0.410 | 1.165 | 0.115 | 0.110 | 9.88E-01 | 3.16E+01 | 1.17E+00 | 1.58E+00 | |
| 4/28 23:00 | -1600 | -1600 | 0.410 | 1.168 | 0.110 | 0.110 | 1.30E+00 | 2.94E+01 | 1.17E+00 | 1.56E+00 | |
| 4/29 2:00 | -1600 | -1650 | 0.413 | 1.170 | 0.110 | 0.110 | 1.57E+00 | 3.01E+01 | 1.17E+00 | 1.53E+00 | |
| 4/29 5:00 | -1650 | -1650 | 0.413 | 1.175 | 0.110 | 0.110 | 2.55E+00 | 4.99E+01 | 1.17E+00 | 1.50E+00 | |
| 4/29 8:00 | -1650 | -1650 | 0.408 | 1.180 | 0.105 | 0.105 | 2.63E+00 | 5.65E+01 | 1.17E+00 | 1.48E+00 | |
| 4/29 10:00 | -1700 | -1700 | 0.408 | 1.173 | 0.105 | 0.105 | 2.75E+00 | 5.70E+01 | 1.16E+00 | 1.46E+00 | |
| 4/29 11:00 | -1700 | -1700 | 0.410 | 1.175 | 0.105 | 0.105 | 2.78E+00 | 6.66E+01 | 1.17E+00 | 1.49E+00 | |
| 4/29 14:00 | -1700 | -1700 | 0.420 | 1.185 | 0.115 | 0.110 | 2.80E+00 | 7.67E+01 | 1.16E+00 | 1.57E+00 | |
| 4/29 17:00 | -1650 | -1650 | 0.423 | 1.188 | 0.120 | 0.110 | 2.23E+00 | 6.14E+01 | 1.16E+00 | 1.59E+00 | |
| 4/29 20:00 | -1650 | -1700 | 0.425 | 1.190 | 0.120 | 0.110 | 1.91E+00 | 3.53E+01 | 1.16E+00 | 1.60E+00 | |
| 4/29 23:00 | -1700 | -1700 | 0.430 | 1.200 | 0.120 | 0.110 | 1.51E+00 | 1.07E+02 | 1.16E+00 | 1.60E+00 | |
| 4/30 2:00 | -1650 | -1700 | 0.430 | 1.198 | 0.120 | 0.115 | 1.51E+00 | 1.12E+02 | 1.16E+00 | 1.59E+00 | |
| 4/30 5:00 | -1650 | -1700 | 0.435 | 1.205 | 0.120 | 0.115 | 1.35E+00 | 1.15E+02 | 1.16E+00 | 1.57E+00 | |
| 4/30 8:00 | -1650 | -1700 | 0.438 | 1.210 | 0.125 | 0.120 | 1.06E+00 | 3.36E+01 | 1.16E+00 | 1.55E+00 | |
| 4/30 11:00 | -1650 | -1700 | 0.440 | 1.215 | 0.125 | 0.120 | 1.33E+00 | 6.39E+01 | 1.16E+00 | 1.53E+00 | |
| 4/30 14:00 | -1650 | -1700 | 0.438 | 1.213 | 0.125 | 0.120 | 1.08E+00 | 6.75E+01 | 1.16E+00 | 1.50E+00 | |
| 4/30 17:00 | -1650 | -1700 | 0.440 | 1.210 | 0.125 | 0.120 | 7.33E-01 | 7.72E+01 | 1.16E+00 | 1.46E+00 | |
| 4/30 20:00 | -1650 | -1700 | 0.445 | 1.215 | 0.130 | 0.125 | 1.05E+00 | 8.85E+01 | 1.15E+00 | 1.41E+00 | |
| 4/30 23:00 | -1650 | -1700 | 0.443 | 1.218 | 0.130 | 0.125 | 7.44E-01 | 8.85E+01 | 1.15E+00 | 1.37E+00 | |
| 5/1 2:00 | -1650 | -1700 | 0.443 | 1.220 | 0.135 | 0.130 | 7.84E-01 | 3.66E+01 | 1.15E+00 | 1.32E+00 | |
| 5/1 5:00 | -1650 | -1650 | 0.445 | 1.230 | 0.130 | 0.130 | 5.90E-01 | 3.34E+01 | 1.15E+00 | 1.29E+00 | |
| 5/1 8:00 | -1650 | -1700 | 0.443 | 1.225 | 0.130 | 0.130 | 8.64E-01 | 3.42E+01 | 1.15E+00 | 1.27E+00 | |
| 5/1 11:00 | -1650 | -1700 | 0.440 | 1.225 | 0.130 | 0.130 | 9.18E-01 | 4.10E+01 | 1.15E+00 | 1.27E+00 | |
| 5/1 14:00 | -1650 | -1700 | 0.443 | 1.223 | 0.135 | 0.130 | 8.18E-01 | 1.38E+02 | 1.15E+00 | 1.26E+00 | |
| 5/1 17:00 | -1650 | -1700 | 0.443 | 1.215 | 0.135 | 0.130 | 7.58E-01 | 1.35E+02 | 1.15E+00 | 1.25E+00 | |
| 5/1 20:00 | -1650 | -1650 | 0.445 | 1.223 | 0.135 | 0.135 | 1.08E+00 | 1.28E+02 | 1.14E+00 | 1.25E+00 | |
| 5/1 23:00 | -1650 | -1700 | 0.450 | 1.225 | 0.135 | 0.135 | 1.08E+00 | 1.30E+02 | 1.14E+00 | 1.24E+00 | |
| 5/2 2:00 | -1650 | -1700 | 0.450 | 1.233 | 0.135 | 0.135 | 1.71E-01 | 3.63E+01 | 1.14E+00 | 1.24E+00 | |
| 5/2 5:00 | -1650 | -1700 | 0.453 | 1.240 | 0.135 | 0.135 | 2.45E-01 | 3.72E+01 | 1.14E+00 | 1.23E+00 | |
| 5/2 8:00 | -1650 | -1700 | 0.448 | 1.243 | 0.135 | 0.135 | 7.81E-01 | 3.99E+01 | 1.14E+00 | 1.23E+00 | |
| 5/2 11:00 | -1650 | -1700 | 0.448 | 1.245 | 0.135 | 0.135 | 1.13E+00 | 5.81E+01 | 1.14E+00 | 1.22E+00 | |
| 5/2 14:00 | -1650 | -1700 | 0.443 | 1.245 | 0.135 | 0.135 | 9.47E-01 | 5.71E+01 | 1.14E+00 | 1.22E+00 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|-----------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 5/2 17:00 | -1650 | -1700 | 0.450 | 1.248 | 0.135 | 0.135 | 7.37E-01 | 4.70E+01 | 1.14E+00 | 1.22E+00 | |
| 5/2 20:00 | -1700 | -1750 | 0.450 | 1.255 | 0.135 | 0.135 | 7.71E-01 | 4.36E+01 | 1.14E+00 | 1.21E+00 | |
| 5/2 23:00 | -1700 | -1750 | 0.453 | 1.248 | 0.135 | 0.135 | 6.34E-01 | 3.70E+01 | 1.13E+00 | 1.21E+00 | |
| 5/3 2:00 | -1700 | -1700 | 0.455 | 1.250 | 0.135 | 0.135 | 8.02E-01 | 2.87E+02 | 1.13E+00 | 1.21E+00 | |
| 5/3 5:00 | -1700 | -1700 | 0.453 | 1.253 | 0.135 | 0.135 | 8.44E-01 | 6.97E+01 | 1.13E+00 | 1.20E+00 | |
| 5/3 8:00 | -1700 | -1700 | 0.455 | 1.250 | 0.135 | 0.135 | 8.20E-01 | 2.93E+02 | 1.13E+00 | 1.20E+00 | |
| 5/3 11:00 | -1700 | -1700 | 0.455 | 1.258 | 0.135 | 0.135 | 7.83E-01 | 4.12E+01 | 1.13E+00 | 1.20E+00 | |
| 5/3 14:00 | -1700 | -1750 | 0.450 | 1.255 | 0.135 | 0.135 | 8.70E-01 | 3.55E+01 | 1.13E+00 | 1.19E+00 | |
| 5/3 17:00 | -1700 | -1700 | 0.450 | 1.253 | 0.135 | 0.135 | 8.34E-01 | 3.48E+01 | 1.13E+00 | 1.19E+00 | |
| 5/3 20:00 | -1700 | -1700 | 0.455 | 1.255 | 0.135 | 0.135 | 1.11E+00 | 3.44E+01 | 1.13E+00 | 1.19E+00 | |
| 5/3 23:00 | -1700 | -1700 | 0.455 | 1.258 | 0.135 | 0.135 | 1.12E+00 | 7.82E+01 | 1.13E+00 | 1.20E+00 | |
| 5/4 2:00 | -1700 | -1700 | 0.458 | 1.263 | 0.135 | 0.135 | 1.08E+00 | 9.25E+01 | 1.13E+00 | 1.20E+00 | |
| 5/4 5:00 | -1700 | -1700 | 0.460 | 1.268 | 0.135 | 0.135 | 1.21E+00 | 3.80E+01 | 1.14E+00 | 1.20E+00 | |
| 5/4 8:00 | -1700 | -1700 | 0.455 | 1.270 | 0.135 | 0.135 | 1.26E+00 | 3.53E+01 | 1.14E+00 | 1.20E+00 | |
| 5/4 11:00 | -1700 | -1700 | 0.450 | 1.265 | 0.135 | 0.135 | 1.02E+00 | 3.17E+01 | 1.14E+00 | 1.19E+00 | |
| 5/4 14:00 | -1700 | -1650 | 0.453 | 1.260 | 0.135 | 0.135 | 9.40E-01 | 6.65E+01 | 1.14E+00 | 1.19E+00 | |
| 5/4 17:00 | -1700 | -1650 | 0.453 | 1.260 | 0.135 | 0.135 | 9.98E-01 | 4.05E+01 | 1.14E+00 | 1.19E+00 | |
| 5/4 20:00 | -1650 | -1650 | 0.450 | 1.265 | 0.135 | 0.135 | 1.33E+00 | 5.85E+01 | 1.14E+00 | 1.19E+00 | |
| 5/4 23:00 | -1600 | -1600 | 0.450 | 1.268 | 0.135 | 0.135 | 1.02E+00 | 3.01E+01 | 1.14E+00 | 1.19E+00 | |
| 5/5 2:00 | -1600 | -1600 | 0.455 | 1.273 | 0.135 | 0.135 | 7.33E-01 | 4.44E+01 | 1.14E+00 | 1.19E+00 | |
| 5/5 5:00 | -1600 | -1600 | 0.450 | 1.278 | 0.130 | 0.130 | 1.22E+00 | 5.29E+01 | 1.14E+00 | 1.18E+00 | |
| 5/5 8:00 | -1650 | -1600 | 0.450 | 1.275 | 0.130 | 0.130 | 1.17E+00 | 4.80E+01 | 1.14E+00 | 1.18E+00 | |
| 5/5 11:00 | -1650 | -1500 | 0.460 | 1.283 | 0.130 | 0.130 | 1.19E+00 | 5.80E+01 | 1.14E+00 | 1.18E+00 | |
| 5/5 14:00 | -1650 | -1500 | 0.460 | 1.283 | 0.130 | 0.130 | 1.20E+00 | 7.61E+01 | 1.14E+00 | 1.18E+00 | |
| 5/5 17:00 | -1650 | -1450 | 0.463 | 1.283 | 0.130 | 0.130 | 1.20E+00 | 4.18E+01 | 1.14E+00 | 1.18E+00 | |
| 5/5 20:00 | -1700 | -1450 | 0.460 | 1.280 | 0.130 | 0.125 | 1.23E+00 | 5.20E+01 | 1.14E+00 | 1.18E+00 | |
| 5/5 23:00 | -1700 | -1600 | 0.463 | 1.290 | 0.130 | 0.120 | 1.36E+00 | 2.05E+02 | 1.14E+00 | 1.18E+00 | |
| 5/6 2:00 | -1700 | -1650 | 0.448 | 1.280 | 0.130 | 0.120 | 1.70E+00 | 6.05E+01 | 1.14E+00 | 1.17E+00 | |
| 5/6 5:00 | -1700 | -1700 | 0.463 | 1.295 | 0.130 | 0.120 | 2.04E+00 | 2.22E+02 | 1.13E+00 | 1.17E+00 | |
| 5/6 8:00 | -1700 | -1650 | 0.460 | 1.288 | 0.130 | 0.120 | 1.15E+00 | 2.29E+02 | 1.13E+00 | 1.17E+00 | |
| 5/6 11:00 | -1650 | -1700 | 0.465 | 1.285 | 0.130 | 0.120 | 1.81E+00 | 2.19E+02 | 1.13E+00 | 1.16E+00 | |
| 5/6 14:00 | -1650 | -1700 | 0.463 | 1.290 | 0.125 | 0.120 | 1.93E+00 | 4.26E+01 | 1.13E+00 | 1.16E+00 | |
| 5/6 17:00 | -1650 | -1700 | 0.463 | 1.285 | 0.125 | 0.120 | 2.29E+00 | 3.71E+01 | 1.13E+00 | 1.16E+00 | |
| 5/6 20:00 | -1650 | -1700 | 0.460 | 1.295 | 0.125 | 0.115 | 2.80E+00 | 3.35E+01 | 1.12E+00 | 1.16E+00 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 5/6 23:00 | -1650 | -1700 | 0.460 | 1.295 | 0.125 | 0.115 | 2.11E+00 | 3.27E+01 | 1.12E+00 | 1.16E+00 | |
| 5/7 2:00 | -1650 | -1650 | 0.468 | 1.303 | 0.125 | 0.115 | 2.54E+00 | 2.88E+01 | 1.12E+00 | 1.16E+00 | |
| 5/7 5:00 | -1700 | -1700 | 0.465 | 1.303 | 0.125 | 0.115 | 2.56E+00 | 3.40E+01 | 1.12E+00 | 1.15E+00 | |
| 5/7 8:00 | -1700 | -1650 | 0.468 | 1.293 | 0.125 | 0.115 | 2.65E+00 | 3.54E+01 | 1.12E+00 | 1.15E+00 | |
| 5/7 11:00 | -1700 | -1650 | 0.463 | 1.290 | 0.125 | 0.115 | 2.31E+00 | 3.20E+01 | 1.12E+00 | 1.15E+00 | |
| 5/7 14:00 | -1650 | -1650 | 0.460 | 1.285 | 0.125 | 0.115 | 2.60E+00 | 3.28E+01 | 1.12E+00 | 1.15E+00 | |
| 5/7 17:00 | -1650 | -1650 | 0.463 | 1.293 | 0.125 | 0.115 | 3.07E+00 | 3.80E+01 | 1.12E+00 | 1.15E+00 | |
| 5/7 20:00 | -1700 | -1700 | 0.463 | 1.293 | 0.120 | 0.110 | 3.26E+00 | 3.15E+01 | 1.12E+00 | 1.15E+00 | |
| 5/7 23:00 | -1650 | -1650 | 0.458 | 1.293 | 0.125 | 0.110 | 3.40E+00 | 3.38E+01 | 1.12E+00 | 1.15E+00 | |
| 5/8 2:00 | -1650 | -1700 | 0.460 | 1.298 | 0.120 | 0.110 | 2.94E+00 | 2.97E+01 | 1.12E+00 | 1.14E+00 | |
| 5/8 5:00 | -1650 | -1700 | 0.460 | 1.290 | 0.120 | 0.110 | 2.59E+00 | 3.63E+01 | 1.12E+00 | 1.14E+00 | |
| 5/8 8:00 | -1700 | -1700 | 0.458 | 1.293 | 0.120 | 0.110 | 3.48E+00 | 3.12E+01 | 1.12E+00 | 1.14E+00 | |
| 5/8 11:00 | -1700 | -1700 | 0.455 | 1.290 | 0.120 | 0.110 | 3.16E+00 | 3.00E+01 | 1.12E+00 | 1.14E+00 | |
| 5/8 14:00 | -1700 | -1700 | 0.458 | 1.290 | 0.120 | 0.110 | 3.25E+00 | 3.30E+01 | 1.12E+00 | 1.14E+00 | |
| 5/8 17:00 | -1700 | -1700 | 0.458 | 1.285 | 0.120 | 0.110 | 3.62E+00 | 4.52E+01 | 1.12E+00 | 1.14E+00 | |
| 5/8 20:00 | -1700 | -1700 | 0.458 | 1.295 | 0.120 | 0.110 | 3.05E+00 | 3.02E+01 | 1.11E+00 | 1.13E+00 | |
| 5/8 23:00 | -1700 | -1700 | 0.465 | 1.295 | 0.120 | 0.110 | 2.78E+00 | 3.81E+01 | 1.11E+00 | 1.13E+00 | |
| 5/9 2:00 | -1650 | -1700 | 0.460 | 1.290 | 0.120 | 0.105 | 2.88E+00 | 3.60E+01 | 1.11E+00 | 1.13E+00 | |
| 5/9 5:00 | -1650 | -1700 | 0.460 | 1.300 | 0.120 | 0.105 | 3.18E+00 | 2.76E+01 | 1.11E+00 | 1.13E+00 | |
| 5/9 8:00 | -1650 | -1700 | 0.458 | 1.293 | 0.120 | 0.105 | 3.10E+00 | 3.23E+01 | 1.11E+00 | 1.13E+00 | |
| 5/9 11:00 | -1650 | -1650 | 0.465 | 1.288 | 0.120 | 0.105 | 3.19E+00 | 4.48E+01 | 1.11E+00 | 1.12E+00 | |
| 5/9 14:00 | -1650 | -1650 | 0.458 | 1.290 | 0.120 | 0.105 | 3.71E+00 | 4.68E+01 | 1.11E+00 | 1.12E+00 | |
| 5/9 17:00 | -1650 | -1700 | 0.460 | 1.280 | 0.115 | 0.105 | 3.55E+00 | 2.48E+01 | 1.11E+00 | 1.12E+00 | |
| 5/9 20:00 | -1650 | -1700 | 0.460 | 1.278 | 0.120 | 0.105 | 3.30E+00 | 1.72E+02 | 1.11E+00 | 1.12E+00 | |
| 5/9 23:00 | -1650 | -1650 | 0.458 | 1.283 | 0.120 | 0.105 | 3.97E+00 | 3.19E+01 | 1.11E+00 | 1.12E+00 | |
| 5/10 2:00 | -1650 | -1650 | 0.465 | 1.280 | 0.120 | 0.105 | 3.73E+00 | 2.93E+01 | 1.11E+00 | 1.12E+00 | |
| 5/10 5:00 | -1650 | -1650 | 0.458 | 1.275 | 0.115 | 0.105 | 3.40E+00 | 1.72E+02 | 1.10E+00 | 1.11E+00 | |
| 5/10 8:00 | -1650 | -1650 | 0.463 | 1.280 | 0.120 | 0.105 | 3.76E+00 | 3.16E+01 | 1.10E+00 | 1.11E+00 | |
| 5/10 11:00 | | -1650 | 0.463 | 1.273 | 0.120 | 0.105 | 3.44E+00 | 1.50E+02 | 1.10E+00 | 1.11E+00 | |
| 5/10 14:00 | | -1650 | 0.463 | 1.273 | 0.120 | 0.105 | 3.69E+00 | 6.22E+01 | 1.10E+00 | 1.11E+00 | |
| 5/10 17:00 | | -1650 | 0.463 | 1.273 | 0.120 | 0.105 | 3.71E+00 | 1.70E+02 | 1.10E+00 | 1.11E+00 | |
| 5/10 20:00 | | -1650 | 0.463 | 1.278 | 0.120 | 0.105 | 3.28E+00 | 1.76E+02 | 1.10E+00 | 1.11E+00 | |
| 5/10 23:00 | | -1650 | 0.470 | 1.283 | 0.120 | 0.105 | 3.25E+00 | 3.10E+01 | 1.10E+00 | 1.10E+00 | |
| 5/11 2:00 | | -1700 | 0.465 | 1.285 | 0.120 | 0.105 | 3.20E+00 | 1.81E+02 | 1.10E+00 | 1.10E+00 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 5/11 5:00 | | -1700 | 0.463 | 1.280 | 0.120 | 0.105 | 3.61E+00 | 1.81E+02 | 1.09E+00 | 1.10E+00 | |
| 5/11 8:00 | | -1700 | 0.465 | 1.288 | 0.120 | 0.105 | 3.56E+00 | 1.88E+02 | 1.09E+00 | 1.10E+00 | |
| 5/11 11:00 | | -1500 | 0.460 | 1.278 | 0.110 | 0.100 | 3.35E+00 | 1.95E+02 | 1.09E+00 | 1.10E+00 | |
| 5/11 14:00 | | -1450 | 0.458 | 1.278 | 0.115 | 0.100 | 3.33E+00 | 3.00E+01 | 1.09E+00 | 1.10E+00 | |
| 5/11 17:00 | | -1550 | 0.460 | 1.283 | 0.117 | 0.100 | 3.88E+00 | 2.01E+02 | 1.09E+00 | 1.10E+00 | |
| 5/11 20:00 | | -1650 | 0.458 | 1.285 | 0.118 | 0.100 | 3.48E+00 | 3.69E+01 | 1.09E+00 | 1.10E+00 | |
| 5/11 23:00 | | -1650 | 0.460 | 1.290 | 0.119 | 0.100 | 3.65E+00 | 2.04E+02 | 1.09E+00 | 1.09E+00 | |
| 5/12 5:00 | | -1650 | 0.463 | 1.293 | 0.120 | 0.100 | 3.65E+00 | 2.63E+01 | 1.09E+00 | 1.09E+00 | |
| 5/12 8:00 | | -1700 | 0.460 | 1.293 | 0.121 | 0.100 | 3.82E+00 | 2.07E+02 | 1.09E+00 | 1.09E+00 | |
| 5/12 11:00 | | -1700 | 0.465 | 1.300 | 0.121 | 0.100 | 3.59E+00 | 3.75E+01 | 1.09E+00 | 1.09E+00 | |
| 5/12 14:00 | | -1700 | 0.465 | 1.310 | 0.122 | 0.100 | 3.83E+00 | 2.12E+02 | 1.08E+00 | 1.09E+00 | |
| 5/12 17:00 | | -1700 | 0.470 | 1.305 | 0.122 | 0.100 | 4.13E+00 | 1.97E+02 | 1.08E+00 | 1.09E+00 | |
| 5/12 20:00 | | -1700 | 0.475 | 1.303 | 0.122 | 0.100 | 4.06E+00 | 2.08E+02 | 1.08E+00 | 1.09E+00 | |
| 5/12 23:00 | | -1650 | 0.480 | 1.303 | 0.121 | 0.100 | 3.87E+00 | 3.50E+01 | 1.08E+00 | 1.09E+00 | |
| 5/13 2:00 | | -1700 | 0.480 | 1.295 | 0.121 | 0.100 | 3.88E+00 | 2.08E+02 | 1.08E+00 | 1.08E+00 | |
| 5/13 5:00 | | -1700 | 0.485 | 1.295 | 0.120 | 0.100 | 3.50E+00 | 2.04E+02 | 1.07E+00 | 1.08E+00 | |
| 5/13 8:00 | | -1700 | 0.480 | 1.293 | 0.120 | 0.100 | 3.77E+00 | 2.15E+02 | 1.07E+00 | 1.08E+00 | |
| 5/13 11:00 | | -1700 | 0.478 | 1.298 | 0.120 | 0.100 | 3.78E+00 | 2.19E+02 | 1.07E+00 | 1.08E+00 | |
| 5/13 14:00 | | -1700 | 0.483 | 1.295 | 0.121 | 0.100 | 3.59E+00 | 2.23E+02 | 1.07E+00 | 1.08E+00 | |
| 5/13 17:00 | | -1700 | 0.480 | 1.298 | 0.121 | 0.100 | 4.15E+00 | 3.23E+01 | 1.07E+00 | 1.08E+00 | |
| 5/13 20:00 | | -1700 | 0.483 | 1.313 | 0.121 | 0.100 | 3.57E+00 | 2.26E+02 | 1.07E+00 | 1.08E+00 | |
| 5/13 23:00 | | -1700 | 0.480 | 1.318 | 0.121 | 0.100 | 3.50E+00 | 2.15E+02 | 1.07E+00 | 1.08E+00 | |
| 5/14 2:00 | | -1700 | 0.478 | 1.313 | 0.121 | 0.100 | 3.63E+00 | 2.22E+02 | 1.07E+00 | 1.07E+00 | |
| 5/14 5:00 | | -1700 | 0.480 | 1.310 | 0.121 | 0.100 | 3.54E+00 | 2.28E+02 | 1.06E+00 | 1.07E+00 | |
| 5/14 8:00 | | -1700 | 0.483 | 1.308 | 0.121 | 0.100 | 3.82E+00 | 2.20E+02 | 1.06E+00 | 1.07E+00 | |
| 5/14 11:00 | | -1700 | 0.483 | 1.305 | 0.121 | 0.100 | 3.67E+00 | 2.57E+02 | 1.06E+00 | 1.07E+00 | |
| 5/14 14:00 | | -1700 | 0.480 | 1.300 | 0.122 | 0.100 | 3.00E+00 | 2.54E+02 | 1.06E+00 | 1.07E+00 | |
| 5/14 17:00 | | -1700 | 0.478 | 1.300 | 0.121 | 0.100 | 3.90E+00 | 2.53E+02 | 1.06E+00 | 1.07E+00 | |
| 5/14 20:00 | | -1700 | 0.478 | 1.295 | 0.121 | 0.100 | 3.72E+00 | 2.51E+02 | 1.06E+00 | 1.07E+00 | |
| 5/14 23:00 | | -1700 | 0.488 | 1.313 | 0.122 | 0.100 | 3.63E+00 | 2.51E+02 | 1.06E+00 | 1.06E+00 | |
| 5/15 2:00 | | -1700 | 0.490 | 1.323 | 0.122 | 0.100 | 3.73E+00 | 3.07E+01 | 1.06E+00 | 1.06E+00 | |
| 5/15 5:00 | | -1700 | 0.488 | 1.330 | 0.122 | 0.100 | 3.62E+00 | 5.27E+01 | 1.06E+00 | 1.06E+00 | |
| 5/15 8:00 | | -1700 | 0.488 | 1.335 | 0.122 | 0.100 | 3.76E+00 | 4.90E+01 | 1.06E+00 | 1.06E+00 | |
| 5/15 11:00 | | -1700 | 0.485 | 1.335 | 0.122 | 0.100 | 3.80E+00 | 3.28E+01 | 1.05E+00 | 1.06E+00 | |

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level(fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | note |
|------------|---|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|------|
| 5/15 14:00 | | -1700 | 0.485 | 1.330 | 0.122 | 0.100 | 3.99E+00 | 2.29E+02 | 1.05E+00 | 1.06E+00 | |
| 5/15 17:00 | | -1650 | 0.485 | 1.323 | 0.120 | 0.100 | 3.88E+00 | 2.29E+02 | 1.05E+00 | 1.06E+00 | |
| 5/15 20:00 | | -1700 | 0.483 | 1.330 | 0.119 | 0.100 | 4.06E+00 | 5.30E+01 | 1.05E+00 | 1.05E+00 | |
| 5/15 23:00 | | -1700 | 0.483 | 1.333 | 0.119 | 0.100 | 3.85E+00 | 4.40E+01 | 1.05E+00 | 1.05E+00 | |

measurement instrument measurement instrument

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Vessel Flange | Vessel Flange | Feedwater Nozzle N4B (end) | Feedwater Nozzle N4B (inside) | Feedwater Nozzle N4C (end) | Feedwater Nozzle N4C (inside) | Vessel Core | Reactor Pressure Vessel Bottom Part | CRD Housing Upper Part | CRD Housing Lower Part | Safety Valve (exhaust air) 203-4A① | Safety Valve (exhaust air) 203-4C② | Safety Valve (exhaust air) 203-4B③ | SR Valve (exhaust air) 203-3A⑥ | SR Valve (exhaust air) 203-3B⑦ | SR Valve (exhaust air) 203-3C⑧ | SR Valve (exhaust air) 203-3D⑨ | D/W HVH Return Air Duct (HVH-12C) | RPV Bellows Air (HVH-12A) | S/C Pool Water Temperature A | S/C Pool Water Temperature B |
|------------|---------------|---------------|----------------------------|-------------------------------|----------------------------|-------------------------------|-------------|-------------------------------------|------------------------|------------------------|------------------------------------|------------------------------------|------------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|------------------------------------|---------------------------|------------------------------|------------------------------|
| 5/14 14:00 | 92.5 | 90.5 | 110.7 | 90.4 | 89.9 | 89 | 89.8 | 90.3 | 91.1 | 90.8 | 107.3 | 98.7 | 93.1 | 100.6 | 97.3 | 100.6 | 93.7 | 85 | 90.4 | 52 | 51.8 |
| 5/14 17:00 | 91.8 | 90 | 110.9 | 89.9 | 89.3 | 88.3 | 89.1 | 89.7 | 90.7 | 90.4 | 106.6 | 98.1 | 92.5 | 99.8 | 96.7 | 99.9 | 93.1 | 84.5 | 89.9 | 52 | 51.8 |
| 5/14 20:00 | 91.6 | 89.9 | 111.1 | 89.8 | 89.2 | 88.1 | 88.9 | 89.5 | 90.6 | 90.3 | 106.6 | 98.1 | 92.3 | 99.7 | 96.5 | 99.9 | 92.9 | 84.4 | 89.7 | 51.9 | 51.8 |
| 5/14 23:00 | 91.3 | 89.6 | 109.7 | 89.6 | 88.9 | 87.9 | 88.7 | 89.2 | 90.4 | 90 | 106.6 | 97.9 | 92 | 99.4 | 96.3 | 99.6 | 92.6 | 84.2 | 89.5 | 52 | 51.8 |
| 5/15 2:00 | 91.1 | 89.3 | 110.4 | 89.3 | 88.7 | 87.7 | 88.5 | 89 | 90.1 | 89.8 | 106.3 | 97.8 | 91.9 | 98.8 | 96.1 | 98.9 | 92.4 | 84 | 89.3 | 52 | 51.8 |
| 5/15 5:00 | 90.8 | 89.1 | 110.2 | 89.2 | 88.5 | 87.5 | 88.3 | 88.8 | 89.9 | 89.6 | 106 | 97.7 | 91.6 | 98.5 | 95.9 | 98.6 | 92.1 | 84 | 89.1 | 52 | 51.8 |
| 5/15 8:00 | 90.8 | 89 | 109.9 | 89.1 | 88.4 | 87.4 | 88.2 | 88.7 | 89.8 | 89.5 | 105.8 | 97.8 | 91.5 | 98.3 | 95.9 | 98.4 | 92 | 84 | 89.1 | 52 | 51.8 |
| 5/15 11:00 | 90.8 | 89 | 110.4 | 88.9 | 88.3 | 87.3 | 88.1 | 88.6 | 89.7 | 89.4 | 105.6 | 98 | 91.3 | 98 | 95.8 | 98 | 91.7 | 84.1 | 89.1 | 52 | 51.8 |
| 5/15 14:00 | 90.9 | 89.1 | 110.9 | 88.9 | 88.3 | 87.3 | 88.1 | 88.7 | 89.7 | 89.4 | 105.4 | 98.1 | 91.2 | 97.8 | 95.6 | 97.9 | 91.6 | 84.2 | 89.2 | 52 | 51.9 |
| 5/15 17:00 | 90 | 88.2 | 107.8 | 88.1 | 87.5 | 86.6 | 87.4 | 87.9 | 88.9 | 88.5 | 103.2 | 96.9 | 90.5 | 96.3 | 94.1 | 96.2 | 90.7 | 83.7 | 88.3 | 52.1 | 51.9 |
| 5/15 20:00 | 89 | 87 | 101.2 | 87.1 | 86.6 | 85.6 | 86.4 | 86.8 | 88 | 87.6 | 101.3 | 95.8 | 89.6 | 94.5 | 92.5 | 94.2 | 89.7 | 83 | 87.4 | 52.1 | 51.9 |
| 5/15 23:00 | 88 | 86.1 | 99.1 | 86.4 | 85.8 | 84.8 | 85.6 | 86.1 | 87.3 | 86.9 | 99.7 | 94.7 | 88.8 | 93.3 | 91.4 | 93.1 | 88.8 | 82.5 | 86.7 | 52.1 | 51.9 |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|---|
| 2011/3/11 20:00 | | | | | | | | | | | | |
| 2011/3/11 20:07 | | | 7.000 | | | | | | | | | |
| 2011/3/11 20:15 | | | | | | | | | | | | |
| 2011/3/11 20:30 | | | | | | | | | | | | |
| 2011/3/11 21:00 | | | | | | | | | | | | |
| 2011/3/11 21:30 | | | | | | | | | | | | |
| 2011/3/11 22:00 | 3400 | | | | | | | | | | | |
| 2011/3/11 22:10 | 3400 | | | | | | | | | | | |
| 2011/3/11 22:20 | 3400 | | | | | | | | | | | |
| 2011/3/11 22:30 | | | | | | | | | | | | |
| 2011/3/11 22:35 | 3400 | | | | | | | | | | | |
| 2011/3/11 22:47 | 3400 | | | | | | | | | | | |
| 2011/3/11 23:05 | 3400 | | | | | | | | | | | |
| 2011/3/11 23:20 | 3500 | | | | | | | | | | | |
| 2011/3/11 23:25 | | | 6.300 | | 0.141 | | | | | | | D/W pressure – converted from gage to abs |
| 2011/3/11 23:30 | 3500 | | | | | | | | | | | |
| 2011/3/11 23:50 | 3500 | | | | | | | | | | | |
| 2011/3/11 23:55 | 3500 | | | | | | | | | | | |
| 2011/3/12 0:00 | 3500 | | | | | | | | | | | |
| 2011/3/12 0:30 | | | | | | | | | | | | |
| 2011/3/12 0:43 | 3500 | | | | | | | | | | | |
| 2011/3/12 1:00 | 3600 | | | | | | | | | | | |
| 2011/3/12 1:25 | 3600 | | | | | | | | | | | |
| 2011/3/12 1:30 | | | 5.300 | | 0.151 | | | | | | | D/W pressure – converted from gage to abs |
| 2011/3/12 1:40 | 3600 | | | | | | | | | | | |
| 2011/3/12 1:55 | 3600 | | | | | | | | | | | |
| 2011/3/12 2:12 | 3600 | | | | | | | | | | | |
| 2011/3/12 2:30 | 3600 | | | | | | | | | | | |
| 2011/3/12 2:50 | 3700 | | 5.600 | | | | | | | | | |
| 2011/3/12 2:55 | | | | | | | | | | | | |
| 2011/3/12 3:05 | 3700 | | | | | | | | | | | |
| 2011/3/12 3:15 | | | | | 0.161 | | | | | | | D/W pressure – converted from gage to abs |
| 2011/3/12 3:30 | 3700 | | | | | | | | | | | |
| 2011/3/12 3:40 | | | | | | | | | | | | |
| 2011/3/12 3:55 | 3700 | | | | | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

Replaced on June 13

[Note]
Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|---|
| 2011/3/12 4:19 | 3700 | | | | | | | | | | | |
| 2011/3/12 4:35 | 3700 | | | | | | | | | | | |
| 2011/3/12 4:55 | 3700 | | | | | | | | | | | |
| 2011/3/12 5:20 | 3700 | | | | | | | | | | | |
| 2011/3/12 5:30 | 3700 | | | | | | | | | | | |
| 2011/3/12 5:55 | 3700 | | | | | | | | | | | |
| 2011/3/12 6:00 | 3700 | | | | | | | | | | | |
| 2011/3/12 6:30 | 3700 | | | | | | | | | | | |
| 2011/3/12 6:47 | 3600 | | | | | | | | | | | |
| 2011/3/12 7:00 | 3600 | | | | | | | | | | | |
| 2011/3/12 7:15 | 3600 | | | | | | | | | | | |
| 2011/3/12 7:30 | 3600 | | | | | | | | | | | |
| 2011/3/12 7:55 | 3600 | | | | | | | | | | | |
| 2011/3/12 8:10 | 3600 | | | | | | | | | | | |
| 2011/3/12 8:20 | | | | | | | | | | | | |
| 2011/3/12 8:25 | | | | | | | | | | | | |
| 2011/3/12 8:30 | 3600 | | | | | | | | | | | |
| 2011/3/12 8:38 | 3600 | | | | | | | | | | | |
| 2011/3/12 8:46 | 3600 | | 6.000 | | 0.186 | | | | | | | D/W pressure – converted from gage to abs |
| 2011/3/12 8:49 | | | | | | | | | | | | |
| 2011/3/12 8:58 | 3600 | | | | | | | | | | | |
| 2011/3/12 9:10 | | | | | | | | | | | | |
| 2011/3/12 9:25 | 3600 | | | | | | | | | | | |
| 2011/3/12 9:30 | | | | | | | | | | | | |
| 2011/3/12 9:48 | 3600 | | | | | | | | | | | |
| 2011/3/12 10:41 | 3600 | | | | | | | | | | | |
| 2011/3/12 10:52 | 3600 | | | | | | | | | | | |
| 2011/3/12 11:20 | 3600 | | | | | | | | | | | |
| 2011/3/12 11:30 | 3600 | | | | | | | | | | | |
| 2011/3/12 12:05 | | | | | | | | | | | | |
| 2011/3/12 12:12 | 3600 | | | | | | | | | | | |
| 2011/3/12 12:35 | | | | | | | | | | | | |
| 2011/3/12 12:55 | 3600 | | 6.100 | | 0.211 | | | | | | | D/W pressure – converted from gage to abs |
| 2011/3/12 13:14 | 3600 | | | | | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

Replaced on June 13

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|---|
| 2011/3/12 13:26 | 3600 | | | | | | | | | | | |
| 2011/3/12 13:38 | 3600 | | | | | | | | | | | |
| 2011/3/12 13:58 | 3600 | | | | | | | | | | | |
| 2011/3/12 14:10 | 3600 | | | | | | | | | | | |
| 2011/3/12 14:50 | 3600 | | | | | | | | | | | |
| 2011/3/12 15:22 | 3600 | | 6.300 | | 0.231 | | | | | | | D/W pressure – converted from gage to abs |
| 2011/3/12 15:37 | 3550 | | | | | | | | | | | |
| 2011/3/12 16:10 | 3600 | | | | | | | | | | | |
| 2011/3/12 16:31 | 3550 | | | | | | | | | | | |
| 2011/3/12 16:45 | 3550 | | | | | | | | | | | |
| 2011/3/12 17:00 | 3550 | | | | | | | | | | | |
| 2011/3/12 17:30 | 3550 | | | | | | | | | | | |
| 2011/3/12 18:00 | 3550 | | | | | | | | | | | |
| 2011/3/12 18:20 | | | 6.300 | | 0.256 | | | | | | | D/W pressure – converted from gage to abs |
| 2011/3/12 18:30 | 3550 | | | | | | | | | | | |
| 2011/3/12 19:00 | 3550 | | | | | | | | | | | |
| 2011/3/12 19:27 | 3550 | | | | | | | | | | | |
| 2011/3/12 19:42 | 3550 | | | | | | | | | | | |
| 2011/3/12 20:00 | 3550 | | | | | | | | | | | |
| 2011/3/12 20:30 | 3500 | | | | | | | | | | | |
| 2011/3/12 21:00 | 3550 | | | | | | | | | | | |
| 2011/3/12 21:30 | 3600 | | | | | | | | | | | |
| 2011/3/12 22:00 | 3600 | | | | | | | | | | | |
| 2011/3/12 22:20 | 3600 | | | | | | | | | | | |
| 2011/3/12 23:00 | 3600 | | | | | | | | | | | |
| 2011/3/12 23:30 | 3600 | | | | | | | | | | | |
| 2011/3/13 0:00 | 3600 | | | | | | | | | | | |
| 2011/3/13 0:30 | 3600 | | | | | | | | | | | |
| 2011/3/13 1:00 | 3650 | | | | | | | | | | | |
| 2011/3/13 2:00 | 3650 | | | | | | | | | | | |
| 2011/3/13 3:00 | 3650 | | 6.098 | | 0.315 | | | | | | | |
| 2011/3/13 3:38 | | | | | | | | | | | | |
| 2011/3/13 4:00 | 3650 | | 6.140 | | | | | | | | | |
| 2011/3/13 5:00 | 3650 | | 6.140 | | 0.330 | | | | | | | |
| 2011/3/13 5:30 | 3650 | | 6.140 | | 0.330 | | | | | | | |
| 2011/3/13 6:00 | 3650 | | 6.120 | | 0.340 | | | | | | | |
| 2011/3/13 6:30 | 3650 | | 6.120 | | 0.340 | | | | | | | |
| 2011/3/13 7:00 | 3650 | | 6.120 | | 0.340 | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/13 7:30 | 3650 | | 6.120 | | 0.350 | | | | | | | |
| 2011/3/13 8:00 | 3650 | | 6.100 | | 0.350 | | | | | | | |
| 2011/3/13 8:20 | 3650 | | 6.100 | | 0.350 | | | | | | | |
| 2011/3/13 8:30 | | | | | | | | | | | | |
| 2011/3/13 8:55 | 3700 | | 6.080 | | 0.360 | | | | | | | |
| 2011/3/13 9:25 | | 3700 | 6.080 | | 0.365 | | | | | | | |
| 2011/3/13 9:55 | | 3700 | 1.283 | | 0.160 | | | | | | | |
| 2011/3/13 10:30 | | 3800 | | | 0.100 | | | | | | | |
| 2011/3/13 10:35 | | 3700 | | | 0.010 | | | | | | | |
| 2011/3/13 10:40 | | 3700 | | | | | | | | | | |
| 2011/3/13 10:55 | | 3700 | | | | | | | | | | |
| 2011/3/13 11:05 | | 3700 | | | | | | | | | | |
| 2011/3/13 11:15 | | 3700 | | | | | | | | | | |
| 2011/3/13 11:25 | | 3700 | | | | | | | | | | |
| 2011/3/13 11:35 | | 3700 | | | 0.380 | | | | | | | |
| 2011/3/13 11:45 | | 3700 | | | | | | | | | | |
| 2011/3/13 11:55 | 3750 | | | | | | | | | | | |
| 2011/3/13 12:10 | | 3750 | | | | | | | | | | |
| 2011/3/13 12:20 | | 3750 | | | | | | | | | | |
| 2011/3/13 12:30 | | 3750 | | | | | | | | | | |
| 2011/3/13 12:40 | | 3750 | | | | | | | | | | |
| 2011/3/13 13:00 | | 3750 | | | | | | | | | | |
| 2011/3/13 13:10 | | 3750 | | | | | | | | | | |
| 2011/3/13 13:45 | | | | | 0.390 | | | | | | | |
| 2011/3/13 13:58 | | | | | 0.390 | | | | | | | |
| 2011/3/13 14:10 | | | | | | | | | | | | |
| 2011/3/13 14:15 | 3750 | | | | 0.390 | | | | | | | |
| 2011/3/13 14:30 | | 3750 | | | 0.390 | | | | | | | |
| 2011/3/13 14:45 | 3750 | | | | 0.395 | | | | | | | |
| 2011/3/13 15:00 | | 3750 | | | 0.395 | | | | | | | |
| 2011/3/13 15:15 | | 3750 | | | 0.395 | | | | | | | |
| 2011/3/13 15:30 | | 3750 | 5.850 | | 0.400 | | | | | | | |
| 2011/3/13 15:45 | | 3800 | 5.850 | | 0.400 | | | | | | | |
| 2011/3/13 16:00 | | 3750 | 5.850 | | 0.400 | | | | | | | |
| 2011/3/13 16:15 | 3750 | 3800 | 5.850 | | 0.400 | | | | | | | |
| 2011/3/13 16:30 | 3750 | 3800 | 5.850 | | 0.400 | | | | | | | |
| 2011/3/13 16:45 | 3750 | 3800 | 5.810 | | 0.405 | | | | | | | |
| 2011/3/13 17:00 | 3750 | 3800 | 5.810 | | 0.405 | | | | | | | |
| 2011/3/13 17:15 | 3750 | 3800 | 5.810 | | 0.405 | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

Replaced on June 13

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/13 17:30 | 3750 | 3750 | 5.780 | | 0.410 | | | | | | | |
| 2011/3/13 18:00 | 3750 | 3800 | | | 0.410 | | | | | | | |
| 2011/3/13 18:20 | 3800 | 3800 | | | 0.410 | | | | | | | |
| 2011/3/13 18:40 | 3800 | 3750 | | | 0.410 | | | | | | | |
| 2011/3/13 18:45 | | | | | | | | | | | | |
| 2011/3/13 19:00 | 3800 | 3800 | | | 0.420 | | | | | | | |
| 2011/3/13 19:30 | 3800 | 3800 | | | 0.420 | | | | | | | |
| 2011/3/13 20:00 | 3800 | 3800 | | | 0.420 | | | | | | | |
| 2011/3/13 20:15 | 3800 | 3800 | | | 0.420 | | | | | | | |
| 2011/3/13 20:30 | 3800 | 3800 | | | 0.420 | | | | | | | |
| 2011/3/13 21:00 | 3800 | 3850 | | | 0.420 | | | | | | | |
| 2011/3/13 21:30 | 3800 | 3850 | | | 0.425 | | | | | | | |
| 2011/3/13 22:00 | 3850 | 3900 | | | 0.430 | | | | | | | |
| 2011/3/13 22:30 | 3850 | 3900 | | | 0.430 | | | | | | | |
| 2011/3/13 23:00 | 3850 | 3900 | | | 0.430 | | | | | | | |
| 2011/3/13 23:30 | 3850 | 3900 | | | 0.435 | | | | | | | |
| 2011/3/14 0:00 | 3850 | 3900 | | | 0.435 | | | | | | | |
| 2011/3/14 0:30 | 3850 | 3900 | | | 0.435 | | | | | | | |
| 2011/3/14 1:00 | 3850 | 3900 | | | 0.435 | | | | | | | |
| 2011/3/14 1:30 | 3850 | 3900 | | | 0.440 | | | | | | | |
| 2011/3/14 2:00 | 3850 | 3900 | | | 0.440 | | | | | | | |
| 2011/3/14 2:30 | 3850 | 3900 | 5.470 | | 0.440 | | | | | | | |
| 2011/3/14 2:45 | 3850 | 3900 | 5.450 | | 0.440 | | | | | | | |
| 2011/3/14 3:00 | 3850 | 3900 | 5.450 | | | | | | | | | |
| 2011/3/14 3:30 | 3850 | 3900 | 5.450 | | | | | | | | | |
| 2011/3/14 4:00 | 3850 | 3900 | 5.420 | | | | | | | | | |
| 2011/3/14 4:30 | 3850 | 3900 | 5.400 | | | 0.467 | | | | | | |
| 2011/3/14 5:00 | 3900 | 3900 | 5.400 | | | 0.467 | | | | | | |
| 2011/3/14 5:30 | 3900 | 3900 | 5.400 | | | 0.469 | | | | | | |
| 2011/3/14 6:00 | 3900 | 3900 | 5.355 | | | 0.471 | 1.00E-03 | | 9.00E-03 | | | |
| 2011/3/14 6:10 | | | | | 0.455 | | | | | | | |
| 2011/3/14 6:30 | 3900 | 3900 | 5.355 | | 0.455 | | 1.00E-03 | | 9.00E-03 | | | |
| 2011/3/14 7:00 | 3900 | 3950 | 5.333 | | 0.455 | 0.473 | 1.00E-03 | | 8.50E-03 | | | |
| 2011/3/14 7:15 | 3950 | 3950 | | | | | | | | | | |
| 2011/3/14 7:30 | 3950 | 3950 | 5.333 | | 0.455 | 0.473 | 1.00E-03 | | 8.00E-03 | | | |
| 2011/3/14 8:00 | 3950 | 3950 | 5.310 | | 0.455 | 0.474 | 1.00E-03 | | 1.00E-02 | | | |
| 2011/3/14 8:30 | 3950 | 3950 | 5.310 | | 0.455 | 0.474 | 1.00E-03 | | 1.10E-02 | | | |
| 2011/3/14 8:45 | | | | | | | 1.00E-03 | | 1.10E-02 | | | |
| 2011/3/14 9:00 | 3900 | 3950 | 5.310 | | 0.460 | 0.478 | 1.00E-03 | | 1.15E-02 | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

Replaced on June 13

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/14 9:35 | 3800 | 3850 | 5.468 | | 0.460 | 0.476 | 1.00E-03 | | 1.15E-02 | | | |
| 2011/3/14 9:37 | 3850 | 3850 | | | | | | | | | | |
| 2011/3/14 9:45 | 3800 | 3800 | 5.445 | | 0.460 | | 1.00E-03 | | 1.20E-02 | | | |
| 2011/3/14 10:00 | 3800 | 3850 | 5.490 | | 0.460 | 0.480 | 1.00E-03 | | 1.15E-02 | | | |
| 2011/3/14 10:15 | | | | | | | 1.00E-03 | | 9.70E-03 | | | |
| 2011/3/14 10:30 | 3800 | 3850 | 5.648 | | 0.460 | 0.481 | 1.00E-03 | | 9.50E-03 | | | |
| 2011/3/14 11:30 | 3400 | 3400 | 6.008 | | 0.460 | 0.485 | 1.00E-03 | | 1.20E-02 | | | |
| 2011/3/14 12:00 | 3400 | 3400 | 6.008 | | 0.460 | 0.485 | 1.00E-03 | | 1.20E-02 | | | |
| 2011/3/14 12:30 | 2950 | 3000 | 6.188 | | 0.465 | 0.486 | 1.00E-03 | | 1.10E-02 | | | |
| 2011/3/14 13:00 | 2500 | 2500 | 7.065 | | | | | | | | | |
| 2011/3/14 13:10 | 2500 | 2500 | 7.065 | | 0.465 | | | | | | | |
| 2011/3/14 13:24 | 2400 | 2400 | 7.470 | | 0.465 | | | | | | | |
| 2011/3/14 13:30 | | | 7.459 | | | | | | | | | |
| 2011/3/14 13:40 | 2250 | 2250 | | | | | | | | | | |
| 2011/3/14 13:45 | 2200 | 2200 | 7.225 | | 0.460 | | | | | | | |
| 2011/3/14 14:00 | 2000 | 2000 | 7.527 | | 0.460 | | | | | | | |
| 2011/3/14 14:10 | 1850 | 1850 | 7.392 | | 0.460 | | | | | | | |
| 2011/3/14 14:20 | 1650 | 1650 | | | 0.455 | | | | | | | |
| 2011/3/14 14:27 | 1650 | 1650 | | | 0.455 | | | | | | | |
| 2011/3/14 14:40 | 1550 | 1550 | 7.425 | | 0.450 | | 1.00E-03 | | 1.30E-02 | | | |
| 2011/3/14 14:50 | 1250 | 1250 | 7.470 | | 0.445 | | | | | | | |
| 2011/3/14 15:00 | 1200 | 1200 | 7.392 | | 0.440 | | 1.00E-03 | | 1.30E-02 | | | |
| 2011/3/14 15:15 | 1100 | 1100 | 7.302 | | 0.440 | | 1.08E-03 | | 1.03E-02 | | | |
| 2011/3/14 15:30 | 900 | 900 | 7.020 | | 0.430 | | | | | | | |
| 2011/3/14 15:40 | 700 | 700 | 7.070 | | 0.430 | | | | | | | |
| 2011/3/14 15:50 | 500 | 500 | 7.425 | | 0.420 | | | | | | | |
| 2011/3/14 16:00 | 300 | 300 | 7.448 | | 0.420 | | | | | | | |
| 2011/3/14 16:10 | 100 | 100 | 7.448 | | 0.420 | | | | | | | |
| 2011/3/14 16:20 | 0 | 0 | 6.998 | | 0.420 | | | | | | | |
| 2011/3/14 16:34 | | | 6.998 | | | | | | | | | |
| 2011/3/14 16:36 | | | 7.403 | | | | | | | | | |
| 2011/3/14 16:39 | | | 7.425 | | | | | | | | | |
| 2011/3/14 16:43 | -300 | | | | | | | | | | | |
| 2011/3/14 16:57 | -520 | | | | 0.400 | | | | | | | |
| 2011/3/14 17:12 | -800 | | 7.403 | | | | | | | | | |
| 2011/3/14 17:14 | -850 | | 7.403 | | | | | | | | | |
| 2011/3/14 17:16 | -950 | | 6.975 | | | | | | | | | |
| 2011/3/14 17:17 | -1000 | | | | | | | | | | | |
| 2011/3/14 17:20 | | | 7.290 | | | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/14 17:24 | | | 7.358 | | 0.400 | | | | | | | |
| 2011/3/14 17:28 | -1050 | | 7.358 | | | | | | | | | |
| 2011/3/14 17:30 | -1100 | | 6.970 | | | | | | | | | |
| 2011/3/14 17:31 | | | 7.380 | | | | | | | | | |
| 2011/3/14 17:33 | | | 7.880 | | | | | | | | | |
| 2011/3/14 17:35 | | | 6.975 | | | | | | | | | |
| 2011/3/14 17:48 | -1450 | | 7.358 | | | | | | | | | |
| 2011/3/14 17:52 | -1500 | | 7.358 | | | | | | | | | |
| 2011/3/14 17:55 | -1600 | | 6.975 | | 0.400 | | | | | | | |
| 2011/3/14 18:00 | -1600 | | 7.133 | | | | | | | | | |
| 2011/3/14 18:03 | | | 6.075 | | | | | | | | | |
| 2011/3/14 18:05 | -2000 | | 5.625 | | | | | | | | | |
| 2011/3/14 18:06 | -1100 | | 5.400 | | | | | | | | | |
| 2011/3/14 18:07 | -2100 | | 4.950 | | | | | | | | | |
| 2011/3/14 18:08 | -2000 | | 4.500 | | | | | | | | | |
| 2011/3/14 18:09 | -3000 | | 3.150 | | 0.395 | | | | | | | |
| 2011/3/14 18:10 | -3000 | | 2.995 | | 0.395 | | | | | | | |
| 2011/3/14 18:12 | -3250 | | 2.475 | | 0.395 | | | | | | | |
| 2011/3/14 18:13 | -3400 | | 2.183 | | 0.395 | | | | | | | |
| 2011/3/14 18:14 | -3500 | | 1.913 | | 0.395 | | | | | | | |
| 2011/3/14 18:17 | -3500 | | 1.643 | | 0.395 | | | | | | | |
| 2011/3/14 18:18 | -3600 | | 1.513 | | 0.400 | | | | | | | |
| 2011/3/14 18:19 | -3600 | | 1.463 | | 0.400 | | | | | | | |
| 2011/3/14 18:20 | -3600 | | 1.395 | | 0.400 | | | | | | | |
| 2011/3/14 18:21 | -3600 | | 1.305 | | 0.400 | | | | | | | |
| 2011/3/14 18:22 | -3700 | | 1.215 | | 0.400 | | | | | | | |
| 2011/3/14 18:23 | -3700 | | 1.170 | | 0.400 | | | | | | | |
| 2011/3/14 18:24 | -3700 | | 1.125 | | 0.400 | | | | | | | |
| 2011/3/14 18:25 | -3700 | | 0.125 | | 0.400 | | | | | | | |
| 2011/3/14 18:26 | -3700 | | 1.035 | | 0.400 | | | | | | | |
| 2011/3/14 18:27 | -3700 | | 0.990 | | 0.400 | | | | | | | |
| 2011/3/14 18:28 | -3700 | | 0.945 | | 0.400 | | | | | | | |
| 2011/3/14 18:29 | -3700 | | 0.900 | | 0.400 | | | | | | | |
| 2011/3/14 18:30 | -3700 | | 0.878 | | 0.400 | | | | | | | |
| 2011/3/14 18:31 | -3700 | | 0.855 | | 0.400 | | | | | | | |
| 2011/3/14 18:32 | -3700 | | 0.810 | | 0.400 | | | | | | | |
| 2011/3/14 18:33 | -3700 | | 0.780 | | 0.400 | | | | | | | |
| 2011/3/14 18:34 | -3700 | | 0.765 | | 0.400 | | | | | | | |
| 2011/3/14 18:35 | -3700 | | 0.720 | | 0.400 | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

Replaced on June 13

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/14 18:36 | -3700 | | 0.698 | | 0.400 | | | | | | | |
| 2011/3/14 18:37 | -3700 | | 0.675 | | 0.400 | | | | | | | |
| 2011/3/14 18:39 | -3700 | | 0.540 | | 0.400 | | | | | | | |
| 2011/3/14 18:40 | -3700 | | 0.563 | | 0.400 | | | | | | | |
| 2011/3/14 18:42 | -3700 | | 0.540 | | 0.400 | | | | | | | |
| 2011/3/14 18:45 | -3700 | | 0.563 | | 0.400 | | | | | | | |
| 2011/3/14 18:47 | -3700 | | 0.585 | | 0.400 | | | | | | | |
| 2011/3/14 18:50 | | | 0.585 | | 0.400 | | | | | | | |
| 2011/3/14 18:52 | | | 0.638 | | 0.400 | | | | | | | |
| 2011/3/14 18:55 | | | 0.638 | | 0.400 | | | | | | | |
| 2011/3/14 19:00 | | | 0.630 | | 0.400 | | | | | | | |
| 2011/3/14 19:03 | | | 0.630 | | 0.400 | | | | | | | |
| 2011/3/14 19:12 | | | 0.653 | | 0.400 | | | | | | | |
| 2011/3/14 19:13 | | | 0.653 | | 0.400 | | | | | | | |
| 2011/3/14 19:18 | | | 0.653 | | 0.400 | | | | | | | |
| 2011/3/14 19:22 | | | 0.650 | | 0.395 | | | | | | | |
| 2011/3/14 19:35 | | | 0.608 | | 0.395 | | | | | | | |
| 2011/3/14 19:45 | | | 0.585 | | 0.395 | | | | | | | |
| 2011/3/14 19:49 | | | 0.585 | | 0.395 | | | | | | | |
| 2011/3/14 19:54 | | | 0.563 | | 0.395 | | | | | | | |
| 2011/3/14 19:55 | | | 0.563 | | 0.395 | | | | | | | |
| 2011/3/14 19:57 | | | 0.560 | | | | | | | | | |
| 2011/3/14 19:59 | | | 0.563 | | 0.455 | | | | | | | |
| 2011/3/14 20:03 | | | 0.540 | | 0.410 | | | | | | | |
| 2011/3/14 20:05 | | | 0.540 | | 0.410 | | | | | | | |
| 2011/3/14 20:07 | | | 0.540 | | 0.415 | | | | | | | |
| 2011/3/14 20:08 | | | 0.563 | | 0.415 | | | | | | | |
| 2011/3/14 20:10 | | | 0.540 | | 0.418 | | | | | | | |
| 2011/3/14 20:12 | | | 0.563 | | 0.419 | | | | | | | |
| 2011/3/14 20:13 | | | 0.540 | | 0.420 | | | | | | | |
| 2011/3/14 20:15 | | | 0.540 | | 0.420 | | | | | | | |
| 2011/3/14 20:18 | | | 0.563 | | 0.420 | | | | | | | |
| 2011/3/14 20:20 | | | 0.563 | | 0.420 | | | | | | | |
| 2011/3/14 20:21 | | | 0.563 | | 0.420 | | | | | | | |
| 2011/3/14 20:23 | | | 0.563 | | 0.420 | | | | | | | |
| 2011/3/14 20:26 | | | 0.585 | | 0.420 | | | | | | | |
| 2011/3/14 20:28 | | | 0.608 | | 0.420 | | | | | | | |
| 2011/3/14 20:32 | | | 0.608 | | 0.420 | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/14 20:33 | | | 0.653 | | 0.420 | | | | | | | |
| 2011/3/14 20:37 | | | 0.810 | | 0.421 | | | | | | | |
| 2011/3/14 20:43 | | | 0.833 | | 0.421 | | | | | | | |
| 2011/3/14 20:54 | | | 1.170 | | 0.420 | | | | | | | |
| 2011/3/14 20:59 | | | 1.373 | | 0.419 | | | | | | | |
| 2011/3/14 21:03 | | | 1.418 | | 0.419 | | | | | | | |
| 2011/3/14 21:06 | | | | | 0.419 | | | | | | | |
| 2011/3/14 21:09 | | | 1.440 | | 0.418 | | | | | | | |
| 2011/3/14 21:18 | | | 1.463 | | 0.418 | | | | | | | |
| 2011/3/14 21:20 | -3400 | | 0.833 | | 0.470 | | | | | | | |
| 2011/3/14 21:21 | -3500 | | 0.675 | | 0.465 | | | | | | | |
| 2011/3/14 21:26 | -3300 | | 0.608 | | 0.470 | | | | | | | |
| 2011/3/14 21:27 | -3300 | | 0.563 | | 0.470 | | | | | | | |
| 2011/3/14 21:29 | -3200 | | 0.518 | | 0.475 | | | | | | | |
| 2011/3/14 21:30 | -3000 | | 0.495 | | 0.475 | | | | | | | |
| 2011/3/14 21:31 | -3000 | | 0.450 | | 0.480 | | | | | | | |
| 2011/3/14 21:32 | -3000 | | 0.450 | | 0.480 | | | | | | | |
| 2011/3/14 21:33 | -2000 | | 0.450 | | 0.480 | | | | | | | |
| 2011/3/14 21:34 | -2000 | | 0.405 | | 0.480 | | | | | | | |
| 2011/3/14 21:35 | -2000 | | 0.405 | | 0.480 | | | | | | | |
| 2011/3/14 21:38 | -2000 | | | | 0.480 | | | | | | | |
| 2011/3/14 21:42 | -2000 | | | | 0.480 | | | | | | | |
| 2011/3/14 21:55 | -1800 | | 0.405 | | 0.470 | | 5.36E+00 | | 3.83E-01 | | | |
| 2011/3/14 22:00 | -1600 | | 0.405 | | 0.480 | | 5.79E+00 | | 3.95E-01 | | | |
| 2011/3/14 22:10 | -1600 | | 0.405 | | 0.480 | 0.400 | 6.49E+00 | | 5.04E-01 | | | |
| 2011/3/14 22:20 | -1400 | | 0.405 | | 0.480 | 0.370 | 6.88E+00 | | 5.06E-01 | | | |
| 2011/3/14 22:30 | -1200 | | 0.405 | | 0.482 | 0.370 | 7.46E+00 | | 5.51E-01 | | | |
| 2011/3/14 22:40 | -700 | | 0.428 | | 0.482 | 0.350 | 7.92E+00 | | 7.35E-01 | | | |
| 2011/3/14 22:50 | -1600 | | 1.823 | | 0.540 | 0.380 | 6.54E+00 | | 1.01E+00 | | | |
| 2011/3/14 23:00 | -1700 | | 2.070 | | 0.580 | 0.360 | | | | | | |
| 2011/3/14 23:10 | -2000 | | 2.655 | | 0.620 | 0.350 | | | | | | |
| 2011/3/14 23:11 | -2000 | | 2.655 | | 0.620 | 0.350 | | | | | | |
| 2011/3/14 23:20 | | | 3.150 | | | | 8.81E+00 | | 6.61E+00 | | | |
| 2011/3/14 23:25 | | | 3.150 | | 0.700 | | 8.81E+00 | | 6.61E+00 | | | |
| 2011/3/14 23:30 | | | 1.913 | | 0.700 | 0.310 | 1.50E+01 | | 7.40E+00 | | | |
| 2011/3/14 23:35 | | | 1.733 | | 0.740 | 0.300 | | | | | | |
| 2011/3/14 23:38 | | | 1.463 | | | 0.300 | | | | | | |
| 2011/3/14 23:40 | | | 1.170 | | 0.740 | 0.300 | | | | | | |
| 2011/3/14 23:41 | | | 0.968 | | 0.740 | 0.300 | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/14 23:42 | | | 0.810 | | 0.740 | 0.300 | 2.25E+01 | | 9.11E+00 | | | |
| 2011/3/14 23:44 | | | 0.698 | | 0.750 | 0.340 | 2.29E+01 | | 9.12E+00 | | | |
| 2011/3/14 23:46 | | | 0.675 | | 0.750 | 0.350 | 2.33E+01 | | 9.11E+00 | | | |
| 2011/3/14 23:50 | | | 0.675 | | 0.750 | 0.330 | 2.35E+01 | | 9.07E+00 | | | |
| 2011/3/14 23:52 | | | 0.653 | | 0.750 | 0.300 | 2.42E+01 | | 9.04E+00 | | | |
| 2011/3/14 23:54 | | | 0.653 | | 0.745 | 0.300 | 2.45E+01 | | 9.10E+00 | | | |
| 2011/3/15 0:02 | | | | | 0.740 | | | | | | | |
| 2011/3/15 0:04 | | | | | 0.740 | | | | | | | |
| 2011/3/15 0:05 | | | 0.653 | | 0.740 | 0.300 | | | | | | |
| 2011/3/15 0:06 | | | 0.675 | | 0.740 | 0.300 | | | | | | |
| 2011/3/15 0:07 | | | 0.675 | | 0.740 | 0.300 | | | | | | |
| 2011/3/15 0:08 | | | 0.788 | | 0.740 | 0.300 | | | | | | |
| 2011/3/15 0:10 | | | 0.833 | | 0.740 | 0.300 | | | | | | |
| 2011/3/15 0:16 | | | 1.035 | | 0.740 | 0.300 | | | | | | |
| 2011/3/15 0:22 | | | 1.170 | | 0.735 | 0.300 | | | | | | |
| 2011/3/15 0:28 | | | 1.350 | | 0.730 | 0.300 | | | | | | |
| 2011/3/15 0:32 | | | 1.485 | | 0.725 | 0.330 | | | | | | |
| 2011/3/15 0:41 | | | 1.710 | | 0.720 | 0.330 | | | | | | |
| 2011/3/15 0:45 | | | 1.823 | | | | | | | | | |
| 2011/3/15 0:49 | | | 2.003 | | | | | | | | | |
| 2011/3/15 1:00 | | | 2.430 | | | | | | | | | |
| 2011/3/15 1:02 | | | 2.520 | | | | | | | | | |
| 2011/3/15 1:10 | | | 1.440 | | 0.725 | | | | | | | |
| 2011/3/15 1:11 | | | 1.058 | | 0.725 | 0.330 | | | | | | |
| 2011/3/15 1:12 | | | 0.923 | | | | | | | | | |
| 2011/3/15 1:13 | | | 0.855 | | 0.730 | 0.330 | | | | | | |
| 2011/3/15 1:14 | | | 0.743 | | 0.730 | 0.310 | | | | | | |
| 2011/3/15 1:16 | | | 0.698 | | 0.720 | 0.310 | | | | | | |
| 2011/3/15 1:18 | | | 0.675 | | 0.730 | 0.300 | 2.88E+01 | | 8.08E+00 | | | |
| 2011/3/15 1:20 | | | 0.653 | | 0.730 | 0.330 | 2.89E+01 | | 8.12E+00 | | | |
| 2011/3/15 1:22 | | | 0.653 | | 0.730 | 0.310 | 2.90E+01 | | 8.13E+00 | | | |
| 2011/3/15 1:28 | | | 0.630 | | 0.730 | 0.330 | 2.90E+01 | | 7.96E+00 | | | |
| 2011/3/15 1:31 | | | 0.630 | | 0.730 | 0.320 | 2.91E+01 | | 7.81E+00 | | | |
| 2011/3/15 1:40 | | | 0.630 | | 0.725 | 0.310 | 2.94E+01 | | 7.84E+00 | | | |
| 2011/3/15 1:48 | | | 0.630 | | 0.725 | 0.310 | | | | | | |
| 2011/3/15 1:53 | | | 0.630 | | 0.725 | 0.330 | 3.04E+01 | | 7.56E+00 | | | |
| 2011/3/15 2:03 | | | 0.630 | | 0.725 | 0.330 | 3.04E+01 | | 7.40E+00 | | | |
| 2011/3/15 2:08 | | | 0.630 | | 0.725 | 0.330 | 3.09E+01 | | 7.37E+00 | | | |
| 2011/3/15 2:10 | | | 0.630 | | 0.730 | 0.340 | 3.11E+01 | | 7.27E+00 | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

Replaced on June 13

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|-----------------------------------|
| 2011/3/15 2:17 | | | 0.630 | | 0.730 | 0.340 | 3.15E+01 | | 7.15E+00 | | | |
| 2011/3/15 2:22 | | | 0.675 | | 0.740 | 0.330 | 3.22E+01 | | 7.00E+00 | | | |
| 2011/3/15 2:39 | | | 0.653 | | 0.750 | 0.330 | 3.46E+01 | | 6.96E+00 | | | |
| 2011/3/15 2:45 | | | 0.653 | | 0.750 | 0.320 | 3.65E+01 | | 6.88E+00 | | | |
| 2011/3/15 2:50 | | | 0.653 | | 0.750 | 0.330 | 3.78E+01 | | 6.82E+00 | | | |
| 2011/3/15 3:00 | | | 0.653 | | 0.750 | 0.330 | 4.09E+01 | | 6.60E+00 | | | |
| 2011/3/15 3:05 | | | 0.653 | | 0.750 | 0.330 | 4.18E+01 | | 6.58E+00 | | | |
| 2011/3/15 3:20 | | | 0.653 | | 0.750 | 0.330 | 4.30E+01 | | 6.42E+00 | | | |
| 2011/3/15 3:30 | | | 0.653 | | 0.750 | 0.330 | 4.59E+01 | | 6.31E+00 | | | |
| 2011/3/15 3:40 | | | 0.653 | | 0.750 | 0.330 | 4.76E+01 | | 6.23E+00 | | | |
| 2011/3/15 3:50 | | | 0.653 | | 0.750 | 0.330 | 4.94E+01 | | 6.22E+00 | | | |
| 2011/3/15 4:00 | | | 0.653 | | 0.750 | 0.330 | 5.01E+01 | | 6.09E+00 | | | |
| 2011/3/15 4:05 | | | 0.653 | | 0.750 | 0.330 | 5.12E+01 | | 5.87E+00 | | | |
| 2011/3/15 4:10 | | | 0.653 | | 0.750 | 0.310 | 5.19E+01 | | 5.72E+00 | | | |
| 2011/3/15 4:20 | | | 0.637 | | 0.750 | 0.310 | 5.32E+01 | | 5.65E+00 | | | |
| 2011/3/15 4:30 | | | 0.632 | | 0.750 | 0.300 | 5.44E+01 | | 5.58E+00 | | | |
| 2011/3/15 4:45 | | | 0.632 | | 0.750 | 0.310 | 5.55E+01 | | 5.52E+00 | | | |
| 2011/3/15 5:00 | | | 0.626 | | 0.750 | 0.300 | 5.75E+01 | | 5.29E+00 | | | |
| 2011/3/15 5:15 | | | 0.623 | | 0.740 | 0.300 | 5.83E+01 | | 5.19E+00 | | | |
| 2011/3/15 5:30 | | | 0.621 | | 0.730 | 0.310 | 5.95E+01 | | 5.08E+00 | | | |
| 2011/3/15 5:45 | | | 0.617 | | 0.740 | 0.320 | 6.06E+01 | | 5.00E+00 | | | |
| 2011/3/15 6:00 | | | 0.614 | | 0.730 | 0.270 | 6.16E+01 | | 4.89E+00 | | | |
| 2011/3/15 6:02 | | | 0.612 | | 0.730 | 0.000 | 6.26E+01 | | 4.80E+00 | | | |
| 2011/3/15 6:10 | -2800 | | | | 0.730 | 0.000 | | | | | | |
| 2011/3/15 6:20 | -2700 | | 0.612 | | 0.730 | 0.000 | 6.27E+01 | | 4.80E+00 | | | |
| 2011/3/15 6:25 | -2300 | | 0.610 | | 0.730 | 0.000 | 4.30E+01 | | 4.70E+00 | | | |
| 2011/3/15 7:20 | -2500 | | 0.612 | | 0.730 | 0.000 | | | | | | |
| 2011/3/15 11:25 | -1200 | | 0.270 | | 0.155 | | 4.56E+01 | | 5.79E+00 | | | Instrument failure - S/C pressure |
| 2011/3/15 11:42 | -1400 | | 0.315 | | 0.155 | | 4.61E+01 | | 5.52E+00 | | | |
| 2011/3/15 11:58 | -1350 | | 0.428 | | 0.155 | | 4.65E+01 | | 5.27E+00 | | | |
| 2011/3/15 13:00 | -1700 | | 0.608 | | 0.415 | | 4.77E+01 | | 4.62E+00 | | | |
| 2011/3/15 15:25 | -1950 | | 0.119 | | 0.275 | | 1.35E+02 | | 6.92E+00 | | | |
| 2011/3/15 15:50 | -1750 | | 0.117 | | 0.270 | | | | | | | |
| 2011/3/15 16:10 | -1700 | | 0.119 | | 0.270 | | 1.38E+02 | | 6.49E+00 | | | |
| 2011/3/15 18:43 | -1200 | | 0.099 | | 0.250 | | 1.22E+02 | | 4.40E+00 | | | |
| 2011/3/16 1:24 | -1400 | | -0.023 | | 0.120 | | 1.03E+02 | | 3.68E+00 | | | |
| 2011/3/16 1:44 | -1400 | | -0.023 | | 0.120 | | 1.02E+02 | | 3.66E+00 | | | |
| 2011/3/16 1:54 | -1400 | | -0.023 | | 0.120 | | 1.02E+02 | | 3.65E+00 | | | |
| 2011/3/16 5:00 | -1475 | | -0.038 | | 0.125 | | 9.85E+01 | | 3.67E+00 | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/16 5:15 | -1475 | | -0.041 | | 0.120 | | 9.83E+01 | | 3.69E+00 | | | |
| 2011/3/16 5:35 | -1450 | | -0.041 | | 0.040 | | 6.05E+01 | | 2.43E+00 | | | |
| 2011/3/16 6:10 | -1425 | | -0.043 | | 0.050 | | 9.77E+01 | | 3.63E+00 | | | |
| 2011/3/16 6:55 | -1400 | | -0.043 | | 0.045 | | 9.72E+01 | | 3.57E+00 | | | |
| 2011/3/16 12:35 | -1400 | | | | 0.040 | | 9.38E+01 | | 3.01E+00 | | | |
| 2011/3/16 15:30 | -1400 | | -0.061 | | 0.075 | 0.145 | 9.24E+01 | | 2.86E+00 | | | |
| 2011/3/16 20:00 | -1400 | | -0.063 | | 0.075 | | 9.03E+01 | | 2.75E+00 | | | |
| 2011/3/16 20:20 | -1400 | | -0.063 | | 0.075 | | 9.03E+01 | | 2.75E+00 | | | |
| 2011/3/16 20:40 | -1400 | | -0.063 | | 0.075 | | 9.03E+01 | | 2.75E+00 | | | |
| 2011/3/16 23:50 | -1400 | | -0.063 | | 0.075 | | | | | | | |
| 2011/3/17 3:10 | -1400 | | -0.065 | | 0.075 | | 8.70E+01 | | 2.65E+00 | | | |
| 2011/3/17 6:00 | -1400 | | -0.068 | | 0.075 | | 8.63E+01 | | 2.63E+00 | | | |
| 2011/3/17 11:00 | -1600 | | -0.029 | | 0.110 | | 8.46E+01 | | 2.50E+00 | | | |
| 2011/3/17 11:15 | -1700 | | -0.029 | | 0.115 | | 8.46E+01 | | 2.50E+00 | | | |
| 2011/3/17 11:30 | -1800 | | -0.029 | | 0.115 | | 8.46E+01 | | 2.50E+00 | | | |
| 2011/3/17 12:50 | -1800 | | -0.027 | | 0.110 | | 8.44E+01 | | 2.43E+00 | | | |
| 2011/3/17 21:40 | -1400 | | | | 0.130 | | 8.21E+01 | | 2.40E+00 | | | |
| 2011/3/17 21:50 | -1400 | | | | 0.130 | | 8.24E+01 | | 2.41E+00 | | | |
| 2011/3/18 2:20 | -1400 | | -0.018 | | 0.130 | | 8.02E+01 | | 2.40E+00 | | | |
| 2011/3/18 2:50 | -1400 | | -0.016 | | 0.130 | | 7.98E+01 | | 2.40E+00 | | | |
| 2011/3/18 7:40 | -1400 | | -0.014 | | 0.130 | | 7.81E+01 | | 2.37E+00 | | | |
| 2011/3/18 7:55 | -1400 | | -0.014 | | 0.130 | | 7.80E+01 | | 2.37E+00 | | | |
| 2011/3/18 9:40 | -1400 | | -0.009 | | 0.135 | | 7.74E+01 | | 2.36E+00 | | | |
| 2011/3/18 16:00 | -1400 | | -0.002 | | 0.139 | | 7.50E+01 | | 2.34E+00 | | | |
| 2011/3/18 20:55 | -1400 | | -0.002 | | 0.140 | | 7.35E+01 | | 2.33E+00 | | | |
| 2011/3/18 21:10 | -1400 | | -0.005 | | 0.140 | | 7.35E+01 | | 2.32E+00 | | | |
| 2011/3/19 2:40 | -1400 | | -0.005 | | 0.135 | | 7.18E+01 | | 2.30E+00 | | | |
| 2011/3/19 3:30 | -1400 | | -0.005 | | 0.135 | | 7.15E+01 | | 2.30E+00 | | | |
| 2011/3/19 7:10 | -1350 | | -0.005 | | 0.135 | | 7.06E+01 | | 2.29E+00 | | | |
| 2011/3/19 11:00 | -1400 | -400 | -0.009 | | 0.135 | | 6.96E+01 | | 2.27E+00 | | | |
| 2011/3/19 16:30 | -1300 | -300 | -0.009 | | 0.135 | | 6.83E+01 | | 2.26E+00 | | | |
| 2011/3/19 19:00 | -1300 | -350 | -0.009 | | 0.135 | | 6.76E+01 | | 2.25E+00 | | | |
| 2011/3/19 22:30 | -1350 | -400 | -0.009 | | 0.130 | | 6.68E+01 | | 2.20E+00 | | | |
| 2011/3/20 0:00 | -1300 | -380 | -0.007 | | 0.130 | | 6.58E+01 | | 2.20E+00 | | | |
| 2011/3/20 4:50 | -1300 | -380 | -0.014 | | 0.130 | | 6.97E+01 | | 2.18E+00 | | | |
| 2011/3/20 5:00 | -1300 | -500 | -0.014 | | 0.130 | | 6.47E+01 | | 2.17E+00 | | | |
| 2011/3/20 10:00 | | | -0.011 | | 0.130 | | 6.36E+01 | | 2.16E+00 | | | |
| 2011/3/20 11:00 | -1400 | -400 | -0.016 | | 0.125 | | 1.34E+01 | | 2.15E+00 | | | |
| 2011/3/20 15:00 | -1400 | -400 | -0.016 | -0.020 | 0.125 | | 6.25E+01 | | 2.13E+00 | | 0.060 | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/20 22:00 | -1400 | -200 | -0.018 | -0.020 | 0.120 | | 6.12E+01 | | 2.11E+00 | | 0.060 | |
| 2011/3/21 3:00 | -1350 | -250 | -0.018 | -0.020 | 0.120 | | 6.01E+01 | | 2.09E+00 | | 0.060 | |
| 2011/3/21 8:00 | -1350 | -300 | -0.020 | -0.020 | 0.120 | | 5.91E+01 | | 2.06E+00 | | 0.060 | |
| 2011/3/21 13:30 | -1350 | -200 | -0.020 | -0.025 | 0.120 | | 5.83E+01 | | 2.04E+00 | | | |
| 2011/3/21 14:00 | -1350 | -200 | -0.023 | -0.025 | 0.120 | | 5.81E+01 | | 2.03E+00 | | | |
| 2011/3/21 14:25 | -1350 | -200 | -0.023 | -0.025 | 0.120 | | 5.81E+01 | | 2.03E+00 | | | |
| 2011/3/22 0:15 | -1400 | -200 | -0.025 | -0.027 | 0.110 | | 5.64E+01 | | 1.99E+00 | | | |
| 2011/3/22 5:00 | -1300 | -100 | -0.016 | -0.018 | 0.110 | | 5.55E+01 | | 1.90E+00 | | | |
| 2011/3/22 6:00 | -1350 | 0 | -0.005 | -0.029 | 0.110 | | 5.54E+01 | | 1.95E+00 | | | |
| 2011/3/22 10:30 | -1350 | 0 | -0.020 | -0.023 | 0.110 | | 5.47E+01 | | 1.93E+00 | | | |
| 2011/3/22 11:20 | -1350 | 175 | -0.018 | -0.018 | 0.110 | | | | | | | |
| 2011/3/22 15:30 | -1300 | -400 | -0.029 | -0.032 | 0.110 | | 5.36E+01 | | 1.90E+00 | | | |
| 2011/3/22 17:00 | -1350 | -150 | -0.027 | -0.032 | 0.110 | | 5.35E+01 | | 1.88E+00 | | | |
| 2011/3/22 18:00 | -1350 | -100 | -0.029 | -0.034 | 0.110 | | 5.34E+01 | | 1.88E+00 | | | |
| 2011/3/22 23:00 | -1350 | -500 | -0.020 | -0.043 | 0.110 | | 5.28E+01 | | 1.83E+00 | | | |
| 2011/3/23 4:20 | -1300 | 0 | -0.025 | -0.025 | 0.110 | | 5.20E+01 | | 1.80E+00 | | | |
| 2011/3/23 9:00 | -1300 | -150 | -0.023 | -0.023 | 0.110 | | 5.14E+01 | | 1.76E+00 | | | |
| 2011/3/23 14:00 | -1250 | 100 | -0.036 | -0.036 | 0.110 | | 5.07E+01 | | 1.67E+00 | | | |
| 2011/3/23 21:00 | -1200 | -550 | -0.036 | -0.036 | 0.110 | | 4.98E+01 | | 1.53E+00 | | | |
| 2011/3/24 1:00 | -1200 | -250 | -0.025 | -0.025 | 0.105 | | 4.93E+01 | | 1.49E+00 | | | |
| 2011/3/24 5:00 | -1150 | -100 | -0.027 | -0.027 | 0.110 | | 4.88E+01 | | 1.43E+00 | | | |
| 2011/3/24 9:00 | -1150 | -100 | -0.135 | -0.038 | 0.110 | | 4.84E+01 | | 1.40E+00 | | 0.100 | |
| 2011/3/24 13:00 | -1150 | -200 | -0.023 | -0.025 | 0.100 | | 4.79E+01 | | 1.37E+00 | | 0.100 | |
| 2011/3/24 17:00 | -1200 | -250 | -0.036 | -0.036 | 0.110 | | 4.74E+01 | | 1.36E+00 | | | |
| 2011/3/24 20:00 | -1100 | 0 | -0.036 | -0.036 | 0.100 | | 4.71E+01 | | 1.34E+00 | | | |
| 2011/3/24 22:00 | -1150 | -150 | -0.020 | -0.020 | 0.105 | | 4.68E+01 | | 1.39E+00 | | | |
| 2011/3/24 22:30 | -1150 | -50 | -0.032 | -0.032 | 0.105 | | 4.68E+01 | | 1.47E+00 | | | |
| 2011/3/25 0:00 | -1400 | -600 | -0.025 | -0.027 | 0.120 | | 4.66E+01 | | 1.50E+00 | | | |
| 2011/3/25 1:20 | -1600 | -750 | -0.025 | -0.027 | 0.120 | | | | | | 0.120 | |
| 2011/3/25 2:00 | -1300 | -1400 | -0.023 | -0.025 | 0.120 | | 4.64E+01 | | 1.52E+00 | | | |
| 2011/3/25 2:30 | -1200 | -300 | | | | | | | | | | |
| 2011/3/25 6:00 | -1100 | -200 | -0.020 | -0.020 | 0.120 | | 4.59E+01 | | 1.54E+00 | | 0.100 | |
| 2011/3/25 10:00 | -1200 | -500 | -0.020 | -0.020 | 0.120 | | 4.56E+01 | | 1.54E+00 | | | |
| 2011/3/25 14:00 | -1400 | -400 | -0.016 | -0.018 | 0.120 | | 4.52E+01 | | 1.54E+00 | | | |
| 2011/3/25 18:30 | -1150 | -250 | -0.020 | -0.018 | 0.120 | | 4.47E+01 | | 1.54E+00 | | | |
| 2011/3/25 23:00 | -1150 | -450 | -0.009 | -0.009 | 0.120 | | 4.43E+01 | | 1.53E+00 | | | |
| 2011/3/26 5:00 | -1000 | -300 | -0.014 | -0.014 | 0.120 | | 4.38E+01 | | 1.51E+00 | | | |
| 2011/3/26 9:30 | -1100 | -500 | -0.014 | -0.014 | 0.115 | | 4.34E+01 | | 1.49E+00 | | | |
| 2011/3/26 10:21 | -1000 | -500 | -0.014 | -0.014 | 0.115 | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/26 10:40 | -1100 | -500 | -0.014 | -0.016 | 0.115 | | | | | | | |
| 2011/3/26 11:00 | -1100 | -500 | -0.014 | -0.016 | 0.115 | | | | | | | |
| 2011/3/26 11:30 | -1100 | -600 | -0.025 | -0.027 | 0.110 | | 4.33E+01 | | 1.49E+00 | | | |
| 2011/3/26 12:00 | -1100 | -700 | -0.027 | -0.027 | 0.110 | | 4.32E+01 | | 1.49E+00 | | | |
| 2011/3/26 13:00 | -1200 | -1000 | -0.027 | -0.027 | 0.110 | | 4.32E+01 | | 1.48E+00 | | | |
| 2011/3/26 17:30 | -1150 | -1600 | -0.018 | -0.038 | 0.110 | | 4.28E+01 | | 1.47E+00 | | | |
| 2011/3/26 17:50 | -1150 | -1650 | | | | | | | | | | |
| 2011/3/26 18:00 | -1200 | -1600 | | | | | | | | | | |
| 2011/3/26 18:10 | -1200 | -1600 | -0.016 | -0.016 | 0.110 | | | | | | | |
| 2011/3/26 18:30 | -1200 | -1550 | -0.016 | -0.016 | 0.110 | | | | | | | |
| 2011/3/26 19:00 | -1200 | -1650 | -0.018 | -0.016 | 0.110 | | | | | | | |
| 2011/3/26 21:00 | -1200 | -1850 | -0.016 | -0.018 | 0.110 | | 4.26E+01 | | 1.46E+00 | | | |
| 2011/3/27 1:00 | -1200 | -1850 | -0.018 | -0.018 | 0.110 | 0.160 | 4.22E+01 | | 1.45E+00 | | | |
| 2011/3/27 5:00 | -1200 | -1850 | -0.018 | -0.018 | 0.110 | 0.040 | 4.19E+01 | | 1.43E+00 | | | |
| 2011/3/27 9:00 | -1200 | -1850 | -0.018 | -0.020 | 0.110 | | 4.16E+01 | | 1.41E+00 | | | |
| 2011/3/27 15:30 | -1250 | -1900 | -0.018 | -0.020 | 0.110 | | 4.11E+01 | | 1.39E+00 | | | |
| 2011/3/27 16:20 | -1150 | -1850 | -0.018 | -0.020 | 0.110 | | 4.11E+01 | | 1.38E+00 | | | |
| 2011/3/27 17:50 | -1200 | -1900 | -0.018 | -0.020 | 0.110 | | 4.10E+01 | | 1.38E+00 | | | |
| 2011/3/27 18:40 | -1400 | -1850 | -0.018 | -0.020 | 0.110 | | | | | | | |
| 2011/3/27 19:00 | -1250 | -1950 | -0.020 | -0.020 | 0.110 | | | | | | | |
| 2011/3/27 19:20 | -1300 | -1900 | -0.020 | -0.023 | 0.110 | | | | | | | |
| 2011/3/27 19:40 | -1400 | -1900 | -0.020 | -0.020 | 0.110 | | | | | | | |
| 2011/3/27 20:00 | -1400 | -1900 | -0.020 | -0.023 | 0.110 | | | | | | | |
| 2011/3/27 20:20 | -1500 | -2000 | -0.020 | -0.023 | 0.110 | | 4.08E+01 | | 1.37E+00 | | | |
| 2011/3/27 20:40 | -1500 | -2000 | -0.020 | -0.023 | 0.110 | | | | | | | |
| 2011/3/27 22:00 | -1500 | -2050 | -0.020 | -0.020 | 0.110 | | 4.07E+01 | | 1.37E+00 | | 0.120 | |
| 2011/3/28 0:00 | -1400 | -2000 | -0.020 | -0.020 | 0.110 | | 4.06E+01 | | 1.36E+00 | | | |
| 2011/3/28 0:15 | -1400 | -1950 | -0.020 | -0.020 | 0.110 | | | | | | | |
| 2011/3/28 0:35 | -1500 | -2100 | -0.020 | -0.020 | 0.110 | | | | | | | |
| 2011/3/28 0:55 | -1500 | -2100 | -0.020 | -0.020 | 0.110 | | 4.05E+01 | | 1.36E+00 | | | |
| 2011/3/28 1:15 | -1500 | -2100 | -0.020 | -0.020 | 0.110 | | | | | | | |
| 2011/3/28 3:00 | -1500 | -2100 | -0.020 | -0.020 | 0.110 | | 4.05E+01 | | 1.37E+00 | | 0.150 | |
| 2011/3/28 3:30 | -1500 | -2100 | -0.020 | -0.020 | 0.110 | | 4.05E+01 | | 1.37E+00 | | | |
| 2011/3/28 4:00 | -1500 | -2100 | -0.020 | -0.023 | 0.110 | | 4.05E+01 | | 1.37E+00 | | | |
| 2011/3/28 7:00 | -1500 | -2100 | -0.020 | -0.023 | 0.105 | | 4.05E+01 | | 1.39E+00 | | | |
| 2011/3/28 12:30 | -1500 | -2100 | -0.032 | -0.032 | 0.100 | | 4.04E+01 | | 1.39E+00 | | | |
| 2011/3/28 17:30 | -1500 | -2100 | -0.032 | -0.032 | 0.100 | | 4.04E+01 | | 1.40E+00 | | | |
| 2011/3/28 21:00 | -1500 | -2100 | -0.034 | -0.034 | 0.100 | | 4.04E+01 | | 1.40E+00 | | | |
| 2011/3/29 1:00 | -1500 | -2050 | -0.027 | -0.029 | 0.100 | | 4.04E+01 | | 1.39E+00 | | 0.120 | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/29 4:00 | -1500 | -2100 | -0.027 | -0.029 | 0.100 | | 4.04E+01 | | 1.37E+00 | | 0.120 | |
| 2011/3/29 7:00 | -1500 | -2100 | -0.027 | -0.029 | 0.100 | | 4.04E+01 | | 1.36E+00 | | 0.100 | |
| 2011/3/29 10:00 | -1500 | -2100 | -0.025 | -0.027 | 0.100 | | 4.04E+01 | | 1.35E+00 | | 0.110 | |
| 2011/3/29 13:00 | -1500 | -2100 | -0.025 | -0.025 | 0.100 | | 4.05E+01 | | 1.33E+00 | | 0.110 | |
| 2011/3/29 16:00 | -1500 | -2100 | -0.025 | -0.025 | 0.100 | | 4.04E+01 | | 1.32E+00 | | 0.120 | |
| 2011/3/29 19:00 | -1500 | -2100 | -0.034 | -0.032 | 0.100 | | 4.02E+01 | | 1.31E+00 | | 0.120 | |
| 2011/3/29 22:00 | -1500 | -2100 | -0.032 | -0.032 | 0.100 | | 4.01E+01 | | 1.30E+00 | | 0.110 | |
| 2011/3/30 1:00 | -1500 | -2100 | -0.025 | -0.025 | 0.100 | | 4.01E+01 | | 1.29E+00 | | 0.100 | |
| 2011/3/30 4:00 | -1500 | -2100 | -0.025 | -0.025 | 0.100 | | 4.00E+01 | | 1.28E+00 | | 0.110 | |
| 2011/3/30 7:00 | -1500 | -2100 | -0.032 | -0.032 | 0.100 | | 3.99E+01 | | 1.28E+00 | | 0.100 | |
| 2011/3/30 10:00 | -1500 | -2100 | -0.032 | -0.032 | 0.100 | | 3.98E+01 | | 1.27E+00 | | 0.110 | |
| 2011/3/30 10:30 | -1500 | -2100 | -0.025 | -0.027 | 0.100 | | | | | | | |
| 2011/3/30 10:50 | -1500 | -2100 | -0.032 | -0.034 | 0.100 | | | | | | | |
| 2011/3/30 11:10 | -1500 | -2100 | -0.032 | -0.034 | 0.100 | | | | | | | |
| 2011/3/30 11:30 | -1500 | -2100 | -0.032 | -0.034 | 0.100 | | | | | | | |
| 2011/3/30 13:00 | -1500 | -2100 | -0.023 | -0.023 | 0.100 | | 3.96E+01 | | 1.26E+00 | | 0.100 | |
| 2011/3/30 14:00 | -1500 | -2100 | -0.025 | -0.023 | 0.100 | | | | | | | |
| 2011/3/30 14:20 | -1500 | -2100 | -0.027 | -0.025 | 0.100 | | | | | | | |
| 2011/3/30 14:40 | -1500 | -2050 | -0.027 | -0.027 | 0.100 | | | | | | | |
| 2011/3/30 15:00 | -1500 | -2050 | -0.027 | -0.027 | 0.100 | | | | | | | |
| 2011/3/30 15:20 | -1500 | -2050 | -0.029 | -0.027 | 0.100 | | | | | | | |
| 2011/3/30 16:00 | -1500 | -2050 | -0.032 | -0.032 | 0.100 | | 3.95E+01 | | 1.24E+00 | | 0.130 | |
| 2011/3/30 18:00 | -1500 | -2050 | -0.029 | -0.027 | 0.100 | | 3.94E+01 | | 1.23E+00 | | 0.130 | |
| 2011/3/30 18:30 | -1500 | -2050 | -0.029 | -0.027 | 0.100 | | | | | | | |
| 2011/3/30 22:00 | -1500 | -2050 | -0.014 | -0.011 | 0.120 | | 3.92E+01 | | 1.22E+00 | | 0.100 | |
| 2011/3/31 0:00 | -1500 | -2050 | -0.027 | -0.025 | 0.110 | | 3.91E+01 | | 1.21E+00 | | 0.110 | |
| 2011/3/31 2:00 | -1500 | -2050 | -0.025 | -0.025 | 0.110 | | 3.89E+01 | | 1.21E+00 | | 0.100 | |
| 2011/3/31 4:00 | -1500 | -2050 | -0.018 | -0.020 | 0.110 | | 3.87E+01 | | 1.19E+00 | | 0.100 | |
| 2011/3/31 6:00 | -1500 | -2050 | -0.014 | -0.014 | 0.110 | | 3.86E+01 | | 1.19E+00 | | 0.110 | |
| 2011/3/31 8:00 | -1500 | -2050 | -0.016 | -0.018 | 0.110 | | 3.85E+01 | | 1.17E+00 | | 0.120 | |
| 2011/3/31 10:00 | -1500 | -2050 | -0.018 | -0.020 | 0.110 | | 3.84E+01 | | 1.17E+00 | | 0.130 | |
| 2011/3/31 12:00 | -1500 | -2100 | -0.011 | -0.011 | 0.110 | | 3.79E+01 | | 1.16E+00 | | 0.110 | |
| 2011/3/31 14:00 | -1500 | -2100 | -0.011 | -0.011 | 0.110 | | 3.80E+01 | | 1.16E+00 | | 0.110 | |
| 2011/3/31 16:00 | -1500 | -2100 | -0.009 | -0.011 | 0.110 | | 3.79E+01 | | 1.16E+00 | | 0.110 | |
| 2011/3/31 18:00 | -1500 | -2100 | -0.011 | -0.011 | 0.110 | | 3.78E+01 | | 1.15E+00 | | 0.110 | |
| 2011/3/31 20:00 | -1500 | -2050 | -0.014 | -0.016 | 0.110 | | 3.78E+01 | | 1.15E+00 | | 0.110 | |
| 2011/3/31 22:00 | -1500 | -2050 | -0.007 | -0.009 | 0.110 | | 3.77E+01 | | 1.14E+00 | | 0.110 | |
| 2011/4/1 0:00 | -1500 | -2050 | -0.014 | -0.014 | 0.110 | | 3.76E+01 | | 1.14E+00 | | 0.110 | |
| 2011/4/1 2:00 | -1500 | -2050 | -0.014 | -0.014 | 0.110 | | 3.75E+01 | | 1.14E+00 | | 0.120 | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/4/1 4:00 | -1500 | -2050 | -0.009 | -0.009 | 0.115 | | 3.73E+01 | | 1.13E+00 | | 0.090 | |
| 2011/4/1 6:00 | -1500 | -2050 | -0.014 | -0.016 | 0.110 | | 3.72E+01 | | 1.11E+00 | | 0.110 | |
| 2011/4/1 8:00 | -1500 | -2100 | -0.014 | -0.014 | 0.110 | | 3.71E+01 | | 1.10E+00 | | 0.120 | |
| 2011/4/1 10:00 | -1500 | -2050 | -0.007 | -0.009 | 0.110 | | 3.70E+01 | | 1.09E+00 | | 0.100 | |
| 2011/4/1 12:00 | -1500 | -2050 | -0.007 | -0.007 | 0.110 | | 3.69E+01 | | 1.08E+00 | | 0.100 | |
| 2011/4/1 16:00 | -1500 | -2050 | -0.005 | -0.005 | 0.115 | | 3.67E+01 | | 1.06E+00 | | 0.110 | |
| 2011/4/1 20:00 | -1500 | -2050 | -0.011 | -0.014 | 0.110 | | 3.65E+01 | | 1.04E+00 | | 0.120 | |
| 2011/4/2 0:30 | -1500 | -2050 | -0.011 | -0.014 | 0.110 | | 3.63E+01 | | 9.93E-01 | | 0.130 | |
| 2011/4/2 4:00 | -1500 | -2050 | -0.011 | -0.014 | 0.110 | | 3.61E+01 | | 9.81E-01 | | 0.130 | |
| 2011/4/2 8:00 | -1500 | -2050 | -0.007 | -0.009 | 0.110 | | 3.59E+01 | | 9.72E-01 | | 0.110 | |
| 2011/4/2 12:00 | -1550 | -2100 | -0.007 | -0.007 | 0.110 | | 3.57E+01 | | 9.66E-01 | | 0.120 | |
| 2011/4/2 16:30 | -1500 | -2100 | -0.011 | -0.014 | 0.110 | | 3.55E+01 | | 9.59E-01 | | 0.130 | |
| 2011/4/2 20:00 | -1500 | -2100 | -0.007 | -0.009 | 0.110 | | 3.54E+01 | | 9.53E-01 | | 0.120 | |
| 2011/4/2 20:53 | -1500 | -2100 | -0.009 | -0.009 | 0.110 | | | | | | | |
| 2011/4/2 21:03 | -1500 | -2100 | -0.007 | -0.009 | 0.110 | | | | | | | |
| 2011/4/2 21:23 | -1500 | -2100 | -0.009 | -0.009 | 0.110 | | 3.53E+01 | | 9.50E-01 | | 0.120 | |
| 2011/4/2 23:00 | -1500 | -2100 | -0.014 | -0.016 | 0.110 | | 3.53E+01 | | 9.51E-01 | | 0.130 | |
| 2011/4/3 3:00 | -1500 | -2100 | -0.016 | -0.018 | 0.105 | | 3.50E+01 | | 9.47E-01 | | 0.100 | |
| 2011/4/3 7:00 | -1500 | -2050 | -0.016 | -0.020 | 0.105 | | 3.45E+01 | | 9.39E-01 | | 0.110 | |
| 2011/4/3 9:00 | -1500 | -2050 | -0.016 | -0.018 | 0.105 | | 3.43E+01 | | 9.35E-01 | | 0.090 | |
| 2011/4/3 10:26 | -1500 | -2050 | -0.018 | -0.020 | 0.105 | | | | | | | |
| 2011/4/3 10:42 | -1500 | -2050 | -0.018 | -0.018 | 0.105 | | | | | | | |
| 2011/4/3 10:47 | -1500 | -2050 | -0.018 | -0.018 | 0.105 | | | | | | | |
| 2011/4/3 10:52 | | | -0.016 | -0.018 | 0.105 | | | | | | | |
| 2011/4/3 11:30 | -1500 | -2050 | -0.011 | -0.011 | 0.110 | | 3.43E+01 | | 9.32E-01 | | 0.120 | |
| 2011/4/3 12:30 | -1450 | -1950 | -0.011 | -0.011 | 0.110 | | | | | | | |
| 2011/4/3 13:00 | -1500 | -1950 | -0.011 | -0.011 | 0.110 | | | | | | | |
| 2011/4/3 14:00 | -1500 | -2050 | -0.016 | -0.016 | 0.110 | | 3.39E+01 | | 9.25E-01 | | 0.130 | |
| 2011/4/3 18:00 | -1500 | -2100 | -0.011 | -0.011 | 0.105 | | 3.38E+01 | | 9.20E-01 | | 0.100 | |
| 2011/4/4 0:00 | -1500 | -2100 | -0.011 | -0.014 | 0.105 | | 3.34E+01 | | 9.11E-01 | | 0.100 | |
| 2011/4/4 6:00 | -1500 | -2100 | -0.011 | -0.016 | 0.100 | | 3.30E+01 | | 9.02E-01 | | 0.080 | |
| 2011/4/4 11:00 | -1500 | -2100 | -0.018 | -0.020 | 0.100 | | 3.28E+01 | | 8.79E-01 | | 0.090 | |
| 2011/4/4 18:00 | -1500 | -2050 | -0.014 | -0.016 | 0.100 | | 3.26E+01 | | 8.86E-01 | | 0.080 | |
| 2011/4/5 0:00 | -1500 | -2050 | -0.016 | -0.018 | 0.100 | | 3.24E+01 | | 8.76E-01 | | 0.100 | |
| 2011/4/5 6:00 | -1500 | -2100 | -0.018 | -0.018 | 0.100 | | 3.21E+01 | | 8.67E-01 | | 0.090 | |
| 2011/4/5 12:00 | -1500 | -2100 | -0.020 | -0.023 | 0.100 | | 3.19E+01 | | 8.58E-01 | | 0.080 | |
| 2011/4/5 18:00 | -1500 | -2100 | -0.014 | -0.016 | 0.100 | | 3.17E+01 | | 8.49E-01 | | 0.080 | |
| 2011/4/6 0:00 | -1500 | -2050 | -0.018 | -0.023 | 0.100 | | 3.15E+01 | | 8.39E-01 | | 0.080 | |
| 2011/4/6 6:00 | -1450 | -2100 | -0.016 | -0.020 | 0.100 | | 3.13E+01 | | 8.33E-01 | | 0.090 | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/4/6 12:00 | -1500 | -2100 | -0.016 | -0.018 | 0.100 | | 3.11E+01 | | 8.25E-01 | | 0.090 | |
| 2011/4/6 18:00 | -1500 | -2100 | -0.014 | -0.018 | 0.100 | | 3.10E+01 | | 8.17E-01 | | 0.090 | |
| 2011/4/7 0:00 | -1500 | -2050 | -0.011 | -0.018 | 0.100 | | 3.08E+01 | | 8.09E-01 | | 0.070 | |
| 2011/4/7 6:00 | -1500 | -2050 | -0.018 | -0.025 | 0.100 | | 3.06E+01 | | 8.01E-01 | | | |
| 2011/4/7 12:00 | -1500 | -2050 | -0.009 | -0.016 | 0.100 | | 3.05E+01 | | 7.94E-01 | | 0.080 | |
| 2011/4/7 18:00 | -1500 | -2050 | -0.011 | -0.014 | 0.100 | | 3.03E+01 | | 7.87E-01 | | 0.070 | |
| 2011/4/7 19:00 | -1500 | -2100 | -0.011 | -0.014 | 0.100 | | | | | | 0.080 | |
| 2011/4/7 19:20 | -1500 | -2100 | -0.011 | -0.014 | 0.100 | | | | | | | |
| 2011/4/7 19:40 | -1500 | -2100 | -0.011 | -0.014 | 0.100 | | | | | | | |
| 2011/4/7 20:00 | -1500 | -2100 | -0.011 | -0.014 | 0.100 | | | | | | | |
| 2011/4/7 20:30 | -1500 | -2100 | -0.011 | -0.014 | 0.100 | | | | | | | |
| 2011/4/7 21:00 | -1500 | -2100 | -0.011 | -0.016 | 0.100 | | | | | | 0.070 | |
| 2011/4/7 21:30 | -1500 | -2100 | -0.011 | -0.016 | 0.100 | | | | | | | |
| 2011/4/7 22:00 | -1500 | -2100 | -0.011 | -0.016 | 0.100 | | | | | | | |
| 2011/4/8 0:00 | -1500 | -2100 | -0.009 | -0.014 | 0.100 | | 3.10E+01 | | 7.81E-01 | | 0.090 | |
| 2011/4/8 3:00 | -1500 | -2100 | -0.011 | -0.016 | 0.100 | | 3.00E+01 | | 7.72E-01 | | 0.080 | |
| 2011/4/8 6:00 | -1500 | -2100 | -0.016 | -0.018 | 0.100 | | 2.99E+01 | | 7.75E-01 | | 0.090 | |
| 2011/4/8 9:00 | -1500 | -2050 | -0.014 | -0.018 | 0.100 | | | | | | | |
| 2011/4/8 12:00 | -1500 | -2100 | -0.020 | -0.020 | 0.100 | | 2.94E+01 | | 7.65E-01 | | 0.080 | |
| 2011/4/8 15:00 | -1500 | -2100 | -0.018 | -0.018 | 0.095 | | 2.96E+01 | | 7.59E-01 | | 0.080 | |
| 2011/4/8 18:00 | -1500 | -2100 | -0.018 | -0.020 | 0.095 | | 2.96E+01 | | 7.56E-01 | | 0.080 | |
| 2011/4/8 21:00 | -1500 | -2100 | -0.018 | -0.020 | 0.095 | | 2.95E+01 | | 7.54E-01 | | 0.080 | |
| 2011/4/9 0:00 | -1500 | -2100 | -0.018 | -0.020 | 0.095 | | 2.94E+01 | | 7.51E-01 | | 0.100 | |
| 2011/4/9 3:00 | -1500 | -2050 | -0.018 | -0.023 | 0.095 | | 2.94E+01 | | 7.50E-01 | | 0.070 | |
| 2011/4/9 6:00 | -1500 | -2050 | -0.018 | -0.023 | 0.095 | | 2.93E+01 | | 7.48E-01 | | 0.070 | |
| 2011/4/9 9:00 | -1500 | -2100 | -0.018 | -0.023 | 0.095 | | 2.93E+01 | | 7.46E-01 | | 0.080 | |
| 2011/4/9 12:00 | -1500 | -2100 | -0.020 | -0.025 | 0.095 | | 2.92E+01 | | 7.43E-01 | | 0.080 | |
| 2011/4/9 16:00 | -1500 | -2100 | -0.018 | -0.025 | 0.090 | | 2.91E+01 | | 7.42E-01 | | 0.080 | |
| 2011/4/9 18:00 | -1500 | -2100 | -0.018 | -0.027 | 0.095 | | 2.91E+01 | | 7.41E-01 | | 0.070 | |
| 2011/4/9 20:00 | -1500 | -2100 | -0.018 | -0.025 | 0.095 | | 2.91E+01 | | 7.41E-01 | | 0.070 | |
| 2011/4/9 22:00 | -1500 | -2100 | -0.020 | -0.025 | 0.095 | | 2.90E+01 | | 7.40E-01 | | 0.070 | |
| 2011/4/10 0:00 | -1500 | -2100 | -0.020 | -0.025 | 0.090 | | 2.90E+01 | | 7.39E-01 | | 0.077 | |
| 2011/4/10 2:00 | -1500 | -2100 | -0.020 | -0.025 | 0.090 | | 2.90E+01 | | 7.39E-01 | | 0.077 | |
| 2011/4/10 4:00 | -1500 | -2050 | -0.020 | -0.025 | 0.090 | | 2.90E+01 | | 7.38E-01 | | 0.077 | |
| 2011/4/10 6:00 | -1450 | -2050 | -0.020 | -0.025 | 0.095 | | 2.90E+01 | | 7.37E-01 | | 0.120 | |
| 2011/4/10 8:00 | -1450 | -2050 | -0.018 | -0.025 | 0.095 | | 2.89E+01 | | 7.35E-01 | | 0.090 | |
| 2011/4/10 10:00 | -1450 | -2050 | -0.020 | -0.025 | 0.095 | | 2.89E+01 | | 7.34E-01 | | 0.090 | |
| 2011/4/10 12:00 | -1500 | -2100 | -0.020 | -0.025 | 0.095 | | 2.85E+01 | | 7.32E-01 | | 0.070 | |
| 2011/4/10 14:00 | -1500 | -2100 | -0.023 | -0.025 | 0.095 | | 2.86E+01 | | 7.31E-01 | | 0.095 | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/4/10 16:00 | -1500 | -2100 | -0.023 | -0.025 | 0.095 | | 2.87E+01 | | 7.30E-01 | | 0.090 | |
| 2011/4/10 18:00 | -1500 | -2050 | -0.023 | -0.025 | 0.095 | | 2.87E+01 | | 7.28E-01 | | 0.110 | |
| 2011/4/10 20:00 | -1500 | -2050 | -0.023 | -0.025 | 0.090 | | 2.86E+01 | | 7.27E-01 | | 0.110 | |
| 2011/4/10 22:00 | -1500 | -2050 | -0.023 | -0.025 | 0.090 | | 2.86E+01 | | 7.26E-01 | | 0.095 | |
| 2011/4/11 0:00 | -1500 | -2050 | -0.020 | -0.025 | 0.090 | | 2.86E+01 | | 7.25E-01 | | 0.100 | |
| 2011/4/11 2:00 | -1500 | -2050 | -0.025 | -0.027 | 0.090 | | 2.86E+01 | | 7.24E-01 | | 0.100 | |
| 2011/4/11 4:00 | -1500 | -2050 | -0.020 | -0.025 | 0.090 | | 2.85E+01 | | 7.22E-01 | | 0.120 | |
| 2011/4/11 6:00 | -1500 | -2050 | -0.025 | -0.029 | 0.090 | | 2.85E+01 | | 7.21E-01 | | 0.110 | |
| 2011/4/11 12:00 | -1500 | -2050 | -0.020 | -0.023 | 0.095 | | 2.84E+01 | | 7.17E-01 | | 0.120 | |
| 2011/4/11 18:30 | -1500 | -2100 | -0.020 | -0.023 | 0.095 | 0.105 | 2.80E+01 | | 6.92E-01 | | 0.090 | |
| 2011/4/12 0:00 | -1500 | -2050 | -0.023 | -0.025 | 0.090 | 0.000 | 2.81E+01 | | 6.85E-01 | | 0.080 | |
| 2011/4/12 6:00 | -1500 | -2100 | -0.023 | -0.025 | 0.090 | | 2.81E+01 | | 6.81E-01 | | 0.090 | |
| 2011/4/12 13:00 | -1500 | -2100 | -0.027 | -0.027 | 0.085 | | 2.74E+01 | | 6.72E-01 | | 0.080 | |
| 2011/4/12 15:00 | -1500 | -2050 | -0.020 | -0.025 | 0.095 | | 2.77E+01 | | 6.72E-01 | | 0.070 | |
| 2011/4/12 18:00 | -1500 | -2050 | -0.018 | -0.020 | 0.095 | | 2.78E+01 | | 6.70E-01 | | 0.080 | |
| 2011/4/12 23:00 | -1500 | -2050 | -0.023 | -0.025 | 0.095 | | 2.79E+01 | | 6.63E-01 | | 0.085 | |
| 2011/4/13 6:00 | -1500 | -2100 | -0.018 | -0.023 | 0.095 | | 2.79E+01 | | 6.56E-01 | | 0.080 | |
| 2011/4/13 12:00 | -1500 | -2050 | -0.016 | -0.020 | 0.095 | | 2.79E+01 | | 6.53E-01 | | 0.100 | |
| 2011/4/13 18:00 | -1500 | -2050 | -0.016 | -0.018 | 0.095 | | 2.78E+01 | | 6.48E-01 | | 0.080 | |
| 2011/4/14 0:00 | -1500 | -2050 | -0.016 | -0.020 | 0.095 | | 2.77E+01 | | 6.45E-01 | | 0.080 | |
| 2011/4/14 6:00 | -1500 | -2050 | -0.016 | -0.021 | 0.095 | | 2.76E+01 | | 6.41E-01 | | 0.080 | |
| 2011/4/14 12:00 | -1500 | -2050 | -0.016 | -0.021 | 0.090 | | 2.74E+01 | | 6.37E-01 | | 0.090 | |
| 2011/4/14 18:00 | -1500 | -2050 | -0.018 | -0.020 | 0.090 | | 2.73E+01 | | 6.33E-01 | | 0.090 | |
| 2011/4/15 0:00 | -1450 | -2050 | -0.018 | -0.023 | 0.090 | | 2.71E+01 | | 6.29E-01 | | 0.090 | |
| 2011/4/15 6:00 | -1450 | -2050 | -0.018 | -0.025 | 0.090 | | 2.70E+01 | | 6.24E-01 | | 0.090 | |
| 2011/4/15 12:00 | -1500 | -2100 | -0.018 | -0.023 | 0.090 | | 2.69E+01 | | 6.20E-01 | | 0.100 | |
| 2011/4/15 18:00 | -1500 | -2050 | -0.018 | -0.023 | 0.090 | | 2.68E+01 | 3.04E+01 | 6.16E-01 | 5.62E+01 | 0.100 | |
| 2011/4/16 0:00 | -1500 | -2100 | -0.018 | -0.023 | 0.085 | | 2.66E+01 | 3.02E+01 | 6.12E-01 | 7.00E+01 | 0.080 | |
| 2011/4/16 6:00 | -1500 | -2100 | -0.018 | -0.023 | 0.090 | | 2.65E+01 | 3.01E+01 | 6.08E-01 | 1.33E+02 | 0.080 | |
| 2011/4/16 12:00 | -1500 | -2100 | -0.018 | -0.025 | 0.090 | | 2.64E+01 | 3.00E+01 | 6.08E-01 | 1.35E+02 | 0.090 | |
| 2011/4/16 18:00 | -1500 | -2100 | -0.020 | -0.025 | 0.085 | | 2.63E+01 | 2.99E+01 | 6.11E-01 | 1.27E+02 | 0.070 | |
| 2011/4/17 0:00 | -1500 | -2100 | -0.023 | -0.025 | 0.085 | | 2.62E+01 | 2.98E+01 | 6.08E-01 | 1.13E+02 | 0.080 | |
| 2011/4/17 6:00 | -1500 | -2100 | -0.025 | -0.025 | 0.085 | | 2.61E+01 | 2.96E+01 | 6.05E-01 | 1.18E+02 | 0.070 | |
| 2011/4/17 12:00 | -1500 | -2100 | -0.023 | -0.025 | 0.085 | | 2.60E+01 | 2.95E+01 | 6.00E-01 | 1.21E+02 | 0.070 | |
| 2011/4/17 18:00 | -1500 | -2100 | -0.023 | -0.025 | 0.085 | | 2.59E+01 | 2.94E+01 | 5.97E-01 | 1.08E+02 | 0.070 | |
| 2011/4/18 0:00 | -1500 | -2100 | -0.023 | -0.027 | 0.085 | | 2.58E+01 | 2.93E+01 | 5.92E-01 | 1.08E+02 | 0.060 | |
| 2011/4/18 6:00 | -1500 | -2100 | -0.025 | -0.029 | 0.085 | | 2.57E+01 | 2.92E+01 | 5.80E-01 | 1.01E+02 | 0.100 | |
| 2011/4/18 12:00 | -1500 | -2100 | -0.023 | -0.032 | 0.085 | | 2.56E+01 | 2.91E+01 | 5.84E-01 | 1.01E+02 | 0.080 | |
| 2011/4/18 13:00 | -1500 | -2100 | -0.023 | -0.032 | 0.085 | | 2.56E+01 | 2.91E+01 | 5.84E-01 | 1.01E+02 | 0.080 | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level(fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|---|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/4/18 18:00 | -1500 | -2100 | -0.018 | -0.027 | 0.085 | | 2.55E+01 | 2.90E+01 | 5.78E-01 | 8.54E+01 | 0.070 | |
| 2011/4/19 0:00 | -1500 | -2100 | -0.020 | -0.029 | 0.085 | | 2.54E+01 | 2.89E+01 | 5.71E-01 | 9.72E+01 | 0.080 | |
| 2011/4/19 6:00 | -1500 | -2100 | -0.020 | -0.029 | 0.085 | | 2.53E+01 | 2.88E+01 | 5.68E-01 | 1.14E+02 | 0.080 | |
| 2011/4/19 12:00 | -1500 | -2100 | -0.020 | -0.029 | 0.085 | | 2.53E+01 | 2.87E+01 | 5.65E-01 | 1.08E+02 | 0.070 | |
| 2011/4/19 18:00 | -1500 | -2100 | -0.023 | -0.027 | 0.080 | | 2.52E+01 | 2.86E+01 | 5.64E-01 | 9.92E+01 | 0.070 | |
| 2011/4/20 0:00 | -1500 | -2100 | -0.020 | -0.027 | 0.080 | | 2.51E+01 | 2.85E+01 | 5.60E-01 | 8.93E+01 | 0.100 | |
| 2011/4/20 6:00 | -1500 | -2100 | -0.023 | -0.029 | 0.080 | | 2.50E+01 | 2.84E+01 | 5.55E-01 | 1.05E+02 | 0.080 | |
| 2011/4/20 12:00 | -1500 | -2100 | -0.023 | -0.029 | 0.080 | | 2.49E+01 | 2.83E+01 | 5.51E-01 | 1.03E+02 | 0.090 | |
| 2011/4/20 18:00 | -1500 | -2100 | -0.023 | -0.029 | 0.080 | | 2.48E+01 | 2.81E+01 | 5.47E-01 | 1.01E+02 | 0.080 | |
| 2011/4/21 0:00 | -1500 | -2100 | -0.023 | -0.029 | 0.080 | | 2.47E+01 | 2.81E+01 | 5.42E-01 | 1.08E+02 | 0.080 | |
| 2011/4/21 6:00 | -1500 | -2050 | -0.023 | -0.029 | 0.080 | | 2.46E+01 | 2.80E+01 | 5.38E-01 | 1.09E+02 | 0.080 | |
| 2011/4/21 12:00 | -1500 | -2050 | -0.023 | -0.025 | 0.085 | | 2.46E+01 | 2.79E+01 | 5.34E-01 | 1.14E+02 | 0.050 | |
| 2011/4/21 18:00 | -1500 | -2050 | -0.020 | -0.025 | 0.090 | | 2.45E+01 | 2.78E+01 | 5.30E-01 | 1.20E+02 | 0.065 | |
| 2011/4/22 0:00 | -1500 | -2050 | -0.018 | -0.023 | 0.085 | | 2.44E+01 | 2.77E+01 | 5.26E-01 | 1.32E+02 | 0.072 | |
| 2011/4/22 6:00 | -1500 | -2100 | -0.023 | -0.027 | 0.085 | | 2.43E+01 | 2.76E+01 | 5.22E-01 | 1.37E+02 | 0.065 | |
| 2011/4/22 12:00 | -1500 | -2050 | -0.023 | -0.027 | 0.085 | | 2.42E+01 | 2.75E+01 | 5.19E-01 | 1.36E+02 | 0.080 | |
| 2011/4/22 18:00 | -1500 | -2050 | -0.027 | -0.034 | 0.085 | | 2.41E+01 | 2.74E+01 | 5.17E-01 | 1.35E+02 | 0.060 | |
| 2011/4/23 0:00 | -1500 | -2100 | -0.023 | -0.027 | 0.085 | | 2.41E+01 | 2.73E+01 | 5.16E-01 | 1.32E+02 | 0.080 | |
| 2011/4/23 6:00 | -1500 | -2100 | -0.023 | -0.027 | 0.080 | | 2.40E+01 | 2.70E+01 | 5.12E-01 | 1.35E+02 | 0.070 | |
| 2011/4/23 12:00 | -1500 | -2100 | -0.023 | -0.025 | 0.080 | | 2.39E+01 | 2.68E+01 | 5.09E-01 | 1.36E+02 | 0.070 | |
| 2011/4/23 18:00 | -1500 | -2050 | -0.020 | -0.023 | 0.080 | | 2.38E+01 | 2.67E+01 | 5.06E-01 | 1.28E+02 | 0.100 | |
| 2011/4/24 0:00 | -1500 | -2050 | -0.020 | -0.020 | 0.080 | | 2.37E+01 | 2.66E+01 | 5.03E-01 | 1.26E+02 | 0.100 | |
| 2011/4/24 6:00 | -1500 | -2050 | -0.020 | -0.025 | 0.080 | | 2.36E+01 | 2.65E+01 | 5.00E-01 | 1.10E+02 | 0.100 | |
| 2011/4/24 12:00 | -1500 | -2050 | -0.018 | -0.025 | 0.080 | | 2.36E+01 | 2.65E+01 | 4.97E-01 | 1.15E+02 | 0.080 | |
| 2011/4/24 18:00 | -1500 | -2050 | -0.020 | -0.025 | 0.080 | | 2.35E+01 | 2.64E+01 | 4.96E-01 | 1.07E+02 | 0.070 | |
| 2011/4/25 0:00 | -1500 | -2100 | -0.020 | -0.027 | 0.080 | | 2.34E+01 | 2.63E+01 | 4.93E-01 | 1.19E+02 | 0.060 | |
| 2011/4/25 6:00 | -1450 | -2100 | -0.020 | -0.027 | 0.080 | | 2.33E+01 | 2.62E+01 | 4.90E-01 | 1.03E+02 | 0.060 | |
| 2011/4/25 11:00 | -1500 | -2100 | -0.020 | -0.025 | 0.080 | | 2.32E+01 | 2.61E+01 | 4.89E-01 | 9.41E+01 | 0.050 | |
| 2011/4/25 17:00 | -1500 | -2100 | -0.018 | -0.025 | 0.080 | | 2.32E+01 | 2.60E+01 | 4.86E-01 | 9.86E+01 | 0.070 | |
| 2011/4/25 23:00 | -1500 | -2100 | -0.020 | -0.025 | 0.080 | | 2.31E+01 | 2.60E+01 | 4.83E-01 | 1.05E+02 | 0.050 | |
| 2011/4/26 5:00 | -1500 | -2100 | -0.020 | -0.025 | 0.080 | | 2.30E+01 | 2.59E+01 | 4.80E-01 | 1.04E+02 | 0.060 | |
| 2011/4/26 11:00 | -1500 | -2050 | -0.016 | -0.025 | 0.080 | | 2.29E+01 | 2.58E+01 | 4.77E-01 | 7.64E+01 | 0.070 | |
| 2011/4/26 17:00 | -1500 | -2100 | -0.018 | -0.025 | 0.080 | | 2.28E+01 | 2.57E+01 | 4.76E-01 | 1.06E+02 | 0.080 | |
| 2011/4/26 23:00 | -1500 | -2100 | -0.020 | -0.027 | 0.075 | | 2.27E+01 | 2.56E+01 | 4.74E-01 | 5.77E+01 | 0.080 | |
| 2011/4/27 5:00 | -1500 | -2100 | -0.018 | -0.023 | 0.080 | | 2.27E+01 | 2.56E+01 | 4.72E-01 | 4.33E+01 | 0.080 | |
| 2011/4/27 11:00 | -1500 | -2100 | -0.018 | -0.025 | 0.075 | | 2.26E+01 | 2.55E+01 | 4.70E-01 | 4.59E+01 | 0.060 | |
| 2011/4/27 17:00 | -1500 | -2100 | -0.020 | -0.023 | 0.075 | | 2.25E+01 | 2.54E+01 | 4.67E-01 | 4.33E+01 | 0.050 | |
| 2011/4/27 23:00 | -1500 | -2100 | -0.018 | -0.020 | 0.075 | | 2.25E+01 | 2.53E+01 | 4.65E-01 | 4.19E+01 | 0.080 | |
| 2011/4/28 5:00 | -1500 | -2100 | -0.016 | -0.020 | 0.075 | | 2.24E+01 | 2.52E+01 | 4.63E-01 | 4.08E+01 | 0.080 | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/4/28 11:00 | -1500 | -2100 | -0.020 | -0.023 | 0.075 | | 2.23E+01 | 2.52E+01 | 4.61E-01 | 3.97E+01 | 0.040 | |
| 2011/4/28 17:00 | -1500 | -2100 | -0.020 | -0.020 | 0.075 | | 2.23E+01 | 2.51E+01 | 4.60E-01 | 3.83E+01 | 0.070 | |
| 2011/4/28 23:00 | -1500 | -2100 | -0.020 | -0.023 | 0.075 | | 2.22E+01 | 2.50E+01 | 4.56E-01 | 3.74E+01 | 0.060 | |
| 2011/4/29 5:00 | -1500 | -2100 | -0.023 | -0.023 | 0.075 | | 2.21E+01 | 2.49E+01 | 4.54E-01 | 3.59E+01 | 0.080 | |
| 2011/4/29 11:00 | -1500 | -2100 | -0.020 | -0.023 | 0.075 | | 2.21E+01 | 2.48E+01 | 4.52E-01 | 3.71E+01 | 0.080 | |
| 2011/4/29 17:00 | -1500 | -2100 | -0.025 | -0.025 | 0.075 | | 2.20E+01 | 2.48E+01 | 4.49E-01 | 3.61E+01 | 0.070 | |
| 2011/4/29 23:00 | -1500 | -2100 | -0.025 | -0.023 | 0.075 | | 2.20E+01 | 2.47E+01 | 4.47E-01 | 3.85E+01 | 0.070 | |
| 2011/4/30 5:00 | -1500 | -2100 | -0.025 | -0.025 | 0.075 | | 2.19E+01 | 2.46E+01 | 4.44E-01 | 4.52E+01 | 0.070 | |
| 2011/4/30 11:00 | -1500 | -2100 | -0.023 | -0.020 | 0.075 | | 2.18E+01 | 2.46E+01 | 4.42E-01 | 4.56E+01 | 0.080 | |
| 2011/4/30 17:00 | -1500 | -2100 | -0.020 | -0.020 | 0.075 | | 2.18E+01 | 2.45E+01 | 4.39E-01 | 4.49E+01 | 0.030 | |
| 2011/4/30 23:00 | -1500 | -2100 | -0.020 | -0.020 | 0.075 | | 2.17E+01 | 2.44E+01 | 4.37E-01 | 4.62E+01 | 0.050 | |
| 2011/5/1 5:00 | -1500 | -2100 | -0.023 | -0.020 | 0.075 | | 2.17E+01 | 2.44E+01 | 4.34E-01 | 4.64E+01 | 0.040 | |
| 2011/5/1 11:00 | -1500 | -2100 | -0.020 | -0.020 | 0.075 | | 2.16E+01 | 2.43E+01 | 4.32E-01 | 4.22E+01 | 0.050 | |
| 2011/5/1 17:00 | -1500 | -2100 | -0.020 | -0.016 | 0.075 | | 2.16E+01 | 2.42E+01 | 4.31E-01 | 4.33E+01 | 0.042 | |
| 2011/5/1 23:00 | -1500 | -2100 | -0.018 | -0.018 | 0.070 | | 2.15E+01 | 2.42E+01 | 4.29E-01 | 3.98E+01 | 0.045 | |
| 2011/5/2 5:00 | -1500 | -2100 | -0.023 | -0.018 | 0.070 | | 2.14E+01 | 2.41E+01 | 4.27E-01 | 3.91E+01 | 0.050 | |
| 2011/5/2 11:00 | -1500 | -2100 | -0.020 | -0.018 | 0.070 | | 2.14E+01 | 2.41E+01 | 4.26E-01 | 4.13E+01 | 0.042 | |
| 2011/5/2 17:00 | -1500 | -2100 | -0.020 | -0.018 | 0.070 | | 2.13E+01 | 2.40E+01 | 4.25E-01 | 4.33E+01 | 0.040 | |
| 2011/5/2 23:00 | -1500 | -2100 | -0.020 | -0.018 | 0.070 | | 2.13E+01 | 2.39E+01 | 4.23E-01 | 4.50E+01 | 0.040 | |
| 2011/5/3 5:00 | -1500 | -2100 | -0.020 | -0.018 | 0.070 | | 2.12E+01 | 2.39E+01 | 4.21E-01 | 4.35E+01 | 0.040 | |
| 2011/5/3 11:00 | -1500 | -2100 | -0.023 | -0.018 | 0.070 | | 2.12E+01 | 2.38E+01 | 4.19E-01 | 4.72E+01 | 0.040 | |
| 2011/5/3 17:00 | -1500 | -2100 | -0.023 | -0.016 | 0.070 | | 2.11E+01 | 2.37E+01 | 4.17E-01 | 4.94E+01 | 0.050 | |
| 2011/5/3 23:00 | -1500 | -2100 | -0.023 | -0.016 | 0.065 | | 2.10E+01 | 2.37E+01 | 4.15E-01 | 4.63E+01 | 0.050 | |
| 2011/5/4 5:00 | -1500 | -2100 | -0.023 | -0.018 | 0.065 | | 2.10E+01 | 2.36E+01 | 4.13E-01 | 5.34E+01 | 0.040 | |
| 2011/5/4 11:00 | -1500 | -2100 | -0.020 | -0.016 | 0.065 | | 2.09E+01 | 2.36E+01 | 4.11E-01 | 5.58E+01 | 0.040 | |
| 2011/5/4 17:00 | -1500 | -2100 | -0.020 | -0.016 | 0.065 | | 2.09E+01 | 2.35E+01 | 4.10E-01 | 5.97E+01 | 0.050 | |
| 2011/5/4 23:00 | -1500 | -2100 | -0.023 | -0.018 | 0.065 | | 2.08E+01 | 2.35E+01 | 4.08E-01 | 6.97E+01 | 0.050 | |
| 2011/5/5 5:00 | -1500 | -2100 | -0.023 | -0.018 | 0.065 | | 2.07E+01 | 2.34E+01 | 4.06E-01 | 7.66E+01 | 0.050 | |
| 2011/5/5 11:00 | -1500 | -2100 | -0.023 | -0.018 | 0.065 | | 2.07E+01 | 2.33E+01 | 4.05E-01 | 8.35E+01 | 0.040 | |
| 2011/5/5 17:00 | -1500 | -2100 | -0.023 | -0.018 | 0.065 | | 2.06E+01 | 2.33E+01 | 4.03E-01 | 9.52E+01 | 0.040 | |
| 2011/5/5 23:00 | -1500 | -2100 | -0.023 | -0.018 | 0.065 | | 2.06E+01 | 2.32E+01 | 4.02E-01 | 1.06E+02 | 0.050 | |
| 2011/5/6 5:00 | -1500 | -2100 | -0.023 | -0.018 | 0.065 | | 2.05E+01 | 2.32E+01 | 4.00E-01 | 1.18E+02 | 0.050 | |
| 2011/5/6 11:00 | -1500 | -2100 | -0.020 | -0.020 | 0.065 | | 2.05E+01 | 2.31E+01 | 3.99E-01 | 1.30E+02 | 0.040 | |
| 2011/5/6 17:00 | -1500 | -2100 | -0.020 | -0.018 | 0.065 | | 2.04E+01 | 2.30E+01 | 3.97E-01 | 1.37E+02 | 0.040 | |
| 2011/5/6 23:00 | -1500 | -2100 | -0.020 | -0.018 | 0.065 | | 2.04E+01 | 2.30E+01 | 3.95E-01 | 1.33E+02 | 0.040 | |
| 2011/5/7 5:00 | -1500 | -2100 | -0.018 | -0.020 | 0.065 | | 2.03E+01 | 2.29E+01 | 3.93E-01 | 1.30E+02 | 0.040 | |
| 2011/5/7 11:00 | -1500 | -2100 | -0.020 | -0.018 | 0.065 | | 2.03E+01 | 2.29E+01 | 3.91E-01 | 1.35E+02 | 0.040 | |
| 2011/5/7 17:00 | -1500 | -2100 | -0.020 | -0.018 | 0.060 | | 2.03E+01 | 2.28E+01 | 3.90E-01 | 1.45E+02 | 0.040 | |
| 2011/5/7 23:00 | -1500 | -2100 | -0.023 | -0.018 | 0.060 | | 2.01E+01 | 2.27E+01 | 3.88E-01 | 1.48E+02 | 0.050 | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|------------------------------------|--------------------|--------------------|--------------------|---|------|
| 2011/5/8 5:00 | -1500 | -2100 | -0.020 | -0.018 | 0.060 | | 2.01E+01 | 2.27E+01 | 3.86E-01 | 1.48E+02 | 0.050 | |
| 2011/5/8 11:00 | -1500 | -2100 | -0.020 | -0.018 | 0.060 | | 2.00E+01 | 2.26E+01 | 3.86E-01 | 1.40E+02 | 0.050 | |
| 2011/5/8 17:00 | -1500 | -2100 | -0.020 | -0.016 | 0.060 | | 2.00E+01 | 2.26E+01 | 3.84E-01 | 1.38E+02 | 0.050 | |
| 2011/5/8 23:00 | -1500 | -2100 | -0.020 | -0.018 | 0.060 | | 2.00E+01 | 2.25E+01 | 3.83E-01 | 1.32E+02 | 0.050 | |
| 2011/5/9 5:00 | -1500 | -2100 | -0.023 | -0.020 | 0.060 | | 1.99E+01 | 2.25E+01 | 3.82E-01 | 1.28E+02 | 0.055 | |
| 2011/5/9 11:00 | -1500 | -2100 | -0.020 | -0.018 | 0.060 | 0.190 | 1.99E+01 | 2.24E+01 | 3.80E-01 | 1.24E+02 | 0.040 | |
| 2011/5/9 17:00 | -1500 | -2100 | -0.023 | -0.020 | 0.060 | | 1.98E+01 | 2.23E+01 | 3.79E-01 | 1.22E+02 | 0.035 | |
| 2011/5/9 23:00 | -1500 | -2100 | -0.020 | -0.014 | 0.060 | | 1.98E+01 | 2.23E+01 | 3.78E-01 | 1.18E+02 | 0.036 | |
| 2011/5/10 5:00 | -1500 | -2100 | -0.020 | -0.016 | 0.060 | | 1.97E+01 | 2.22E+01 | 3.76E-01 | 1.17E+02 | 0.035 | |
| 2011/5/10 11:00 | -1500 | -2100 | -0.020 | -0.016 | 0.060 | | 1.97E+01 | 2.22E+01 | 3.76E-01 | 1.20E+02 | 0.040 | |
| 2011/5/10 17:00 | -1500 | -2100 | -0.023 | -0.016 | 0.055 | | 1.96E+01 | 2.21E+01 | 3.74E-01 | 1.13E+02 | 0.035 | |
| 2011/5/10 23:00 | -1500 | -2100 | -0.020 | -0.018 | 0.060 | | 1.96E+01 | 2.21E+01 | 3.72E-01 | 1.10E+02 | 0.040 | |
| 2011/5/11 5:00 | -1500 | -2100 | -0.023 | -0.018 | 0.060 | | 1.95E+01 | 2.20E+01 | 3.70E-01 | 1.06E+02 | 0.035 | |
| 2011/5/11 11:00 | -1500 | -2100 | -0.023 | -0.018 | 0.060 | | 1.95E+01 | 2.20E+01 | 3.68E-01 | 1.01E+02 | 0.037 | |
| 2011/5/11 17:00 | -1500 | -2100 | -0.023 | -0.020 | 0.060 | | 1.95E+01 | 2.19E+01 | 3.69E-01 | 1.02E+02 | 0.040 | |
| 2011/5/11 23:00 | -1500 | -2100 | -0.023 | -0.020 | 0.060 | | 1.94E+01 | 2.19E+01 | 3.68E-01 | 9.85E+01 | 0.060 | |
| 2011/5/12 5:00 | -1500 | -2100 | -0.023 | -0.020 | 0.055 | | 1.94E+01 | 2.18E+01 | 3.67E-01 | 9.29E+01 | 0.040 | |
| 2011/5/12 11:00 | -1500 | -2100 | -0.023 | -0.018 | 0.055 | | 1.93E+01 | 2.17E+01 | 3.66E-01 | 9.02E+01 | 0.035 | |
| 2011/5/12 17:00 | -1500 | -2100 | -0.023 | -0.018 | 0.055 | | 1.93E+01 | 2.16E+01 | 3.64E-01 | 8.76E+01 | 0.040 | |
| 2011/5/12 23:00 | -1500 | -2100 | -0.023 | -0.018 | 0.055 | | 1.92E+01 | 2.16E+01 | 3.63E-01 | 8.58E+01 | 0.045 | |
| 2011/5/13 5:00 | -1500 | -2100 | -0.018 | -0.018 | 0.055 | | 1.92E+01 | 2.15E+01 | 3.61E-01 | 8.24E+01 | 0.030 | |
| 2011/5/13 11:00 | -1500 | -2100 | -0.018 | -0.016 | 0.055 | | 1.91E+01 | 2.15E+01 | 3.60E-01 | 8.17E+01 | 0.040 | |
| 2011/5/13 17:00 | -1500 | -2100 | -0.020 | -0.016 | 0.055 | | 1.91E+01 | 2.15E+01 | 3.58E-01 | 8.02E+01 | 0.040 | |
| 2011/5/13 23:00 | -1500 | -2100 | -0.023 | -0.018 | 0.055 | | 1.90E+01 | 2.14E+01 | 3.57E-01 | 7.70E+01 | 0.040 | |
| 2011/5/14 5:00 | -1500 | -2100 | -0.023 | -0.018 | 0.055 | | 1.90E+01 | 2.14E+01 | 3.56E-01 | 7.21E+01 | 0.040 | |
| 2011/5/14 11:00 | -1500 | -2100 | -0.023 | -0.020 | 0.055 | | 1.90E+01 | 2.13E+01 | 3.53E-01 | 7.61E+01 | 0.040 | |
| 2011/5/14 17:00 | -1500 | -2100 | -0.025 | -0.018 | 0.055 | | 1.89E+01 | 2.13E+01 | 3.52E-01 | 7.28E+01 | 0.040 | |
| 2011/5/14 23:00 | -1500 | -2100 | -0.023 | -0.020 | 0.055 | | 1.89E+01 | 2.12E+01 | 3.50E-01 | 7.19E+01 | 0.040 | |
| 2011/5/15 5:00 | -1500 | -2100 | -0.023 | -0.020 | 0.055 | | 1.88E+01 | 2.12E+01 | 3.49E-01 | 7.00E+01 | 0.040 | |
| 2011/5/15 11:00 | -1500 | -2100 | -0.023 | -0.020 | 0.055 | | 1.88E+01 | 2.11E+01 | 3.47E-01 | 6.84E+01 | 0.030 | |
| 2011/5/15 17:00 | -1500 | -2100 | -0.018 | -0.020 | 0.055 | | 1.88E+01 | 2.11E+01 | 3.47E-01 | 6.58E+01 | 0.030 | |
| 2011/5/15 23:00 | -1500 | -2100 | -0.020 | -0.020 | 0.055 | | 1.87E+01 | 2.10E+01 | 3.45E-01 | 6.50E+01 | 0.030 | |
| | | | | | | | measurement instrument malfunction | | | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Safety Relief Valve Leakage Detector RV-2-71A | Main Steam Isolation Valve Leakage Detector 2-86A | Feedwater Nozzle N-4B | ORD Housing Upper Part | Reactor Pressure Vessel Botom Head | Reactor Pressure Vessel Supporting Skirt Upper Part | Reactor Pressure Vessel Drain Pipe Upper Part | D/W HVH Return Air Duct (HVH-16A) | RPV Bellows Air | Reactor Supression Chamber Gas | S/C Pool Water A | S/C Pool Water B | note |
|------------|---|---|-----------------------|------------------------|------------------------------------|---|---|-----------------------------------|-----------------|--------------------------------|------------------|------------------|------|
| 3/20 22:00 | 150 | 49 | 108 | | 120 | | | 105 | | | | | |
| 3/21 3:00 | 146 | 42 | 100 | | 115 | | | 100 | | | | | |
| 3/21 8:00 | 150 | 45 | 105 | | 115 | | | 105 | | | | | |
| 3/21 13:30 | 150 | 50 | 110 | | 120 | | | 110 | | | | | |
| 3/21 14:00 | 140 | 50 | 110 | | 110 | | | 100 | | | | | |
| 3/21 14:25 | 150 | 50 | 110 | | 120 | | | 100 | | | | | |
| 3/22 0:15 | 146 | 47 | 101 | | 109 | | | 102 | | | | | |
| 3/22 5:00 | 145 | 50 | 110 | | 110 | | | 110 | | | | | |
| 3/22 6:00 | 145 | 45 | 100 | | 110 | | | 101 | | | | | |
| 3/22 10:30 | 140 | 47 | 105 | | 107 | | | 101 | | | | | |
| 3/22 11:20 | 142 | 47 | 105 | | 109 | | | 103 | | | | | |
| 3/22 15:30 | 140 | 45 | 100 | | 105 | | | 100 | | | | | |
| 3/22 17:00 | 142 | 46 | 102 | | 111 | | | 100 | | | | | |
| 3/22 18:00 | 140 | 44 | 102 | | 102 | | | 99 | | | | | |
| 3/22 23:00 | 142 | 47 | 105 | | 105 | | | 100 | | | | | |
| 3/23 4:20 | 140 | 50 | 102 | | 109 | | | 105 | | | | | |
| 3/23 9:00 | 140 | 47 | 105 | | 105 | | | 101 | | | | | |
| 3/23 14:00 | 138 | 46 | 101 | | 102 | | | 100 | | | | | |
| 3/23 21:00 | 134 | 45 | 100 | | 103 | | | 96 | | | | | |
| 3/24 1:00 | 138 | 49 | 102 | | 109 | | | 101 | | | | | |
| 3/24 5:00 | 135 | 49 | 100 | | 109 | | | 96 | | | | | |
| 3/24 9:00 | 134 | 45 | 100 | | 105 | | | 96 | | | | | |
| 3/24 13:00 | 130 | 50 | 100 | | 110 | | | 100 | | | | | |
| 3/24 17:00 | 135 | 47 | 100 | | 105 | | | 100 | | | | | |
| 3/24 20:00 | 130 | 42 | 100 | | 105 | | | 95 | | | | | |
| 3/24 22:00 | 130 | 47 | 100 | | 110 | | | 100 | | | | | |
| 3/24 22:30 | 130 | 45 | 101 | | 109 | | | 100 | | | | | |
| 3/25 0:00 | 130 | 45 | 104 | | 109 | | | 100 | | | | | |
| 3/25 2:00 | 135 | 45 | 105 | | 105 | | | 100 | | | | | |
| 3/25 6:00 | 135 | 45 | 105 | | 105 | | | 101 | | | | | |
| 3/25 10:00 | 135 | 45 | 107 | | 105 | | | 104 | | | | | |
| 3/25 14:00 | 135 | 45 | 107 | | 104 | | | 104 | | | | | |
| 3/25 18:30 | 132 | 42 | 107 | | 94 | | | 99 | | | | | |
| 3/25 23:00 | 137 | 47 | 109 | | 100 | | | 100 | | | | | |
| 3/26 9:30 | 137 | 50 | 107 | | 100 | | | 104 | | | | | |
| 3/26 10:21 | 137 | 50 | 107 | | 100 | | | 104 | | | | | |
| 3/26 10:40 | 137 | 47 | 107 | | 100 | | | 104 | | | | | |
| 3/26 13:00 | 136 | 47 | 107 | | 99 | | | 103 | | | | | |
| 3/26 17:30 | 148.1 | 63.6 | 121.8 | | 111.1 | | | 106 | | | | | |
| 3/26 17:50 | 150.1 | 63.5 | 121.9 | | 111.1 | | | 106 | | | | | |
| 3/26 18:00 | 150.1 | 63.5 | 122 | | 111.1 | | | 106 | | | | | |
| 3/26 18:10 | 150.1 | 63.5 | 122 | | 111.1 | | | 106 | | | | | |
| 3/26 18:30 | 150.2 | 63.6 | 122.1 | | 111.2 | | | 106 | | | | | |
| 3/26 19:00 | 150.2 | 63.6 | 122.2 | | 111.4 | | | 106 | | | | | |
| 3/26 21:00 | 150.7 | 63.7 | 123 | | 111 | | | 103 | | | | | |
| 3/27 1:00 | 151.6 | 63.8 | 123.9 | | 111.2 | | | 106 | | | | | |
| 3/27 5:00 | 151.6 | 63.7 | 123.9 | 123.3 | 96.6 | | | 106 | | | | | |
| 3/27 9:00 | 151.4 | 63.7 | 123.6 | 122.9 | 111.2 | | | 104 | | | | | |
| 3/27 15:30 | 150.8 | 63.8 | 123.2 | 122.6 | 123.4 | | | 119 | | | | | |
| 3/27 16:20 | 150.8 | 63.8 | 123.1 | 122.5 | 128.3 | | | 119 | | | | | |
| 3/27 17:50 | 150.6 | 63.8 | 123 | 122.4 | 97.3 | | | 118 | | | | | |
| 3/27 20:20 | 150.7 | 63.8 | 123.6 | 122.9 | 93 | | | 119 | | | | | |
| 3/27 22:00 | 151.5 | 63.8 | 124.6 | 123.9 | 88.4 | | | 119 | | | | | |
| 3/28 0:00 | 152.1 | 63.8 | 124.8 | 124.1 | 84.4 | | | 119 | | | | | |
| 3/28 0:55 | 152.4 | 63.8 | 125.5 | 124.8 | 84.4 | | | 120 | | | | | |
| 3/28 3:00 | 154.5 | 63.8 | 129 | 128.2 | 84 | | | 121 | | | | | |
| 3/28 3:30 | 154.9 | 63.8 | 129.6 | 128.7 | 82 | | | 121 | | | | | |
| 3/28 4:00 | 154.3 | 63.8 | 130.3 | 129.4 | 81.5 | | | 121 | | | | | |
| 3/28 7:00 | 158.7 | 63.7 | 135.4 | 134.5 | 76.8 | | | 124 | | | | | |
| 3/28 12:30 | 166.3 | 63.7 | 144.1 | 142.9 | 60 | | | 131 | | | | | |
| 3/28 17:30 | 171.9 | 63.4 | 148.3 | 147 | 67.3 | | | 136 | | | | | |
| 3/28 21:00 | 176.3 | 63.5 | 149.5 | 148.2 | 101.5 | | | 139 | | | | | |
| 3/29 1:00 | 180.9 | 63.4 | 152 | 150.7 | 71.4 | | | 142 | | | | | |
| 3/29 4:00 | 184.7 | 63.3 | 153.7 | 152.6 | 77.7 | | | 144.5 | | | | | |
| 3/29 7:00 | 188.5 | 63.2 | 156.2 | 154.9 | 120 | | | 147.5 | | | | | |
| 3/29 10:00 | 191.9 | 63.2 | 158.5 | 157.2 | 120.3 | | | 150 | | | | | |
| 3/29 13:00 | 195.4 | 63.2 | 160.5 | 161.6 | 143.6 | | | 152 | | | | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Temperature

[Note]
Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Safety Relief Valve Leakage Detector RV-2-71A | Main Steam Isolation Valve Leakage Detector 2-86A | Feedwater Nozzle N-4B | CRD Housing Upper Part | Reactor Pressure Vessel Botom Head | Reactor Pressure Vessel Supporting Skirt Upper Part | Reactor Pressure Vessel Drain Pipe Upper Part | D/W HVH Return Air Duct (HVH-16A) | RPV Bellows Air | Reactor Supression Chamber Gas | S/C Pool Water A | S/C Pool Water B | note |
|------------|---|---|-----------------------|------------------------|------------------------------------|---|---|-----------------------------------|-----------------|--------------------------------|------------------|------------------|---|
| 3/29 16:00 | 198.6 | 63.7 | 198.2 | -126.8 | 141.6 | | | 154 | | | | | Instrument failure – temperature at upper CRD housing |
| 3/29 17:30 | 200 | | 164.7 | | | | | | | | | | |
| 3/29 19:00 | 201.4 | 63.3 | 166.3 | 105.5 | 85.7 | | | 156 | | | | | |
| 3/29 22:00 | 204 | 63.3 | 167.4 | 140.5 | 80.8 | | | 158 | | | | | |
| 3/30 1:00 | 206.3 | 63.3 | 168.6 | 126.3 | 82.2 | | | 160 | | | | | |
| 3/30 4:00 | 208.9 | 63 | 170.7 | -126.2 | 87.7 | | | 162 | | | | | |
| 3/30 7:00 | 211.4 | 63.2 | 172.4 | -126 | 131.6 | | | 163.5 | | | | | |
| 3/30 10:00 | 212.6 | 63.3 | 172.9 | -126 | 110.7 | | | 164 | | | | | |
| 3/30 10:30 | 212.8 | 63.3 | 173 | -126 | 112.8 | | | 164 | | | | | |
| 3/30 10:50 | 212.9 | 63.3 | 173 | -99.2 | 114.6 | | | 164 | | | | | |
| 3/30 11:10 | 213 | 63.2 | 173 | -125.9 | 117.2 | | | 164 | | | | | |
| 3/30 11:30 | 213.3 | 63.3 | 173.3 | -125.6 | 119.1 | | | 164 | | | | | |
| 3/30 13:00 | 215 | 63.3 | 174.3 | -125.9 | -125.7 | | | 165 | | | | | Instrument failure – temperature at PPV bottom |
| 3/30 14:00 | 215.8 | 63.4 | 186.5 | -125.9 | -125.7 | | | 169 | | | | | |
| 3/30 14:20 | 215.4 | 63.3 | 180.2 | -125.8 | -125.6 | | | 169 | | | | | |
| 3/30 14:40 | 214.9 | 63.3 | 179.9 | -125.8 | -125.6 | | | 168 | | | | | |
| 3/30 15:00 | 214.4 | 63.4 | 179.7 | -125.7 | -125.6 | | | 168 | | | | | |
| 3/30 15:20 | 214 | 63.4 | 179.5 | -125.7 | -102.3 | | | 168 | | | | | |
| 3/30 16:00 | 213.5 | 63.4 | 179.6 | -125.7 | -45.2 | | | 168 | | | | | |
| 3/30 18:00 | 214.6 | 63.5 | 180.6 | -125.6 | -125.5 | | | 168 | | | | | |
| 3/30 18:30 | 214.9 | 63.5 | 180.7 | -125.6 | -125.5 | | | 168 | | | | | |
| 3/30 22:00 | 218.2 | 63.6 | 184.9 | -125.5 | 30.6 | | | 173.5 | | | | | |
| 3/31 0:00 | 217.2 | 63.6 | 183 | 228.3 | -125.3 | | | 172 | | | | | |
| 3/31 2:00 | 217.1 | 63.6 | 183.4 | 561.6 | -125.2 | | | 172.5 | | | | | |
| 3/31 4:00 | 216.8 | 63.7 | 181.2 | 561.7 | -125.2 | | | 171 | | | | | |
| 3/31 6:00 | 211.8 | 63.8 | 178.7 | 561.7 | -125.1 | | | 168 | | | | | |
| 3/31 8:00 | 209.4 | 63.9 | 175.3 | 561.7 | -125 | | | 164 | | | | | |
| 3/31 10:00 | 207.2 | 64 | 173.4 | 556.6 | -124.9 | | | 162 | | | | | |
| 3/31 12:00 | 207.1 | 64 | 172.4 | 561.7 | -124.9 | | | 162 | | | | | |
| 3/31 14:00 | 208.1 | 64.2 | 172.2 | 561.7 | -125 | | | 162 | | | | | |
| 3/31 16:00 | 207.7 | 64.2 | 172 | 230.7 | -125 | | | 162 | | | | | |
| 3/31 18:00 | 207.3 | 64.3 | 171.5 | 215.2 | -124.9 | | | 162 | | | | | |
| 3/31 20:00 | 207.1 | 64.3 | 169 | 204.6 | -124.8 | | | 162 | | | | | |
| 3/31 22:00 | 206.2 | 64 | 168 | 193.3 | -124.7 | 279 | 197 | 161 | | 99 | | | |
| 4/1 0:00 | 205.4 | 64 | 167 | 222.1 | -124.6 | 278 | 196 | 160 | | 100 | | | |
| 4/1 2:00 | 203.6 | 64.4 | 165.3 | 220.6 | -124.5 | 284.8 | 194.7 | 159 | | 100 | | | |
| 4/1 4:00 | 201.9 | 64.4 | 164.4 | 208.9 | -124.4 | 283.1 | 194.5 | 158 | | 100 | | | |
| 4/1 6:00 | 200.5 | 64.4 | 163.5 | 219.4 | -124.4 | 281.1 | 193.3 | 157 | | 99 | | | |
| 4/1 8:00 | 199 | 64.5 | 162.1 | 208.7 | -124.3 | 270.7 | 192 | 156 | | 100 | | | |
| 4/1 10:00 | 197.7 | 64.6 | 161 | 219.3 | -124.5 | 277.7 | 190.7 | 155 | | 100 | | | |
| 4/1 12:00 | 196.3 | 64.7 | 160.1 | 198.2 | -124.5 | 265.3 | 189.5 | 154 | | 100 | | | |
| 4/1 16:00 | 193.7 | 64.7 | 158.1 | 210.8 | -125.3 | 258.9 | 187.1 | 152 | | 100 | | | |
| 4/1 20:00 | 191.7 | 64.8 | 156.9 | 194.1 | -114 | 265 | 185.9 | 150 | | 100 | | | |
| 4/2 0:30 | 189.8 | 64.8 | 156.1 | 190.6 | -61.4 | 251.9 | 184.4 | 149 | | 100 | | | |
| 4/2 4:00 | 188.3 | 64.9 | 155 | 179.4 | -30.6 | 259.4 | 183.1 | 148 | | 99 | | | |
| 4/2 8:00 | 186.6 | 64.9 | 153.7 | 174.9 | 41.3 | 243.8 | 181.6 | 146 | | 99 | | | |
| 4/2 12:00 | 185.3 | 65 | 152.9 | 185.3 | 81.1 | 251.7 | 180.3 | 146 | | 99 | | | |
| 4/2 16:30 | 183.9 | 64.9 | 151.9 | 232.5 | 88.1 | 253.7 | 179.3 | 144.5 | | 99 | 98.9 | | |
| 4/2 20:00 | 183.6 | 64.8 | 151.3 | 164.5 | 112.4 | 248.6 | 178.2 | 144 | | 99 | 98.8 | | |
| 4/2 21:23 | 183.4 | 64.8 | 151.1 | 162.9 | 114.8 | 241.4 | 177.7 | 144 | | 99 | 98.7 | | |
| 4/2 23:00 | 183.5 | 64.8 | 151.7 | 164.8 | 125.6 | 244.2 | 177.8 | 144 | | 99 | 98.5 | | |
| 4/3 3:00 | 185 | 64.9 | 153.4 | 159.2 | 144 | 252.1 | 178.5 | 145 | | 99 | 98.1 | | |
| 4/3 7:00 | 185.6 | 64.8 | 151 | 157.6 | 148.9 | 258.6 | 177.9 | 142 | | 98 | 98.1 | | |
| 4/3 9:00 | 185.4 | 64.8 | 150.5 | 157 | 146.1 | 254 | 176.8 | 141 | | 98 | 97.6 | | |
| 4/3 11:30 | 186.6 | 64.8 | 152.3 | 161.1 | 134.9 | 258.4 | 177.1 | 143 | | 98 | 98.5 | | |
| 4/3 14:00 | 170.3 | 64.9 | 144.5 | 148.1 | 130 | 245.7 | 173.8 | 138 | | 98 | 98.5 | | |
| 4/3 18:00 | 165.8 | 64.9 | 143.6 | 145.4 | 132.3 | 247.7 | 172.6 | 135 | | 98 | 98.5 | | |
| 4/4 0:00 | 163 | 64.9 | 140.3 | 141.6 | 138.2 | 251.7 | 170.6 | 127 | | 98 | 98.3 | | |
| 4/4 6:00 | 161.5 | 64.8 | 138.8 | 139.6 | 129.5 | 249.3 | 168.5 | 124 | | 98 | 98.1 | | |
| 4/4 11:00 | 162.1 | 64.7 | 139 | 139.6 | 127.7 | 251.8 | 169 | 124 | | 98 | 97.9 | | |
| 4/4 18:00 | 163 | 64.7 | 140.5 | 140.8 | 115.2 | 256.3 | 166.4 | 125 | | 98 | 97.6 | | |
| 4/5 0:00 | 164.2 | 64.7 | 141.7 | 141.2 | 110.5 | 258.9 | 166.4 | 124 | | 98 | 97.4 | | |
| 4/5 6:00 | 164.3 | 64.6 | 141.7 | 146.2 | 133.7 | 263 | 166 | 126 | | 97 | 97.3 | | |
| 4/5 12:00 | 163.1 | 64.7 | 140.3 | 143.9 | 124.7 | 252.7 | 164.1 | 126 | | 98 | 97.2 | | |
| 4/5 18:00 | 163.4 | 64.8 | 140.7 | 141.1 | 118.7 | 254.9 | 165.2 | 126 | | 97 | 97 | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Temperature

[Note]
Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Safety Relief Valve Leakage Detector RV-2-71A | Main Steam Isolation Valve Leakage Detector 2-86A | Feedwater Nozzle N-4B | ORD Housing Upper Part | Reactor Pressure Vessel Botom Head | Reactor Pressure Vessel Supporting Skirt Upper Part | Reactor Pressure Vessel Drain Pipe Upper Part | D/W HVH Return Air Duct (HVH-16A) | RPV Bellows Air | Reactor Suppression Chamber Gas | S/C Pool Water A | S/C Pool Water B | note |
|------------|---|---|-----------------------|------------------------|------------------------------------|---|---|-----------------------------------|-----------------|---------------------------------|------------------|------------------|------|
| 4/6 0:00 | 163.6 | 64.7 | 140.9 | 142.6 | 139.6 | 257.5 | 164.5 | 127 | | 97 | 97 | | |
| 4/6 6:00 | 163.5 | 64.7 | 141.6 | 111.8 | 137.7 | 257.3 | 131.1 | 127 | | 97 | 96.7 | | |
| 4/6 12:00 | 164.1 | 64.8 | 142.5 | 124.4 | 119.6 | 262.2 | 165.3 | 128 | | 97 | 96.8 | | |
| 4/6 18:00 | 165 | 64.8 | 143.6 | 124.4 | 111.8 | 257.7 | 165.7 | 129 | | 97 | 96.6 | | |
| 4/7 0:00 | 165.6 | 64.8 | 144.2 | 127.6 | 57.8 | 259.6 | 166.8 | 130 | | 97 | 96.6 | | |
| 4/7 6:00 | 165.5 | 64.8 | 144.2 | 138.2 | 23 | 253.5 | 166.8 | 130 | | 97 | 96.5 | | |
| 4/7 12:00 | 164.2 | 64.9 | 143.6 | 134.3 | 23.6 | 149.3 | 167.5 | 129 | | 98 | 96.6 | | |
| 4/7 18:00 | 162.3 | 65 | 141.5 | 132.5 | | 147.7 | 165.7 | 128 | | 96 | 96.5 | | |
| 4/7 19:00 | 162 | 65 | 141.4 | 131 | 1.5 | 175 | 165.5 | 128 | | | 96.3 | | |
| 4/7 19:20 | 161.9 | 65 | 141.3 | 126.4 | | 277.7 | 165.5 | 128 | | 96 | 96.2 | | |
| 4/7 19:40 | 161.9 | 65 | 141.2 | 126.4 | | 287.1 | 165.5 | 128 | | 96 | 96.2 | | |
| 4/7 20:00 | 161.8 | 65 | 141.2 | 126.4 | | 283.3 | 165.4 | 128 | | 96 | 96.1 | | |
| 4/7 20:30 | 161.7 | 65 | 141.2 | 127.6 | | 288.6 | 165.4 | 128 | | 96 | 96.1 | | |
| 4/7 21:00 | 161.5 | 65 | 141 | 124.3 | -6.5 | 279.6 | 165.3 | 128 | | 97 | 96 | | |
| 4/7 21:30 | 161.5 | 65 | 141 | | | 273.8 | 165.3 | 128 | | | 95.9 | | |
| 4/7 22:00 | 161.5 | 65 | 141 | | | 282.6 | 165.3 | 128 | | | 95.8 | | |
| 4/8 0:00 | 160.6 | 65 | 143.3 | 148 | 33.7 | 276.6 | 170.3 | 128 | | 97 | 96.6 | | |
| 4/8 3:00 | 158.5 | 65 | 143 | | | 251.5 | 154.3 | 128 | | | 96 | | |
| 4/8 6:00 | 158.8 | 65 | 143.9 | 127.2 | 74.8 | 141.7 | 153.9 | 128 | | 96 | 94.6 | | |
| 4/8 9:00 | 159 | 65 | 143.6 | | | 252.4 | 151.6 | 128.5 | | | 93.7 | | |
| 4/8 12:00 | 157.9 | 65 | 141.2 | 50 | 130.1 | 259.9 | 154.7 | 128 | | 96 | 92.8 | | |
| 4/8 15:00 | 157.2 | 65 | 140.3 | | 121 | 253.1 | 156.8 | 126 | | | 92.1 | | |
| 4/8 18:00 | 157.9 | 64.9 | 140.3 | -7.3 | 131.4 | 264.2 | 165.2 | 126 | | 95 | 91.4 | | |
| 4/8 21:00 | 158.1 | 64.9 | 140.5 | | 137.1 | 257.9 | 164.1 | 127 | | | 90.9 | | |
| 4/9 0:00 | 159.8 | 64.8 | 141.5 | -66.3 | 177.2 | 267.5 | 163.7 | 128 | | 96 | 90.3 | | |
| 4/9 3:00 | 160.4 | 64.7 | 142.5 | | 187.1 | 261.1 | 164.5 | 129 | | | 89.8 | | |
| 4/9 6:00 | 161.1 | 64.7 | 143 | -27.3 | 150.9 | 262.3 | 165.2 | 130 | | 95 | 89.3 | | |
| 4/9 9:00 | 162.6 | 64.6 | 143.9 | | 135.9 | 259.8 | 155.8 | 132 | | 95 | 88.9 | | |
| 4/9 12:00 | 163.5 | 64.6 | 144.5 | 60.8 | 126.4 | 253.6 | 166.7 | 132 | | 95 | 88.5 | | |
| 4/9 16:00 | 164.8 | 64.6 | 145.5 | | 144.5 | 255.6 | 167.6 | | | | 88 | | |
| 4/9 18:00 | 165.5 | 64.6 | 146 | 118.4 | 142.8 | 255.7 | 162.4 | 134 | | 95 | 87.7 | | |
| 4/9 20:00 | 166.7 | 64.6 | 147.1 | | 138.2 | 261 | 157 | 134 | | | 87.5 | | |
| 4/9 22:00 | 167.4 | 64.6 | 148.3 | | 140.2 | 261.3 | 173.5 | 135 | | | 87.2 | | |
| 4/10 0:00 | 167.9 | 64.5 | 149.7 | 162.1 | 139.1 | 261.8 | 174.4 | 136 | | 95 | 86.9 | | |
| 4/10 2:00 | 167.8 | 64.5 | 149.2 | | 140.8 | 264.4 | 173 | 137 | | | 86.7 | | |
| 4/10 4:00 | 167.8 | 64.5 | 149.2 | | 140.1 | 257.7 | 170.4 | 137 | | | 86.5 | | |
| 4/10 6:00 | 168.3 | 64.5 | 149.4 | 194.2 | 143.8 | 152.1 | 167.8 | 138 | | 95 | 86.2 | | |
| 4/10 8:00 | 168.4 | 64.5 | 149.5 | | 142 | 151.5 | 168.1 | 136 | | | 86 | | |
| 4/10 10:00 | 168.8 | 64.5 | 149.6 | | 144.3 | 158 | 168.6 | 138 | | | 85.8 | | |
| 4/10 12:00 | 168.9 | 64.5 | 150 | 240.3 | 142.8 | 161.1 | 162.9 | 138 | | 94 | 85.5 | | |
| 4/10 14:00 | 169.2 | 64.5 | 150.5 | | 146.4 | 161.6 | 169.9 | 139 | | | 85.3 | | |
| 4/10 16:00 | 169.9 | 64.5 | 151 | | 145.7 | 161.4 | 170.6 | 139.5 | | | 85.1 | | |
| 4/10 18:00 | 170.3 | 64.5 | 151.4 | 279.1 | 145.8 | 152.5 | 171.2 | 140 | | 94 | 84.9 | | |
| 4/10 20:00 | 170.7 | 64.5 | 151.9 | | 142.3 | 158.8 | 171.8 | 140 | | | 84.8 | | |
| 4/10 22:00 | 171.2 | 64.4 | 152.3 | | 132.4 | 162.6 | 172.4 | 140.5 | | | 84.6 | | |
| 4/11 0:00 | 171.5 | 64.4 | 152.6 | 319.9 | 130.1 | 157.5 | 172.9 | 141 | | 94 | 84.4 | | |
| 4/11 2:00 | 171.2 | 64.4 | 152.8 | | 131.3 | 156.1 | 173.2 | 141 | | | 84.2 | | |
| 4/11 4:00 | 171.5 | 64.4 | 153.2 | | 152.9 | 160.3 | 173.6 | 142 | | | 84.1 | | |
| 4/11 6:00 | 172.3 | 64.5 | 153.6 | 390.5 | 169.2 | 157.4 | 173.9 | 142 | | 94 | 83.9 | | |
| 4/11 12:00 | 173.4 | 64.5 | 154.8 | 446.6 | 201.9 | 158.1 | 175.3 | 143 | | 94 | 83.5 | | |
| 4/11 18:30 | 172.5 | 64.4 | 156 | 493.8 | 226.4 | 161.9 | 189 | 144 | | 93 | 81.5 | | |
| 4/12 0:00 | 171.6 | 64.2 | 156.2 | 498.2 | 225.2 | 163.9 | 185.2 | 144 | | 94 | 81.4 | | |
| 4/12 6:00 | 176.3 | 63.9 | 165.8 | 564.6 | 208.1 | 170.9 | 265.5 | 151 | | 93 | 84.6 | | |
| 4/12 8:00 | | | 165.6 | 564.6 | 206.9 | 169.1 | 266.7 | | | | | | |
| 4/12 13:00 | 176.7 | 63.4 | 165.9 | 563.4 | 193.2 | 172 | 258.2 | 152 | | 92 | 82.9 | | |
| 4/12 15:00 | 178.3 | 64 | 167.6 | 564.2 | 186.3 | 176.1 | 258.4 | 153 | | 94 | 82.8 | | |
| 4/12 18:00 | 186.5 | 64.2 | 171.7 | 564.4 | 187.1 | 183.5 | 191.5 | 162 | | 92 | 87 | | |
| 4/12 23:00 | 187.5 | 64.4 | 169.7 | 564.6 | 193.3 | 176.3 | 118.6 | 159 | | 92 | 85.1 | | |
| 4/13 6:00 | 190.2 | 64.4 | 170.1 | 564.7 | 183.2 | 177.1 | 118.1 | 160 | | 93 | 83.9 | | |
| 4/13 12:00 | 186.2 | 64.7 | 166.9 | 291.6 | 69.1 | 172.3 | 122 | 156 | | 94 | 83.3 | | |
| 4/13 18:00 | 182.4 | 65 | 163.2 | 477.2 | -9.2 | 168.2 | 118.6 | 152 | | 94 | 82.8 | | |
| 4/14 0:00 | 178.7 | 65.1 | 159.7 | 418.4 | -104.7 | 163.8 | 120.7 | 148 | | 94 | 82.4 | | |
| 4/14 6:00 | 175.3 | 65.2 | 156.8 | 395.2 | -116.3 | 160.8 | 118.3 | 146 | | 94 | 82.3 | | |
| 4/14 12:00 | 172.3 | 65.3 | 154.1 | 309.6 | -116.3 | 157.9 | 119.2 | 144 | | 94 | 82 | | |
| 4/14 18:00 | 169.4 | 65.4 | 151.8 | 258.4 | -116.2 | 155.8 | 118 | 141 | | 94 | 81.7 | | |
| 4/15 0:00 | 167.5 | 65.4 | 150 | 164.6 | -116 | 154 | 116.5 | 139 | | 94 | 81.3 | | |
| 4/15 6:00 | 165.7 | 65.4 | 148.2 | 148.8 | -115.9 | 152.1 | 118.6 | 138 | | 94 | 81 | | |
| 4/15 12:00 | 164.1 | 65.5 | 146.6 | 255.6 | -115.8 | 150.4 | 116.7 | 136 | | 94 | 80.6 | | |
| 4/15 18:00 | 162.8 | 65.6 | 145.7 | 322.4 | -115.7 | 149.4 | 116.7 | 135 | | 94 | 80.3 | | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Safety Relief Valve Leakage Detector RV-2-71A | Main Steam Isolation Valve Leakage Detector 2-86A | Feedwater Nozzle N-4B | ORD Housing Upper Part | Reactor Pressure Vessel Bottom Head | Reactor Pressure Vessel Supporting Skirt Upper Part | Reactor Pressure Vessel Drain Pipe Upper Part | D/W HVH Return Air Duct (HVH-16A) | RPV Bellows Air | Reactor Suppression Chamber Gas | S/C Pool Water A | S/C Pool Water B | note |
|------------|---|---|-----------------------|------------------------|-------------------------------------|---|---|-----------------------------------|-----------------|---------------------------------|------------------|------------------|------|
| 4/16 0:00 | 161.2 | 65.6 | 144.3 | 328.8 | -115.5 | 147.8 | 116.7 | 134 | | 94 | 79.9 | | |
| 4/16 6:00 | 159.5 | 65.6 | 142.8 | 324.2 | -115.3 | 146.3 | 114.8 | 132 | | 94 | 79.5 | | |
| 4/16 12:00 | 158.6 | 65.6 | 141.6 | 316.4 | -115.3 | 145 | 117.1 | 131 | | 94 | 79.1 | | |
| 4/16 18:00 | 158.7 | 65.4 | 141.6 | 119.7 | -115.2 | 144.9 | 119.9 | 131 | | 94 | 78.6 | | |
| 4/17 0:00 | 159 | 65.4 | 142 | 227.1 | -115.1 | 145.1 | 121.3 | 132 | | 94 | 78.1 | | |
| 4/17 6:00 | 158.9 | 65.3 | 141.5 | 64.6 | -115 | 144.7 | 119.8 | 132 | | 94 | 77.6 | | |
| 4/17 12:00 | 158.5 | 65.4 | 141.1 | 76.1 | -114.8 | 144.1 | 119.9 | 131 | | 94 | 77 | 77.4 | |
| 4/17 18:00 | 158.8 | 65.4 | 141.5 | 99.5 | -114.8 | 144.4 | 121.4 | 132 | | 94 | 76.5 | 77 | |
| 4/18 0:00 | 158.5 | 65.4 | 141.7 | 3.7 | -114.6 | 144.5 | 121.3 | 132 | | 94 | 76.1 | 76.4 | |
| 4/18 6:00 | 158.6 | 65.3 | 141.8 | -9.8 | -114.5 | 144.6 | 119.5 | 132 | | 93 | 75.6 | 76 | |
| 4/18 12:00 | 158.2 | 65.4 | 140.9 | -14.4 | -114.9 | 143.7 | 120.3 | 132 | | 93 | 75.2 | 75.5 | |
| 4/18 13:00 | | | 140.8 | -3.8 | -114.7 | 143.6 | 121.4 | | | | 75.2 | 75.5 | |
| 4/18 18:00 | 156.5 | 65.4 | 140 | -14.4 | -114.4 | 196.6 | 120 | 130 | | 93 | 74.9 | 75.2 | |
| 4/19 0:00 | 154.1 | 65.4 | 138.2 | -35.7 | -114.3 | 193 | 117.1 | 129 | | 93 | 74.6 | 74.9 | |
| 4/19 6:00 | 152 | 65.4 | 136.5 | -71.1 | -114.2 | 189.9 | 123.3 | 128 | | 94 | 74.5 | 74.8 | |
| 4/19 12:00 | 149.9 | 65.6 | 135.4 | -114.6 | -114.4 | 187.9 | 127.8 | 127 | | 93 | 74.4 | 74.8 | |
| 4/19 18:00 | 147.9 | 65.7 | 134.6 | -114.7 | -114.4 | 182.5 | 127.5 | 126 | | 93 | 74.4 | 74.8 | |
| 4/20 0:00 | 147.5 | 65.1 | 133.4 | 123 | -114.1 | 137.1 | 126.2 | 124 | | 93 | 74.3 | 74.6 | |
| 4/20 6:00 | 151 | 65.2 | 133.6 | 118.4 | -114 | 136.9 | 125.8 | 122 | | 93 | 74 | 74.3 | |
| 4/20 12:00 | 153.9 | 65.2 | 134.7 | 125.2 | -114 | 137.6 | 126.2 | 123 | | 92 | 73.7 | 74 | |
| 4/20 18:00 | 155.3 | 65.4 | 135.5 | 130 | -114.1 | 138.5 | 126.9 | 124 | | 93 | 73.4 | 73.7 | |
| 4/21 0:00 | 156.2 | 65.3 | 136 | 132.1 | -114.1 | 138.7 | 127.2 | 126 | | 93 | 73.2 | 73.5 | |
| 4/21 6:00 | 155.9 | 65.2 | 136.1 | 130.9 | -114.1 | 138.8 | 128.4 | 126 | | 93 | 72.9 | 73.2 | |
| 4/21 12:00 | 156.2 | 65.3 | 136 | 129.4 | -114.2 | 138.7 | 128.4 | 126 | | 93 | 72.8 | 73 | |
| 4/21 18:00 | 153.8 | 65.5 | 134.6 | 124.4 | -114.3 | 137.2 | 127.6 | 125 | | 94 | 72.6 | 72.9 | |
| 4/22 0:00 | 151.2 | 65.5 | 133.1 | -54 | -114.3 | 135.9 | 126.7 | 124 | | 94 | 72.6 | 72.9 | |
| 4/22 6:00 | 146.1 | 65.7 | 131.2 | 123.9 | -114.2 | 134.4 | 125.5 | 122 | | 93 | 72.5 | 72.8 | |
| 4/22 12:00 | 141.8 | 65.7 | 129.2 | -48.2 | -114 | 132.4 | 124.4 | 120 | | 93 | 72.4 | 72.7 | |
| 4/22 18:00 | 140.7 | 65.7 | 128.8 | -20.8 | -114 | 131.7 | 120.4 | 118 | | 93 | 72.3 | 72.6 | |
| 4/23 0:00 | 140.1 | 65.7 | 128.4 | 157.2 | -113.9 | 131 | 108.4 | 117 | | 93 | 72.2 | 72.5 | |
| 4/23 6:00 | 140 | 65.8 | 128 | 45.8 | -114 | 131.6 | 108.5 | 116 | | 93 | 72.1 | 72.3 | |
| 4/23 12:00 | 139.8 | 65.8 | 127.7 | -43.2 | -113.9 | 133.4 | 111 | 116 | | 93 | 72 | 72.2 | |
| 4/23 18:00 | 138.7 | 65.8 | 127.2 | -80.7 | -113.8 | 130.1 | 112.5 | 116 | | 93 | 71.9 | 72.1 | |
| 4/24 0:00 | 136.6 | 65.8 | 126.3 | -113.9 | -113.7 | 129.1 | 118.1 | 115 | | 93 | 71.8 | 72.1 | |
| 4/24 6:00 | 134 | 65.8 | 125.2 | -92.9 | -113.6 | 129.1 | 119.8 | 114 | | 92 | 71.7 | 71.9 | |
| 4/24 12:00 | 140.2 | 65.8 | 124.2 | -42.4 | -113.5 | 128.5 | 118.9 | 114 | | 92 | 71.5 | 71.8 | |
| 4/24 18:00 | 138.9 | 65.8 | 123.4 | 8 | -113.5 | 123.3 | 117.2 | 114 | | 92 | 71.4 | 71.6 | |
| 4/25 0:00 | 138.1 | 65.8 | 122.9 | -3.7 | -113.3 | 123.2 | 114.4 | 113 | | 92 | 71.3 | 71.6 | |
| 4/25 6:00 | 137.6 | 65.7 | 122.5 | 35.9 | -113.1 | 122 | 115.5 | 114 | | 93 | 71.2 | 71.4 | |
| 4/25 11:00 | 137.2 | 65.7 | 122.3 | -40.4 | -113.1 | 122.9 | 116.3 | 114 | | 92 | 71.1 | 71.3 | |
| 4/25 17:00 | 137.4 | 65.7 | 122.5 | -28.4 | -113.1 | 122.2 | 115.6 | 114 | | 92 | 71 | 71.3 | |
| 4/25 23:00 | 137.1 | 65.7 | 121.9 | -61.5 | -112.9 | 120.5 | 116.4 | 114 | | 92 | 70.9 | 71.1 | |
| 4/26 5:00 | 136.4 | 65.6 | 121.2 | -70.8 | -112.8 | 120 | 117.5 | 113 | | 92 | 70.8 | 70.9 | |
| 4/26 11:00 | 135.4 | 65.7 | 120.5 | -50.3 | -112.7 | 120.1 | 116.2 | 112 | | 92 | 70.7 | 71 | |
| 4/26 17:00 | 135.4 | 65.8 | 120.2 | -39.5 | -112.7 | 117.3 | 115 | 112 | | 92 | 70.7 | 70.9 | |
| 4/26 23:00 | 135 | 65.7 | 120.4 | -65.5 | -112.6 | 117 | 115.7 | 112 | | 92 | 70.6 | 70.9 | |
| 4/27 5:00 | 134.9 | 65.7 | 120.4 | -62.5 | -112.6 | 117.6 | 114 | 112 | | 92 | 70.5 | 70.8 | |
| 4/27 11:00 | 134.4 | 65.7 | 120.3 | -111.7 | -112.6 | 116 | 114.2 | 111 | | 92 | 70.5 | 70.8 | |
| 4/27 17:00 | 134 | 65.8 | 120.1 | -101.6 | -112.6 | 116.5 | 113.4 | 111 | | 92 | 70.5 | 70.7 | |
| 4/27 23:00 | 134.4 | 65.8 | 120.1 | -112.7 | -112.4 | 117.6 | 116.1 | 111 | | 92 | 70.4 | 70.7 | |
| 4/28 5:00 | 133.8 | 65.7 | 119.9 | -112.5 | -112.3 | 117.1 | 113.3 | 111 | | 92 | 70.4 | 70.7 | |
| 4/28 11:00 | 133.4 | 65.7 | 119.8 | -112.4 | -112.3 | 116.2 | 113.1 | 110 | | 92 | 70.3 | 70.6 | |
| 4/28 17:00 | 133.2 | 65.6 | 119.6 | -112.1 | -111.9 | 117 | 116.3 | 110 | | 92 | 70.3 | 70.5 | |
| 4/28 23:00 | 133 | 65.6 | 119.4 | -111.8 | -111.7 | 116.2 | 116.1 | 110 | | 92 | 70 | 70.3 | |
| 4/29 5:00 | 132.9 | 65.6 | 119.2 | -111.7 | -111.6 | 88.3 | 116.5 | 110 | | 92 | 69.7 | 70 | |
| 4/29 11:00 | 132.6 | 65.7 | 119.2 | -111.8 | -111.6 | 118.3 | 115.8 | 110 | | 92 | 69.6 | 69.8 | |
| 4/29 17:00 | 128 | 65.8 | 119.3 | -111.7 | -111.5 | 116.7 | 113 | 108 | | 92 | 69.3 | 69.6 | |
| 4/29 23:00 | 132.9 | 65.7 | 119.3 | -111.5 | -111.3 | 117.5 | 115.8 | 108 | | 92 | 69.1 | 69.3 | |
| 4/30 5:00 | 129.6 | 65.6 | 119.1 | -111.3 | -111.1 | 116.8 | 115.3 | 109 | | 92 | 68.8 | 69.1 | |
| 4/30 11:00 | 132.1 | 65.6 | 118.9 | -111.1 | -110.9 | 105.9 | 117.1 | 108 | | 93 | 68.6 | 68.8 | |
| 4/30 17:00 | 127.3 | 65.6 | 118.9 | -111.1 | -110.9 | 104.7 | 123.2 | 108 | | 92 | 68.5 | 68.7 | |
| 4/30 23:00 | 129.1 | 65.7 | 118.8 | -110.9 | -110.9 | 105 | 123.2 | 109 | | 92 | 68.3 | 68.6 | |
| 5/1 5:00 | 131.9 | 65.5 | 118.7 | -110.9 | -110.9 | 104.7 | 119.1 | 109 | | 92 | 68.2 | 68.5 | |
| 5/1 11:00 | 131.6 | 65.5 | 118.5 | -110.7 | -110.7 | 106.2 | 119.6 | 115 | | 92 | 68.2 | 68.4 | |
| 5/1 17:00 | 131.4 | 65.5 | 118.3 | -110.6 | -110.6 | 106.3 | 117.1 | 113.4 | | 92 | 68.2 | 68.4 | |
| 5/1 23:00 | 130.9 | 65.5 | 118 | -110.2 | -110.2 | 105.4 | 116.8 | 112.5 | | 92 | 68.2 | 68.4 | |
| 5/2 5:00 | 123.5 | 65.5 | 117.9 | -110 | -110 | 102.4 | 117.7 | 113.9 | | 92 | 68.1 | 68.3 | |
| 5/2 11:00 | 123.4 | 65.5 | 117.6 | -109.8 | -109.8 | 104.4 | 119.1 | 113.4 | | 92 | 68 | 68.2 | |
| 5/2 17:00 | 116.9 | 65.5 | 117.6 | -109.6 | -109.6 | 102.7 | 122.2 | 113.7 | | 92 | 67.8 | 68.1 | |

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Safety Relief Valve Leakage Detector RV-2-71A | Main Steam Isolation Valve Leakage Detector 2-86A | Feedwater Nozzle N-4B | ORD Housing Upper Part | Reactor Pressure Vessel Botom Head | Reactor Pressure Vessel Supporting Skirt Upper Part | Reactor Pressure Vessel Drain Pipe Upper Part | D/W HVH Return Air Duct (HVH-16A) | RPV Bellows Air | Reactor Supression Chamber Gas | S/C Pool Water A | S/C Pool Water B | note |
|------------|---|---|-----------------------|------------------------------------|------------------------------------|---|---|-----------------------------------|-----------------|--------------------------------|------------------|------------------|------|
| 5/2 23:00 | 117.7 | 65.6 | 117.5 | -109.5 | 101.8 | 120.6 | 113.3 | 108 | | 92 | 67.7 | 67.9 | |
| 5/3 5:00 | 122.5 | 65.5 | 117.3 | -109.5 | 104.8 | 118.6 | 113.8 | 108 | | 92 | 67.6 | 67.9 | |
| 5/3 11:00 | 123.3 | 65.5 | 117.3 | -109.5 | 106 | 119.6 | 113.8 | 107 | | 92 | 67.6 | 67.8 | |
| 5/3 17:00 | 123.1 | 65.5 | 117.4 | -109.5 | 106.5 | 119.8 | 114.2 | 107 | | 92 | 67.6 | 67.8 | |
| 5/3 23:00 | 124.6 | 65.5 | 117.4 | -109.4 | 104.6 | 119.5 | 114.2 | 107 | | 92 | 67.6 | 67.8 | |
| 5/4 5:00 | 128.3 | 65.5 | 117.2 | -109.2 | 108.8 | 116.8 | 112.7 | 107 | | 92 | 67.5 | 67.8 | |
| 5/4 11:00 | 127.9 | 65.5 | 117 | -109.3 | 108.8 | 113.8 | 113.8 | 107 | | 92 | 67.5 | 67.8 | |
| 5/4 17:00 | 127.6 | 65.6 | 117 | -109.3 | 108.3 | 117.6 | 113.5 | 107 | | 92 | 67.5 | 67.7 | |
| 5/4 23:00 | 128.9 | 65.5 | 117.1 | -109.1 | 108.2 | 117.8 | 112.5 | 107 | | 91 | 67.4 | 67.6 | |
| 5/5 5:00 | 130.6 | 65.4 | 117 | -109 | 108.3 | 116.4 | 112.7 | 107 | | 91 | 67.3 | 67.6 | |
| 5/5 11:00 | 130.6 | 65.5 | 116.8 | -109 | 109.8 | 116.5 | 112.5 | 108 | | 91 | 67.3 | 67.5 | |
| 5/5 17:00 | 130.7 | 65.5 | 116.7 | -109 | 110.8 | 115.5 | 112.6 | 108 | | 91 | 67.3 | 67.5 | |
| 5/5 23:00 | 130.2 | 65.5 | 116.7 | -109.1 | 110.5 | 115.3 | 111.5 | 108 | | 91 | 67.2 | 67.5 | |
| 5/6 5:00 | 130.2 | 65.4 | 116.5 | -109 | 111.1 | 118.1 | 111.9 | 110 | | 91 | 67.2 | 67.4 | |
| 5/6 11:00 | 130.2 | 65.5 | 116.4 | -109.1 | 110.8 | 117.4 | 111.4 | 110 | | 91 | 67.1 | 67.4 | |
| 5/6 17:00 | 129.6 | 65.5 | 116.4 | -109 | 113.7 | 113.7 | 111.8 | 110 | | 91 | 67 | 67.3 | |
| 5/6 23:00 | 130 | 65.4 | 116.3 | -108.9 | 110.2 | 117.2 | 112 | 111 | | 91 | 67 | 67.2 | |
| 5/7 5:00 | 130.1 | 65.4 | 116.1 | -108.8 | 113.2 | 114.6 | 112.4 | 111 | | 91 | 66.9 | 67.2 | |
| 5/7 11:00 | 129.7 | 65.5 | 116 | -108.7 | 113 | 116.3 | 112.6 | 111 | | 91 | 66.9 | 67.1 | |
| 5/7 17:00 | 128.9 | 65.4 | 115.8 | 64.1 | 113.5 | 116.9 | 112.4 | 111 | | 91 | 66.8 | 67.1 | |
| 5/7 23:00 | 129.3 | 65.4 | 115.7 | -108.5 | 110.6 | 119.5 | 112.7 | 111 | | 91 | 66.8 | 67 | |
| 5/8 5:00 | 128.4 | 65.5 | 115.6 | -108.4 | 113.4 | 116.9 | 113.2 | 111 | | 91 | 66.8 | 67 | |
| 5/8 11:00 | 128.1 | 65.5 | 115.4 | -108.1 | 110.6 | 119.3 | 112.4 | 111 | | 91 | 66.7 | 66.9 | |
| 5/8 17:00 | 128.5 | 65.4 | 115.6 | -107.9 | 110.5 | 116.7 | 110.9 | 112 | | 91 | 66.7 | 66.9 | |
| 5/8 23:00 | 129 | 65.1 | 115.7 | -107.8 | 111.4 | 118.3 | 112.7 | 110 | | 91 | 66.7 | 66.9 | |
| 5/9 5:00 | 127.9 | 65.3 | 115.6 | -107.5 | 111.7 | 117.3 | 112.1 | 110 | | 90 | 66.6 | 66.8 | |
| 5/9 11:00 | 128 | 65.3 | 115.6 | -107.6 | 112.9 | 120.2 | 112.3 | 109 | | 91 | 66.6 | 66.8 | |
| 5/9 17:00 | 128.4 | 65.4 | 115.5 | -107.7 | 114.4 | 120.3 | 112.6 | 110 | | 91 | 66.5 | 66.8 | |
| 5/9 23:00 | 127.5 | 65.3 | 115.3 | -107.6 | 110.4 | 119.1 | 111.8 | 110 | | 90 | 66.5 | 66.7 | |
| 5/10 5:00 | 127.3 | 65.4 | 115.3 | -107.4 | 111 | 116.9 | 112.2 | 110 | | 90 | 66.5 | 66.7 | |
| 5/10 11:00 | 127.2 | 65.4 | 115.3 | -107.1 | 113.3 | 114.7 | 112 | 110 | | 90 | 66.5 | 66.8 | |
| 5/10 17:00 | 127.1 | 65.4 | 115.3 | -106.9 | 110.5 | 114.9 | 112.7 | 110 | | 91 | 66.5 | 66.7 | |
| 5/10 23:00 | 126.3 | 65.4 | 115.1 | -106.8 | 110.7 | 113.5 | 112.7 | 110 | | 90 | 66.4 | 66.6 | |
| 5/11 5:00 | 127 | 65.3 | 115 | -106.9 | 112.1 | 113.2 | 112.4 | 110 | | 90 | 66.2 | 66.5 | |
| 5/11 11:00 | 126.1 | 65.3 | 115 | -106.7 | 113.3 | 113.3 | 112.6 | 110 | | 90 | 66.1 | 66.4 | |
| 5/11 17:00 | 125.5 | 65.2 | 115 | -98.3 | 109.3 | 114.4 | 112.8 | 110 | | 90 | 66.1 | 66.3 | |
| 5/11 23:00 | 126.3 | 65.2 | 114.9 | -17.1 | 109.4 | 114.8 | 112.3 | 110 | | 90 | 66 | 66.3 | |
| 5/12 5:00 | 118.9 | 65.1 | 114.8 | -106.2 | 110.9 | 113.6 | 111.9 | 110 | | 90 | 66 | 66.3 | |
| 5/12 11:00 | 119.2 | 65.1 | 114.8 | -106.3 | 111 | 112.2 | 111.8 | 110 | | 90 | 65.9 | 66.2 | |
| 5/12 17:00 | 119.2 | 65 | 114.6 | -106.2 | 109.9 | 114.5 | 111.8 | 108 | | 90 | 65.9 | 66.1 | |
| 5/12 23:00 | 119 | 64.9 | 114.6 | -106.2 | 109.9 | 113.1 | 111.2 | 110 | | 90 | 65.9 | 66.2 | |
| 5/13 5:00 | 118.5 | 64.8 | 114.6 | -106.2 | 110.9 | 112.8 | 110.6 | 110 | | 90 | 66 | 66.2 | |
| 5/13 11:00 | 118.5 | 64.8 | 114.6 | 14.7 | 110.1 | 114.2 | 110.7 | 110 | | 90 | 65.9 | 66.2 | |
| 5/13 17:00 | 118.6 | 64.7 | 114.3 | 20.9 | 109.2 | 113.3 | 110.7 | 110 | | 90 | 66 | 66.3 | |
| 5/13 23:00 | 118.4 | 64.7 | 114.5 | -106.2 | 110.9 | 112 | 110.6 | 110 | | 90 | 65.8 | 66.1 | |
| 5/14 5:00 | 117.1 | 64.8 | 114.5 | -106 | 111.3 | 111.3 | 110.6 | 110 | | 90 | 65.7 | 65.9 | |
| 5/14 11:00 | 118.4 | 64.8 | 114.3 | -106.5 | 110.7 | 111.9 | 110 | 110 | | 90 | 65.6 | 65.8 | |
| 5/14 17:00 | 118.8 | 64.9 | 114.2 | -105.9 | 110.1 | 113.6 | 109.6 | 110 | | 90 | 65.4 | 65.6 | |
| 5/14 23:00 | 119.1 | 64.9 | 113.9 | -105.8 | 109.8 | 113.1 | 109.9 | 110 | | 90 | 65.2 | 65.4 | |
| 5/15 5:00 | 119.7 | 64.8 | 113.7 | -85.9 | 109.5 | 112.3 | 109.9 | 110 | | 90 | 65 | 65.3 | |
| 5/15 11:00 | 120 | 64.9 | 113.7 | -87 | 110.6 | 110.2 | 109.8 | 111 | | 90 | 64.9 | 65.1 | |
| 5/15 17:00 | 120.2 | 64.9 | 113.6 | -21.5 | 108.8 | 110.2 | 108.8 | 111 | | 90 | 64.8 | 65 | |
| 5/15 23:00 | 123.6 | 64.9 | 113.5 | -45.5 | 109.7 | 111.4 | 108 | 111 | | 90 | 64.7 | 64.9 | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | measurement instrument malfunction | measurement instrument malfunction | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/11 19:30 | | | | | 0.1450 | | | | | | | |
| 2011/3/11 19:37 | | | 7.170 | | | | | | | | | |
| 2011/3/11 20:00 | | | | | 0.1450 | | | | | | | |
| 2011/3/11 20:07 | | | 7.100 | | | | | | | | | |
| 2011/3/11 20:15 | | | | | 0.1450 | | | | | | | |
| 2011/3/11 20:30 | | | 7.100 | | 0.1450 | | | | | | | |
| 2011/3/11 21:10 | | | 7.190 | | 0.1550 | | | | | | | |
| 2011/3/11 21:30 | | | 7.250 | | | | | | | | | |
| 2011/3/11 22:00 | | | 7.200 | | | | | | | | | |
| 2011/3/11 22:10 | | | 7.260 | | | | | | | | | |
| 2011/3/11 22:20 | | | 7.200 | | | | | | | | | |
| 2011/3/11 22:30 | | | 7.300 | | | | | | | | | |
| 2011/3/11 22:58 | | | 7.300 | | | | | | | | | |
| 2011/3/11 23:05 | | | 7.300 | | | | | | | | | |
| 2011/3/11 23:19 | | | 7.380 | | | | | | | | | |
| 2011/3/11 23:35 | | | 7.320 | | | | | | | | | |
| 2011/3/11 23:50 | | | 7.340 | | | | | | | | | |
| 2011/3/12 0:00 | | | 7.340 | | 0.2200 | | | | | | | |
| 2011/3/12 0:30 | | | 7.350 | | 0.2300 | | | | | | | |
| 2011/3/12 1:00 | | | 7.400 | | 0.2400 | | | | | | | |
| 2011/3/12 1:25 | | | 7.100 | | 0.2450 | | | | | | | |
| 2011/3/12 1:55 | | | 7.370 | | 0.2500 | | | | | | | |
| 2011/3/12 2:30 | | | 7.340 | | 0.2650 | | | | | | | |
| 2011/3/12 2:50 | | | | | | | | | | | | |
| 2011/3/12 3:30 | | | 7.400 | | 0.2800 | | | | | | | |
| 2011/3/12 3:40 | | | | | | | | | | | | |
| 2011/3/12 3:55 | | | 7.470 | | 0.2850 | | | | | | | |
| 2011/3/12 4:19 | | | 6.800 | | 0.2900 | | | | | | | |
| 2011/3/12 4:35 | | | 7.400 | | 0.2950 | | | | | | | |
| 2011/3/12 4:55 | | | 7.400 | | 0.3000 | | | | | | | |
| 2011/3/12 5:20 | | | 7.400 | | 0.3000 | | | | | | | |
| 2011/3/12 5:30 | | | 7.290 | | 0.3050 | | | | | | | |
| 2011/3/12 5:55 | | | 7.430 | | 0.3100 | | | | | | | |
| 2011/3/12 6:00 | | | 7.250 | | 0.3100 | | | | | | | |
| 2011/3/12 6:30 | | | 7.490 | | 0.3200 | | | | | | | |
| 2011/3/12 7:00 | | | 7.390 | | 0.3300 | | | | | | | |
| 2011/3/12 7:30 | | | 7.230 | | 0.3400 | | | | | | | |
| 2011/3/12 8:30 | | | 7.520 | | 0.3500 | | | | | | | |
| 2011/3/12 8:30 | | | 7.520 | | 0.3500 | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

Replaced on June 13

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/12 9:10 | | | 7.460 | | 0.3600 | | | | | | | |
| 2011/3/12 9:30 | | | 7.460 | | 0.3600 | | | | | | | |
| 2011/3/12 11:23 | | | 7.360 | | 0.3600 | | | | | | | |
| 2011/3/12 12:10 | | | 7.530 | | 0.3900 | | | | | | | |
| 2011/3/12 12:45 | | | 5.600 | | 0.3800 | | | | | | | |
| 2011/3/12 13:05 | | | 4.800 | | 0.3700 | | | | | | | |
| 2011/3/12 13:14 | | | 4.200 | | 0.3650 | | | | | | | |
| 2011/3/12 13:38 | | | 4.000 | | 0.3600 | | | | | | | |
| 2011/3/12 13:58 | | | 3.630 | | 0.3600 | | | | | | | |
| 2011/3/12 14:25 | | | 3.560 | | 0.3600 | | | | | | | |
| 2011/3/12 17:00 | | | 2.900 | | 0.3000 | | | | | | | |
| 2011/3/12 18:30 | | | 1.350 | | 0.2800 | | | | | | | |
| 2011/3/12 19:00 | | | 0.950 | | 0.2850 | | | | | | | |
| 2011/3/12 19:42 | | | 0.820 | | 0.2800 | | | | | | | |
| 2011/3/12 20:00 | | | 0.820 | | 0.2800 | | | | | | | |
| 2011/3/12 20:15 | | | 0.800 | | 0.2700 | | | | | | | |
| 2011/3/12 20:30 | | | 0.820 | | | | | | | | | |
| 2011/3/12 20:40 | | | 0.820 | | | | | | | | | |
| 2011/3/12 21:00 | | | 0.720 | | | | | | | | | |
| 2011/3/12 21:30 | | | 0.970 | | | | | | | | | |
| 2011/3/12 22:00 | | | 0.970 | | 0.1700 | | | | | | | |
| 2011/3/12 22:30 | | | 0.970 | | | | | | | | | |
| 2011/3/12 23:00 | | | 0.960 | | | | | | | | | |
| 2011/3/12 23:30 | | | 0.970 | | | | | | | | | |
| 2011/3/13 0:00 | | | 0.970 | | | | | | | | | |
| 2011/3/13 0:30 | | | 0.970 | | | | | | | | | |
| 2011/3/13 1:00 | | | 0.970 | | | | | | | | | |
| 2011/3/13 2:00 | | | 0.850 | | | | | | | | | |
| 2011/3/13 2:44 | | | 0.580 | | | | | | | | | |
| 2011/3/13 3:00 | | | 0.770 | | | | | | | | | |
| 2011/3/13 3:44 | | | 4.100 | | | | | | | | | |
| 2011/3/13 5:00 | -2000 | | 7.380 | | 0.3600 | | | | | | | |
| 2011/3/13 5:10 | -2300 | | 7.350 | | 0.3450 | | | | | | | |
| 2011/3/13 5:25 | -2400 | | 7.270 | | 0.3550 | | | | | | | |
| 2011/3/13 6:00 | -2600 | | 7.390 | | 0.3900 | | | | | | | |
| 2011/3/13 6:30 | -2800 | | 7.390 | | 0.4250 | | | | | | | |
| 2011/3/13 6:50 | -2850 | | 7.350 | | 0.4400 | | | | | | | |
| 2011/3/13 7:05 | -2900 | | 7.350 | | 0.4500 | 0.4300 | | | | | | |
| 2011/3/13 7:10 | -2900 | | 7.340 | | 0.4500 | 0.4300 | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/13 7:15 | -2950 | | 7.340 | | 0.4550 | 0.4350 | | | | | | |
| 2011/3/13 7:25 | -2950 | | 7.330 | | 0.4550 | 0.4350 | | | | | | |
| 2011/3/13 7:30 | -2950 | | 7.330 | | 0.4600 | 0.4400 | | | | | | |
| 2011/3/13 7:35 | -3000 | | 7.320 | | 0.4600 | 0.4400 | | | | | | |
| 2011/3/13 7:39 | -3000 | | 7.310 | | 0.4600 | 0.4400 | | | | | | |
| 2011/3/13 7:45 | -3000 | | 7.310 | | 0.4600 | 0.4400 | | | | | | |
| 2011/3/13 7:50 | -3000 | | 7.270 | | 0.4650 | 0.4450 | | | | | | |
| 2011/3/13 7:55 | -3000 | | 7.260 | | 0.4650 | 0.4450 | | | | | | |
| 2011/3/13 8:00 | -3000 | | 7.270 | | 0.4650 | 0.4450 | | | | | | |
| 2011/3/13 8:05 | -3000 | | 7.250 | | 0.4650 | 0.4450 | | | | | | |
| 2011/3/13 8:10 | -3000 | | 7.250 | | 0.4650 | 0.4450 | | | | | | |
| 2011/3/13 8:15 | -3000 | | 7.240 | | 0.4650 | 0.4450 | | | | | | |
| 2011/3/13 8:20 | -3000 | | 7.240 | | 0.4650 | 0.4450 | | | | | | |
| 2011/3/13 8:30 | -3000 | | 7.240 | | 0.4650 | 0.4450 | | | | | | |
| 2011/3/13 8:35 | -3000 | | 7.240 | | 0.4650 | 0.4450 | | | | | | |
| 2011/3/13 8:55 | -3000 | | 7.300 | | 0.4700 | 0.4550 | | | | | | |
| 2011/3/13 9:10 | 1800 | | 0.460 | | 0.6370 | 0.5900 | | | | | | |
| 2011/3/13 9:15 | 900 | 1150 | 0.410 | | 0.6300 | 0.5900 | | | | | | |
| 2011/3/13 9:20 | | | 0.390 | | 0.5700 | 0.5200 | | | | | | |
| 2011/3/13 9:20 | | | 0.380 | | 0.5600 | 0.5000 | | | | | | |
| 2011/3/13 9:22 | 700 | 1300 | 0.380 | | 0.5500 | 0.5000 | | | | | | |
| 2011/3/13 9:24 | | | 0.360 | | 0.5400 | 0.4900 | | | | | | |
| 2011/3/13 9:25 | 1000 | 1300 | 0.350 | | 0.5300 | 0.4700 | | | | | | |
| 2011/3/13 9:27 | 1000 | 1100 | 0.340 | | 0.5000 | 0.4500 | | | | | | |
| 2011/3/13 9:29 | 1050 | 1650 | 0.340 | | 0.5000 | 0.4500 | | | | | | |
| 2011/3/13 9:30 | 1000 | 900 | 0.320 | | 0.4800 | 0.4300 | | | | | | |
| 2011/3/13 9:32 | 1000 | 600 | 0.310 | | 0.4750 | 0.4250 | | | | | | |
| 2011/3/13 9:35 | 1000 | 600 | 0.300 | | 0.4700 | 0.4200 | | | | | | |
| 2011/3/13 9:36 | 1000 | 700 | 0.290 | | 0.4600 | 0.4100 | | | | | | |
| 2011/3/13 9:37 | 900 | 800 | 0.280 | | 0.4500 | 0.4000 | | | | | | |
| 2011/3/13 9:38 | 1000 | 800 | 0.280 | | 0.4400 | 0.3900 | | | | | | |
| 2011/3/13 9:40 | 900 | 700 | 0.270 | | 0.4350 | 0.3850 | | | | | | |
| 2011/3/13 9:41 | 900 | 700 | 0.260 | | 0.4250 | 0.3750 | | | | | | |
| 2011/3/13 9:43 | 1000 | 800 | 0.250 | | 0.4200 | 0.3700 | | | | | | |
| 2011/3/13 9:45 | 800 | 650 | 0.250 | | 0.4100 | 0.3600 | | | | | | |
| 2011/3/13 9:47 | 1000 | 600 | 0.250 | | 0.4050 | 0.3550 | | | | | | |
| 2011/3/13 9:49 | 1000 | 600 | 0.240 | | 0.4000 | 0.3500 | | | | | | |
| 2011/3/13 9:53 | 850 | 1550 | 0.230 | | 0.3900 | 0.3350 | | | | | | |
| 2011/3/13 9:55 | 1000 | 600 | 0.240 | | 0.4000 | 0.3500 | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/13 9:56 | 850 | 450 | 0.210 | | 0.3800 | 0.3300 | | | | | | |
| 2011/3/13 9:59 | 500 | 300 | 0.210 | | 0.3700 | 0.3200 | | | | | | |
| 2011/3/13 10:02 | 2300 | 2400 | 0.380 | | 0.3700 | 0.3300 | | | | | | |
| 2011/3/13 10:35 | -200 | -700 | 0.120 | | 0.2800 | 0.2300 | | | | | | |
| 2011/3/13 10:55 | -900 | -1200 | 0.100 | | 0.2700 | 0.2200 | | | | | | |
| 2011/3/13 11:25 | 0 | 1600 | 0.110 | | 0.2800 | 0.2300 | | | | | | |
| 2011/3/13 11:55 | 1000 | 1000 | 0.120 | | | | | | | | | |
| 2011/3/13 12:40 | -1400 | 0 | 0.450 | | 0.4800 | 0.4800 | | | | | | |
| 2011/3/13 13:00 | -1400 | -2000 | 0.190 | | 0.3000 | 0.2500 | | | | | | |
| 2011/3/13 14:10 | -1800 | -2200 | 0.080 | | 0.2350 | 0.1850 | | | | | | |
| 2011/3/13 14:30 | -1800 | -2200 | 0.080 | | 0.2300 | 0.1800 | | | | | | |
| 2011/3/13 15:00 | -1600 | -2000 | 0.090 | | 0.2600 | 0.2100 | | | | | | |
| 2011/3/13 15:30 | -1500 | -1900 | 0.140 | | 0.3100 | 0.2600 | | | | | | |
| 2011/3/13 16:00 | -1500 | -2000 | 0.180 | | 0.3500 | 0.3000 | | | | | | |
| 2011/3/13 16:15 | -1500 | -2000 | 0.190 | | 0.3600 | 0.3100 | | | | | | |
| 2011/3/13 16:30 | -1500 | -1700 | 0.260 | | 0.3950 | 0.3450 | | | | | | |
| 2011/3/13 16:45 | -1500 | -1900 | 0.240 | | 0.4100 | 0.3600 | | | | | | |
| 2011/3/13 17:00 | -1500 | -1900 | 0.240 | | 0.4100 | 0.3600 | | | | | | |
| 2011/3/13 17:15 | -1500 | -1900 | 0.240 | | 0.4100 | 0.3600 | | | | | | |
| 2011/3/13 17:30 | -1800 | -2100 | 0.240 | | 0.4150 | 0.3650 | | | | | | |
| 2011/3/13 18:00 | -1800 | -2100 | 0.250 | | 0.4200 | 0.3700 | | | | | | |
| 2011/3/13 18:20 | -1800 | -2200 | 0.250 | | 0.4200 | 0.3700 | | | | | | |
| 2011/3/13 18:40 | -1800 | -2200 | 0.250 | | 0.4200 | 0.3750 | | | | | | |
| 2011/3/13 19:00 | -1800 | -2200 | 0.250 | | 0.4250 | 0.3750 | | | | | | |
| 2011/3/13 19:30 | -1800 | -2200 | 0.250 | | 0.4250 | 0.3750 | | | | | | |
| 2011/3/13 20:00 | -1800 | -2200 | 0.250 | | 0.4250 | 0.3750 | | | | | | |
| 2011/3/13 20:15 | -1800 | -2200 | | | 0.4250 | 0.3750 | | | | | | |
| 2011/3/13 20:30 | -1800 | -2200 | | | 0.4250 | 0.3750 | | | | | | |
| 2011/3/13 20:45 | -1800 | -2200 | | | 0.4100 | 0.3700 | | | | | | |
| 2011/3/13 21:00 | -1800 | -2200 | | | 0.3950 | 0.3650 | | | | | | |
| 2011/3/13 21:15 | -1800 | -2200 | | | 0.3750 | 0.3550 | | | | | | |
| 2011/3/13 21:30 | -1800 | -2200 | | | 0.3400 | 0.3300 | | | | | | |
| 2011/3/13 21:40 | -1800 | -2200 | | | 0.3200 | 0.3200 | | | | | | |
| 2011/3/13 21:45 | -1800 | -2200 | | | 0.3200 | 0.3100 | | | | | | |
| 2011/3/13 22:00 | -1800 | -2250 | | | 0.3050 | 0.3000 | | | | | | |
| 2011/3/13 22:05 | -1800 | -2250 | | | 0.3000 | 0.3000 | | | | | | |
| 2011/3/13 22:15 | -1800 | -2250 | | | 0.2950 | 0.2950 | | | | | | |
| 2011/3/13 22:30 | -1800 | -2200 | | | 0.2850 | 0.2900 | | | | | | |
| 2011/3/13 23:00 | -1800 | -2250 | 0.084 | 0.082 | 0.2650 | 0.2750 | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/13 23:15 | -1800 | -2250 | | | 0.2600 | 0.2700 | | | | | | |
| 2011/3/13 23:30 | -1800 | -2250 | 0.062 | 0.064 | 0.2500 | 0.2600 | | | | | | |
| 2011/3/14 0:00 | -1800 | -2250 | 0.050 | 0.050 | 0.2400 | 0.2550 | | | | | | |
| 2011/3/14 0:10 | -1800 | -2250 | | | 0.2400 | 0.2550 | | | | | | |
| 2011/3/14 0:20 | -1800 | -2250 | | | 0.2400 | 0.2550 | | | | | | |
| 2011/3/14 0:30 | -1800 | -2250 | 0.048 | 0.048 | 0.2400 | 0.2550 | | | | | | |
| 2011/3/14 0:40 | -1800 | -2250 | | | 0.2400 | 0.2550 | | | | | | |
| 2011/3/14 0:50 | -1800 | -2250 | | | 0.2400 | 0.2600 | | | | | | |
| 2011/3/14 1:00 | -1800 | -2250 | 0.054 | 0.057 | 0.2450 | 0.2600 | | | | | | |
| 2011/3/14 1:10 | -1800 | -2250 | | | 0.2450 | 0.2600 | | | | | | |
| 2011/3/14 1:20 | -1800 | -2250 | | | 0.2500 | 0.2650 | | | | | | |
| 2011/3/14 1:30 | -1800 | -2250 | 0.062 | 0.062 | 0.2550 | 0.2650 | | | | | | |
| 2011/3/14 1:40 | -1800 | -2250 | | | 0.2550 | 0.2700 | | | | | | |
| 2011/3/14 1:50 | -1800 | -2250 | | | 0.2600 | 0.2750 | | | | | | |
| 2011/3/14 2:00 | -1800 | -2250 | 0.073 | 0.075 | 0.2650 | 0.2750 | | | | | | |
| 2011/3/14 2:10 | -1800 | -2250 | | | 0.2700 | 0.2800 | | | | | | |
| 2011/3/14 2:30 | -1850 | -2250 | 0.091 | 0.091 | 0.2800 | 0.2800 | | | | | | |
| 2011/3/14 2:45 | -1850 | -2300 | | | 0.3050 | 0.3000 | | | | | | |
| 2011/3/14 2:50 | -1850 | -2300 | | | 0.3100 | 0.3000 | | | | | | |
| 2011/3/14 3:00 | -1850 | -2300 | 0.127 | 0.127 | 0.3150 | 0.3050 | | | | | | |
| 2011/3/14 3:10 | -1850 | -2300 | | | 0.3200 | 0.3100 | | | | | | |
| 2011/3/14 3:15 | -1850 | | | | | | | | | | | |
| 2011/3/14 3:20 | -1850 | -2300 | | | 0.3300 | 0.3100 | | | | | | |
| 2011/3/14 3:30 | -1850 | -2400 | 0.137 | 0.139 | 0.3300 | 0.3200 | | | | | | |
| 2011/3/14 4:00 | -1800 | -2800 | 0.150 | 0.150 | 0.3400 | 0.3250 | | | | | | |
| 2011/3/14 4:30 | -1850 | -3000 | 0.166 | 0.166 | 0.3600 | 0.3400 | | | | | | |
| 2011/3/14 4:40 | -1850 | -3000 | | | 0.3600 | 0.3400 | | | | | | |
| 2011/3/14 5:00 | -2000 | | 0.171 | 0.171 | 0.3650 | 0.3450 | 1.58E+02 | | 3.78E+00 | | | |
| 2011/3/14 5:30 | -2000 | | | | 0.3900 | 0.3650 | | | | | | |
| 2011/3/14 5:40 | -1800 | | | | 0.4100 | 0.3900 | | | | | | |
| 2011/3/14 6:00 | -2350 | | 0.225 | 0.229 | 0.4250 | 0.4000 | 1.66E+02 | | 3.77E+00 | | | |
| 2011/3/14 6:20 | | | | | 0.4700 | 0.4500 | | | | | | |
| 2011/3/14 6:30 | -100 | -3500 | | | 0.4950 | 0.4700 | | | | | | |
| 2011/3/14 7:00 | | -3000 | 0.319 | 0.315 | 0.5200 | 0.5000 | 1.67E+02 | | 4.00E+00 | | | |
| 2011/3/14 7:10 | | -2700 | 0.303 | 0.307 | 0.5100 | 0.4900 | | | | | | |
| 2011/3/14 7:15 | 1000 | -2100 | 0.299 | 0.303 | 0.5050 | 0.4900 | | | | | | |
| 2011/3/14 7:20 | 2000 | -1600 | 0.298 | 0.299 | 0.5000 | 0.4800 | | | | | | |
| 2011/3/14 7:25 | 1700 | -1300 | 0.298 | 0.299 | 0.5000 | 0.4800 | | | | | | |
| 2011/3/14 7:30 | 1500 | -1400 | 0.298 | 0.301 | 0.5000 | 0.4800 | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/14 7:35 | 1400 | -1500 | 0.295 | 0.301 | 0.5000 | 0.4850 | | | | | | |
| 2011/3/14 7:40 | 1100 | -800 | 0.293 | 0.301 | 0.5000 | 0.4800 | | | | | | |
| 2011/3/14 7:45 | 800 | -500 | 0.295 | 0.299 | 0.5000 | 0.4800 | | | | | | |
| 2011/3/14 7:50 | 400 | 100 | 0.298 | 0.293 | 0.5000 | 0.4800 | | | | | | |
| 2011/3/14 8:00 | -1000 | 650 | 0.291 | 0.298 | 0.5000 | 0.4800 | 1.60E+02 | | 4.40E+00 | | | |
| 2011/3/14 8:05 | -800 | 2100 | 0.289 | 0.293 | 0.5400 | 0.4800 | | | | | | |
| 2011/3/14 8:10 | -500 | 2800 | 0.287 | 0.291 | 0.4950 | 0.4750 | | | | | | |
| 2011/3/14 8:15 | -200 | 3100 | 0.285 | 0.289 | 0.4950 | 0.4750 | | | | | | |
| 2011/3/14 8:20 | -200 | 2600 | 0.285 | 0.289 | 0.4900 | 0.4700 | | | | | | |
| 2011/3/14 8:30 | -1800 | 200 | 0.281 | 0.287 | 0.4900 | 0.4700 | | | | | | |
| 2011/3/14 8:40 | -1800 | 1200 | 0.289 | 0.287 | 0.4900 | 0.4700 | | | | | | |
| 2011/3/14 8:45 | -1700 | 1600 | 0.289 | 0.285 | 0.4900 | 0.4750 | 1.57E+02 | | 4.56E+00 | | | |
| 2011/3/14 8:55 | -1700 | 2500 | 0.285 | 0.291 | 0.4900 | 0.4750 | 1.58E+02 | | 4.53E+00 | | | |
| 2011/3/14 9:05 | -1500 | 2800 | 0.287 | 0.291 | 0.4900 | 0.4750 | 1.57E+02 | | 4.50E+00 | | | |
| 2011/3/14 9:10 | -1700 | 3100 | 0.287 | 0.293 | 0.4950 | 0.4750 | 1.57E+02 | | 4.49E+00 | | | |
| 2011/3/14 9:15 | -1500 | 2500 | 0.289 | 0.295 | 0.4950 | 0.4750 | 1.57E+02 | | 4.47E+00 | | | |
| 2011/3/14 9:20 | -1500 | 1700 | 0.293 | 0.298 | 0.4950 | 0.4800 | 1.56E+02 | | 4.42E+00 | | | |
| 2011/3/14 9:25 | -1500 | 1100 | 0.295 | 0.299 | 0.5000 | 0.4800 | 1.56E+02 | | 4.42E+00 | | | |
| 2011/3/14 9:30 | -1500 | 800 | 0.298 | 0.301 | 0.5000 | 0.4800 | 1.55E+02 | | 4.36E+00 | | | |
| 2011/3/14 9:35 | -1500 | 200 | 0.299 | 0.301 | 0.5000 | 0.4850 | 1.55E+02 | | 4.39E+00 | | | |
| 2011/3/14 9:40 | -1500 | -400 | 0.299 | 0.303 | 0.5000 | 0.4850 | 1.56E+02 | | 4.48E+00 | | | |
| 2011/3/14 9:45 | -1500 | -400 | 0.299 | 0.305 | 0.5000 | 0.4850 | 1.55E+02 | | 4.55E+00 | | | |
| 2011/3/14 9:50 | -1400 | -400 | 0.301 | 0.307 | 0.5000 | 0.4850 | 1.55E+02 | | 4.55E+00 | | | |
| 2011/3/14 9:55 | -1500 | 800 | 0.303 | 0.309 | 0.5050 | 0.4900 | 1.54E+02 | | 4.47E+00 | | | |
| 2011/3/14 10:00 | -1400 | -300 | 0.305 | 0.311 | 0.5100 | 0.4900 | 1.54E+02 | | 4.41E+00 | | | |
| 2011/3/14 10:05 | -1500 | 800 | 0.309 | 0.314 | 0.5100 | 0.4950 | 1.54E+02 | | 4.40E+00 | | | |
| 2011/3/14 10:10 | -1600 | -200 | 0.309 | 0.315 | 0.5150 | 0.4950 | 1.55E+02 | | 4.38E+00 | | | |
| 2011/3/14 10:15 | -1700 | 600 | 0.314 | 0.317 | 0.5150 | 0.4950 | 1.54E+02 | | 4.35E+00 | | | |
| 2011/3/14 10:20 | -1400 | -100 | 0.315 | 0.319 | 0.5200 | 0.5000 | 1.54E+02 | | 4.28E+00 | | | |
| 2011/3/14 10:25 | -1700 | -500 | 0.315 | 0.321 | 0.5200 | 0.5000 | 1.54E+02 | | 4.30E+00 | | | |
| 2011/3/14 10:30 | -1500 | -1000 | 0.315 | 0.321 | 0.5200 | 0.5000 | 1.54E+02 | | 4.35E+00 | | | |
| 2011/3/14 10:35 | -1600 | -600 | 0.315 | 0.321 | 0.5200 | 0.5000 | 1.54E+02 | | 4.35E+00 | | | |
| 2011/3/14 10:40 | -1700 | 0 | 0.315 | 0.321 | 0.5200 | 0.5000 | 1.55E+02 | | 4.34E+00 | | | |
| 2011/3/14 10:45 | -1700 | -100 | 0.315 | 0.321 | 0.5200 | 0.5000 | 1.55E+02 | | 4.35E+00 | | | |
| 2011/3/14 10:50 | -1800 | -400 | 0.317 | 0.323 | 0.5200 | 0.5000 | 1.54E+02 | | 4.35E+00 | | | |
| 2011/3/14 10:55 | -1500 | -600 | 0.317 | 0.323 | 0.5200 | 0.5000 | 1.54E+02 | | 4.34E+00 | | | |
| 2011/3/14 11:02 | -1400 | 3200 | 0.291 | 0.285 | 0.4800 | 0.4700 | | | | | | |
| 2011/3/14 11:15 | -1600 | | 0.195 | 0.203 | 0.3800 | 0.3900 | | | | | | |
| 2011/3/14 11:20 | -1800 | | 0.166 | 0.175 | 0.3600 | 0.3800 | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/14 11:25 | -1800 | | 0.175 | 0.180 | 0.3600 | 0.3800 | | | | | | |
| 2011/3/14 11:30 | -1800 | | 0.166 | 0.175 | 0.3600 | 0.3800 | | | | | | |
| 2011/3/14 11:35 | -1800 | | 0.164 | 0.171 | 0.3600 | 0.3800 | | | | | | |
| 2011/3/14 11:45 | -1800 | -2200 | 0.169 | 0.175 | 0.3600 | 0.3800 | | | | | | |
| 2011/3/14 11:55 | -1800 | -2200 | 0.173 | 0.180 | 0.3600 | 0.3800 | | | | | | |
| 2011/3/14 12:05 | -1800 | -2200 | 0.180 | 0.187 | 0.3700 | 0.3900 | | | | | | |
| 2011/3/14 12:15 | -1800 | -2200 | 0.189 | 0.190 | 0.3800 | 0.3900 | | | | | | |
| 2011/3/14 12:30 | -1800 | -2200 | 0.205 | 0.219 | 0.4000 | 0.4050 | | | | | | |
| 2011/3/14 12:40 | -1800 | -2200 | 0.214 | 0.219 | 0.4050 | 0.4100 | | | | | | |
| 2011/3/14 12:50 | -1800 | -2200 | 0.223 | 0.229 | 0.4150 | 0.4200 | | | | | | |
| 2011/3/14 13:00 | -1800 | -2200 | 0.233 | 0.237 | 0.4300 | 0.4300 | | | | | | |
| 2011/3/14 13:10 | -1800 | -2200 | 0.241 | 0.247 | 0.4400 | 0.4300 | | | | | | |
| 2011/3/14 13:20 | -1800 | -2200 | 0.247 | 0.251 | 0.4450 | 0.4400 | | | | | | |
| 2011/3/14 13:30 | -1800 | -2200 | 0.251 | 0.255 | 0.4500 | 0.4400 | | | | | | |
| 2011/3/14 13:40 | -1800 | -2200 | 0.255 | 0.259 | 0.4500 | 0.4450 | | | | | | |
| 2011/3/14 13:50 | -1800 | -2200 | 0.257 | 0.261 | 0.4500 | 0.4450 | | | | | | |
| 2011/3/14 14:00 | -1800 | -2200 | 0.261 | 0.265 | 0.4600 | 0.4500 | | | | | | |
| 2011/3/14 14:10 | -1800 | -2200 | 0.267 | 0.269 | 0.4600 | 0.4550 | | | | | | |
| 2011/3/14 14:20 | -1800 | -2200 | 0.273 | 0.275 | 0.4700 | 0.4600 | | | | | | |
| 2011/3/14 14:30 | -1800 | -2200 | 0.273 | 0.277 | 0.4700 | 0.4600 | | | | | | |
| 2011/3/14 14:40 | -1800 | -2200 | 0.275 | 0.279 | 0.4750 | 0.4650 | | | | | | |
| 2011/3/14 14:50 | -1800 | -2300 | 0.277 | 0.281 | 0.4800 | 0.4700 | | | | | | |
| 2011/3/14 15:00 | -1800 | -2200 | 0.279 | 0.281 | 0.4800 | 0.4700 | | | | | | |
| 2011/3/14 15:10 | -1800 | -2200 | 0.279 | 0.281 | 0.4800 | 0.4700 | | | | | | |
| 2011/3/14 15:20 | -1800 | -2200 | 0.281 | 0.283 | 0.4800 | 0.4700 | | | | | | |
| 2011/3/14 15:30 | -1800 | -2200 | 0.281 | 0.283 | 0.4800 | 0.4700 | | | | | | |
| 2011/3/14 15:40 | -1800 | -2200 | 0.283 | 0.285 | 0.4800 | 0.4700 | | | | | | |
| 2011/3/14 15:50 | -1800 | -2200 | 0.285 | 0.285 | 0.4800 | 0.4750 | | | | | | |
| 2011/3/14 16:00 | -1800 | -2200 | 0.287 | 0.289 | 0.4800 | 0.4750 | | | | | | |
| 2011/3/14 16:10 | -1800 | -2200 | 0.287 | 0.289 | 0.4800 | 0.4750 | | | | | | |
| 2011/3/14 16:20 | -1800 | -2200 | 0.287 | 0.289 | 0.4800 | 0.4750 | | | | | | |
| 2011/3/14 16:30 | -1800 | -2200 | 0.285 | 0.287 | 0.4800 | 0.4750 | | | | | | |
| 2011/3/14 16:40 | -1800 | -2200 | 0.279 | 0.264 | 0.4750 | 0.4700 | | | | | | |
| 2011/3/14 16:50 | -1800 | -2200 | 0.259 | 0.261 | 0.4600 | 0.4500 | | | | | | |
| 2011/3/14 17:00 | -1800 | -2200 | 0.247 | 0.247 | 0.4400 | 0.4400 | | | | | | |
| 2011/3/14 17:10 | -1800 | -2200 | 0.233 | 0.235 | 0.4300 | 0.4300 | | | | | | |
| 2011/3/14 17:20 | -1800 | -2200 | 0.223 | 0.225 | 0.4200 | 0.0200 | | | | | | |
| 2011/3/14 17:30 | -1800 | -2200 | 0.213 | 0.213 | 0.4000 | | | | | | | |
| 2011/3/14 17:40 | -1800 | -2200 | 0.205 | 0.205 | 0.4000 | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/14 17:50 | -1800 | -2200 | 0.195 | 0.195 | 0.3850 | | | | | | | |
| 2011/3/14 18:00 | -1850 | -2200 | 0.191 | 0.191 | 0.3800 | | | | | | | |
| 2011/3/14 18:10 | -1900 | -2300 | 0.185 | 0.185 | 0.3700 | | | | | | | |
| 2011/3/14 18:20 | -1850 | -2300 | 0.180 | 0.180 | 0.3700 | | | | | | | |
| 2011/3/14 18:30 | -1850 | -2300 | 0.179 | 0.179 | 0.3700 | | | | | | | |
| 2011/3/14 18:40 | -1900 | -2300 | 0.175 | 0.175 | 0.3600 | | | | | | | |
| 2011/3/14 18:50 | -1900 | -2300 | 0.175 | 0.175 | 0.3600 | | | | | | | |
| 2011/3/14 19:00 | -1900 | -2300 | 0.173 | 0.173 | 0.3600 | | | | | | | |
| 2011/3/14 19:10 | -1900 | -2300 | 0.173 | 0.173 | 0.3600 | | | | | | | |
| 2011/3/14 19:20 | -1900 | -2300 | 0.173 | 0.173 | 0.3600 | | | | | | | |
| 2011/3/14 19:30 | -1900 | -2300 | 0.173 | 0.173 | 0.3550 | | | | | | | |
| 2011/3/14 20:00 | -1900 | -2300 | 0.175 | 0.175 | 0.3550 | | | | | | | |
| 2011/3/14 20:10 | -1900 | -2300 | 0.175 | 0.175 | 0.3550 | | | | | | | |
| 2011/3/14 20:20 | -1900 | -2300 | 0.173 | 0.173 | 0.3550 | | | | | | | |
| 2011/3/14 20:30 | -1900 | -2300 | 0.173 | 0.173 | 0.3550 | | | | | | | |
| 2011/3/14 20:40 | -1850 | -2300 | 0.173 | 0.173 | 0.3600 | | | | | | | |
| 2011/3/14 20:50 | -1850 | -2300 | 0.175 | 0.175 | 0.3600 | | | | | | | |
| 2011/3/14 21:00 | -1850 | -2300 | 0.175 | 0.175 | 0.3600 | | | | | | | |
| 2011/3/14 21:10 | -1850 | -2300 | 0.175 | 0.175 | 0.3600 | | | | | | | |
| 2011/3/14 21:20 | -1850 | -2300 | 0.175 | 0.175 | 0.3600 | | | | | | | |
| 2011/3/14 21:30 | -1850 | -2300 | 0.175 | 0.175 | 0.3600 | | | | | | | |
| 2011/3/14 21:40 | -1850 | -2300 | 0.175 | 0.175 | 0.3600 | | | | | | | |
| 2011/3/14 22:00 | -1850 | -2300 | 0.177 | 0.177 | 0.3600 | | | | | | | |
| 2011/3/14 22:15 | -1850 | -2300 | 0.179 | 0.179 | 0.3600 | | | | | | | |
| 2011/3/14 22:30 | -1900 | -2300 | 0.180 | 0.180 | 0.3600 | | | | | | | |
| 2011/3/14 22:40 | -1900 | -2300 | 0.185 | 0.185 | 0.3700 | | | | | | | |
| 2011/3/14 22:45 | -1900 | -2300 | 0.185 | 0.185 | 0.3700 | | | | | | | |
| 2011/3/14 23:00 | -1900 | -2300 | 0.189 | 0.189 | 0.3700 | | | | | | | |
| 2011/3/14 23:15 | -1900 | -2300 | 0.193 | 0.193 | 0.3700 | | | | | | | |
| 2011/3/14 23:30 | -1850 | -2300 | 0.195 | 0.195 | 0.3800 | | | | | | | |
| 2011/3/14 23:45 | -1900 | -2300 | 0.201 | 0.198 | 0.3950 | | | | | | | |
| 2011/3/15 0:00 | -1900 | -2300 | 0.203 | 0.203 | 0.3900 | | | | | | | |
| 2011/3/15 0:15 | -1900 | -2300 | 0.207 | 0.205 | 0.3900 | | | | | | | |
| 2011/3/15 0:30 | -1900 | -2300 | 0.211 | 0.211 | 0.4000 | | | | | | | |
| 2011/3/15 0:45 | -1900 | -2300 | 0.211 | 0.211 | 0.4000 | | | | | | | |
| 2011/3/15 1:00 | -1900 | -2300 | 0.211 | 0.213 | 0.4000 | | | | | | | |
| 2011/3/15 1:15 | -1800 | -2200 | 0.214 | 0.214 | 0.4000 | | | | | | | |
| 2011/3/15 1:30 | -1800 | -2300 | 0.214 | 0.214 | 0.4000 | | | | | | | |
| 2011/3/15 1:45 | -1850 | -2300 | 0.219 | 0.219 | 0.4000 | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/15 2:00 | -1900 | -2300 | 0.221 | 0.221 | 0.4000 | | | | | | | |
| 2011/3/15 2:15 | -1900 | -2300 | 0.221 | 0.221 | 0.4100 | | | | | | | |
| 2011/3/15 2:30 | -1900 | -2300 | 0.225 | 0.223 | 0.4050 | | | | | | | |
| 2011/3/15 2:45 | -1900 | -2300 | 0.227 | 0.227 | 0.4050 | | | | | | | |
| 2011/3/15 3:00 | -1900 | -2300 | 0.229 | 0.229 | 0.4100 | | | | | | | |
| 2011/3/15 3:10 | -1900 | -2300 | 0.233 | 0.233 | 0.4150 | | | | | | | |
| 2011/3/15 3:45 | -1900 | -2300 | 0.233 | 0.233 | 0.4150 | | | | | | | |
| 2011/3/15 4:00 | -1900 | -2300 | 0.235 | 0.235 | 0.4150 | | | | | | | |
| 2011/3/15 4:15 | -1900 | -2300 | 0.235 | 0.235 | 0.4150 | | | | | | | |
| 2011/3/15 4:30 | -1800 | -2300 | 0.233 | 0.233 | 0.4150 | | | | | | | |
| 2011/3/15 4:47 | -1800 | -2300 | 0.230 | 0.230 | 0.4150 | | | | | | | |
| 2011/3/15 5:00 | -1800 | -2300 | 0.230 | 0.230 | 0.4150 | | | | | | | |
| 2011/3/15 5:30 | -1800 | -2300 | 0.230 | 0.230 | 0.4150 | | | | | | | |
| 2011/3/15 6:00 | -1800 | -2300 | 0.230 | 0.230 | 0.4150 | | | | | | | |
| 2011/3/15 11:20 | -1900 | -2300 | 0.235 | 0.237 | 0.4200 | | | | | | | |
| 2011/3/15 11:30 | -1900 | -2300 | 0.235 | 0.235 | 0.4200 | | | | | | | |
| 2011/3/15 11:50 | -1900 | -2300 | 0.235 | 0.237 | 0.4200 | | | | | | | |
| 2011/3/15 13:00 | -1900 | -2300 | 0.235 | 0.237 | 0.4200 | | | | | | | |
| 2011/3/15 16:00 | -1900 | -2300 | 0.227 | 0.227 | 0.4150 | | | | | | | |
| 2011/3/15 20:45 | -1900 | -2300 | 0.170 | 0.170 | 0.3400 | | | | | | | |
| 2011/3/15 20:55 | -1900 | -2300 | 0.170 | 0.170 | 0.3400 | | | | | | | |
| 2011/3/15 21:05 | -1900 | -2300 | 0.161 | 0.170 | 0.3350 | | | | | | | |
| 2011/3/16 1:35 | -1900 | -2300 | 0.146 | 0.151 | 0.3200 | | | | | | | |
| 2011/3/16 2:05 | -1900 | -2300 | 0.143 | 0.149 | 0.3200 | | | | | | | |
| 2011/3/16 2:20 | -1900 | -2300 | 0.143 | 0.149 | 0.3200 | | | | | | | |
| 2011/3/16 6:15 | -1900 | -2300 | 0.117 | 0.117 | 0.2950 | | | | | | | |
| 2011/3/16 9:10 | -1900 | -2300 | 0.128 | 0.134 | 0.3050 | | | | | | | |
| 2011/3/16 9:20 | -1900 | -2300 | 0.100 | 0.104 | 0.2750 | | | | | | | |
| 2011/3/16 9:30 | -1900 | -2300 | 0.094 | 0.098 | 0.2700 | | | | | | | |
| 2011/3/16 9:40 | -1900 | -2300 | 0.094 | 0.090 | 0.2650 | | | | | | | |
| 2011/3/16 9:55 | -1900 | -2300 | 0.083 | 0.090 | 0.2600 | | | | | | | |
| 2011/3/16 10:00 | -1900 | -2300 | 0.077 | 0.077 | 0.2500 | | | | | | | |
| 2011/3/16 10:10 | -1900 | -2300 | 0.073 | 0.078 | 0.2500 | | | | | | | |
| 2011/3/16 10:20 | -1900 | -2300 | 0.068 | 0.075 | 0.2450 | | | | | | | |
| 2011/3/16 10:30 | -1900 | -2300 | 0.072 | 0.079 | 0.2450 | | | | | | | |
| 2011/3/16 11:45 | -1900 | -2300 | 0.051 | 0.058 | 0.2250 | | | | | | | |
| 2011/3/16 12:20 | -1900 | -2300 | 0.056 | 0.061 | 0.2300 | | | | | | | |
| 2011/3/16 12:35 | -1900 | -2300 | 0.056 | 0.061 | 0.2300 | | | | | | | |
| 2011/3/16 12:40 | -1900 | -2300 | 0.056 | 0.061 | 0.2300 | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/16 12:45 | -1900 | -2300 | 0.056 | 0.061 | 0.2300 | | | | | | | |
| 2011/3/16 14:35 | -1900 | -2300 | 0.043 | 0.051 | 0.2200 | | | | | | | |
| 2011/3/16 14:45 | -1900 | -2300 | 0.043 | 0.051 | 0.2200 | | | | | | | |
| 2011/3/16 19:25 | -1900 | -2300 | 0.036 | 0.041 | 0.1900 | | | | | | | |
| 2011/3/16 20:40 | -1900 | -2300 | 0.041 | 0.041 | 0.1900 | | | | | | | |
| 2011/3/16 23:50 | -1950 | -2300 | 0.009 | 0.015 | 0.1850 | | | | | | | |
| 2011/3/17 0:07 | -1950 | -2300 | 0.010 | 0.017 | 0.1850 | | | | | | | |
| 2011/3/17 3:05 | -1950 | -2300 | 0.022 | 0.030 | 0.2000 | | | | | | | |
| 2011/3/17 3:20 | -1950 | -2300 | 0.022 | 0.030 | 0.2000 | | | | | | | |
| 2011/3/17 4:00 | -1950 | -2300 | 0.022 | 0.030 | 0.2000 | | | | | | | |
| 2011/3/17 6:15 | -1900 | -2300 | 0.022 | 0.030 | 0.2000 | 0.0100 | | | | | | |
| 2011/3/17 6:30 | -1900 | -2300 | 0.024 | 0.032 | 0.2000 | 0.0950 | | | | | | |
| 2011/3/17 6:45 | -1900 | -2300 | 0.024 | 0.032 | 0.2000 | 0.3250 | | | | | | |
| 2011/3/17 6:50 | -1900 | -2300 | 0.024 | 0.032 | 0.2000 | 0.2250 | | | | | | |
| 2011/3/17 6:55 | -1900 | -2300 | 0.024 | 0.032 | 0.2000 | 0.1250 | | | | | | |
| 2011/3/17 7:00 | -1900 | -2300 | 0.024 | 0.032 | 0.2000 | 0.1900 | | | | | | |
| 2011/3/17 7:05 | -1900 | -2300 | 0.024 | 0.032 | 0.2000 | 0.2700 | | | | | | |
| 2011/3/17 7:10 | -1900 | -2300 | 0.024 | 0.032 | 0.2000 | 0.1700 | | | | | | |
| 2011/3/17 7:15 | -1900 | -2300 | 0.024 | 0.032 | 0.2000 | 0.3850 | | | | | | |
| 2011/3/17 7:20 | -1900 | -2300 | 0.026 | 0.034 | 0.2000 | 0.0700 | | | | | | |
| 2011/3/17 7:25 | -1900 | -2300 | 0.026 | 0.034 | 0.2000 | 0.5500 | | | | | | |
| 2011/3/17 7:30 | -1900 | -2300 | 0.024 | 0.034 | 0.2000 | 0.4150 | | | | | | |
| 2011/3/17 7:35 | -1900 | -2300 | 0.026 | 0.034 | 0.2000 | 0.0500 | | | | | | |
| 2011/3/17 7:45 | -1900 | -2300 | 0.026 | 0.034 | 0.2000 | 0.1900 | | | | | | |
| 2011/3/17 7:55 | -1900 | -2350 | 0.026 | 0.034 | 0.2000 | 0.4150 | | | | | | |
| 2011/3/17 8:15 | -1900 | -2300 | 0.026 | 0.034 | 0.2000 | 0.1500 | | | | | | |
| 2011/3/17 8:30 | -1900 | -2300 | 0.026 | 0.034 | 0.2000 | 0.2500 | | | | | | |
| 2011/3/17 8:45 | -1900 | -2300 | 0.026 | 0.036 | 0.2000 | 0.2800 | | | | | | |
| 2011/3/17 11:06 | -1950 | -2300 | 0.013 | 0.024 | 0.1900 | 0.3250 | | | | | | |
| 2011/3/17 11:10 | -1950 | -2300 | 0.013 | 0.022 | 0.1900 | | | | | | | |
| 2011/3/17 16:10 | -1950 | -2300 | | | 0.1700 | | | | | | | |
| 2011/3/17 16:17 | -1950 | -2300 | | | 0.1700 | | | | | | | |
| 2011/3/17 16:25 | -1950 | -2300 | 0.005 | 0.017 | 0.1700 | | | | | | | |
| 2011/3/17 16:35 | -1950 | -2300 | 0.005 | 0.017 | 0.1700 | | | | | | | |
| 2011/3/17 21:35 | -1950 | -2300 | -0.030 | -0.017 | 0.1500 | | | | | | | |
| 2011/3/17 21:50 | -1950 | -2300 | 0.010 | 0.008 | 0.1500 | | | | | | | |
| 2011/3/17 22:00 | -1950 | -2300 | -0.009 | 0.005 | 0.1500 | | | | | | | |
| 2011/3/18 2:00 | -2000 | -2300 | -0.007 | 0.009 | 0.1500 | | | | | | | |
| 2011/3/18 2:20 | -2000 | -2300 | -0.009 | 0.009 | 0.1500 | | | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/18 2:30 | -2000 | -2300 | -0.005 | 0.013 | 0.1550 | | | | | | | |
| 2011/3/18 2:45 | -2000 | -2300 | -0.005 | 0.013 | 0.1550 | | | | | | | |
| 2011/3/18 7:20 | -1900 | -2300 | -0.010 | 0.007 | 0.1500 | | | | | | | |
| 2011/3/18 7:30 | -1900 | -2300 | -0.007 | 0.009 | 0.1500 | | | | | | | |
| 2011/3/18 7:50 | -1900 | -2300 | -0.009 | 0.009 | 0.1500 | | | | | | | |
| 2011/3/18 8:00 | -1900 | -2300 | -0.005 | 0.009 | 0.1500 | | 5.44E+01 | | 3.40E+00 | | | |
| 2011/3/18 11:50 | -1900 | -2300 | 0.000 | -0.017 | 0.1550 | | 1.05E+02 | 9.52E+01 | 5.90E+00 | 3.81E+00 | | |
| 2011/3/18 12:15 | -2000 | -2300 | 0.000 | -0.017 | 0.1550 | | 1.05E+02 | 9.52E+01 | 5.90E+00 | 3.81E+00 | | |
| 2011/3/18 12:35 | -2000 | -2300 | 0.000 | -0.017 | 0.1550 | | 1.05E+02 | 9.52E+01 | 5.90E+00 | 3.81E+00 | | |
| 2011/3/18 15:45 | -2000 | -2300 | 0.015 | -0.015 | 0.1600 | | 1.02E+02 | 9.33E+01 | 5.28E+00 | 3.71E+00 | 0.400 | |
| 2011/3/18 15:55 | -2000 | -2300 | 0.015 | -0.015 | 0.1600 | | 1.02E+02 | 9.33E+01 | 5.28E+00 | 3.71E+00 | | |
| 2011/3/18 20:50 | -1900 | -2300 | 0.017 | -0.015 | 0.1600 | | 9.68E+01 | 9.07E+01 | 5.10E+00 | 3.58E+00 | | |
| 2011/3/18 21:05 | -1900 | -2300 | 0.015 | -0.015 | 0.1600 | | 9.64E+01 | 9.06E+01 | 5.09E+00 | 3.58E+00 | | |
| 2011/3/19 2:10 | -3200 | -3300 | 0.020 | -0.143 | 0.0550 | | 9.21E+01 | 8.41E+01 | 4.90E+00 | 3.46E+00 | | |
| 2011/3/19 2:25 | -3200 | -3350 | 0.020 | -0.143 | 0.0550 | | 9.24E+01 | 8.58E+01 | 4.90E+00 | 3.45E+00 | | |
| 2011/3/19 2:40 | -3250 | -3350 | 0.019 | -0.015 | 0.0500 | | 9.19E+01 | 8.56E+01 | 4.89E+00 | 3.45E+00 | | |
| 2011/3/19 2:55 | -3300 | -3400 | 0.019 | -0.015 | 0.0450 | | 9.19E+01 | 8.53E+01 | 4.88E+00 | 3.44E+00 | | |
| 2011/3/19 3:11 | -3350 | -3400 | 0.026 | -0.015 | 0.0400 | | 9.14E+01 | 8.51E+01 | 4.88E+00 | 3.44E+00 | | |
| 2011/3/19 4:40 | | | | | | | 8.99E+01 | 8.40E+01 | 4.36E+00 | 3.21E+00 | | |
| 2011/3/19 5:40 | -1650 | -2300 | 0.010 | 0.043 | 0.1900 | | 9.09E+01 | 8.33E+01 | 3.70E+00 | 3.15E+00 | | |
| 2011/3/19 6:00 | -1300 | -2300 | 0.005 | 0.041 | 0.1850 | | 8.86E+01 | 8.32E+01 | 3.78E+00 | 3.11E+00 | | |
| 2011/3/19 6:10 | -1200 | -2300 | 0.005 | 0.043 | 0.1850 | | 8.83E+01 | 8.31E+01 | 3.76E+00 | 3.09E+00 | | |
| 2011/3/19 8:00 | -2400 | -2300 | 0.009 | 0.044 | 0.1800 | | 8.74E+01 | 8.27E+01 | 3.72E+00 | 3.06E+00 | | |
| 2011/3/19 8:20 | -2700 | -2300 | 0.015 | 0.053 | 0.1900 | | 8.97E+01 | 8.25E+01 | 3.80E+00 | 3.13E+00 | | |
| 2011/3/19 8:30 | -2600 | -2300 | 0.013 | 0.051 | 0.1900 | | 8.95E+01 | 8.24E+01 | 3.83E+00 | 3.12E+00 | 0.350 | |
| 2011/3/19 11:00 | -1950 | -2300 | 0.017 | -0.019 | 0.1600 | | | | | | | |
| 2011/3/19 11:15 | -1950 | -2300 | 0.015 | -0.022 | 0.1600 | | | | | | 0.320 | |
| 2011/3/19 16:35 | -1950 | -2300 | 0.060 | -0.026 | 0.1900 | | 7.63E+01 | 7.76E+01 | 3.52E+00 | 3.31E+00 | | |
| 2011/3/19 16:50 | -1950 | -2300 | 0.084 | -0.043 | 0.2100 | | 7.85E+01 | 7.79E+01 | 3.90E+00 | 3.68E+00 | | |
| 2011/3/19 17:25 | -1850 | -2300 | 0.081 | -0.047 | 0.2100 | | 7.84E+01 | 7.78E+01 | 3.85E+00 | 3.49E+00 | | |
| 2011/3/19 21:30 | -1950 | -2250 | 0.112 | 0.081 | 0.2550 | | | | | | 0.330 | |
| 2011/3/19 21:55 | -1950 | -2250 | 0.115 | 0.083 | 0.2550 | | | | | | 0.330 | |
| 2011/3/20 0:25 | -1950 | -2350 | 0.136 | 0.104 | 0.2700 | | 6.12E+01 | 6.70E+01 | 3.24E+00 | 3.39E+00 | 0.300 | |
| 2011/3/20 0:50 | -1950 | -2350 | 0.138 | 0.102 | 0.2800 | | 6.59E+01 | 6.71E+01 | 3.10E+00 | 3.35E+00 | 0.300 | |
| 2011/3/20 1:10 | -1950 | -2350 | 0.141 | 0.107 | 0.2800 | | 6.70E+01 | 6.80E+01 | 3.12E+00 | 3.37E+00 | 0.300 | |
| 2011/3/20 3:10 | -1950 | -2250 | 0.187 | 0.151 | 0.3200 | 0.1800 | 7.20E+01 | 6.47E+01 | 3.08E+00 | 3.04E+00 | 0.330 | |
| 2011/3/20 4:10 | -1950 | -2300 | 0.197 | 0.163 | 0.3350 | 0.0600 | 7.05E+01 | 6.45E+01 | 3.07E+00 | 2.88E+00 | 0.330 | |
| 2011/3/20 4:30 | -1950 | -2300 | 0.204 | 0.170 | 0.3400 | 0.0500 | 6.96E+01 | 6.47E+01 | 3.07E+00 | 2.86E+00 | 0.330 | |
| 2011/3/20 9:55 | -1950 | -2350 | 0.180 | 0.146 | 0.3200 | 0.4000 | 7.08E+01 | 6.31E+01 | 2.30E+00 | 2.31E+00 | 0.330 | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/20 10:10 | -1950 | -2350 | 0.175 | 0.136 | 0.3100 | 0.4000 | 7.11E+01 | 6.29E+01 | 2.23E+00 | 2.25E+00 | 0.330 | |
| 2011/3/20 10:35 | -1950 | -2300 | 0.170 | 0.132 | 0.3100 | 0.4000 | 7.08E+01 | 6.28E+01 | 2.18E+00 | 2.23E+00 | 0.330 | |
| 2011/3/20 11:00 | -1950 | -2250 | 0.179 | 0.141 | 0.3100 | 0.4000 | 7.09E+01 | 6.28E+01 | 2.20E+00 | 2.25E+00 | 0.330 | |
| 2011/3/20 15:00 | -1600 | -2000 | 0.155 | 0.121 | 0.3000 | 0.3150 | 7.20E+01 | 6.30E+01 | 2.02E+00 | 2.11E+00 | 0.330 | |
| 2011/3/20 15:35 | -1550 | -2000 | 0.158 | 0.117 | 0.2900 | 0.1250 | 7.18E+01 | 6.29E+01 | 2.01E+00 | 2.09E+00 | 0.330 | |
| 2011/3/20 16:00 | -1650 | -2000 | 0.153 | 0.112 | 0.2900 | 0.4000 | 7.17E+01 | 6.28E+01 | 2.00E+00 | 2.08E+00 | 0.330 | |
| 2011/3/20 19:40 | -2000 | -2000 | 0.095 | 0.056 | 0.2300 | | 7.11E+01 | 6.27E+01 | 1.93E+00 | 2.05E+00 | 0.330 | |
| 2011/3/20 19:50 | -2000 | -2000 | 0.095 | 0.056 | 0.2300 | | 7.11E+01 | 6.27E+01 | 1.93E+00 | 2.05E+00 | 0.330 | |
| 2011/3/20 20:00 | -1625 | -1900 | 0.094 | 0.049 | 0.2250 | | 7.10E+01 | 6.25E+01 | 1.92E+00 | 2.05E+00 | 0.330 | |
| 2011/3/21 1:25 | -1700 | -2000 | 8.968 | -0.005 | 0.1800 | | 6.99E+01 | 6.14E+01 | 1.88E+00 | 2.00E+00 | 0.310 | |
| 2011/3/21 1:45 | -1650 | -2000 | 11.571 | -0.010 | 0.1700 | | 6.97E+01 | 6.12E+01 | 1.88E+00 | 2.00E+00 | 0.300 | |
| 2011/3/21 2:30 | -1650 | -2000 | 10.774 | -0.009 | 0.1700 | | 6.96E+01 | 6.10E+01 | 1.87E+00 | 2.00E+00 | 0.290 | |
| 2011/3/21 4:00 | -1650 | -1950 | 0.202 | -0.026 | 0.1600 | | 6.92E+01 | 6.05E+01 | 1.88E+00 | 1.99E+00 | 0.290 | |
| 2011/3/21 10:00 | -2550 | -2750 | -0.500 | -0.043 | 0.1200 | | 6.74E+01 | 5.90E+01 | 1.86E+00 | 1.87E+00 | 0.290 | |
| 2011/3/21 12:15 | -1600 | -2000 | 0.041 | -0.078 | 0.1200 | | 6.72E+01 | 5.86E+01 | 1.83E+00 | 1.85E+00 | 0.290 | |
| 2011/3/21 14:40 | -1550 | -2025 | 0.043 | -0.083 | 0.1100 | | 6.63E+01 | 5.76E+01 | | | 0.280 | |
| 2011/3/21 14:55 | -1550 | -2025 | 0.043 | -0.083 | 0.1100 | | | | | | 0.280 | |
| 2011/3/21 23:40 | -1500 | -2300 | 0.039 | -0.094 | 0.1000 | | | | | | 0.280 | |
| 2011/3/22 0:15 | -1575 | -2250 | 0.041 | -0.094 | 0.1000 | | | | | | 0.280 | |
| 2011/3/22 5:15 | -1550 | -2350 | 0.036 | -0.095 | 0.1000 | | | | | | 0.280 | |
| 2011/3/22 5:30 | -1575 | -2350 | 0.036 | -0.095 | 0.1000 | | | | | | 0.280 | |
| 2011/3/22 10:20 | -1575 | -2325 | 0.036 | -0.094 | 0.1000 | | | | | | 0.260 | |
| 2011/3/22 10:35 | -1575 | -2350 | 0.034 | -0.095 | 0.1000 | | 6.00E+01 | 5.28E+01 | 1.58E+00 | 1.59E+00 | 0.260 | |
| 2011/3/22 17:10 | -1525 | -2250 | 0.036 | -0.094 | 0.1000 | | | | | | 0.240 | |
| 2011/3/22 17:40 | -1525 | -2250 | 0.034 | -0.094 | 0.1000 | | | | | | 0.240 | |
| 2011/3/22 22:00 | -1750 | -2350 | 0.036 | -0.094 | 0.1000 | | | | | | 0.240 | |
| 2011/3/22 22:40 | -1750 | -2350 | 0.036 | -0.094 | 0.1000 | | 6.10E+01 | 5.15E+01 | 1.69E+00 | 1.59E+00 | 0.240 | |
| 2011/3/23 3:00 | -1900 | -2300 | 0.032 | -0.098 | 0.1000 | | 6.05E+01 | 5.05E+01 | 1.75E+00 | 1.60E+00 | 0.240 | |
| 2011/3/23 4:00 | -1900 | -2300 | 0.034 | -0.095 | 0.1000 | | 6.05E+01 | 5.04E+01 | 1.75E+00 | 1.60E+00 | 0.240 | |
| 2011/3/23 8:20 | -1800 | -2300 | 0.034 | -0.098 | 0.1000 | | 6.02E+01 | 4.95E+01 | 1.74E+00 | 1.57E+00 | 0.240 | |
| 2011/3/23 8:50 | -1900 | -2300 | 0.032 | -0.098 | 0.1000 | | 6.02E+01 | 4.94E+01 | 1.74E+00 | 1.57E+00 | 0.250 | |
| 2011/3/23 9:10 | -1800 | -2300 | 0.032 | -0.098 | 0.1000 | | 6.02E+01 | 4.93E+01 | 1.74E+00 | 1.56E+00 | 0.250 | |
| 2011/3/23 13:40 | -1800 | -2300 | 0.041 | -0.094 | 0.1000 | | 5.95E+01 | 4.85E+01 | 1.72E+00 | 1.54E+00 | 0.230 | |
| 2011/3/23 21:10 | -1700 | -2300 | 0.041 | -0.095 | | | 5.88E+01 | 4.73E+01 | 1.69E+00 | 1.51E+00 | 0.200 | |
| 2011/3/23 21:40 | -1800 | -2300 | 0.036 | -0.098 | | | 5.87E+01 | 4.72E+01 | 1.68E+00 | 1.51E+00 | 0.200 | |
| 2011/3/24 2:20 | -1800 | -2300 | 0.041 | -0.092 | | | 5.81E+01 | 4.65E+01 | 1.66E+00 | 1.50E+00 | 0.230 | |
| 2011/3/24 2:40 | -1800 | -2300 | 0.039 | -0.092 | | | 5.79E+01 | 4.64E+01 | 1.66E+00 | 1.50E+00 | 0.220 | |
| 2011/3/24 6:20 | -1800 | -2300 | 0.039 | -0.090 | 0.1076 | 0.1955 | 5.80E+01 | 4.59E+01 | 1.64E+00 | 1.49E+00 | 0.210 | |
| 2011/3/24 6:35 | -1800 | -2300 | 0.039 | -0.090 | 0.1078 | 0.1958 | 5.72E+01 | 4.57E+01 | 1.64E+00 | 1.49E+00 | 0.200 | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/24 10:00 | -1900 | -2300 | 0.036 | -0.094 | 0.1074 | 0.1978 | 5.59E+01 | 4.50E+01 | 1.62E+00 | 1.48E+00 | 0.200 | |
| 2011/3/24 10:20 | -1900 | -2300 | 0.034 | -0.094 | 0.1071 | 0.1986 | 5.59E+01 | 4.49E+01 | 1.62E+00 | 1.47E+00 | 0.200 | |
| 2011/3/24 18:00 | -1850 | -2300 | 0.036 | -0.095 | 0.1073 | 0.1999 | 5.33E+01 | 4.37E+01 | 1.45E+00 | 1.59E+00 | 0.300 | |
| 2011/3/24 21:40 | -1900 | -2300 | 0.041 | -0.092 | 0.1066 | 0.1993 | 5.47E+01 | 4.28E+01 | 1.57E+00 | 1.42E+00 | 0.250 | |
| 2011/3/24 22:00 | -1800 | -2300 | 0.030 | -0.098 | 0.1068 | 0.1997 | 5.29E+01 | 4.28E+01 | 1.56E+00 | 1.42E+00 | 0.240 | |
| 2011/3/24 23:30 | -1700 | -2300 | 0.039 | -0.092 | 0.1085 | 0.1981 | 5.20E+01 | 4.25E+01 | 1.55E+00 | 1.41E+00 | 0.250 | |
| 2011/3/25 0:30 | -1700 | -2300 | 0.041 | -0.092 | 0.1085 | 0.1972 | 5.18E+01 | 4.24E+01 | 1.54E+00 | 1.40E+00 | 0.250 | |
| 2011/3/25 5:30 | -1900 | -2300 | 0.039 | -0.092 | 0.1076 | 0.1948 | 5.00E+01 | 4.15E+01 | 1.50E+00 | 1.36E+00 | 0.200 | |
| 2011/3/25 6:10 | -1900 | -2300 | 0.036 | -0.092 | 0.1074 | 0.1937 | 5.10E+01 | 4.14E+01 | 1.50E+00 | 1.36E+00 | 0.200 | |
| 2011/3/25 9:30 | -1900 | -2300 | 0.034 | -0.092 | 0.1074 | 0.1923 | 4.93E+01 | 4.08E+01 | 1.47E+00 | 1.34E+00 | 0.200 | |
| 2011/3/25 14:10 | -1900 | -2300 | 0.036 | -0.098 | 0.1089 | 0.1913 | 4.85E+01 | 4.00E+01 | 1.31E+00 | 1.44E+00 | 0.200 | |
| 2011/3/25 16:10 | -1900 | -2300 | 0.034 | -0.094 | 0.1075 | 0.1895 | 3.88E+01 | 2.94E+01 | 1.31E+00 | 1.44E+00 | | |
| 2011/3/25 18:10 | -1800 | -2300 | 0.036 | -0.098 | 0.1069 | 0.1883 | 3.78E+01 | 2.85E+01 | 1.43E+00 | 1.30E+00 | 0.170 | |
| 2011/3/25 19:10 | -1900 | -2300 | 0.034 | -0.098 | 0.1069 | 0.1824 | 3.73E+01 | 2.83E+01 | 1.42E+00 | 1.20E+00 | 0.180 | |
| 2011/3/26 4:20 | -1825 | -2300 | 0.036 | -0.094 | 0.1068 | 0.1850 | 3.68E+01 | 2.77E+01 | 1.41E+00 | 1.30E+00 | 0.180 | |
| 2011/3/26 5:05 | -1850 | -2300 | 0.036 | -0.095 | 0.1069 | 0.1848 | 3.66E+01 | 2.77E+01 | 1.41E+00 | 1.30E+00 | 0.180 | |
| 2011/3/26 10:00 | -1800 | -2300 | 0.036 | -0.095 | 0.1066 | 0.1839 | 3.61E+01 | 2.75E+01 | 1.40E+00 | 1.30E+00 | 0.190 | |
| 2011/3/26 11:15 | -1850 | -2300 | 0.036 | -0.095 | 0.1068 | 0.1836 | 3.61E+01 | 2.74E+01 | 1.40E+00 | 1.30E+00 | 0.220 | |
| 2011/3/26 14:30 | -1850 | -2300 | 0.032 | -0.100 | 0.1068 | 0.1831 | 3.57E+01 | 2.71E+01 | 1.30E+00 | 1.39E+00 | 0.200 | |
| 2011/3/26 16:00 | -1900 | -2250 | 0.034 | -0.100 | 0.1066 | 0.1825 | 3.55E+01 | 2.69E+01 | 1.39E+00 | 1.29E+00 | 0.190 | |
| 2011/3/26 20:00 | -1900 | -2300 | 0.034 | -0.098 | 0.1071 | 0.1824 | 3.56E+01 | 2.66E+01 | 1.37E+00 | 1.28E+00 | 0.170 | |
| 2011/3/26 21:20 | -1900 | -2250 | 0.036 | -0.098 | 0.1071 | 0.1818 | 3.50E+01 | 2.64E+01 | 1.37E+00 | 1.27E+00 | 0.170 | |
| 2011/3/26 23:10 | -1900 | -2250 | 0.034 | -0.094 | 0.1076 | 0.1818 | 3.49E+01 | 2.62E+01 | 1.36E+00 | 1.27E+00 | 0.170 | |
| 2011/3/27 4:15 | -1850 | -2300 | 0.030 | -0.092 | 0.1073 | 0.1804 | 3.41E+01 | 2.57E+01 | 1.34E+00 | 1.25E+00 | 0.160 | |
| 2011/3/27 4:45 | -1850 | -2300 | 0.027 | -0.094 | 0.1073 | 0.1804 | 3.42E+01 | 2.56E+01 | 1.34E+00 | 1.25E+00 | 0.160 | |
| 2011/3/27 9:25 | -1900 | -2300 | 0.027 | -0.094 | 0.1078 | 0.1808 | 3.43E+01 | 2.52E+01 | 1.32E+00 | 1.23E+00 | 0.160 | |
| 2011/3/27 10:10 | -1900 | -2300 | 0.030 | -0.094 | 0.1076 | 0.1806 | 3.37E+01 | 2.51E+01 | 1.31E+00 | 1.23E+00 | 0.170 | |
| 2011/3/27 16:00 | -1850 | -2300 | 0.027 | -0.094 | 0.1069 | 0.1797 | 3.31E+01 | 2.45E+01 | 1.31E+00 | 1.22E+00 | 0.160 | |
| 2011/3/27 16:25 | -1850 | -2300 | 0.032 | -0.092 | 0.1069 | 0.1797 | 3.22E+01 | 2.45E+01 | 1.30E+00 | 1.22E+00 | 0.160 | |
| 2011/3/27 17:30 | -1900 | -2300 | 0.030 | -0.092 | 0.1073 | 0.1799 | 3.29E+01 | 2.44E+01 | 1.29E+00 | 1.21E+00 | 0.150 | |
| 2011/3/27 18:30 | -1900 | -2300 | 0.032 | -0.092 | 0.1075 | 0.1801 | 3.31E+01 | 2.43E+01 | 1.29E+00 | 1.21E+00 | 0.150 | |
| 2011/3/27 19:00 | -1900 | -2300 | 0.030 | -0.094 | 0.1080 | 0.1804 | 3.29E+01 | 2.43E+01 | 1.29E+00 | 1.21E+00 | 0.150 | |
| 2011/3/28 0:00 | -1900 | -2300 | 0.027 | -0.087 | 0.1082 | 0.1796 | 3.20E+01 | 2.38E+01 | 1.26E+00 | 1.18E+00 | 0.150 | |
| 2011/3/28 0:50 | -1900 | -2300 | 0.026 | -0.087 | 0.1083 | 0.1797 | 3.20E+01 | 2.38E+01 | 1.26E+00 | 1.18E+00 | 0.150 | |
| 2011/3/28 5:00 | -1900 | -2300 | 0.030 | -0.085 | 0.1085 | 0.1797 | 3.16E+01 | 2.35E+01 | 1.24E+00 | 1.17E+00 | 0.140 | |
| 2011/3/28 5:30 | -1900 | -2300 | 0.027 | -0.085 | 0.1083 | 0.1794 | 3.15E+01 | 2.34E+01 | 1.24E+00 | 1.16E+00 | 0.140 | |
| 2011/3/28 10:00 | -1850 | -2250 | 0.024 | -0.090 | 0.1082 | 0.1799 | 3.11E+01 | 2.31E+01 | 1.23E+00 | 1.14E+00 | 0.140 | |
| 2011/3/28 10:30 | -1850 | -2250 | 0.024 | -0.090 | 0.1076 | 0.1792 | 3.10E+01 | 2.31E+01 | 1.23E+00 | 1.14E+00 | 0.140 | |
| 2011/3/28 15:00 | -1850 | -2250 | 0.027 | -0.092 | 0.1076 | 0.1797 | 3.06E+01 | 2.27E+01 | 1.21E+00 | 1.13E+00 | 0.150 | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/3/28 16:00 | -1850 | -2300 | 0.030 | -0.090 | 0.1078 | 0.1797 | 3.05E+01 | 2.27E+01 | 1.21E+00 | 1.13E+00 | 0.140 | |
| 2011/3/28 19:30 | -1850 | -2300 | 0.030 | -0.087 | 0.1083 | 0.1794 | 3.01E+01 | 2.24E+01 | 1.20E+00 | 1.12E+00 | 0.140 | |
| 2011/3/28 20:35 | -1850 | -2300 | 0.030 | -0.087 | 0.1085 | 0.1797 | 3.00E+01 | 2.04E+01 | 1.20E+00 | 1.12E+00 | 0.150 | |
| 2011/3/28 21:00 | -1850 | -2300 | 0.030 | -0.087 | 0.1083 | 0.1796 | 3.00E+01 | 2.23E+01 | 1.20E+00 | 1.11E+00 | 0.140 | |
| 2011/3/28 21:20 | -1900 | -2300 | 0.026 | -0.090 | 0.1082 | 0.1794 | 2.99E+01 | 2.23E+01 | 1.20E+00 | 1.11E+00 | 0.140 | |
| 2011/3/28 21:40 | -1900 | -2300 | 0.026 | -0.090 | 0.1082 | 0.1796 | 3.01E+01 | 2.23E+01 | 1.20E+00 | 1.11E+00 | 0.140 | |
| 2011/3/28 23:30 | -1800 | -2250 | 0.034 | -0.090 | 0.1082 | 0.1796 | 3.09E+01 | 2.22E+01 | 1.19E+00 | 1.11E+00 | 0.140 | |
| 2011/3/29 0:00 | -1800 | -2250 | 0.027 | -0.087 | 0.1073 | 0.1792 | 2.95E+01 | 2.21E+01 | 1.19E+00 | 1.11E+00 | 0.140 | |
| 2011/3/29 4:45 | -1900 | -2300 | 0.032 | -0.085 | 0.1085 | 0.1792 | 2.92E+01 | 2.18E+01 | 1.18E+00 | 1.09E+00 | 0.140 | |
| 2011/3/29 5:15 | -1900 | -2300 | 0.026 | -0.090 | 0.1083 | 0.1792 | 2.91E+01 | 2.18E+01 | 1.17E+00 | 1.09E+00 | 0.130 | |
| 2011/3/29 10:15 | -1900 | -2300 | 0.027 | -0.087 | 0.1075 | 0.1790 | 2.93E+01 | 2.15E+01 | 1.16E+00 | 1.08E+00 | 0.140 | |
| 2011/3/29 10:45 | -1850 | -2250 | 0.024 | -0.092 | 0.1073 | 0.1790 | 2.86E+01 | 2.14E+01 | 1.16E+00 | 1.08E+00 | 0.150 | |
| 2011/3/29 12:00 | -1850 | -2250 | 0.027 | -0.090 | 0.1075 | 0.1796 | 2.86E+01 | 2.14E+01 | 1.16E+00 | 1.08E+00 | 0.150 | |
| 2011/3/29 14:30 | -1900 | -2250 | 0.026 | -0.092 | 0.1068 | 0.1785 | 2.86E+01 | 2.12E+01 | 1.15E+00 | 1.07E+00 | 0.130 | |
| 2011/3/29 15:15 | -1850 | -2250 | 0.026 | -0.094 | 0.1076 | 0.1803 | 2.86E+01 | 2.12E+01 | 1.15E+00 | 1.07E+00 | 0.130 | |
| 2011/3/29 15:45 | -1850 | -2250 | 0.027 | -0.092 | 0.1073 | 0.1801 | 2.84E+01 | 2.11E+01 | 1.15E+00 | 1.07E+00 | 0.140 | |
| 2011/3/29 16:50 | -1850 | -2250 | 0.027 | -0.092 | 0.1069 | 0.1790 | 2.84E+01 | 2.11E+01 | 1.14E+00 | 1.06E+00 | 0.130 | |
| 2011/3/29 22:10 | -1900 | -2300 | 0.027 | -0.090 | 0.1069 | 0.1790 | 2.80E+01 | 2.08E+01 | 1.13E+00 | 1.05E+00 | 0.130 | |
| 2011/3/29 23:00 | -1900 | -2300 | 0.027 | -0.090 | 0.1069 | 0.1785 | 2.78E+01 | 2.07E+01 | 1.13E+00 | 1.05E+00 | 0.130 | |
| 2011/3/30 3:20 | -1900 | -2250 | 0.024 | -0.087 | 0.1071 | 0.1780 | 2.77E+01 | 2.05E+01 | 1.11E+00 | 1.04E+00 | 0.140 | |
| 2011/3/30 3:50 | -1850 | -2250 | 0.022 | -0.087 | 0.1071 | 0.1780 | 2.76E+01 | 2.05E+01 | 1.11E+00 | 1.03E+00 | 0.130 | |
| 2011/3/30 8:30 | -1850 | -2250 | 0.022 | -0.087 | 0.1073 | 0.1782 | 2.72E+01 | 2.02E+01 | 1.10E+00 | 1.02E+00 | 0.130 | |
| 2011/3/30 13:00 | -1850 | -2250 | 0.024 | -0.085 | 0.1062 | 0.1771 | 2.69E+01 | 2.00E+01 | 1.09E+00 | 1.01E+00 | 0.140 | |
| 2011/3/30 13:30 | -1850 | -2250 | 0.017 | -0.090 | 0.1064 | 0.1775 | 2.68E+01 | 2.00E+01 | 1.09E+00 | 1.01E+00 | 0.140 | |
| 2011/3/30 18:20 | -1850 | -2250 | 0.019 | -0.087 | 0.1068 | 0.1773 | 2.65E+01 | 1.97E+01 | 1.07E+00 | 9.90E-01 | 0.140 | |
| 2011/3/30 19:00 | -1850 | -2250 | 0.022 | -0.085 | 0.1068 | 0.1769 | 2.64E+01 | 1.97E+01 | 1.07E+00 | 9.98E-01 | 0.140 | |
| 2011/3/30 23:20 | -1850 | -2250 | 0.022 | -0.085 | 0.1071 | 0.1775 | 2.61E+01 | 1.95E+01 | 1.06E+00 | 9.88E-01 | 0.130 | |
| 2011/3/30 23:50 | -1850 | -2250 | 0.019 | -0.085 | 0.1073 | 0.1773 | 2.61E+01 | 1.95E+01 | 1.06E+00 | 9.87E-01 | 0.130 | |
| 2011/3/31 4:10 | -1900 | -2300 | 0.019 | -0.085 | 0.1075 | 0.1768 | 2.60E+01 | 1.93E+01 | 1.05E+00 | 9.79E-01 | 0.130 | |
| 2011/3/31 4:40 | -1900 | -2300 | 0.019 | -0.085 | 0.1073 | 0.1764 | 2.57E+01 | 1.92E+01 | 1.05E+00 | 9.77E-01 | 0.130 | |
| 2011/3/31 9:40 | -1850 | -2250 | 0.015 | -0.087 | 0.1066 | 0.1755 | 2.54E+01 | 1.90E+01 | 1.04E+00 | 9.67E-01 | 0.130 | |
| 2011/3/31 16:10 | -1900 | -2250 | 0.015 | -0.085 | 0.1071 | 0.1761 | 2.51E+01 | 1.87E+01 | 1.02E+00 | 9.55E-01 | 0.130 | |
| 2011/3/31 16:45 | -1900 | -2250 | 0.017 | -0.085 | 0.1071 | 0.1761 | 2.59E+01 | 1.87E+01 | 1.02E+00 | 9.54E-01 | 0.130 | |
| 2011/3/31 19:00 | -1850 | -2250 | 0.010 | -0.090 | 0.1069 | 0.1761 | 2.48E+01 | 1.86E+01 | 1.02E+00 | 9.49E-01 | 0.130 | |
| 2011/3/31 19:30 | -1850 | -2250 | 0.019 | -0.083 | 0.1064 | 0.1754 | 2.54E+01 | 1.86E+01 | 1.02E+00 | 9.49E-01 | 0.130 | |
| 2011/3/31 19:50 | -1850 | -2250 | 0.022 | -0.083 | 0.1068 | 0.1759 | 2.48E+01 | 1.86E+01 | 1.02E+00 | 9.47E-01 | 0.130 | |
| 2011/4/1 0:00 | -1900 | -2250 | 0.015 | -0.083 | 0.1068 | 0.1755 | 2.40E+01 | 1.80E+01 | 1.00E+00 | 9.30E-01 | 0.120 | |
| 2011/4/1 0:45 | -1900 | -2250 | 0.015 | -0.081 | 0.1073 | 0.1838 | 2.40E+01 | 1.80E+01 | 1.00E+00 | 9.30E-01 | 0.120 | |
| 2011/4/1 5:15 | -1900 | -2250 | 0.017 | -0.083 | 0.1071 | 0.1755 | 2.47E+01 | 1.82E+01 | 9.96E-01 | 9.25E-01 | 0.120 | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/4/1 5:45 | -1900 | -2250 | 0.017 | -0.081 | 0.1071 | 0.1775 | 2.45E+01 | 1.82E+01 | 9.95E-01 | 9.24E-01 | 0.120 | |
| 2011/4/1 11:10 | -1900 | -2250 | 0.017 | -0.081 | 0.1071 | 0.1759 | 2.45E+01 | 1.80E+01 | 9.83E-01 | 9.12E-01 | 0.120 | |
| 2011/4/1 11:45 | -1900 | -2250 | 0.015 | -0.083 | 0.1068 | 0.1757 | 2.42E+01 | 1.80E+01 | 9.82E-01 | 9.12E-01 | 0.120 | |
| 2011/4/1 15:00 | -1850 | -2250 | 0.017 | -0.083 | 0.1059 | 0.1755 | 2.43E+01 | 1.78E+01 | 9.75E-01 | 9.05E-01 | 0.120 | |
| 2011/4/1 15:30 | -1850 | -2250 | 0.015 | -0.085 | 0.1061 | 0.1755 | 2.40E+01 | 1.78E+01 | 9.74E-01 | 9.04E-01 | 0.120 | |
| 2011/4/1 20:00 | -1850 | -2250 | 0.015 | -0.085 | 0.1066 | 0.1754 | 2.36E+01 | 1.77E+01 | 9.65E-01 | 8.95E-01 | 0.120 | |
| 2011/4/1 20:30 | -1850 | -2250 | 0.017 | -0.083 | 0.1066 | 0.1754 | 2.38E+01 | 1.76E+01 | 9.64E-01 | 8.94E-01 | 0.120 | |
| 2011/4/2 1:00 | -1850 | -2250 | 0.019 | -0.081 | 0.1066 | 0.1755 | 2.37E+01 | 1.75E+01 | 9.55E-01 | 8.85E-01 | 0.120 | |
| 2011/4/2 1:30 | -1850 | -2250 | 0.024 | -0.081 | 0.1055 | 0.1748 | 2.40E+01 | 1.75E+01 | 9.55E-01 | 8.85E-01 | 0.120 | |
| 2011/4/2 5:55 | -1850 | -2250 | 0.013 | -0.087 | 0.1061 | 0.1754 | 2.41E+01 | 1.73E+01 | 9.46E-01 | 8.71E-01 | 0.120 | |
| 2011/4/2 6:25 | -1850 | -2250 | 0.019 | -0.083 | 0.1062 | 0.1754 | 2.33E+01 | 1.73E+01 | 9.46E-01 | 8.77E-01 | 0.120 | |
| 2011/4/2 11:05 | -1850 | -2250 | 0.019 | -0.085 | 0.1055 | 0.1754 | 2.31E+01 | 1.72E+01 | 9.37E-01 | 8.70E-01 | 0.130 | |
| 2011/4/2 11:40 | -1850 | -2250 | 0.017 | -0.087 | 0.1054 | 0.1752 | 2.58E+01 | 1.71E+01 | 9.36E-01 | 8.69E-01 | 0.120 | |
| 2011/4/2 12:10 | -1850 | -2250 | 0.013 | -0.090 | 0.1050 | 0.1748 | 2.32E+01 | 1.71E+01 | 9.35E-01 | 8.68E-01 | 0.120 | |
| 2011/4/2 16:00 | -1850 | -2250 | 0.017 | -0.085 | 0.1050 | 0.1747 | 2.31E+01 | 1.70E+01 | 9.30E-01 | 8.63E-01 | 0.120 | |
| 2011/4/2 16:30 | -1850 | -2250 | 0.013 | -0.085 | 0.1052 | 0.1748 | 2.28E+01 | 1.70E+01 | 9.29E-01 | 8.62E-01 | 0.120 | |
| 2011/4/2 21:00 | -1850 | -2250 | 0.009 | -0.090 | 0.1054 | 0.1747 | 2.30E+01 | 1.68E+01 | 9.20E-01 | 8.55E-01 | 0.120 | |
| 2011/4/2 21:30 | -1850 | -2250 | 0.007 | -0.087 | 0.1055 | 0.1747 | 2.27E+01 | 1.68E+01 | 9.19E-01 | 8.54E-01 | 0.120 | |
| 2011/4/3 2:30 | -1850 | -2250 | 0.010 | -0.083 | 0.1061 | 0.1748 | 2.22E+01 | 1.67E+01 | 9.11E-01 | 8.46E-01 | 0.110 | |
| 2011/4/3 7:00 | -1850 | -2250 | 0.009 | -0.081 | 0.1066 | 0.1750 | 2.22E+01 | 1.66E+01 | 9.03E-01 | 8.39E-01 | 0.100 | |
| 2011/4/3 7:30 | -1850 | -2250 | 0.010 | -0.078 | 0.1066 | 0.1750 | 2.18E+01 | 1.65E+01 | 9.02E-01 | 8.39E-01 | 0.120 | |
| 2011/4/3 9:15 | -1850 | -2250 | 0.013 | -0.078 | 0.1062 | 0.1750 | 2.18E+01 | 1.65E+01 | 8.99E-01 | 8.36E-01 | 0.100 | |
| 2011/4/3 10:00 | -1850 | -2250 | 0.013 | -0.078 | 0.1064 | 0.1750 | 2.17E+01 | 1.65E+01 | 8.98E-01 | 8.35E-01 | 0.100 | |
| 2011/4/3 10:30 | -1850 | -2250 | 0.010 | -0.078 | 0.1062 | 0.1750 | 2.17E+01 | 1.65E+01 | 8.97E-01 | 8.34E-01 | 0.100 | |
| 2011/4/3 12:00 | -1850 | -2250 | 0.007 | -0.085 | 0.1062 | 0.1752 | 2.17E+01 | 1.64E+01 | 8.94E-01 | 8.32E-01 | 0.100 | |
| 2011/4/3 12:30 | -1850 | -2250 | 0.013 | -0.078 | 0.1061 | 0.1750 | 2.17E+01 | 1.64E+01 | 8.94E-01 | 8.31E-01 | 0.100 | |
| 2011/4/3 13:00 | -1850 | -2250 | 0.007 | -0.083 | 0.1064 | 0.1754 | 2.17E+01 | 1.64E+01 | 8.93E-01 | 8.31E-01 | 0.100 | |
| 2011/4/3 13:30 | -1850 | -2250 | 0.010 | -0.081 | 0.1062 | 0.1754 | 2.17E+01 | 1.64E+01 | 8.92E-01 | 8.30E-01 | 0.100 | |
| 2011/4/3 17:00 | -1850 | -2250 | 0.015 | -0.081 | 0.1057 | 0.1750 | 2.17E+01 | 1.63E+01 | 8.86E-01 | 8.21E-01 | 0.100 | |
| 2011/4/3 17:35 | -1850 | -2250 | 0.010 | -0.081 | 0.1059 | 0.1752 | 2.24E+01 | 1.63E+01 | 8.85E-01 | 8.21E-01 | 0.100 | |
| 2011/4/3 18:00 | -1850 | -2250 | 0.009 | -0.083 | 0.1059 | 0.1752 | 2.18E+01 | 1.63E+01 | 8.84E-01 | 8.20E-01 | 0.100 | |
| 2011/4/3 21:00 | -1900 | -2250 | 0.010 | -0.078 | 0.1064 | 0.1754 | 2.15E+01 | 1.62E+01 | 8.80E-01 | 8.17E-01 | 0.100 | |
| 2011/4/3 22:00 | -1850 | -2250 | 0.009 | -0.078 | 0.1068 | 0.1754 | 2.15E+01 | 1.62E+01 | 8.79E-01 | 8.16E-01 | 0.100 | |
| 2011/4/4 3:00 | -1800 | -2250 | 0.007 | -0.077 | 0.1073 | 0.1754 | 2.13E+01 | 1.60E+01 | 8.72E-01 | 8.10E-01 | 0.100 | |
| 2011/4/4 3:30 | -1800 | -2250 | 0.007 | -0.077 | 0.1073 | 0.1754 | 2.15E+01 | 1.60E+01 | 8.71E-01 | 8.10E-01 | 0.100 | |
| 2011/4/4 8:00 | -1850 | -2250 | 0.007 | -0.077 | 0.1071 | 0.1755 | 2.11E+01 | 1.59E+01 | 8.66E-01 | 8.05E-01 | 0.110 | |
| 2011/4/4 8:30 | -1750 | -2250 | 0.009 | -0.077 | 0.1068 | 0.1754 | 2.15E+01 | 1.59E+01 | 8.65E-01 | 8.04E-01 | 0.100 | |
| 2011/4/4 9:30 | -1750 | -2250 | 0.005 | -0.078 | 0.1069 | 0.1757 | 2.11E+01 | 1.59E+01 | 8.64E-01 | 8.03E-01 | 0.110 | |
| 2011/4/4 14:30 | -1850 | -2250 | 0.005 | -0.081 | 0.1071 | 0.1754 | 2.07E+01 | 1.58E+01 | 8.57E-01 | 7.97E-01 | 0.110 | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/4/4 18:30 | -1850 | -2250 | 0.007 | -0.081 | 0.1066 | 0.1743 | 2.25E+01 | 1.57E+01 | 8.52E-01 | 7.93E-01 | 0.100 | |
| 2011/4/4 19:00 | -1850 | -2250 | 0.007 | -0.081 | 0.1071 | 0.1745 | 2.04E+01 | 1.57E+01 | 8.51E-01 | 7.93E-01 | 0.110 | |
| 2011/4/5 0:00 | -1850 | -2250 | 0.005 | -0.078 | 0.1073 | 0.1736 | 2.04E+01 | 1.55E+01 | 8.45E-01 | 7.86E-01 | 0.110 | |
| 2011/4/5 0:30 | -1850 | -2250 | 0.005 | -0.081 | 0.1069 | 0.1731 | 2.05E+01 | 1.55E+01 | 8.44E-01 | 7.86E-01 | 0.110 | |
| 2011/4/5 5:10 | -1850 | -2250 | 0.009 | -0.078 | 0.1078 | 0.1733 | 2.12E+01 | 1.54E+01 | 8.39E-01 | 7.80E-01 | 0.110 | |
| 2011/4/5 5:40 | -1850 | -2250 | 0.010 | -0.077 | 0.1078 | 0.1733 | 2.10E+01 | 1.54E+01 | 8.39E-01 | 7.80E-01 | 0.110 | |
| 2011/4/5 10:20 | -1850 | -2250 | 0.005 | -0.078 | 0.1071 | 0.1733 | 2.06E+01 | 1.53E+01 | 8.33E-01 | 7.74E-01 | 0.110 | |
| 2011/4/5 17:10 | -1850 | -2250 | 0.007 | -0.077 | 0.1071 | 0.1734 | 2.03E+01 | 1.52E+01 | 8.23E-01 | 7.66E-01 | 0.110 | |
| 2011/4/5 18:30 | -1850 | -2250 | 0.007 | -0.077 | 0.1069 | 0.1727 | 2.03E+01 | 1.52E+01 | 8.22E-01 | 7.65E-01 | 0.120 | |
| 2011/4/6 0:00 | -1850 | -2250 | 0.009 | -0.077 | 0.1069 | 0.1733 | 2.09E+01 | 1.51E+01 | 8.15E-01 | 7.58E-01 | 0.120 | |
| 2011/4/6 6:30 | -1800 | -2200 | 0.007 | -0.077 | 0.1076 | 0.1731 | 1.98E+01 | 1.49E+01 | 8.07E-01 | 7.50E-01 | 0.120 | |
| 2011/4/6 12:30 | -1800 | -2200 | 0.005 | -0.081 | 0.1069 | 0.1731 | 1.95E+01 | 1.48E+01 | 7.99E-01 | 7.43E-01 | 0.120 | |
| 2011/4/6 18:00 | -1800 | -2200 | 0.004 | -0.081 | 0.1066 | 0.1731 | 1.95E+01 | 1.47E+01 | 7.92E-01 | 7.37E-01 | 0.110 | |
| 2011/4/7 0:00 | -1800 | -2250 | 0.002 | -0.079 | 0.1071 | 0.1729 | 1.95E+01 | 1.46E+01 | 7.84E-01 | 7.29E-01 | 0.120 | |
| 2011/4/7 6:00 | -1850 | -2250 | -0.002 | -0.079 | 0.1075 | 0.1729 | 1.96E+01 | 1.45E+01 | 7.77E-01 | 7.22E-01 | 0.110 | |
| 2011/4/7 12:00 | -1900 | -2250 | 0.000 | -0.081 | 0.1059 | 0.1720 | 1.93E+01 | 1.44E+01 | 7.68E-01 | 7.14E-01 | 0.100 | |
| 2011/4/7 18:00 | -1950 | -2250 | 0.000 | -0.079 | 0.1062 | 0.1727 | 1.92E+01 | 1.43E+01 | 7.59E-01 | 7.06E-01 | 0.110 | |
| 2011/4/7 19:30 | -2000 | -2250 | 0.000 | -0.081 | 0.1062 | 0.1727 | 1.92E+01 | 1.43E+01 | 7.57E-01 | 7.04E-01 | 0.110 | |
| 2011/4/8 1:30 | -2000 | -2250 | -0.002 | -0.081 | 0.1061 | 0.1726 | 1.90E+01 | 1.42E+01 | 7.48E-01 | 6.94E-01 | 0.110 | |
| 2011/4/8 6:40 | -2000 | -2250 | -0.002 | -0.081 | 0.1057 | 0.1722 | 1.89E+01 | 1.41E+01 | 7.43E-01 | 6.89E-01 | 0.120 | |
| 2011/4/8 12:00 | -1850 | -2250 | -0.004 | -0.079 | 0.1052 | 0.1722 | 1.88E+01 | 1.40E+01 | 7.38E-01 | 6.84E-01 | 0.140 | |
| 2011/4/8 18:00 | -1700 | -2200 | 0.006 | -0.081 | 0.1047 | 0.1720 | 1.87E+01 | 1.40E+01 | 7.33E-01 | 6.80E-01 | 0.100 | |
| 2011/4/9 0:00 | -1950 | -2300 | -0.002 | -0.085 | 0.1054 | 0.1727 | 1.86E+01 | 1.39E+01 | 7.28E-01 | 6.75E-01 | 0.130 | |
| 2011/4/9 6:15 | -1850 | -2250 | -0.002 | -0.081 | 0.1057 | 0.1726 | 1.85E+01 | 1.38E+01 | 7.23E-01 | 6.71E-01 | 0.100 | |
| 2011/4/9 12:25 | -1700 | -2250 | -0.004 | -0.081 | 0.1055 | 0.1722 | 1.84E+01 | 1.37E+01 | 7.17E-01 | 6.66E-01 | 0.090 | |
| 2011/4/9 18:25 | -1900 | -2250 | -0.011 | -0.079 | 0.1054 | 0.1715 | 1.83E+01 | 1.36E+01 | 7.13E-01 | 6.61E-01 | 0.090 | |
| 2011/4/10 0:00 | -1900 | -2250 | -0.011 | -0.081 | 0.1055 | 0.1717 | 1.82E+01 | 1.36E+01 | 7.08E-01 | 6.56E-01 | 0.090 | |
| 2011/4/10 6:00 | -1900 | -2250 | -0.009 | -0.077 | 0.1061 | 0.1717 | 1.81E+01 | 1.35E+01 | 7.03E-01 | 6.52E-01 | 0.090 | |
| 2011/4/10 12:00 | -1900 | -2250 | -0.009 | -0.079 | 0.1054 | 0.1713 | 1.80E+01 | 1.34E+01 | 6.98E-01 | 6.48E-01 | 0.090 | |
| 2011/4/10 18:00 | -1900 | -2250 | -0.013 | -0.083 | 0.1052 | 0.1708 | 1.79E+01 | 1.34E+01 | 6.94E-01 | 6.43E-01 | 0.080 | |
| 2011/4/11 0:00 | -1900 | -2250 | -0.017 | -0.083 | 0.1050 | 0.1703 | 1.78E+01 | 1.33E+01 | 6.90E-01 | 6.40E-01 | 0.080 | |
| 2011/4/11 6:00 | -1900 | -2250 | -0.015 | -0.081 | 0.1031 | 0.1698 | 1.78E+01 | 1.32E+01 | 6.85E-01 | 6.36E-01 | 0.080 | |
| 2011/4/11 12:00 | -1900 | -2250 | -0.017 | -0.083 | 0.1043 | 0.1699 | 1.77E+01 | 1.32E+01 | 6.81E-01 | 6.32E-01 | 0.075 | |
| 2011/4/11 18:30 | -1850 | -2250 | -0.017 | -0.083 | 0.1043 | 0.1698 | 1.75E+01 | 1.31E+01 | 6.24E-01 | 6.80E-01 | 0.085 | |
| 2011/4/12 0:00 | -1850 | -2250 | -0.015 | -0.079 | 0.1045 | 0.1696 | 1.75E+01 | 1.31E+01 | 6.75E-01 | 6.20E-01 | 0.090 | |
| 2011/4/12 6:00 | -1850 | -2250 | -0.019 | -0.079 | 0.1052 | 0.1692 | 1.74E+01 | 1.30E+01 | 6.71E-01 | 6.17E-01 | 0.075 | |
| 2011/4/12 12:00 | -1850 | -2250 | -0.017 | -0.083 | 0.1048 | 0.1689 | 1.73E+01 | 1.29E+01 | 6.68E-01 | 6.13E-01 | 0.080 | |
| 2011/4/12 15:10 | -1850 | -2250 | -0.019 | -0.085 | 0.1048 | 0.1689 | 1.72E+01 | 1.29E+01 | 6.63E-01 | 6.11E-01 | 0.090 | |
| 2011/4/12 18:00 | -1850 | -2250 | -0.019 | -0.083 | 0.1050 | 0.1689 | 1.72E+01 | 1.29E+01 | 6.62E-01 | 6.09E-01 | 0.080 | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/4/12 22:10 | -1850 | -2250 | -0.018 | -0.086 | 0.1055 | 0.1685 | 1.71E+01 | 1.29E+01 | 6.61E-01 | 6.07E-01 | 0.070 | |
| 2011/4/13 6:00 | -1850 | -2250 | -0.019 | -0.079 | 0.1055 | 0.1680 | 1.70E+01 | 1.28E+01 | 6.57E-01 | 6.03E-01 | 0.085 | |
| 2011/4/13 7:00 | -1850 | -2250 | -0.019 | -0.079 | 0.1054 | 0.1680 | 1.70E+01 | 1.28E+01 | 6.56E-01 | 6.03E-01 | 0.080 | |
| 2011/4/13 12:10 | -1750 | -2200 | -0.023 | -0.083 | 0.1036 | 0.1677 | 1.69E+01 | 1.27E+01 | 6.53E-01 | 6.00E-01 | 0.080 | |
| 2011/4/13 18:00 | -1750 | -2250 | -0.021 | -0.085 | 0.1036 | 0.1677 | 1.68E+01 | 1.27E+01 | 6.50E-01 | 5.97E-01 | 0.080 | |
| 2011/4/14 0:00 | -1750 | -2250 | -0.017 | -0.083 | 0.1047 | 0.1680 | 1.67E+01 | 1.26E+01 | 6.47E-01 | 5.95E-01 | 0.080 | |
| 2011/4/14 6:05 | -1800 | -2250 | -0.017 | -0.083 | 0.1045 | 0.1673 | 1.67E+01 | 1.26E+01 | 6.43E-01 | 5.92E-01 | 0.080 | |
| 2011/4/14 12:00 | -1800 | -2250 | -0.017 | -0.085 | 0.1040 | 0.1671 | 1.66E+01 | 1.25E+01 | 6.40E-01 | 5.89E-01 | 0.080 | |
| 2011/4/14 18:00 | -1800 | -2250 | -0.017 | -0.085 | 0.1041 | 0.1670 | 1.65E+01 | 1.25E+01 | 6.37E-01 | 5.86E-01 | 0.080 | |
| 2011/4/15 0:00 | -1800 | -2250 | -0.019 | -0.085 | 0.1043 | 0.1664 | 1.65E+01 | 1.24E+01 | 6.34E-01 | 5.84E-01 | 0.080 | |
| 2011/4/15 6:00 | -1800 | -2250 | -0.023 | -0.083 | 0.1043 | 0.1661 | 1.64E+01 | 1.24E+01 | 6.31E-01 | 5.81E-01 | 0.080 | |
| 2011/4/15 12:00 | -1800 | -2250 | -0.021 | -0.085 | 0.1040 | 0.1661 | 1.63E+01 | 1.24E+01 | 6.28E-01 | 5.79E-01 | 0.080 | |
| 2011/4/15 18:00 | -1800 | -2250 | -0.026 | -0.087 | 0.1033 | 0.1654 | 1.63E+01 | 1.23E+01 | 6.25E-01 | 5.76E-01 | 0.080 | |
| 2011/4/16 0:00 | -1800 | -2250 | -0.028 | -0.085 | 0.1038 | 0.1656 | 1.73E+01 | 1.23E+01 | 6.22E-01 | 5.74E-01 | 0.080 | |
| 2011/4/16 6:00 | -1800 | -2250 | -0.030 | -0.085 | 0.1038 | 0.1656 | 1.62E+01 | 1.22E+01 | 6.20E-01 | 5.71E-01 | 0.080 | |
| 2011/4/16 12:10 | -1800 | -2250 | -0.023 | -0.085 | 0.1031 | 0.1654 | 2.00E+01 | 1.22E+01 | 6.16E-01 | 5.68E-01 | 0.110 | |
| 2011/4/16 18:00 | -1800 | -2250 | -0.030 | -0.083 | 0.1034 | 0.1658 | 1.59E+01 | 1.21E+01 | 6.14E-01 | 5.65E-01 | 0.075 | |
| 2011/4/17 0:00 | -1800 | -2250 | -0.032 | -0.085 | 0.1043 | 0.1666 | 1.59E+01 | 1.21E+01 | 6.11E-01 | 5.64E-01 | 0.070 | |
| 2011/4/17 6:00 | -1800 | -2250 | -0.030 | -0.083 | 0.1047 | 0.1675 | 1.59E+01 | 1.21E+01 | 6.10E-01 | 5.62E-01 | 0.070 | |
| 2011/4/17 14:00 | -1800 | -2250 | -0.030 | -0.085 | 0.1043 | 0.1684 | 1.58E+01 | 1.20E+01 | 6.07E-01 | 5.60E-01 | 0.070 | |
| 2011/4/17 19:00 | -1800 | -2250 | -0.032 | -0.083 | 0.1045 | 0.1687 | 1.58E+01 | 1.20E+01 | 6.05E-01 | 5.59E-01 | 0.070 | |
| 2011/4/18 0:00 | -1800 | -2250 | -0.034 | -0.085 | 0.1045 | 0.1696 | 1.58E+01 | 1.19E+01 | 6.04E-01 | 5.57E-01 | 0.065 | |
| 2011/4/18 6:00 | -1800 | -2250 | -0.034 | -0.081 | 0.1048 | 0.1701 | 1.58E+01 | 1.19E+01 | 6.02E-01 | 5.56E-01 | 0.065 | |
| 2011/4/18 12:00 | -1800 | -2250 | -0.034 | -0.081 | 0.1047 | 0.1710 | 1.58E+01 | 1.19E+01 | 6.00E-01 | 5.54E-01 | 0.065 | |
| 2011/4/18 13:10 | -1800 | -2250 | -0.034 | -0.085 | 0.1047 | 0.1712 | 1.58E+01 | 1.19E+01 | 5.99E-01 | 5.54E-01 | 0.065 | |
| 2011/4/18 13:45 | -1800 | -2250 | -0.034 | -0.081 | 0.1047 | 0.1713 | 1.58E+01 | 1.19E+01 | 5.99E-01 | 5.54E-01 | 0.065 | |
| 2011/4/18 18:00 | -1850 | -2250 | -0.034 | -0.085 | 0.1045 | 0.1715 | 1.57E+01 | 1.18E+01 | 5.98E-01 | 5.52E-01 | 0.065 | |
| 2011/4/19 0:00 | -1850 | -2250 | -0.036 | -0.085 | 0.1041 | 0.1720 | 1.57E+01 | 1.18E+01 | 5.96E-01 | 5.51E-01 | 0.070 | |
| 2011/4/19 6:00 | -1850 | -2250 | -0.034 | -0.085 | 0.1041 | 0.1724 | 1.57E+01 | 1.18E+01 | 5.94E-01 | 5.49E-01 | 0.065 | |
| 2011/4/19 12:00 | -1850 | -2250 | -0.040 | -0.085 | 0.1036 | 0.1722 | 1.56E+01 | 1.17E+01 | 5.92E-01 | 5.47E-01 | 0.080 | |
| 2011/4/19 18:10 | -1850 | -2250 | -0.040 | -0.083 | 0.1034 | 0.1727 | 1.56E+01 | 1.17E+01 | 5.90E-01 | 5.46E-01 | 0.065 | |
| 2011/4/20 0:02 | -1850 | -2250 | -0.038 | -0.087 | 0.1041 | 0.1734 | 1.56E+01 | 1.17E+01 | 5.88E-01 | 5.44E-01 | 0.055 | |
| 2011/4/20 6:00 | -1850 | -2250 | -0.038 | -0.089 | 0.1045 | 0.1741 | 1.55E+01 | 1.16E+01 | 5.87E-01 | 5.42E-01 | 0.070 | |
| 2011/4/20 12:00 | -1850 | -2250 | -0.043 | -0.089 | 0.1045 | 0.1748 | 1.55E+01 | 1.16E+01 | 5.85E-01 | 5.41E-01 | 0.065 | |
| 2011/4/20 18:10 | -1850 | -2250 | -0.043 | -0.087 | 0.1047 | 0.1754 | 1.55E+01 | 1.16E+01 | 5.82E-01 | 5.40E-01 | 0.065 | |
| 2011/4/20 23:50 | -1850 | -2250 | -0.045 | -0.087 | 0.1054 | 0.1761 | 1.54E+01 | 1.15E+01 | 5.80E-01 | 5.39E-01 | 0.065 | |
| 2011/4/21 6:00 | -1850 | -2250 | -0.043 | -0.085 | 0.1061 | 0.1768 | 1.54E+01 | 1.15E+01 | 5.79E-01 | 5.38E-01 | 0.065 | |
| 2011/4/21 12:00 | -1850 | -2250 | -0.043 | -0.087 | 0.1050 | 0.1769 | 1.54E+01 | 1.15E+01 | 5.77E-01 | 5.37E-01 | 0.065 | |
| 2011/4/21 18:00 | -1850 | -2250 | -0.043 | -0.085 | 0.1052 | 0.1775 | 1.53E+01 | 1.14E+01 | 5.75E-01 | 5.35E-01 | 0.065 | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|-----------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 2011/4/22 0:00 | -1850 | -2250 | -0.047 | -0.089 | 0.1055 | 0.1776 | 1.51E+01 | 1.14E+01 | 5.73E-01 | 5.34E-01 | 0.065 | |
| 2011/4/22 6:00 | -1850 | -2250 | -0.047 | -0.087 | 0.1055 | 0.1780 | 1.52E+01 | 1.14E+01 | 5.70E-01 | 5.32E-01 | 0.070 | |
| 2011/4/22 11:50 | -1850 | -2250 | -0.049 | -0.089 | 0.1048 | 0.1780 | 1.52E+01 | 1.14E+01 | 5.69E-01 | 5.31E-01 | 0.070 | |
| 2011/4/22 17:50 | -1850 | -2250 | -0.049 | -0.089 | 0.1047 | 0.1783 | 1.52E+01 | 1.13E+01 | 5.68E-01 | 5.30E-01 | 0.080 | |
| 2011/4/23 0:00 | -1850 | -2250 | -0.053 | -0.087 | 0.1047 | 0.1785 | 1.52E+01 | 1.13E+01 | 5.66E-01 | 5.28E-01 | 0.060 | |
| 2011/4/23 6:15 | -1850 | -2250 | -0.049 | -0.087 | 0.1045 | 0.1782 | 1.51E+01 | 1.13E+01 | 5.64E-01 | 5.27E-01 | 0.070 | |
| 2011/4/23 11:55 | -1850 | -2250 | -0.049 | -0.087 | 0.1038 | 0.1778 | 1.51E+01 | 1.13E+01 | 5.63E-01 | 5.26E-01 | 0.060 | |
| 2011/4/23 18:00 | -1850 | -2250 | -0.051 | -0.089 | 0.1033 | 0.1776 | 1.50E+01 | 1.12E+01 | 5.62E-01 | 5.25E-01 | 0.060 | |
| 2011/4/24 0:00 | -1850 | -2250 | -0.055 | -0.091 | 0.1027 | 0.1776 | 1.50E+01 | 1.12E+01 | 5.61E-01 | 5.23E-01 | 0.070 | |
| 2011/4/24 5:50 | -1850 | -2250 | -0.053 | -0.089 | 0.1031 | 0.1778 | 1.50E+01 | 1.12E+01 | 5.60E-01 | 5.22E-01 | 0.060 | |
| 2011/4/24 12:00 | -1850 | -2250 | -0.051 | -0.091 | 0.1031 | 0.1780 | 1.49E+01 | 1.11E+01 | 5.58E-01 | 5.21E-01 | 0.070 | |
| 4/24 18:00 | -1850 | -2250 | -0.051 | -0.091 | 0.1034 | 0.1785 | 1.49E+01 | 1.11E+01 | 5.57E-01 | 5.20E-01 | 0.070 | |
| 4/25 0:00 | -1850 | -2250 | -0.055 | -0.089 | 0.1038 | 0.1787 | 1.48E+01 | 1.11E+01 | 5.56E-01 | 5.19E-01 | 0.070 | |
| 4/25 6:00 | -1850 | -2250 | -0.053 | -0.089 | 0.1041 | 0.1789 | 1.48E+01 | 1.11E+01 | 5.54E-01 | 5.18E-01 | 0.070 | |
| 4/25 11:00 | -1800 | -2250 | -0.055 | -0.091 | 0.1029 | 0.1787 | 1.47E+01 | 1.10E+01 | 5.53E-01 | 5.17E-01 | 0.050 | |
| 4/25 17:00 | -1850 | -2250 | -0.055 | -0.089 | 0.1034 | 0.1787 | 1.47E+01 | 1.10E+01 | 5.52E-01 | 5.16E-01 | 0.050 | |
| 4/25 23:00 | -1800 | -2250 | -0.055 | -0.091 | 0.1041 | 0.1792 | 1.46E+01 | 1.10E+01 | 5.51E-01 | 5.15E-01 | 0.050 | |
| 4/26 5:00 | -1850 | -2250 | -0.055 | -0.087 | 0.1043 | 0.1794 | 1.46E+01 | 1.10E+01 | 5.50E-01 | 5.14E-01 | 0.040 | |
| 4/26 9:00 | -1850 | -2250 | -0.055 | -0.089 | 0.1041 | 0.1794 | 1.45E+01 | 1.09E+01 | 5.49E-01 | 5.13E-01 | 0.040 | |
| 4/26 17:00 | -1850 | -2250 | -0.051 | -0.089 | 0.1033 | 0.1790 | 1.39E+01 | 1.09E+01 | 5.17E-01 | 5.11E-01 | 0.050 | |
| 4/26 23:00 | -1850 | -2250 | -0.049 | -0.089 | 0.1034 | 0.1792 | 1.42E+01 | 1.09E+01 | 5.30E-01 | 5.10E-01 | 0.050 | |
| 4/27 5:00 | -1850 | -2250 | -0.053 | -0.089 | 0.1031 | 0.1787 | 1.43E+01 | 1.09E+01 | 5.32E-01 | 5.08E-01 | 0.050 | |
| 4/27 11:00 | -1850 | -2250 | -0.053 | -0.089 | 0.1029 | 0.1792 | 1.43E+01 | 1.08E+01 | 5.34E-01 | 5.07E-01 | 0.040 | |
| 4/27 17:00 | -1850 | -2250 | -0.053 | -0.089 | 0.1022 | 0.1789 | 1.43E+01 | 1.08E+01 | 5.34E-01 | 5.05E-01 | 0.050 | |
| 4/27 23:00 | -1850 | -2250 | -0.055 | -0.087 | 0.1022 | 0.1789 | 1.43E+01 | 1.08E+01 | 5.34E-01 | 5.04E-01 | 0.045 | |
| 4/28 5:00 | -1850 | -2250 | -0.055 | -0.089 | 0.1017 | 0.1783 | 1.42E+01 | 1.08E+01 | 5.33E-01 | 5.02E-01 | 0.050 | |
| 4/28 11:00 | -1850 | -2250 | -0.055 | -0.089 | 0.1017 | 0.1785 | 1.42E+01 | 1.07E+01 | 5.32E-01 | 5.01E-01 | 0.050 | |
| 4/28 17:10 | -1850 | -2250 | -0.055 | -0.085 | 0.1017 | 0.1790 | 1.42E+01 | 1.07E+01 | 5.32E-01 | 5.00E-01 | 0.050 | |
| 4/28 23:00 | -1850 | -2250 | -0.060 | -0.089 | 0.1027 | 0.1792 | 1.41E+01 | 1.07E+01 | 5.30E-01 | 4.98E-01 | 0.040 | |
| 4/29 5:00 | -1850 | -2250 | -0.062 | -0.091 | 0.1036 | 0.1799 | 1.41E+01 | 1.06E+01 | 5.29E-01 | 4.96E-01 | 0.050 | |
| 4/29 11:00 | -1850 | -2250 | -0.060 | -0.091 | 0.1033 | 0.1796 | 1.70E+01 | 1.06E+01 | 5.27E-01 | 4.95E-01 | 0.050 | |
| 4/29 17:00 | -1850 | -2250 | -0.060 | -0.089 | 0.1038 | 0.1799 | 1.40E+01 | 1.06E+01 | 5.26E-01 | 4.94E-01 | 0.050 | |
| 4/29 23:00 | -1850 | -2250 | -0.064 | -0.089 | 0.1040 | 0.1804 | 1.40E+01 | 1.05E+01 | 5.25E-01 | 4.92E-01 | 0.050 | |
| 4/30 5:00 | -1850 | -2250 | -0.066 | -0.091 | 0.1043 | 0.1803 | 1.39E+01 | 1.05E+01 | 5.24E-01 | 4.91E-01 | 0.040 | |
| 4/30 10:00 | -1850 | -2250 | -0.064 | -0.091 | 0.1041 | 0.1803 | 1.39E+01 | 1.04E+01 | 5.23E-01 | 4.90E-01 | 0.040 | |
| 4/30 11:30 | -1850 | -2250 | -0.064 | -0.091 | 0.1040 | 0.1801 | 1.33E+01 | 1.04E+01 | 4.94E-01 | 4.88E-01 | 0.040 | |
| 4/30 17:00 | -1850 | -2250 | -0.064 | -0.091 | 0.1034 | 0.1797 | 1.37E+01 | 1.04E+01 | 5.15E-01 | 4.88E-01 | 0.040 | |
| 4/30 23:00 | -1850 | -2250 | -0.066 | -0.089 | 0.1033 | 0.1797 | 1.37E+01 | 1.04E+01 | 5.16E-01 | 4.86E-01 | 0.050 | |
| 5/1 5:00 | -1850 | -2250 | -0.066 | -0.089 | 0.1033 | 0.1796 | 1.37E+01 | 1.03E+01 | 5.16E-01 | 4.85E-01 | 0.050 | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 5/1 10:15 | -1800 | -2250 | -0.068 | -0.089 | 0.1027 | 0.1792 | 1.37E+01 | 1.03E+01 | 5.15E-01 | 4.84E-01 | 0.050 | |
| 5/1 17:00 | -1850 | -2250 | -0.064 | -0.087 | 0.1012 | 0.1785 | 1.36E+01 | 1.02E+01 | 5.14E-01 | 4.82E-01 | 0.050 | |
| 5/1 22:50 | -1850 | -2250 | -0.064 | -0.087 | 0.1013 | 0.1787 | 1.35E+01 | 1.02E+01 | 5.13E-01 | 4.81E-01 | 0.050 | |
| 5/2 5:00 | -1850 | -2250 | -0.064 | -0.089 | 0.1019 | 0.1790 | 1.34E+01 | 1.01E+01 | 5.12E-01 | 4.80E-01 | 0.040 | |
| 5/2 11:00 | -1850 | -2250 | -0.064 | -0.087 | 0.1019 | 0.1785 | 1.33E+01 | 1.00E+01 | 5.11E-01 | 4.79E-01 | 0.040 | |
| 5/2 17:00 | -1850 | -2250 | -0.066 | -0.085 | 0.1022 | 0.1794 | 1.32E+01 | 9.95E+00 | 5.09E-01 | 4.77E-01 | 0.040 | |
| 5/2 23:00 | -1850 | -2250 | -0.064 | -0.087 | 0.1027 | 0.1796 | 1.32E+01 | 9.88E+00 | 5.09E-01 | 4.76E-01 | 0.040 | |
| 5/3 5:00 | -1850 | -2250 | -0.068 | -0.089 | 0.1038 | 0.1806 | 1.31E+01 | 9.81E+00 | 5.08E-01 | 4.75E-01 | 0.050 | |
| 5/3 11:00 | -1850 | -2250 | -0.070 | -0.089 | 0.1031 | 0.1796 | 1.30E+01 | 9.74E+00 | 5.06E-01 | 4.74E-01 | 0.035 | |
| 5/3 17:00 | -1850 | -2250 | -0.070 | -0.091 | 0.1031 | 0.1799 | 1.29E+01 | 9.68E+00 | 5.05E-01 | 4.72E-01 | 0.050 | |
| 5/3 23:00 | -1850 | -2250 | -0.072 | -0.089 | 0.1033 | 0.1799 | 1.28E+01 | 9.62E+00 | 5.04E-01 | 4.71E-01 | 0.050 | |
| 5/4 5:00 | -1850 | -2250 | -0.068 | -0.089 | 0.1034 | 0.1799 | 1.27E+01 | 9.57E+00 | 5.03E-01 | 4.70E-01 | 0.050 | |
| 5/4 11:00 | -1800 | -2200 | -0.077 | -0.091 | 0.1033 | 0.1803 | 1.27E+01 | 9.52E+00 | 5.02E-01 | 4.69E-01 | 0.045 | |
| 5/4 14:00 | -1850 | -2200 | -0.074 | -0.091 | 0.1027 | 0.1801 | 1.26E+01 | 9.50E+00 | 5.01E-01 | 4.68E-01 | 0.045 | |
| 5/4 17:00 | -1850 | -2250 | -0.072 | -0.089 | 0.1029 | 0.1804 | 1.52E+01 | 9.47E+00 | 5.00E-01 | 4.68E-01 | 0.045 | |
| 5/4 23:00 | -2000 | -2250 | -0.074 | -0.089 | 0.1036 | 0.1813 | 1.23E+01 | 9.42E+00 | 4.99E-01 | 4.66E-01 | 0.040 | |
| 5/5 2:00 | -2050 | -2250 | -0.074 | -0.089 | 0.1038 | 0.1815 | 1.24E+01 | 9.40E+00 | 4.99E-01 | 4.66E-01 | 0.040 | |
| 5/5 5:00 | -2050 | -2200 | -0.077 | -0.089 | 0.1038 | 0.1817 | 1.27E+01 | 9.39E+00 | 4.98E-01 | 4.65E-01 | 0.045 | |
| 5/5 11:00 | -2050 | -2200 | -0.074 | -0.091 | 0.1038 | 0.1824 | 1.26E+01 | 9.37E+00 | 4.97E-01 | 4.64E-01 | 0.045 | |
| 5/5 17:00 | -2000 | -2200 | -0.077 | -0.091 | 0.1038 | 0.1827 | 1.24E+01 | 9.36E+00 | 4.95E-01 | 4.62E-01 | 0.045 | |
| 5/5 23:00 | -2000 | -2200 | -0.077 | -0.089 | 0.1041 | 0.1829 | 1.24E+01 | 9.35E+00 | 4.94E-01 | 4.60E-01 | 0.035 | |
| 5/6 5:00 | -2000 | -2150 | -0.079 | -0.089 | 0.1045 | 0.1834 | 1.24E+01 | 9.34E+00 | 4.92E-01 | 4.59E-01 | 0.040 | |
| 5/6 11:00 | -2100 | -2200 | -0.079 | -0.091 | 0.1043 | 0.1836 | 1.24E+01 | 9.33E+00 | 4.90E-01 | 4.57E-01 | 0.045 | |
| 5/6 17:00 | -2050 | -2100 | -0.077 | -0.089 | 0.1040 | 0.1836 | 1.24E+01 | 9.31E+00 | 4.89E-01 | 4.56E-01 | 0.045 | |
| 5/6 23:00 | -2000 | -2050 | -0.081 | -0.091 | 0.1040 | 0.1836 | 1.23E+01 | 9.30E+00 | 4.88E-01 | 4.55E-01 | 0.045 | |
| 5/7 5:00 | -2050 | -2150 | -0.081 | -0.091 | 0.1036 | 0.1836 | 1.23E+01 | 9.28E+00 | 4.87E-01 | 4.53E-01 | 0.040 | |
| 5/7 11:00 | -2050 | -2150 | -0.079 | -0.091 | 0.1027 | 0.1832 | 1.23E+01 | 9.27E+00 | 4.85E-01 | 4.52E-01 | 0.040 | |
| 5/7 17:00 | -2050 | -2150 | -0.079 | -0.089 | 0.1026 | 0.1832 | 1.23E+01 | 9.25E+00 | 4.84E-01 | 4.51E-01 | 0.040 | |
| 5/7 23:00 | -2000 | -2100 | -0.083 | -0.089 | 0.1022 | 0.1831 | 1.23E+01 | 9.24E+00 | 4.83E-01 | 4.49E-01 | 0.040 | |
| 5/8 5:00 | -2100 | -2150 | -0.085 | -0.089 | 0.1020 | 0.1832 | 1.22E+01 | 9.22E+00 | 4.81E-01 | 4.48E-01 | 0.040 | |
| 5/8 11:00 | -2100 | -2150 | -0.081 | -0.087 | 0.1015 | 0.1834 | 1.22E+01 | 9.21E+00 | 4.79E-01 | 4.47E-01 | 0.040 | |
| 5/8 17:00 | -2100 | -2150 | -0.077 | -0.083 | 0.1013 | 0.1836 | 1.22E+01 | 9.19E+00 | 4.78E-01 | 4.45E-01 | 0.040 | |
| 5/8 23:00 | -2100 | -2150 | -0.083 | -0.083 | 0.1022 | 0.1839 | 1.22E+01 | 9.17E+00 | 4.77E-01 | 4.44E-01 | 0.040 | |
| 5/9 5:00 | -2100 | -2150 | -0.085 | -0.091 | 0.1027 | 0.1841 | 1.21E+01 | 9.16E+00 | 4.77E-01 | 4.44E-01 | 0.045 | |
| 5/9 11:00 | -1900 | -2100 | -0.081 | -0.091 | 0.1026 | 0.1843 | 1.21E+01 | 9.14E+00 | 4.76E-01 | 4.43E-01 | 0.041 | |
| 5/9 17:00 | -1850 | -2100 | -0.079 | -0.087 | 0.1020 | 0.1841 | 1.21E+01 | 9.13E+00 | 4.75E-01 | 4.42E-01 | 0.040 | |
| 5/9 23:00 | -1850 | -2100 | -0.083 | -0.089 | 0.1019 | 0.1839 | 1.21E+01 | 9.11E+00 | 4.75E-01 | 4.41E-01 | 0.040 | |
| 5/10 5:00 | -1800 | -2100 | -0.079 | -0.085 | 0.1008 | 0.1834 | 1.21E+01 | 9.10E+00 | 4.73E-01 | 4.40E-01 | 0.040 | |
| 5/10 11:00 | -1800 | -2100 | -0.079 | -0.083 | 0.1006 | 0.1836 | 1.20E+01 | 9.09E+00 | 4.71E-01 | 4.38E-01 | 0.041 | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]

Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | reactor water level (fuel range)(A) (mm) | reactor water level (fuel range)(B) (mm) | A system/ reactor pressure (MPa) | B system/ reactor pressure (MPa) | D/W pressure (MPa abs) | S/C pressure (MPa abs) | CAMS D/W(A) (Sv/h) | CAMS D/W(B) (Sv/h) | CAMS S/C(A) (Sv/h) | CAMS S/C(B) (Sv/h) | radiation dose in main control room (mSv/h) | note |
|------------|--|--|----------------------------------|----------------------------------|------------------------|------------------------|--------------------|--------------------|--------------------|--------------------|---|------|
| 5/10 17:00 | -1750 | -2000 | -0.083 | -0.085 | 0.1013 | 0.1841 | 1.20E+01 | 9.07E+00 | 4.69E-01 | 4.35E-01 | 0.041 | |
| 5/10 23:00 | -1750 | -2000 | -0.081 | -0.091 | 0.1020 | 0.1841 | 1.20E+01 | 9.05E+00 | 4.66E-01 | 4.33E-01 | 0.042 | |
| 5/11 5:00 | -1750 | -2000 | -0.081 | -0.096 | 0.1022 | 0.1841 | 1.19E+01 | 9.03E+00 | 4.64E-01 | 4.31E-01 | 0.038 | |
| 5/11 11:00 | -1750 | -2000 | -0.087 | -0.091 | 0.1022 | 0.1845 | 1.19E+01 | 9.01E+00 | 4.62E-01 | 4.29E-01 | 0.034 | |
| 5/11 17:00 | -1750 | -2000 | -0.087 | -0.091 | 0.1022 | 0.1843 | 1.19E+01 | 9.00E+00 | 4.61E-01 | 4.27E-01 | 0.040 | |
| 5/11 22:50 | -1750 | -1950 | -0.089 | -0.096 | 0.1026 | 0.1843 | 1.20E+01 | 8.99E+00 | 4.59E-01 | 4.26E-01 | 0.040 | |
| 5/12 5:00 | -1750 | -1950 | -0.089 | -0.096 | 0.1024 | 0.1843 | 1.18E+01 | 8.96E+00 | 4.57E-01 | 4.24E-01 | 0.038 | |
| 5/12 9:15 | -1700 | -1950 | -0.087 | -0.096 | 0.1026 | 0.1843 | 1.18E+01 | 8.95E+00 | 4.56E-01 | 4.23E-01 | 0.040 | |
| 5/12 11:15 | -1700 | -1950 | -0.087 | -0.096 | 0.1027 | 0.1846 | 1.12E+01 | 8.95E+00 | 4.28E-01 | 4.21E-01 | 0.041 | |
| 5/12 16:50 | -1700 | -1950 | -0.089 | -0.096 | 0.1020 | 0.1839 | 1.17E+01 | 8.92E+00 | 4.50E-01 | 4.21E-01 | 0.032 | |
| 5/12 20:00 | -1750 | -2000 | -0.087 | -0.096 | 0.1019 | 0.1839 | 1.17E+01 | 8.64E+00 | 4.50E-01 | 4.21E-01 | 0.034 | |
| 5/12 23:00 | -1700 | -1950 | -0.089 | -0.096 | 0.1012 | 0.1836 | 1.17E+01 | 8.56E+00 | 4.51E-01 | 4.20E-01 | 0.034 | |
| 5/13 2:00 | -1650 | -1900 | -0.091 | -0.091 | 0.1006 | 0.1832 | 1.17E+01 | 8.50E+00 | 4.50E-01 | 4.20E-01 | 0.032 | |
| 5/13 5:00 | -1800 | -1900 | -0.091 | -0.094 | 0.1003 | 0.1832 | 1.17E+01 | 8.44E+00 | 4.50E-01 | 4.19E-01 | 0.032 | |
| 5/13 8:00 | -1800 | -1900 | -0.091 | -0.094 | 0.1005 | 0.1834 | 1.17E+01 | 8.38E+00 | 4.49E-01 | 4.18E-01 | 0.032 | |
| 5/13 11:00 | -1800 | -2250 | -0.089 | -0.091 | 0.0998 | 0.1839 | 1.16E+01 | 8.28E+00 | 4.49E-01 | 4.18E-01 | 0.038 | |
| 5/13 14:00 | -1800 | -2250 | -0.085 | -0.087 | 0.0996 | 0.1843 | 1.16E+01 | 8.19E+00 | 4.48E-01 | 4.17E-01 | 0.035 | |
| 5/13 17:00 | -1800 | -2250 | -0.083 | -0.085 | 0.0998 | 0.1846 | 1.15E+01 | 8.09E+00 | 4.48E-01 | 4.16E-01 | 0.035 | |
| 5/13 20:00 | -1800 | -2250 | -0.087 | -0.087 | 0.0999 | 0.1843 | 1.15E+01 | 7.98E+00 | 4.47E-01 | 4.16E-01 | 0.045 | |
| 5/13 23:00 | -1850 | -2250 | -0.094 | -0.087 | 0.1005 | 0.1850 | 1.13E+01 | 7.77E+00 | 4.46E-01 | 4.15E-01 | 0.040 | |
| 5/14 2:00 | -1850 | -2250 | -0.089 | -0.089 | 0.1008 | 0.1850 | 1.11E+01 | 7.57E+00 | 4.46E-01 | 4.14E-01 | 0.038 | |
| 5/14 5:00 | -1800 | -2250 | -0.091 | -0.091 | 0.1012 | 0.1853 | 1.10E+01 | 7.36E+00 | 4.46E-01 | 4.14E-01 | 0.040 | |
| 5/14 8:00 | -1800 | -2250 | -0.091 | -0.091 | 0.1010 | 0.1855 | 1.08E+01 | 7.19E+00 | 4.45E-01 | 4.13E-01 | 0.038 | |
| 5/14 11:00 | -1800 | -2250 | -0.085 | -0.087 | 0.1005 | 0.1857 | 1.06E+01 | 6.98E+00 | 4.45E-01 | 4.13E-01 | 0.038 | |
| 5/14 14:00 | -1900 | -2250 | -0.089 | -0.087 | 0.1003 | 0.1859 | 1.05E+01 | 6.77E+00 | 4.44E-01 | 4.12E-01 | 0.038 | |
| 5/14 17:00 | -1800 | -2250 | -0.085 | -0.085 | 0.1006 | 0.1867 | 1.03E+01 | 6.61E+00 | 4.44E-01 | 4.12E-01 | 0.033 | |
| 5/14 20:00 | -1800 | -2250 | -0.083 | -0.083 | 0.1010 | 0.1874 | 1.02E+01 | 6.45E+00 | 4.43E-01 | 4.11E-01 | 0.036 | |
| 5/14 23:00 | -1800 | -2250 | -0.085 | -0.083 | 0.1013 | 0.1881 | 1.40E+01 | 6.33E+00 | 4.43E-01 | 4.10E-01 | 0.035 | |
| 5/15 2:00 | -1850 | -2250 | -0.085 | -0.085 | 0.1013 | 0.1887 | 1.07E+01 | 6.24E+00 | 4.45E-01 | 4.11E-01 | 0.033 | |
| 5/15 5:00 | -1900 | -2250 | -0.085 | -0.085 | 0.1020 | 0.1892 | 1.00E+01 | 6.15E+00 | 4.46E-01 | 4.13E-01 | 0.037 | |
| 5/15 8:00 | -1900 | -2300 | -0.089 | -0.089 | 0.1020 | 0.1892 | 9.90E+00 | 6.08E+00 | 4.12E-01 | 4.46E-01 | 0.036 | |
| 5/15 9:00 | -1900 | -2300 | -0.087 | -0.089 | 0.1020 | 0.1894 | 9.93E+00 | 6.06E+00 | 4.12E-01 | 4.46E-01 | 0.035 | |
| 5/15 11:00 | -1950 | -2300 | -0.089 | -0.087 | 0.1022 | 0.1895 | 9.90E+00 | 6.01E+00 | 4.45E-01 | 4.12E-01 | 0.035 | |
| 5/15 14:00 | -2000 | -2300 | -0.085 | -0.085 | 0.1015 | 0.1899 | 9.83E+00 | 5.94E+00 | 4.44E-01 | 4.11E-01 | 0.035 | |
| 5/15 17:00 | -2000 | -2300 | -0.085 | -0.085 | 0.1020 | 0.1908 | 9.90E+00 | 5.88E+00 | 4.44E-01 | 4.10E-01 | 0.035 | |
| 5/15 20:00 | -2000 | -2300 | -0.085 | -0.085 | 0.1020 | 0.1904 | 9.72E+00 | 5.83E+00 | 4.43E-01 | 4.10E-01 | 0.035 | |
| 5/15 23:00 | -2000 | -2300 | -0.085 | -0.085 | 0.1024 | 0.1911 | 9.66E+00 | 5.77E+00 | 4.42E-01 | 4.09E-01 | 0.035 | |
| 5/16 2:00 | -2000 | -2300 | -0.085 | -0.087 | 0.1024 | 0.1911 | 1.02E+01 | 5.72E+00 | 4.41E-01 | 4.08E-01 | 0.037 | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Temperature

Replaced on June 13

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Feedwater Nozzle N4B | RPV Bottom Head | RPV Flange | Reactor Pressure Vessel Bottom Part | RPV Stud | RPV Flange Lower Part | Safety Relief Valve 2-71D Leakage | Safety Relief Valve 2-71F | Main Steam Isolation Valve 2-86A Leak-off | D/W HVH Return Duct Air | RPV Bellows Air | S/C Pool Water A | S/C Pool Water B | note |
|------------|----------------------|-----------------|------------|-------------------------------------|----------|-----------------------|-----------------------------------|---------------------------|---|-------------------------|-----------------|------------------|------------------|------|
| 3/19 6:30 | 335 | 286 | 231 | 328 | 329 | 332 | 189 | 271 | 89 | 313 | 349 | | | |
| 3/19 8:20 | 331 | 295 | 228 | 352 | | | 189 | 271 | 90 | 312 | 346 | | | |
| 3/19 8:30 | 331 | 296 | 230 | 350 | | | 189 | 271 | 90 | 312 | 346 | | | |
| 3/19 17:00 | 339 | 327 | 228 | 333 | | | 164 | 281 | 89 | 322 | 316 | | | |
| 3/20 0:25 | 312 | 295 | 261 | 323 | 347 | 275 | 173 | 267 | 95 | 299 | 319 | | | |
| 3/20 0:50 | | 291 | | | | | | | 94 | 297 | | | | |
| 3/20 1:00 | | 288 | | | | | | | 94 | 294 | | | | |
| 3/20 3:10 | 306 | 277 | 272 | 304 | 356 | 264 | 176 | 249 | 92 | 284 | 329 | | | |
| 3/20 3:50 | | | | 301 | | | | | 93 | 282 | | | | |
| 3/20 4:20 | | | | 300 | | | | | 93 | 278 | | | | |
| 3/20 10:00 | 241 | 215 | 309 | 251 | 287 | 252 | 269 | 197 | 93 | 225 | 342 | | | |
| 3/20 10:10 | 216.9 | | | 248.2 | | | | | 92.9 | 223.9 | | | | |
| 3/20 10:35 | 214.4 | | | 246.6 | | | | | 92.6 | 221.9 | | | | |
| 3/20 15:00 | | | | 220 | | | | | 90.9 | 186.5 | | | | |
| 3/20 15:00 | 139.4 | 163 | 347 | | 371 | 225 | 303 | 155 | | | 363 | | | |
| 3/20 15:35 | 138.8 | | | 217.7 | | | | | 90.7 | 183.5 | | | | |
| 3/20 16:00 | 135 | | | 216.1 | | | | | 90.5 | 181.2 | | | | |
| 3/20 16:30 | | 307 | | | | | 307 | 154 | | | | | | |
| 3/20 19:40 | 95.4 | 136.7 | 393 | 198.3 | 359.9 | 228.2 | 296.9 | 137.7 | 89.7 | 156.9 | 382.1 | | | |
| 3/20 20:00 | 90.3 | | | 198.2 | | | | | 89.6 | 156.2 | | | | |
| 3/21 1:25 | 175 | | | 219.8 | | | | 137.7 | 85.6 | 138 | | | | |
| 3/21 1:25 | | 165.7 | 558.8 | | 327.7 | 360.4 | 559.3 | | | | 382.7 | | | |
| 3/21 1:45 | -131.4 | | | 217 | | | | -133.2 | 85.1 | 136.5 | | | | |
| 3/21 2:30 | 171 | | | 214 | | | | 202.7 | 85.5 | 134.8 | | | | |
| 3/21 4:00 | 170.4 | | | 223.6 | | | | 172.6 | 85 | 130.1 | | | | |
| 3/21 8:00 | 155.3 | | | 139.3 | | | | 169.3 | 85.9 | 167.2 | | | | |
| 3/21 10:00 | 155.3 | -131.6 | -131.5 | 139.3 | 218 | 404.2 | 532.3 | 169.3 | 85.9 | 167.2 | 280.3 | | | |
| 3/21 12:15 | 133.4 | | | 146.8 | | | | 177.2 | 86.6 | 126.3 | | | | |
| 3/22 22:40 | | | | 218 | | | | | | 403.4 | -141.1 | | | |
| 3/22 22:40 | -139.4 | 128.1 | -139.7 | | -138.4 | 533.1 | -141.3 | -106.2 | 69.6 | | | | | |
| 3/23 3:00 | | | | | | | -134.7 | -78.4 | | 353.1 | -133.5 | | | |
| 3/23 3:30 | 278.6 | 49.4 | -135 | 253.4 | -129.1 | 504.3 | -134.6 | -75.9 | 71.6 | 356 | -133.3 | | | |
| 3/23 4:00 | 279 | | -135 | 253 | | | -135 | -76 | | 356 | -134 | | | |
| 3/23 8:45 | 316.4 | 122.3 | -132.2 | 221.5 | -129.2 | 481.4 | -134.3 | 0.1 | 73 | 304.8 | -133.5 | | | |
| 3/23 9:10 | 304.8 | | -132.2 | 225.5 | | | -134.2 | -14.2 | | 317.5 | -133.6 | | | |
| 3/23 13:40 | 271.2 | | -132.3 | 203.1 | | | -74.2 | 55.2 | | 337 | -133.4 | | | |
| 3/23 13:50 | 271.2 | 121.4 | -132.3 | 203.1 | -129.6 | 417.5 | -74.2 | 55.2 | 73.5 | 337 | -133.4 | | | |
| 3/23 21:10 | 215.4 | | -67.4 | 195.6 | | | 21.5 | 71 | | 225.7 | -133.6 | | | |
| 3/23 21:25 | 215.7 | 110.1 | -65.3 | 195.8 | -78.5 | 385.9 | 22 | 70.2 | 73.2 | 225.5 | -133.6 | | | |
| 3/23 21:40 | 212.4 | | -64.8 | 195.3 | | | 20.4 | 68.7 | | 223.8 | -133.6 | | | |
| 3/24 2:20 | 80.7 | | -108 | 185.4 | | | 58.3 | 79.3 | | 214 | -133.6 | | | |
| 3/24 2:25 | 70.7 | 93.6 | -115.2 | 183.6 | -128.6 | 347.5 | 60.6 | 78.7 | 72.4 | 210.8 | -133.6 | | | |
| 3/24 6:20 | 99.5 | | -81.8 | 193.3 | | | 82.8 | 70.7 | | 194.8 | -2.4 | | | |
| 3/24 6:35 | 104.9 | | -80.9 | 194.8 | | | 85.6 | 65.6 | | 193.2 | 7.3 | | | |
| 3/24 10:00 | 33.3 | | -107 | 186 | | | 82.2 | 66.3 | | 152.1 | -108.7 | | | |
| 3/24 10:00 | | 27.9 | | | -43.7 | 316.1 | | | 70.7 | | | | | |
| 3/24 10:20 | 14.1 | | -124.6 | 185.5 | | | 81.1 | 72.8 | | 156.4 | -102.3 | | | |
| 3/24 18:00 | 65.6 | | -124.6 | 155.7 | | | 101.5 | 85.6 | | 151.9 | -33.9 | | | |
| 3/24 18:00 | | -14.9 | | | 222.9 | 317 | | | 70.5 | | | | | |
| 3/24 21:00 | 54.1 | 35.8 | -81 | 156.4 | 171.8 | 329 | 125.9 | 88.9 | 69.7 | 138 | -28.4 | | | |
| 3/24 21:20 | 53 | 33.9 | -87 | 155 | 173.3 | 324.6 | 131.5 | 90.3 | 69.6 | 137 | -24.9 | | | |
| 3/24 21:40 | 60.5 | | -85.4 | 150.9 | | | 131.5 | 91.2 | | 137.3 | -21.5 | | | |
| 3/24 21:40 | | 38.7 | | | 168.4 | 318.1 | | | 69.8 | | | | | |
| 3/24 22:00 | 22.4 | | -83.7 | 147.5 | | | 136.6 | 87.8 | | 138.4 | -18 | | | |
| 3/24 22:00 | | 45.9 | | | 163.8 | 312.1 | | | 69.8 | | | | | |
| 3/24 23:30 | 55.9 | | -57.9 | 135.2 | | | 148 | 97.1 | | 138.7 | 1.4 | | | |
| 3/24 23:30 | | 63.1 | | | 167.8 | 277.5 | | | 69.7 | | | | | |
| 3/25 0:30 | 11 | | -57.3 | 133.8 | | | 151.9 | 94.8 | | -32.2 | 7.4 | | | |
| 3/25 0:30 | | 62 | | | 183 | 270.9 | | | 69.7 | | | | | |
| 3/25 5:30 | 43.8 | | -14.5 | 115.9 | | | 191 | 107.3 | | -8.9 | 25.6 | | | |
| 3/25 5:30 | | 20.9 | | | 153.2 | 243 | | | 68.9 | | | | | |
| 3/25 6:10 | 42.8 | | -1.5 | 111.6 | | | 193.4 | 107.1 | | -28.4 | 30 | | | |
| 3/25 9:30 | 43.3 | | 47.3 | 107.8 | | | 216.6 | 100.4 | | -40.7 | 28.9 | | | |
| 3/25 14:10 | 19.7 | | 31.6 | 104.4 | | | 213.7 | 85 | | -88.2 | 19.4 | | | |
| 3/25 14:10 | | 2 | | | 120.9 | 202.7 | | | 74.5 | | | | | |
| 3/25 16:10 | -33.4 | | 41.3 | 111 | | | 31.7 | 74.3 | | -109.6 | -36.4 | | | |
| 3/25 16:10 | | -132.9 | | | 521.1 | 266.5 | | | 73.6 | | | | | |
| 3/25 18:10 | -8.4 | | 29.4 | 86.1 | | | 120.9 | 65.9 | | -135.6 | -135.2 | | | |
| 3/25 18:10 | | -133 | | | 220.9 | 256 | | | 72.3 | | | | | |
| 3/25 19:10 | -5.3 | | 23.3 | 99.2 | | | 150.4 | 70.6 | | -135.7 | -135.2 | | | |
| 3/25 19:10 | | -133 | | | 164.6 | 238.6 | | | 72.4 | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Temperature

[Note]

Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Feedwater Nozzle N4B | RPV Bottom Head | RPV Flange | Reactor Pressure Vessel Bottom Part | RPV Stud | RPV Flange Lower Part | Safety Relief Valve 2-71D Leakage | Safety Relief Valve 2-71F | Main Steam Isolation Valve 2-86A Leak-off | D/W HVH Return Duct Air | RPV Bellows Air | S/C Pool Water A | S/C Pool Water B | note |
|------------|----------------------|-----------------|------------|-------------------------------------|----------|-----------------------|-----------------------------------|---------------------------|---|-------------------------|-----------------|------------------|------------------|------|
| 3/25 19:10 | | -133 | | | 164.6 | 238.6 | | | 72.4 | | | | | |
| 3/25 21:10 | -0.8 | | 13 | 93.9 | | | 178.4 | 74.2 | | -135.7 | -63.8 | | | |
| 3/25 21:10 | | -100.3 | | | 132.8 | 226.9 | | | 72.5 | | | | | |
| 3/25 22:00 | -2.5 | | 4.2 | 95.8 | | | 173.5 | 71.4 | | -135.6 | -33.3 | | | |
| 3/25 23:00 | 3.9 | | 16.3 | 97 | | | 177.8 | 73.3 | | -135.6 | -19.2 | | | |
| 3/25 23:00 | | -52.8 | | | 129.5 | 219.4 | | | 72.4 | | | | | |
| 3/26 4:20 | 21.2 | | 37.9 | 99.4 | | | 173.7 | 75.3 | | -106.6 | 6.6 | | | |
| 3/26 4:20 | | -17.6 | | | 119.2 | 195.8 | | | 71.8 | | | | | |
| 3/26 5:05 | 26.1 | | 41.2 | 102.5 | | | 169.2 | 83.8 | | -119.8 | 9 | | | |
| 3/26 10:00 | 37.6 | | 46.4 | 106.1 | | | 172 | 79.2 | | -49.7 | 39.7 | | | |
| 3/26 10:00 | | -49.9 | | | 97.5 | 216.5 | | | 71.7 | | | | | |
| 3/26 11:15 | 33.7 | | 46.4 | 100.4 | | | 169 | 79.3 | | -57.8 | 45 | | | |
| 3/26 14:30 | 35.7 | | 55.2 | 99.4 | | | 163.5 | 78.5 | | -23.7 | 35.1 | | | |
| 3/26 16:00 | 35.3 | | 57.8 | 102.8 | | | 160.2 | 78.2 | | -46.4 | 27.5 | | | |
| 3/26 16:00 | | 41.6 | | | 105.6 | 212.5 | | | 71.1 | | | | | |
| 3/26 20:00 | 41.9 | | 61.9 | 107 | | | 161.4 | 83 | | 3.7 | 40.6 | | | |
| 3/26 21:00 | 41.7 | 66.4 | 62.4 | 106.5 | 88.2 | 201.1 | 156.7 | 83.1 | 70.8 | 8.4 | 43.3 | | | |
| 3/26 21:20 | 41.7 | | 62.4 | 106.5 | | | 156.7 | 83.1 | | 8.4 | 43.3 | | | |
| 3/26 23:00 | 15.1 | 75.5 | 66.2 | 104.8 | 87.6 | 201.2 | 151.4 | 81.7 | 70.4 | 2.4 | 49 | | | |
| 3/26 23:10 | 15.1 | | 66.2 | 104.8 | | | 151.4 | 81.7 | | 2.4 | 49 | | | |
| 3/27 4:15 | -7.9 | | 67.2 | 106.5 | | | 139.9 | 85.3 | | 49.3 | 45.8 | | | |
| 3/27 4:15 | | 79.7 | | | 91.1 | 197.1 | | | 69.1 | | | | | |
| 3/27 4:45 | -1.7 | | 66.7 | 106.8 | | | 138.6 | 85.6 | | 48.8 | 49.9 | | | |
| 3/27 9:25 | 16.3 | | 73 | 122.7 | | | 135.3 | 90.5 | | 38.3 | 73.3 | | | |
| 3/27 9:25 | | 71.6 | | | 85.3 | 184.8 | | | 68.5 | | | | | |
| 3/27 10:10 | 13.6 | | 72.7 | 121.6 | | | 133.1 | 90.2 | | 38.4 | 74 | | | |
| 3/27 16:00 | 33.1 | | 75.1 | 123.8 | | | 125.5 | 86.4 | | 33.5 | 71.1 | 59.1 | | |
| 3/27 16:00 | | 101.4 | | | 82.9 | 187.2 | | | 67.4 | | | | | |
| 3/27 16:25 | 28.2 | | 75.4 | 124.6 | | | 123.3 | 85.6 | | 34.7 | 73.1 | 59.1 | | |
| 3/27 17:30 | 33.8 | | 75 | 123.1 | | | 132.2 | 82 | | 35.8 | 55.9 | 59.1 | | |
| 3/27 17:30 | | 97.2 | | | 81.9 | 200.3 | | | 67 | | | | | |
| 3/27 18:30 | 39.1 | | 76.2 | 122.5 | | | 127 | 81.5 | | 41.4 | 43.4 | 59 | | |
| 3/27 19:00 | 41.9 | | 77.5 | 121.7 | | | 139.7 | 78 | | 40.1 | 25.2 | 59 | | |
| 3/28 0:00 | 38.1 | | 82 | 123.6 | | | 131.9 | 90.1 | | 56.7 | 82.9 | 58.7 | | |
| 3/28 0:00 | | 102.9 | | | 82.8 | 170 | | | 66.3 | | | | | |
| 3/28 0:50 | 38.2 | | 82.6 | 122.6 | | | 132.7 | 90.2 | | 61.1 | 81 | 58.7 | | |
| 3/28 5:00 | 36.7 | | 83.7 | 124 | | | 130.5 | 91.2 | | 67.4 | 71.8 | 58.4 | | |
| 3/28 5:00 | | 100.5 | | | 81.6 | 173.4 | | | 65.4 | | | | | |
| 3/28 5:30 | 38 | | 84.5 | 123 | | | 130.7 | 91.5 | | 64.9 | 72.9 | 58.4 | | |
| 3/28 10:00 | 39.1 | | 83.6 | 123.8 | | | 125.5 | 92.1 | | 59.2 | 74.3 | 58.2 | | |
| 3/28 10:00 | | 98.2 | | | 81.6 | 156.7 | | | 65 | | | | | |
| 3/28 10:30 | 41.9 | | 83.1 | 124.4 | | | 125.5 | 91.2 | | 59.6 | 75.4 | 58.1 | | |
| 3/28 15:00 | 48 | | 81.5 | 123.1 | | | 122.5 | 92.3 | | 41.5 | 76.6 | 57.9 | | |
| 3/28 15:00 | | 100.4 | | | 82.0 | 157.3 | | | 65.0 | | | | | |
| 3/28 16:00 | 47.6 | | 82.3 | 121.8 | | | 111.7 | 92.6 | | 48.6 | 75.7 | 57.9 | | |
| 3/28 19:30 | 46.3 | | 81 | 122.7 | | | -4.4 | 93.8 | | 37.7 | 77.9 | 57.7 | | |
| 3/28 19:30 | | 110.6 | | | 81.6 | 155.0 | | | 65.0 | | | | | |
| 3/28 20:35 | 49.6 | | 81.5 | 122.8 | | | 41.3 | 94.4 | | 43.7 | 79.4 | 57.6 | | |
| 3/28 20:35 | | 68.2 | | | 82.8 | 155.2 | | | 64.7 | | | | | |
| 3/28 21:10 | 48.2 | | 82.2 | 122.8 | | | 41.9 | 94.3 | | 33.8 | 80 | 57.6 | | |
| 3/28 21:20 | 49.7 | | 82.3 | 122.9 | | | 42.3 | 94.5 | | 21.7 | 79.6 | 57.6 | | |
| 3/28 21:40 | 52.4 | | 82 | 121.7 | | | 41.6 | 94.5 | | 27.8 | 80 | 57.6 | | |
| 3/28 23:00 | 53.7 | 73.7 | 81.5 | 121.9 | 77.9 | 153.5 | 40.5 | 94.8 | 64.3 | 40 | 81.1 | | | |
| 3/28 23:30 | 53.7 | | 81.5 | 121.9 | | | 40.5 | 94.8 | | 40 | 81.1 | 57.5 | | |
| 3/29 0:00 | 53.8 | | 81.6 | 121.8 | | | 43 | 95.1 | | 37.2 | 81.1 | 57.5 | | |
| 3/29 4:45 | 61.5 | | 82 | 120.9 | | | 37.8 | 96.7 | | 45.3 | 80.1 | 57.2 | | |
| 3/29 4:45 | | 80.8 | | | 79.5 | 157.6 | | | 64.1 | | | | | |
| 3/29 5:15 | 61.6 | | 82 | 120.4 | | | 36.4 | 95.7 | | 45 | 79.9 | 57.2 | | |
| 3/29 10:15 | 63.8 | | 82.6 | 118.9 | 49.6 | 156.5 | | | | 21.5 | 82.4 | 57 | | |
| 3/29 10:15 | | 82.8 | | | | | 29 | 96.3 | 63.9 | | | | | |
| 3/29 10:45 | 62.9 | | 83.2 | 111.1 | 51.1 | 148.8 | | | | 29 | 82.2 | 57 | | |
| 3/29 12:00 | 62.2 | | 83.4 | 121.2 | 51.7 | 150.4 | | | | 18.1 | 82.3 | 56.9 | | |
| 3/29 14:30 | 62.3 | | 82.9 | 120.7 | 49.3 | 152.3 | | | | 36.3 | 81.1 | 56.8 | | |
| 3/29 14:30 | | 82.9 | | | | | 19.8 | 96.7 | 64.5 | | | | | |
| 3/29 15:15 | 63.2 | | 82.3 | 120.9 | 34.2 | 153.4 | | | | 36.4 | 80.4 | 56.8 | | |
| 3/29 15:45 | 64.5 | | 82 | 120.5 | 36.2 | 153.1 | | | | 29.3 | 80.4 | 56.8 | | |
| 3/29 16:10 | 64.6 | 85.7 | 82 | 120.7 | 37.7 | 152.7 | 17.5 | 96.5 | 64.6 | 38.9 | 80.5 | | | |
| 3/29 16:50 | 64.1 | | 80.7 | 119.7 | 40.4 | 154.5 | | | | 31.9 | 79.9 | 56.7 | | |
| 3/29 22:10 | 77.2 | | 70.1 | 114.6 | 71.5 | 163.2 | | | | 39.1 | 62.9 | 56.5 | | |
| 3/29 22:10 | | 93.6 | | | | | 38.2 | 87 | 64.6 | | | | | |
| 3/29 23:00 | 77.5 | | 69.9 | 113.7 | 73 | 162.1 | | | | 38.6 | 59.9 | 56.5 | | |
| 3/29 23:00 | | 93.2 | | | | | 36.8 | 86.9 | 64.6 | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Temperature

[Note]
Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Feedwater Nozzle N4B | RPV Bottom Head | RPV Flange | Reactor Pressure Vessel Bottom Part | RPV Stud | RPV Flange Lower Part | Safety Relief Valve 2-71D Leakage | Safety Relief Valve 2-71F Leakage | Main Steam Isolation Valve 2-86A Leak-off | D/W HVH Return Duct Air | RPV Bellows Air | S/C Pool Water A | S/C Pool Water B | note |
|------------|----------------------|-----------------|------------|-------------------------------------|----------|-----------------------|-----------------------------------|-----------------------------------|---|-------------------------|-----------------|------------------|------------------|------|
| 3/30 3:20 | 76.8 | | 67.5 | 115.4 | 72 | 172.2 | | | | 38.5 | 100.5 | 56.3 | | |
| 3/30 3:20 | | 81.2 | | | | | 35.4 | 94.9 | 64.5 | | | | | |
| 3/30 3:50 | 75.3 | | 67.3 | 116 | 72.5 | 170.7 | | | | 41.5 | 102.7 | 56.3 | | |
| 3/30 8:30 | 75.2 | | 62.7 | 115.9 | 72.6 | 165.4 | | | | 52.5 | 87.3 | 56.2 | | |
| 3/30 8:30 | | 79.8 | | | | | 45.9 | 98.7 | 64.4 | | | | | |
| 3/30 13:00 | 77.1 | | 63.5 | 115 | 74 | 165.8 | | | | 56.4 | 89.5 | 55.9 | | |
| 3/30 13:00 | | 80.9 | | | | | 47.8 | 98.7 | 64.8 | | | | | |
| 3/30 13:30 | 76.7 | | 64.4 | 115.4 | 73.7 | 165 | | | | 57.8 | 90.3 | 55.9 | | |
| 3/30 18:20 | 78.7 | | 52.1 | 114.2 | 77 | 164 | | | | 56.7 | 90.7 | 55.7 | | |
| 3/30 18:20 | | 86.8 | | | | | 53.8 | 98.6 | 65.1 | | | | | |
| 3/30 19:00 | 79.5 | | 49.5 | 114.5 | 77.5 | 164 | | | | 55.7 | 90.8 | 55.7 | | |
| 3/30 23:20 | 81.5 | | 50.4 | 113.1 | 76.3 | 157.4 | | | | 49.7 | 93.4 | 55.5 | | |
| 3/30 23:30 | 82.9 | 91.2 | 50.1 | 113.1 | 76.1 | 157.8 | 53.7 | 99.1 | 64.8 | 43.1 | 93.2 | | | |
| 3/30 23:50 | 83.5 | | 50.5 | 113.2 | 76.9 | 158.3 | | | | 39.1 | 93.7 | 55.5 | | |
| 3/31 4:10 | 85 | | 50.7 | 113.8 | 77 | 156.5 | | | | 69.2 | 95.3 | 55.4 | | |
| 3/31 4:20 | 87.8 | 90.9 | 50.5 | 113.9 | 76.8 | 156.1 | 58.9 | 98.9 | 64.6 | 69.3 | 95.3 | | | |
| 3/31 4:40 | 88.5 | | 53.7 | 114.2 | 76.6 | 157.7 | | | | 69.7 | 93.7 | 55.3 | | |
| 3/31 9:40 | 88.6 | | 57.4 | 114.4 | 78 | 155.5 | | | | 73.8 | 96.7 | 55.2 | | |
| 3/31 9:40 | | 92.2 | | | | | 70.3 | 98.7 | 64.6 | | | | | |
| 3/31 16:10 | 93.4 | | 52.5 | 115 | 80.2 | 156.2 | | | | 72.4 | 99 | 55 | | |
| 3/31 16:10 | | 97 | | | | | 70.9 | 98.6 | 65 | | | | | |
| 3/31 16:45 | 93 | | 53.2 | 115.4 | 80.2 | 155.4 | | | | 72.8 | 98.9 | 55 | | |
| 3/31 19:00 | 92.2 | | 53.8 | 114.8 | 81.5 | 157.2 | | | | 72.6 | 97.8 | 54.9 | | |
| 3/31 19:00 | | 97.8 | | | | | 73.8 | 96.9 | 64.4 | | | | | |
| 3/31 19:30 | 93.9 | | 54.7 | 114.6 | 81.3 | 161.2 | | | | 73.1 | 109.8 | 54.9 | | |
| 3/31 19:50 | 94.4 | | 55.3 | 114.1 | 80.9 | 163.5 | | | | 73.6 | 104.2 | 54.9 | | |
| 4/1 0:00 | 100.9 | | 61.8 | 112.4 | 80.4 | 155.5 | | | | 77.3 | 117.4 | 54.7 | | |
| 4/1 0:00 | | 98.1 | | | | | 84.9 | 93.2 | 63.8 | | | | | |
| 4/1 0:45 | 100.8 | | 60.6 | 112.3 | 80.8 | 156.5 | | | | 79.2 | 110.9 | 54.7 | | |
| 4/1 5:15 | 92.7 | | 59.4 | 115.9 | 83.6 | 158.8 | | | | 73.5 | 105.9 | 54.6 | | |
| 4/1 5:15 | | 98.6 | | | | | 57.9 | 97.6 | 63.8 | | | | | |
| 4/1 5:45 | 92.6 | | 59 | 116.3 | 83.4 | 159.1 | | | | 73.6 | 103.4 | 54.6 | | |
| 4/1 11:10 | 89.2 | | 63 | 117.5 | 85.1 | 156 | | | | 74.8 | 98.2 | 54.4 | | |
| 4/1 11:10 | | 98.8 | | | | | 67.1 | 98.3 | 64.1 | | | | | |
| 4/1 11:45 | 90.2 | | 63.8 | 117.8 | 84.7 | 155.8 | | | | 73.5 | 98.1 | 54.4 | | |
| 4/1 15:00 | 90.9 | | 63.8 | 118.6 | 86 | 151.2 | | | | 75.5 | 98.6 | 54.3 | | |
| 4/1 15:00 | | 98.6 | | | | | 74.4 | 98.2 | 64.5 | | | | | |
| 4/1 15:30 | 90 | | 63.9 | 118.3 | 85.6 | 149 | | | | 76.7 | 98.8 | 54.3 | | |
| 4/1 20:00 | 91.6 | | 71.3 | 118.5 | 86 | 156 | | | | 81.4 | 101 | 54.1 | | |
| 4/1 20:00 | | 100.4 | | | | | 79.7 | 98.1 | 64.5 | | | | | |
| 4/1 20:30 | 91.5 | | 71.3 | 118.6 | 85.8 | 155.9 | | | | 81.7 | 101 | 54.1 | | |
| 4/2 1:00 | 90.7 | | 73.9 | 119.4 | 87.6 | 156.3 | | | | 84.2 | 102.5 | 54 | | |
| 4/2 1:00 | | 101.6 | | | | | 81.4 | 98.3 | 64.3 | | | | | |
| 4/2 1:30 | 90.8 | | 73.8 | 119.4 | 86.4 | 155.7 | | | | 82.5 | 103.1 | 54 | | |
| 4/2 5:55 | 91.9 | | 77.2 | 119.4 | 87.3 | 153.8 | | | | 83.1 | 103 | 53.8 | | |
| 4/2 5:55 | | 101.1 | | | | | 58.5 | 97.8 | 64.4 | | | | | |
| 4/2 6:25 | 91.9 | | 79.7 | 119.6 | 87.7 | 153.6 | | | | 83.2 | 103.5 | 53.8 | | |
| 4/2 11:05 | 93.3 | | 78 | 119.6 | 88 | 154.8 | | | | 88.4 | 104.7 | 53.7 | | |
| 4/2 11:05 | | 98.9 | | | | | 79.1 | 97.8 | 64.7 | | | | | |
| 4/2 11:40 | 91.9 | | 79.3 | 118.9 | 88.2 | 154.9 | | | | 89.1 | 104.2 | 53.7 | | |
| 4/2 12:10 | 92.3 | | 78.7 | 117.8 | 88.2 | 156.3 | | | | 90.5 | 103.9 | 53.7 | | |
| 4/2 12:10 | | 100.7 | | | | | 67.6 | 96.7 | 64.7 | | | | | |
| 4/2 16:00 | 96.3 | | 81.5 | 115 | 85.8 | 165.1 | | | | 91.1 | 119.3 | 53.6 | | |
| 4/2 16:00 | | 102.8 | | | | | 79.1 | 92.1 | 64.7 | | | | | |
| 4/2 16:30 | 96.7 | | 81.3 | 114.6 | 85.4 | 165.4 | | | | 90 | 123.8 | 53.6 | | |
| 4/2 21:00 | 93.8 | | 82 | 114.9 | 87 | 160.6 | | | | 64 | 129.9 | 53.5 | | |
| 4/2 21:00 | | 101.0 | | | | | 69.9 | 95.3 | 64.4 | | | | | |
| 4/2 21:30 | 93.9 | | 81.8 | 114.7 | 87.6 | 160.9 | | | | 74 | 127.4 | 53.4 | | |
| 4/3 2:00 | 90.7 | | 78.7 | 115.7 | 88.4 | 155.1 | | | | 83.2 | 104.9 | 53.3 | | |
| 4/3 2:00 | | 100.0 | | | | | 56.6 | 99.4 | 63.7 | | | | | |
| 4/3 2:30 | 90.6 | | 72.4 | 115.9 | 88.4 | 155.5 | | | | 80.7 | 104.8 | 53.3 | | |
| 4/3 7:00 | 91.3 | | 82 | 115.7 | 90.4 | 156.6 | | | | 91 | 106.2 | 53.2 | | |
| 4/3 7:00 | | 99.9 | | | | | 69.4 | 98.9 | 63.0 | | | | | |
| 4/3 7:30 | 91.2 | | 82.3 | 115.5 | 90.6 | 157.1 | | | | 90.8 | 106 | 53.1 | | |
| 4/3 9:15 | 90.5 | | 81.6 | 114.8 | 90.5 | 156.4 | | | | 91 | 105.9 | 53.1 | | |
| 4/3 9:15 | | 102.2 | | | | | 66.9 | 98.9 | 63.2 | | | | | |
| 4/3 10:00 | 89.5 | | 83 | 115.1 | 90.8 | 156 | | | | 91.1 | 106.3 | 53.1 | | |
| 4/3 10:30 | 90.6 | | 83 | 114.3 | 90.7 | 156.5 | | | | 94.2 | 106.2 | 53.1 | | |
| 4/3 10:30 | | 101.4 | | | | | 66.5 | 98.5 | 63.3 | | | | | |
| 4/3 11:00 | 89.6 | | 83.1 | 114 | 90.8 | 156 | | | | 92.1 | 106.7 | 53.1 | | |
| 4/3 12:00 | 88.7 | | 82.8 | 114.1 | 90.8 | 155.4 | | | | 94.2 | 106.3 | 53 | | |
| 4/3 12:00 | | 101.7 | | | | | 59.5 | 98.6 | 63.3 | | | | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Feedwater Nozzle NAB | RPV Bottom Head | RPV Flange | Reactor Pressure Vessel Bottom Part | RPV Stud | RPV Flange Lower Part | Safety Relief Valve 2-71D Leakage | Safety Relief Valve 2-71F Leakage | Main Steam Isolation Valve 2-86A Leak-off | D/W HVH Return Duct Air | RPV Bellows Air | S/C Pool Water A | S/C Pool Water B | note |
|-----------|----------------------|-----------------|------------|-------------------------------------|----------|-----------------------|-----------------------------------|-----------------------------------|---|-------------------------|-----------------|------------------|------------------|------|
| 4/3 12:30 | 89.6 | | 82.2 | 114.1 | 91 | 155.3 | | | | 94.3 | 106.4 | 53 | | |
| 4/3 13:00 | 89.7 | | 82.9 | 114.3 | 91.4 | 154.7 | | | | 94.5 | 106.4 | 53 | | |
| 4/3 13:30 | 89.7 | | 81.7 | 113.9 | 91.3 | 154.6 | | | | 95 | 106.2 | 53 | | |
| 4/3 17:00 | 89.9 | | 79.7 | 113.4 | 91.6 | 155.1 | | | | 95.9 | 107.8 | 52.9 | | |
| 4/3 17:00 | | 100.2 | | | | | 34.8 | 98.5 | 63.8 | | | | | |
| 4/3 17:35 | 89.9 | | 79.3 | 113.5 | 91.5 | 154.9 | | | | 93.8 | 108.4 | 52.9 | | |
| 4/3 18:00 | 88 | | 80.1 | 113.4 | 91.3 | 155.2 | | | | 95.3 | 108.3 | 52.9 | | |
| 4/3 18:00 | | 99.3 | | | | | 35.1 | 98.7 | 63.7 | | | | | |
| 4/3 21:00 | 88.3 | | 81.5 | 113.8 | 91.7 | 155.8 | | | | 91.6 | 108.3 | 52.8 | | |
| 4/3 21:00 | | 100.6 | | | | | 37.7 | 98.5 | 63.5 | | | | | |
| 4/3 22:00 | 88.8 | | 79 | 113.8 | 91.4 | 155.1 | | | | 93.2 | 108.5 | 52.8 | | |
| 4/4 3:00 | 89.6 | | 81.5 | 114.1 | 92.8 | 154.7 | | | | 92.8 | 109.2 | 52.6 | | |
| 4/4 3:00 | | 100.9 | | | | | 41.0 | 98.8 | 62.5 | | | | | |
| 4/4 3:30 | 89.8 | | 80.1 | 114.1 | 92.2 | 155.4 | | | | 94.9 | 109.4 | 52.6 | | |
| 4/4 8:00 | 89.4 | | 78.7 | 114.4 | 93.2 | 154.8 | | | | 94.1 | 109.6 | 52.5 | | |
| 4/4 8:00 | | 104.7 | | | | | 44.0 | 99.0 | 62.3 | | | | | |
| 4/4 8:30 | 89.4 | | 80.1 | 113.3 | 93.4 | 154.9 | | | | 93 | 109.6 | 52.5 | | |
| 4/4 9:30 | 90 | | 80.8 | 113.7 | 93.6 | 154.3 | | | | 93.7 | 109.8 | 52.5 | | |
| 4/4 14:30 | 89.8 | | 80.4 | 113.5 | 94.6 | 155.9 | | | | 95.6 | 109.8 | 52.3 | | |
| 4/4 14:30 | | 104.2 | | | | | 48.5 | 99.0 | 63.3 | | | | | |
| 4/4 18:30 | 88.0 | | 81.5 | 113.7 | 96.4 | 157.4 | | | | 94.8 | 110.0 | 52.2 | | |
| 4/4 18:30 | | 105.1 | | | | | 51.1 | 98.7 | 63.4 | | | | | |
| 4/4 19:00 | 88.8 | | 80.4 | 113.5 | 96.4 | 156.4 | | | | 93.6 | 110.1 | 52.2 | | |
| 4/5 0:00 | 90.2 | | 82.5 | 106.7 | 97.7 | 167.4 | 52.2 | 95.3 | 62.3 | 89.3 | 124.5 | 52.1 | | |
| 4/5 0:30 | 89.9 | | 81.3 | 107.4 | 97.9 | 167.7 | 44.8 | 95.2 | 62.3 | 89.7 | 128.3 | 52.1 | | |
| 4/5 5:10 | 81.5 | | 79.2 | 113.5 | 98.4 | 160.5 | | | | 94.2 | 110.5 | 51.9 | | |
| 4/5 5:10 | | 105.9 | | | | | 52.7 | 99.4 | 62.2 | | | | | |
| 4/5 5:40 | 84.7 | | 80.1 | 113.7 | 98.1 | 159.9 | | | | 92.7 | 109.9 | 51.9 | | |
| 4/5 10:20 | 84.7 | | 80.8 | 114.1 | 99.4 | 158.1 | | | | 94.6 | 108.1 | 51.8 | | |
| 4/5 10:20 | | 106.5 | | | | | 59.4 | 99.5 | 62.7 | | | | | |
| 4/5 17:10 | 81.7 | | 80 | 114.1 | 98.3 | 155.7 | | | | 97.9 | 108.6 | 51.6 | | |
| 4/5 17:10 | | 107.7 | | | | | 46.1 | 99.3 | 63.5 | | | | | |
| 4/5 18:30 | 83.5 | | 81.1 | 114.1 | 98.2 | 155.6 | | | | 95.9 | 108.8 | 51.5 | | |
| 4/6 0:00 | 84.4 | | 84.1 | 114.1 | 99.2 | 154.9 | | | | 97.3 | 109.5 | 51.4 | | |
| 4/6 0:00 | | 107.4 | | | | | 63.5 | 99.4 | 63.7 | | | | | |
| 4/6 6:30 | 74.6 | | 83.6 | 114.7 | 99 | 154.6 | | | | 94.6 | 110 | 51.2 | | |
| 4/6 6:30 | | 109.5 | | | | | 52.3 | 100.5 | 63.4 | | | | | |
| 4/6 12:30 | 78.8 | | 84.9 | 115 | 99.3 | 152.7 | | | | 94.9 | 110.6 | 51 | | |
| 4/6 12:30 | | 104.1 | | | | | 42.0 | 99.1 | 64.0 | | | | | |
| 4/6 18:00 | 83 | | 85.2 | 114.2 | 99.9 | 153.6 | | | | 97.3 | 110.7 | 50.8 | | |
| 4/6 18:00 | | 108.6 | | | | | 51.7 | 89.8 | 64.1 | | | | | |
| 4/7 0:00 | 78.2 | | 85.8 | 115.6 | 100 | 153.9 | | | | 96.8 | 111.9 | 50.6 | | |
| 4/7 0:00 | | 108.6 | | | | | 51.9 | 98.7 | 64 | | | | | |
| 4/7 6:00 | 83.4 | | 86.2 | 115.8 | 99.8 | 152.5 | | | | 96.8 | 114.2 | 50.4 | | |
| 4/7 6:15 | 82.9 | | 84.8 | 116.0 | 98.3 | 152.2 | 46.8 | 98.6 | 63.7 | 96.6 | 114.1 | | | |
| 4/7 12:00 | 88.3 | | 84.8 | 112.3 | 97.6 | 153.3 | | | | 97.3 | 189.6 | 50.2 | | |
| 4/7 12:00 | | 108.6 | | | | | 47.9 | 97.6 | 63.8 | | | | | |
| 4/7 12:40 | | | | | | | | | | 95.5 | 197.3 | | | |
| 4/7 12:40 | | | | | | | 46.6 | 97.6 | | 95.5 | | | | |
| 4/7 18:00 | 85.7 | | 84.7 | 111.6 | 98 | 145 | | | | 93.3 | 138.1 | 50.1 | | |
| 4/7 18:00 | | 107.7 | | | | | 44.4 | 99.4 | 63.7 | | | | | |
| 4/7 19:30 | 86.6 | | 84 | 111.6 | 98.4 | 144.5 | | | | 91.9 | 135.1 | 50 | | |
| 4/8 1:30 | 88.2 | | 80.9 | 110.8 | 103.7 | 135.2 | | | | 86.6 | 140 | 49.8 | | |
| 4/8 1:35 | 87.8 | | 80.6 | 111.1 | 103.4 | 135.7 | 95.1 | 99.9 | 113.4 | 86.3 | 144.4 | | | |
| 4/8 6:00 | 85.9 | | 84.2 | 111.2 | 101.9 | 134.9 | | | | 83.6 | 140.2 | 49.7 | | |
| 4/8 6:15 | 85.8 | | 84.7 | 110.9 | 102.5 | 135.1 | 82.3 | 99.4 | 63.3 | 83.9 | 140.4 | | | |
| 4/8 6:40 | 86.3 | | 84.6 | 110.5 | 102.3 | 135.7 | | | | 85.3 | 141 | 49.6 | | |
| 4/8 12:00 | 88.8 | | 84.3 | 110.7 | 120 | 134.2 | | | | 83.8 | 144.6 | 49.5 | | |
| 4/8 12:00 | | 104.4 | | | | | 86.5 | 98.6 | 63.8 | | | | | |
| 4/8 18:00 | 86.3 | | 84 | 111.1 | 109.1 | 139 | | | | 85.4 | 145.1 | 49.3 | | |
| 4/8 18:00 | | 104.9 | | | | | 86.1 | 99.5 | 63.6 | | | | | |
| 4/9 0:00 | 99.2 | | 84.3 | 107.5 | 102.4 | 144.3 | | | | 86.1 | 182.8 | 49.1 | | |
| 4/9 0:00 | | 104 | | | | | 92.7 | 97.7 | 63.8 | | | | | |
| 4/9 6:15 | 96.6 | | 75.5 | 109.4 | 100.6 | 141.1 | | | | 76.2 | 146.9 | 48.9 | | |
| 4/9 6:15 | | 100.5 | | | | | 81.1 | 100.5 | 63.5 | | | | | |
| 4/9 12:25 | 96.6 | | 73.4 | 109.2 | 100.4 | 140.4 | | | | 83.5 | 138.8 | 48.8 | | |
| 4/9 12:25 | | 99.8 | | | | | 81.1 | 100.9 | 63.3 | | | | | |
| 4/9 18:25 | 97.3 | | 68.9 | 109.8 | 100.1 | 140 | | | | 81.6 | 144.5 | 48.6 | | |
| 4/9 18:25 | | 103.6 | | | | | 88.5 | 100.7 | 63.1 | | | | | |
| 4/10 0:00 | 98.7 | | 68.1 | 110.4 | 102.3 | 139.9 | | | | 87 | 149.7 | 48.4 | | |
| 4/10 0:00 | | 105.2 | | | | | 84.8 | 100.9 | 62.0 | | | | | |
| 4/10 6:00 | 91.7 | | 58.9 | 110.8 | 104.8 | 139.5 | | | | 89.1 | 153.9 | 48.3 | | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Feedwater Nozzle N4B | RPV Bottom Head | RPV Flange | Reactor Pressure Vessel Bottom Part | RPV Stud | RPV Flange Lower Part | Safety Relief Valve 2-71D Leakage | Safety Relief Valve 2-71F | Main Steam Isolation Valve 2-86A Leak-off | D/W HVH Return Duct Air | RPV Bellows Air | S/C Pool Water A | S/C Pool Water B | note |
|------------|----------------------|-----------------|------------|-------------------------------------|----------|-----------------------|-----------------------------------|---------------------------|---|-------------------------|-----------------|------------------|------------------|------|
| 4/10 6:00 | | 104.7 | | | | | 79.8 | 101.2 | 58.4 | | | | | |
| 4/10 12:00 | 95.3 | | 65.5 | 111.2 | 101.9 | 141.6 | | | | 85.7 | 159.6 | 48.1 | | |
| 4/10 18:00 | | 105.6 | | | | | 80.8 | 100.9 | 56.5 | | | | | |
| 4/10 18:00 | 96.3 | 103.8 | 70.2 | 111.6 | 100.9 | 142.8 | 77.2 | 101 | 61.3 | 90.3 | 164.3 | 47.9 | | |
| 4/11 0:00 | 97.7 | 103.6 | 76.4 | 110.2 | 99.3 | 145.4 | 73.2 | 100.4 | 56.1 | 95.8 | 212.6 | 47.8 | | |
| 4/11 6:00 | 97.7 | 103.9 | 77.4 | 110.5 | 100.7 | 142.8 | 77 | 100.2 | 56 | 91 | 161.1 | 47.6 | | |
| 4/11 12:00 | 97 | 107.1 | 77.9 | 111 | 99.8 | 140.4 | 81.1 | 99.8 | 56.5 | 93.4 | 159.6 | 47.5 | | |
| 4/11 18:30 | 97.9 | 108.8 | 86.6 | 112.7 | 104.6 | 143.5 | 96.1 | 99.5 | 56.1 | 85 | 160.8 | 47.2 | | |
| 4/12 0:00 | 102 | 110.6 | 87.2 | 113.2 | 105.8 | 143.2 | 97.7 | 99.4 | 60.3 | 83.2 | 164.8 | 47.1 | | |
| 4/12 6:00 | 105.4 | 110.6 | 86 | 115.6 | 106 | 141.4 | 102.4 | 99.4 | 61.9 | 84.4 | 166.6 | 47 | | |
| 4/12 12:00 | 98.9 | 110.2 | 87 | 115.9 | 104.5 | 144.1 | 103.7 | 99 | 61.7 | 89.5 | 166.2 | 46.8 | | |
| 4/12 15:10 | 98.6 | 110.4 | 83.4 | 115.4 | 109.4 | 138.7 | 99.5 | 98.3 | 62.8 | 79.4 | 168.9 | 46.8 | | |
| 4/12 18:00 | 97.4 | 111.3 | 81.6 | 116.5 | 110.2 | 140.2 | 99.8 | 98.4 | 62.9 | 80.1 | 170.4 | 46.7 | | |
| 4/12 22:10 | 96 | 111.6 | 81.5 | 119.3 | 111.4 | 144 | 103 | 98.3 | 62.1 | 84.9 | 170.8 | 46.6 | | |
| 4/13 6:00 | 92.4 | 111.8 | 80.3 | 118.7 | 109.9 | 151.5 | 107.5 | 98.7 | 61.9 | 92.4 | 187.9 | 46.4 | | |
| 4/13 12:10 | 92.2 | 112.7 | 79.2 | 117.3 | 110 | 153.4 | 107.8 | 98.7 | 62.4 | 93.4 | 195.7 | 46.3 | | |
| 4/13 18:00 | 92.7 | 112.4 | 81.3 | 117.4 | 111.9 | 154.1 | 108.7 | 98.7 | 63 | 94.9 | 209 | 46.1 | | |
| 4/14 0:00 | 90.4 | 115.7 | 80.2 | 122 | 115.3 | 161.5 | 110.4 | 98.9 | 62.9 | 96.1 | 246.1 | 46 | | |
| 4/14 6:05 | 89.3 | 116.1 | 93.6 | 122.6 | 115.5 | 166.8 | 112.4 | 100 | 62.8 | 92.4 | 251.7 | 45.8 | | |
| 4/14 12:00 | 89.9 | 115.6 | 77.8 | 121.7 | 113.1 | 164.9 | 111.4 | 98.7 | 63.1 | 93.9 | 253.6 | 45.7 | | |
| 4/14 18:00 | 90 | 115.2 | 78.1 | 122.9 | 113.3 | 162.5 | 115.6 | 99 | 63.1 | 93.2 | 256.7 | 45.6 | | |
| 4/15 0:00 | 91.2 | 115.2 | 78 | 121.1 | 112.4 | 162.2 | 115.4 | 98.6 | 62.9 | 87.7 | 261.1 | 45.4 | 45.4 | |
| 4/15 6:00 | 90.1 | 115.3 | 80.2 | 121.4 | 110.6 | 162.9 | 116.5 | 98.7 | 62.7 | 80.8 | 262.3 | 45.3 | 45.3 | |
| 4/15 12:00 | 89.6 | 116.1 | 79.5 | 121.5 | 112.4 | 167.3 | 118.8 | 98.8 | 63 | 82 | 263.4 | 45.2 | 45.2 | |
| 4/15 18:00 | 91.2 | 116.5 | 85.2 | 121.3 | 110.1 | 166.6 | 119.3 | 99.1 | 63.2 | 80.4 | 265.2 | 45 | 45 | |
| 4/16 0:00 | 91.4 | 116.6 | 92.8 | 122.1 | 111.7 | 166.6 | 120.5 | 99.1 | 63.1 | 93.9 | 266.9 | 44.9 | 44.9 | |
| 4/16 6:00 | 91.1 | 116.0 | 101.6 | 121.3 | 111.6 | 167.6 | 121.2 | 99.2 | 62.9 | 95.1 | 267.7 | 44.8 | 44.8 | |
| 4/16 12:10 | 89.3 | 115.8 | 95.3 | 119.7 | 113.5 | 168.7 | 120.8 | 98.7 | 63 | 97.9 | 269.2 | 44.6 | 44.6 | |
| 4/16 18:00 | 92.7 | 116.8 | 86.7 | 120.4 | 112.2 | 159.7 | 120.5 | 99 | 65.1 | 99.5 | 261.2 | 44.5 | 44.5 | |
| 4/17 0:00 | 89.3 | 117.1 | 89 | 121.7 | 113.6 | 160.5 | 122.3 | 99.3 | 63.9 | 99.1 | 258.7 | 44.4 | 44.4 | |
| 4/17 6:00 | 90.7 | 117.5 | 90.4 | 121.7 | 114.7 | 166.2 | 123.7 | 99.8 | 57.1 | 103.9 | 253.2 | 44.3 | 44.3 | |
| 4/17 14:00 | 98.4 | 112.4 | 98.4 | 118.6 | 108.8 | 147.2 | 123 | 100.3 | 57.4 | 104.7 | 249.5 | 44.1 | 44.1 | |
| 4/17 19:00 | 98.5 | 110.6 | 100.7 | 116.2 | 108.8 | 145.1 | 119.5 | 99.8 | 57.5 | 82.5 | 44 | 44.1 | | |
| 4/18 0:00 | 98.5 | 110.4 | 101 | 115.2 | 104.9 | 143.2 | 119.2 | 100.4 | 57.1 | 81.8 | 242.8 | 43.9 | 43.9 | |
| 4/18 6:00 | 99.9 | 109.2 | 105.1 | 114.3 | 102.7 | 140.4 | 121.3 | 100.2 | 56.7 | 80.1 | 240.4 | 43.8 | 43.8 | |
| 4/18 12:00 | 101.2 | 108.4 | 106.5 | 113.2 | 102.7 | 137.8 | 119.4 | 100.4 | 57.1 | 78.9 | 236.9 | 43.7 | 43.7 | |
| 4/18 13:10 | 101.5 | 108.7 | 105.7 | 112.7 | 102.4 | 137.1 | 121.3 | 101 | 57.7 | 79.2 | 236.3 | 43.7 | 43.7 | |
| 4/18 13:45 | 101.6 | | 105.5 | 112.4 | 102.2 | 136.2 | | | | 76.2 | 236 | 43.6 | 43.6 | |
| 4/18 18:00 | 102.8 | 108.3 | 109.4 | 111.2 | 100.8 | 136.9 | 120.5 | 100.1 | 57.3 | 77.6 | 232.8 | 43.6 | 43.6 | |
| 4/19 0:00 | 102.6 | 108.0 | 110.6 | 111.2 | 99.7 | 131.6 | 119 | 100.1 | 57 | 78.6 | 229.7 | 43.5 | 43.4 | |
| 4/19 6:00 | 102.2 | 106.6 | 112.9 | 110.3 | 97.9 | 134.7 | 117.4 | 100.1 | 57.4 | 79.5 | 226.5 | 43.4 | 43.3 | |
| 4/19 12:00 | 101.1 | 106.6 | 113.2 | 109.8 | 97.4 | 135.1 | 118.9 | 100.3 | 57.5 | 80.4 | 221.6 | 43.2 | 43.2 | |
| 4/19 18:10 | 99.7 | 106.7 | 118.1 | 109.7 | 96.4 | 133.7 | 117.6 | 100.4 | 57.6 | 78.4 | 219.3 | 43.1 | 43.1 | |
| 4/20 0:02 | 98.5 | 106.6 | 120.4 | 109.5 | 96.3 | 132.7 | 113.9 | 100.3 | 57.1 | 78.3 | 216.6 | 43 | 43 | |
| 4/20 6:00 | 98.7 | 105.6 | 121.3 | 108.4 | 95.1 | 126.7 | 108.9 | 100.4 | 57 | 79.5 | 215 | 42.9 | 42.9 | |
| 4/20 12:00 | 100.2 | 104.7 | 123.7 | 107.5 | 95.8 | 124.8 | 111.8 | 102.6 | 57.1 | 71.5 | 210.7 | 42.8 | 42.8 | |
| 4/20 18:10 | 100.4 | 104.7 | 130.9 | 108.5 | 95.8 | 133.8 | 108.7 | 105.5 | 57.1 | 72 | 205.5 | 42.7 | 42.7 | |
| 4/20 23:50 | 100.7 | 104.7 | 135.3 | 110.9 | 96.7 | 135.4 | 96.1 | 104.3 | 57 | 58 | 199.3 | 42.7 | 42.7 | |
| 4/21 6:00 | 101.6 | 103.2 | 137.3 | 109.4 | 96.6 | 137.6 | 90.5 | 103.6 | 56.9 | 61.9 | 193.9 | 42.6 | 42.6 | |
| 4/21 12:00 | 100.4 | 104.4 | 139.7 | 110.4 | 96.9 | 140.2 | 73.6 | 103.6 | 57.2 | 69.4 | 192.6 | 42.5 | 42.5 | |
| 4/21 18:00 | 100 | 102.8 | 144.7 | 110 | 96.3 | 140 | 72.3 | 103.3 | 57.1 | 74.3 | 191.3 | 42.4 | 42.4 | |
| 4/22 0:00 | 99.5 | 103.3 | 146 | 110.9 | 119.1 | 142.2 | 67.8 | 102.5 | 57 | 65.8 | 142 | 42.3 | 42.3 | |
| 4/22 6:00 | 93.3 | 101.2 | 150.4 | 110.4 | 119.4 | 143.5 | 86.3 | 102.9 | 57.6 | 63.7 | 138.6 | 42.3 | 42.3 | |
| 4/22 11:50 | 92.4 | 104.2 | 148.8 | 111.6 | 116.1 | 146.3 | 77.2 | 102.6 | 57.8 | 62.8 | 137.9 | 42.2 | 42.2 | |
| 4/22 17:50 | 80.5 | 101.8 | 149.9 | 110.1 | 113.3 | 146.2 | 81.7 | 102.3 | 58.5 | 57.3 | 136.6 | 42.1 | 42.1 | |
| 4/23 0:00 | 81.7 | 100.7 | 150 | 109.2 | 110.8 | 148.1 | 71.8 | 102.2 | 58.6 | 58.1 | 135.2 | 42.1 | 42.1 | |
| 4/23 6:15 | 85.9 | 98.2 | 154.9 | 109.4 | 108.5 | 109.9 | 65.2 | 101.4 | 58.9 | 56.2 | 134.2 | 42 | 42 | |
| 4/23 11:55 | 85.7 | 94.8 | 152.1 | 108.6 | 104.3 | 129.5 | 72.4 | 100.6 | 59.2 | 55.7 | 132.9 | 41.9 | 41.9 | |
| 4/23 18:00 | 81.1 | 90.0 | 153 | 110.1 | 100.6 | 144.4 | 80.5 | 100.6 | 59.4 | 57.3 | 130.6 | 41.9 | 41.9 | |
| 4/24 0:00 | 79.1 | 94.6 | 155.7 | 109.6 | 102.7 | 150.4 | 81.9 | 99.5 | 59.6 | 64.4 | 129.6 | 41.8 | 41.8 | |
| 4/24 5:50 | 81.1 | 93.2 | 160.7 | 109.9 | 104.3 | 151.9 | 79.4 | 99.5 | 59.3 | 63.5 | 128.3 | 41.8 | 41.8 | |
| 4/24 12:00 | 65.5 | 95.6 | 163.2 | 110.6 | 102.9 | 140.5 | 74.9 | 98.6 | 59.4 | 65.2 | 126.6 | 41.7 | 41.7 | |
| 4/24 18:00 | 71.6 | 94.6 | 165.5 | 110.2 | 102.8 | 142.7 | 68 | 98.3 | 59.4 | 65.3 | 126.6 | 41.7 | 41.7 | |
| 4/25 0:00 | 74.6 | 93.0 | 169 | 110.8 | 103.4 | 129.6 | 60.4 | 98.4 | 59.2 | 67.8 | 124.3 | 41.6 | 41.6 | |
| 4/25 6:00 | 72.5 | 91.2 | 165.9 | 109.3 | 99.3 | 130 | 53 | 98.5 | 58.9 | 70.2 | 122.5 | 41.6 | 41.6 | |
| 4/25 11:00 | 68.8 | 86.4 | 164.8 | 110 | 99.5 | 145.8 | 43.2 | 97.8 | 59.6 | 69.5 | 120 | 41.6 | 41.5 | |
| 4/25 17:00 | 77.7 | 85.3 | 163.8 | 110 | 98 | 153 | 53.6 | 97.3 | 59.5 | 61.4 | 117.6 | 41.5 | 41.5 | |
| 4/25 23:00 | 84.9 | 92.7 | 155.7 | 109.8 | 98.8 | 158.4 | 62.6 | 96.7 | 59.2 | 64.5 | 103.1 | 41.4 | 41.4 | |
| 4/26 5:00 | 67.9 | 92.7 | 151 | 110.4 | 94.9 | 156.8 | 66.7 | 97 | 59 | 67.3 | 117.9 | 41.4 | 41.4 | |
| 4/26 9:00 | 82.5 | 90.7 | 149.4 | 110.7 | 97 | 158 | 43.4 | 96.7 | 59.1 | 69 | 121.5 | 41.4 | 41.4 | |
| 4/26 17:00 | 86.2 | 93.9 | 154.8 | 110.5 | 94.3 | 160.7 | 62.4 | 96 | 59.6 | 71.2 | 122.2 | 41.3 | 41.3 | |
| 4/26 23:00 | 86.6 | 95.8 | 156.6 | 110.7 | 92 | 158.7 | 63.2 | 96.1 | 59.7 | 96.7 | 122.2 | 41.2 | 41.2 | |

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Temperature

[Note]
 Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
 We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

| Date | Feedwater Nozzle N4B | RPV Bottom Head | RPV Flange | Reactor Pressure Vessel Bottom Part | RPV Stud | RPV Flange Lower Part | Safety Relief Valve 2-71D Leakage | Safety Relief Valve 2-71F | Main Steam Isolation Valve 2-86A Leak-off | D/W HVH Return Duct Air | RPV Bellows Air | S/C Pool Water A | S/C Pool Water B | note |
|------------|----------------------|-----------------|------------|-------------------------------------|----------|-----------------------|-----------------------------------|---------------------------|---|-------------------------|-----------------|------------------|------------------|------|
| 4/27 5:00 | 72 | 95.1 | 153.1 | 110.7 | 94.3 | 157 | 51.7 | 96.3 | 59.9 | 101.9 | 121.7 | 41.2 | 41.2 | |
| 4/27 11:00 | 82.3 | 96.4 | 150.4 | 110.3 | 95.3 | 153.7 | 50 | 97.3 | 59.9 | 103.6 | 123.4 | 41.1 | 41.1 | |
| 4/27 17:00 | 83.2 | 95.7 | 143.2 | 109.9 | 92.4 | 156.8 | 36 | 96.7 | 60.6 | 104 | 124.6 | 41.1 | 41.1 | |
| 4/27 23:00 | 84.6 | 96.4 | 137.1 | 110.2 | 90.5 | 152.1 | 56.6 | 97.2 | 60.7 | 102.9 | 124.1 | 41.1 | 41.1 | |
| 4/28 5:00 | 86 | 96.6 | 129.5 | 109.6 | 92.7 | 150.9 | 57.8 | 96.2 | 60.9 | 102.1 | 124.7 | 41 | 41 | |
| 4/28 11:00 | 85.1 | 102.1 | 127.2 | 109.4 | 91.3 | 154.4 | 54.7 | 95.6 | 60.7 | 98.9 | 125.4 | 41 | 41 | |
| 4/28 17:10 | 83.5 | 101.4 | 124.1 | 110 | 94.9 | 150.1 | 54.7 | 96 | 60.6 | 95.5 | 128 | 41 | 41 | |
| 4/28 23:00 | 82.4 | 103.1 | 120.6 | 112.1 | 92.2 | 149.7 | 96.3 | 96.8 | 60.5 | 98.1 | 129.1 | 40.9 | 40.9 | |
| 4/29 5:00 | 81.3 | 104.1 | 114.7 | 112.7 | 91.6 | 150.8 | 85.1 | 96.7 | 60.2 | 98.6 | 128.3 | 40.9 | 40.9 | |
| 4/29 11:00 | 80.6 | 105.2 | 111 | 112.9 | 84 | 151.7 | 84 | 96.7 | 60.3 | 97.2 | 127.4 | 40.9 | 40.9 | |
| 4/29 17:00 | 80.9 | 105.6 | 105.1 | 113.7 | 83.7 | 151.2 | 84.5 | 96.3 | 60.4 | 97.6 | 127.6 | 40.8 | 40.8 | |
| 4/29 23:00 | 81.6 | 107.9 | 106.2 | 113.3 | 83.2 | 147.1 | 84.8 | 96.1 | 60.1 | 97.9 | 128.6 | 40.8 | 40.8 | |
| 4/30 5:00 | 83.6 | 111.6 | 100.9 | 113.1 | 84.6 | 150 | 81.6 | 97 | 60 | 101.2 | 125.3 | 40.7 | 40.7 | |
| 4/30 10:00 | 84.6 | 113.8 | 100.6 | 114.7 | 87.6 | 152.1 | 79.2 | 96.2 | 60.4 | 100.2 | 129.7 | 40.7 | 40.7 | |
| 4/30 11:30 | 84.8 | 114.7 | 101.2 | 113.4 | 88.2 | 150 | 79.8 | 96.5 | 60.3 | 96.9 | 128.8 | 40.7 | 40.7 | |
| 4/30 17:00 | 89.1 | 117.4 | 98.5 | 116.5 | 91.6 | 153 | 99.7 | 96.9 | 61 | 96.7 | 134.7 | 40.7 | 40.7 | |
| 4/30 23:00 | 90.5 | 119.2 | 98.2 | 116.6 | 97.6 | 154.6 | 94.3 | 96.6 | 61.2 | 99.3 | 137.3 | 40.6 | 40.6 | |
| 5/1 5:00 | 93.7 | 122.3 | 99.6 | 116.5 | 98.8 | 154.6 | 91.3 | 96.9 | 61.2 | 101.7 | 137.3 | 40.6 | 40.6 | |
| 5/1 10:15 | 90.8 | 124.1 | 102.2 | 118.4 | 102.7 | 153.6 | 91.7 | 97.2 | 61.4 | 101.7 | 138.7 | 40.6 | 40.6 | |
| 5/1 17:00 | 96.1 | 128 | 102.9 | 119.9 | 104.6 | 153.9 | 107.2 | 97.7 | 61.6 | 99.9 | 141.7 | 40.5 | 40.5 | |
| 5/1 22:50 | 96.8 | 131.7 | 104.4 | 122.4 | 117.2 | 157 | 104.4 | 97.5 | 61.6 | 101.5 | 188.2 | 40.5 | 40.5 | |
| 5/2 5:00 | 99.2 | 134.3 | 106.4 | 123.6 | 122.5 | 156.7 | 109.9 | 97.1 | 61.2 | 100.4 | 188.1 | 40.5 | 40.5 | |
| 5/2 11:00 | 100.8 | 140.9 | 115 | 125.3 | 127.8 | 156.8 | 112.7 | 98.6 | 61.2 | 108.3 | 189 | 40.5 | 40.5 | |
| 5/2 17:00 | 95.1 | 149.2 | 123.6 | 127.8 | 131.2 | 156.6 | 112 | 97.5 | 61.3 | 96.6 | 201.7 | 40.4 | 40.5 | |
| 5/2 23:00 | 108 | 159.9 | 135.6 | 130.1 | 134.4 | 153.4 | 109.5 | 99.3 | 61.1 | 92 | 212.3 | 40.4 | 40.4 | |
| 5/3 5:00 | 111.6 | 182.1 | 147.1 | 128.5 | 139.3 | 157.2 | 119.5 | 100 | 60.9 | 106 | 202.2 | 40.4 | 40.4 | |
| 5/3 11:00 | 116.6 | 184.3 | 150.1 | 135.1 | 146.6 | 161.2 | 129.3 | 101.1 | 60.8 | 100.5 | 205 | 40.4 | 40.4 | |
| 5/3 17:00 | 112.6 | 194.6 | 158.7 | 136.7 | 157.9 | 162.9 | 134.9 | 100.1 | 60.9 | 93.1 | 200.8 | 40.3 | 40.4 | |
| 5/3 23:00 | 115.4 | 203.7 | 176.7 | 135.6 | 167.7 | 165.9 | 141.8 | 100.8 | 60.7 | 99.9 | 198.2 | 40.3 | 40.3 | |
| 5/4 5:00 | 122.6 | 210.8 | 194.8 | 138.6 | 169.4 | 167.8 | 143.7 | 101.9 | 60.7 | 103.5 | 194.2 | 40.3 | 40.3 | |
| 5/4 11:00 | 128.5 | 217.1 | 125.7 | 140 | 175.1 | 169.6 | 152.2 | 103 | 60.7 | 111.2 | 213.1 | 40.3 | 40.3 | |
| 5/4 14:00 | 119.9 | 220 | 124.2 | 139.4 | 165.2 | 170.5 | 150.6 | 102.4 | 60.6 | 104.2 | 215 | 40.3 | 40.3 | |
| 5/4 17:00 | 135.1 | 221.2 | 124.3 | 141.2 | 165.2 | 171.2 | 132.2 | 103.1 | 60.5 | 109 | 230.9 | 40.2 | 40.3 | |
| 5/4 23:00 | 133.4 | 227.3 | 214.9 | 139.9 | 169.8 | 173.2 | 150.2 | 103.3 | 59.9 | 115.7 | 217.1 | 40.2 | 40.2 | |
| 5/5 2:00 | 133.1 | 231.3 | 222.2 | 141.2 | 170 | 172.6 | 155.3 | 103.8 | 59.7 | 115.5 | 220.3 | 40.2 | 40.2 | |
| 5/5 5:00 | 144 | 233.7 | 228 | 142.7 | 171.9 | 173 | 145.2 | 103.6 | 59.6 | 119.6 | 222.2 | 40.2 | 40.2 | |
| 5/5 11:00 | 156.6 | 239 | 240.7 | 143.5 | 175.6 | 172.5 | 169.6 | 103.7 | 60 | 117.7 | 228.1 | 40.2 | 40.2 | |
| 5/5 17:00 | 157.5 | 244.4 | 252 | 145 | 184.3 | 173.1 | 151.3 | 103 | 60.5 | 124.4 | 225.3 | 40.1 | 40.2 | |
| 5/5 23:00 | 156.1 | 249.7 | 261.4 | 147.2 | 211.5 | 172.9 | 176.8 | 103.2 | 61.1 | 125.9 | 234.1 | 40.1 | 40.1 | |
| 5/6 5:00 | 162 | 255.8 | 273 | 146.8 | 220.3 | 173 | 181.1 | 103.7 | 61.3 | 131.9 | 238.3 | 40.1 | 40.1 | |
| 5/6 11:00 | 163.5 | 258.6 | 277.4 | 147.4 | 224.8 | 174.8 | 183.8 | 104.9 | 61.6 | 137.1 | 243.1 | 40.1 | 40.1 | |
| 5/6 17:00 | 171 | 261.4 | 286.5 | 148 | 230.9 | 175.1 | 178.5 | 105.2 | 61.9 | 141.7 | 219.3 | 40.1 | 40.1 | |
| 5/6 23:00 | 182.1 | 262.9 | 291.7 | 148.7 | 233.5 | 174.7 | 189.5 | 106.2 | 62.1 | 147.5 | 199.1 | 40.1 | 40.1 | |
| 5/7 5:00 | 180.2 | 262.9 | 298 | 149.6 | 236.1 | 174.8 | 190 | 106.7 | 62.2 | 149.5 | 198.5 | 40 | 40.1 | |
| 5/7 11:00 | 163.2 | 260.9 | 300.7 | 150.3 | 162.2 | 176.2 | 181.8 | 107.7 | 62.6 | 153 | 206 | 40 | 40.1 | |
| 5/7 17:00 | 193.8 | 259.3 | 303.8 | 150.4 | 245.4 | 174.2 | 187.6 | 107.7 | 62.8 | 155.9 | 208.3 | 40 | 40 | |
| 5/7 23:00 | 202.3 | 258.4 | 307.3 | 152.2 | 250.2 | 172 | 187.1 | 108.6 | 63 | 154.2 | 204.4 | 40 | 40 | |
| 5/8 5:00 | 202.1 | 255.6 | 310.1 | 151.9 | 253.6 | 173.3 | 158.2 | 108.8 | 63 | 157.6 | 208.6 | 40 | 40 | |
| 5/8 11:00 | 206.2 | 256.3 | 314.5 | 151.3 | 253.8 | 175.6 | 122.9 | 109.4 | 63.1 | 157.7 | 207.3 | 40 | 40 | |
| 5/8 17:00 | 217.2 | 236 | 322.9 | 151.9 | 206.3 | 173.2 | 118.4 | 110.6 | 63.4 | 156 | 207.3 | 40 | 40 | |
| 5/8 23:00 | 217.2 | 239.4 | 326 | 153 | 233.3 | 172.2 | 118.4 | 111.2 | 63.2 | 157.1 | 207.2 | 40 | 40 | |
| 5/9 5:00 | 210.4 | 239.8 | 329.4 | 153 | 250.2 | 171.7 | 104.6 | 112.4 | 62.9 | 154.5 | 209.7 | 40 | 40 | |
| 5/9 11:00 | 216.4 | 238.4 | 333.9 | 154.3 | 246.2 | 173.3 | 109.5 | 113.3 | 63.1 | 147.4 | 209.7 | 40 | 40 | |
| 5/9 17:00 | 216.4 | 231.2 | 332.9 | 145.8 | 241.5 | 174.3 | 105.5 | 113.4 | 63.4 | 149.2 | 208.6 | 40 | 40 | |
| 5/9 23:00 | 218.7 | 237.1 | 300 | 150.4 | 194 | 173.1 | 107.3 | 113.4 | 63.5 | 145.3 | 207.4 | 40 | 40 | |
| 5/10 5:00 | 192.7 | 237.1 | 132.4 | 150.6 | 167.1 | 171.9 | 105.4 | 113.2 | 63.7 | 143.2 | 205.5 | 40 | 40 | |
| 5/10 11:00 | 214.5 | 234.2 | 121.5 | 151.9 | 148.7 | 170.6 | 96.3 | 113.6 | 63.9 | 144.8 | 205.1 | 40 | 40 | |
| 5/10 17:00 | 215.5 | 230.7 | 122 | 151.7 | 214.8 | 168.9 | 90.7 | 114.2 | 63.8 | 144.1 | 203.9 | 40 | 40.1 | |
| 5/10 23:00 | 218.7 | 235.2 | 121.6 | 152.5 | 223.1 | 167.4 | 95.8 | 114.9 | 63.3 | 142.6 | 203.7 | 40 | 40.1 | |
| 5/11 5:00 | 215.3 | 236.4 | 155.9 | 152.4 | 223.9 | 167.4 | 104.0 | 115.5 | 63.2 | 142.6 | 202.6 | 40 | 40.1 | |
| 5/11 11:00 | 220.3 | 231.3 | 125.7 | 149.4 | 221.2 | 162.2 | 100.4 | 116.0 | 63.5 | 135.6 | 202.9 | 40 | 40.1 | |
| 5/11 17:00 | 221.7 | 221.7 | 134.8 | 151.5 | 162.9 | 160.9 | 99.2 | 116.1 | 63.6 | 138.9 | 202.2 | 40 | 40.1 | |
| 5/11 22:50 | 216 | 230.5 | 136.7 | 151.2 | 161.6 | 160.8 | 85.2 | 116.3 | 63.2 | 137.5 | 200.8 | 40.1 | 40.1 | |
| 5/12 5:00 | 215.9 | 232.2 | 280.9 | 150.2 | 156.6 | 160.2 | 99.6 | 116.1 | 62.9 | 136.1 | 199.6 | 40.1 | 40.1 | |
| 5/12 11:15 | 189.2 | 232 | 283.6 | 149 | 202.7 | 161.2 | 93.3 | 115.4 | 62.4 | 133.9 | 197.7 | 40.1 | 40.1 | |
| 5/12 16:50 | 183.5 | 242.7 | 284.1 | 148.8 | 200.7 | 160.3 | 98.7 | 115.5 | 63 | 132.8 | 196.2 | 40.1 | 40.1 | |
| 5/12 20:00 | 195.3 | 237.1 | 289.2 | 148.6 | 195.7 | 165.2 | 100.8 | 114.5 | 63.6 | 132.1 | 191.6 | 40.1 | 40.2 | |
| 5/12 23:00 | 161.5 | 244.8 | 295.6 | 149.9 | 185.1 | 167.5 | 99 | 113.6 | 63.8 | 127.9 | 186.2 | 40.1 | 40.2 | |
| 5/13 2:00 | 181.8 | 238 | 233 | 146 | 135 | 168.2 | 98.9 | 111.4 | 63.9 | 130.5 | 180.4 | 40.1 | 40.2 | |
| 5/13 5:00 | 170.5 | 241.5 | 127.3 | 145.7 | 161.8 | 170.2 | 96.3 | 111 | 64.1 | 130.5 | 179.9 | 40.1 | 40.2 | |
| 5/13 8:00 | 170.6 | 225.9 | 122.4 | 146 | 167 | 171.4 | 94.4 | 110.9 | 64 | 127.7 | 180.3 | 40.1 | 40.2 | |
| 5/13 11:00 | 155.4 | 224 | 121.2 | 142.7 | 155.7 | 173.3 | 88.4 | 109.9 | 64 | 127.8 | 176.8 | 40.1 | 40.2 | |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/3/14 21:15 | 175.0 | 55.0 | 150.0 | 54.3 |
| 2011/3/15 10:00 | | 55.3 | | 54.5 |
| 2011/3/15 11:20 | | 55.8 | | 55.0 |
| 2011/3/15 12:00 | 188.1 | 56.1 | 150.0 | 55.5 |
| 2011/3/15 12:30 | 188.4 | 56.3 | 150.5 | 55.5 |
| 2011/3/15 13:00 | 189.3 | 56.4 | 150.7 | 55.5 |
| 2011/3/15 13:30 | 190.1 | 56.6 | 150.9 | 55.5 |
| 2011/3/15 14:00 | 190.9 | 56.7 | 151.3 | 55.5 |
| 2011/3/15 14:30 | 191.6 | 56.9 | 151.6 | 55.5 |
| 2011/3/15 15:00 | 192.4 | 57.0 | 151.8 | 56.0 |
| 2011/3/15 15:30 | 193.3 | 57.2 | 152.2 | 56.0 |
| 2011/3/15 16:00 | 194.0 | 57.3 | 152.5 | 56.0 |
| 2011/3/15 17:00 | 195.5 | 57.6 | 153.2 | 56.0 |
| 2011/3/15 18:00 | 196.9 | 57.9 | 153.9 | 56.0 |
| 2011/3/15 19:00 | 199.1 | 58.1 | 154.5 | 57.0 |
| 2011/3/15 20:00 | 170.6 | 58.5 | 155.0 | 57.0 |
| 2011/3/15 21:00 | 167.0 | 58.7 | 155.7 | 57.0 |
| 2011/3/15 22:00 | 168.4 | 58.9 | 156.2 | 57.0 |
| 2011/3/15 23:00 | 170.9 | 59.2 | 156.8 | 57.5 |
| 2011/3/16 0:00 | 172.8 | 59.5 | 157.4 | 57.5 |
| 2011/3/16 1:00 | 175.0 | 59.7 | 154.9 | 58.0 |
| 2011/3/16 2:00 | 177.1 | 60.0 | 148.2 | 58.0 |
| 2011/3/16 3:00 | 178.4 | 60.2 | 147.6 | 58.5 |
| 2011/3/16 4:00 | 180.0 | 60.4 | 148.3 | 58.5 |
| 2011/3/16 5:00 | 182.2 | 60.7 | 149.4 | 59.0 |
| 2011/3/16 6:00 | 183.4 | 60.9 | 149.9 | 59.0 |
| 2011/3/16 7:00 | 185.0 | 61.1 | 150.2 | 59.5 |
| 2011/3/16 8:00 | 186.8 | 61.4 | 150.9 | 59.5 |
| 2011/3/16 9:00 | 188.2 | 61.6 | 151.6 | 59.5 |
| 2011/3/16 10:00 | 189.9 | 61.8 | 152.3 | 59.5 |
| 2011/3/16 11:00 | 191.8 | 62.1 | 153.1 | 59.5 |
| 2011/3/16 12:00 | 193.4 | 62.3 | 153.9 | 60.0 |
| 2011/3/16 13:00 | 194.6 | 62.4 | 154.4 | 60.0 |
| 2011/3/16 14:00 | 196.2 | 62.7 | 150.0 | 60.0 |
| 2011/3/16 15:00 | 197.4 | 62.9 | 155.8 | 60.0 |
| 2011/3/16 16:00 | 199.7 | 63.2 | 156.3 | 60.0 |
| 2011/3/16 17:00 | 181.2 | 63.3 | 156.9 | 60.0 |
| 2011/3/16 18:00 | 153.1 | 63.6 | 157.5 | 60.0 |
| 2011/3/16 19:00 | 151.2 | 63.8 | 158.2 | 60.0 |
| 2011/3/16 20:00 | 154.0 | 64.1 | 158.6 | 60.0 |
| 2011/3/16 21:00 | 156.6 | 64.2 | 159.1 | 60.0 |
| 2011/3/16 22:00 | 159.2 | 64.4 | 159.6 | 60.0 |
| 2011/3/16 23:00 | 161.7 | 64.6 | 160.1 | 60.5 |
| 2011/3/17 0:00 | 165.7 | 64.6 | 160.7 | 60.5 |
| 2011/3/17 1:00 | 166.3 | 64.6 | 161.2 | 61.0 |
| 2011/3/17 2:00 | 167.2 | 64.6 | 161.7 | 61.0 |
| 2011/3/17 3:00 | 168.1 | 64.5 | 162.2 | 61.0 |
| 2011/3/17 4:00 | 168.8 | 64.5 | 162.7 | 61.0 |
| 2011/3/17 5:00 | 169.0 | 65.0 | 163.0 | 61.5 |
| 2011/3/17 6:00 | 170.7 | 64.8 | 163.7 | 62.0 |
| 2011/3/17 7:00 | 171.7 | 64.2 | 164.3 | 62.0 |
| 2011/3/17 8:00 | 173.1 | 64.2 | 164.9 | 62.0 |
| 2011/3/17 9:00 | 175.0 | 64.2 | 165.0 | 62.0 |
| 2011/3/17 10:00 | 178.0 | 64.2 | 167.0 | 62.5 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/3/17 11:00 | 178.0 | 64.2 | 167.0 | 62.5 |
| 2011/3/17 12:00 | 179.1 | 64.2 | 167.3 | 62.5 |
| 2011/3/17 13:00 | 180.4 | 64.3 | 162.1 | 63.0 |
| 2011/3/17 14:00 | 182.6 | 64.3 | 154.3 | 63.5 |
| 2011/3/17 15:00 | 183.7 | 64.4 | 153.8 | 63.5 |
| 2011/3/17 16:00 | 184.7 | 64.4 | 153.5 | 63.5 |
| 2011/3/17 17:00 | 186.2 | 64.5 | 153.5 | 64.0 |
| 2011/3/17 18:00 | 187.7 | 64.6 | 154.3 | 64.0 |
| 2011/3/17 19:00 | 189.7 | 64.7 | 155.5 | 62.5 |
| 2011/3/17 20:00 | 190.5 | 64.8 | 156.1 | 62.5 |
| 2011/3/17 21:00 | 192.5 | 64.9 | 157.4 | 62.0 |
| 2011/3/17 22:00 | 193.5 | 64.9 | 158.0 | 61.5 |
| 2011/3/17 23:00 | 194.7 | 65.1 | 158.7 | 61.5 |
| 2011/3/18 0:00 | 196.5 | 65.1 | 159.7 | 61.5 |
| 2011/3/18 1:00 | 175.6 | 65.3 | 160.1 | 61.5 |
| 2011/3/18 2:00 | 163.7 | 65.3 | 163.7 | 61.5 |
| 2011/3/18 3:00 | 163.1 | 65.5 | 157.1 | 62.0 |
| 2011/3/18 4:00 | 165.2 | 65.5 | 157.3 | 62.0 |
| 2011/3/18 5:00 | 167.6 | 65.6 | 158.0 | 62.0 |
| 2011/3/18 6:00 | 169.6 | 65.7 | 158.6 | 62.5 |
| 2011/3/18 7:00 | 171.5 | 65.8 | 159.2 | 62.5 |
| 2011/3/18 8:00 | 173.3 | 65.9 | 159.9 | 63.0 |
| 2011/3/18 9:00 | 175.0 | 66.0 | 160.5 | 63.0 |
| 2011/3/18 10:00 | 176.5 | 66.1 | 161.0 | 63.0 |
| 2011/3/18 11:00 | 178.5 | 66.2 | 161.8 | 63.5 |
| 2011/3/18 12:00 | 180.4 | 66.3 | 162.7 | 63.5 |
| 2011/3/18 13:00 | 181.8 | 66.3 | 161.2 | 64.0 |
| 2011/3/18 14:00 | 183.0 | 66.6 | 158.0 | 64.5 |
| 2011/3/18 15:00 | 185.2 | 66.6 | 157.7 | 64.5 |
| 2011/3/18 16:00 | 187.1 | 66.9 | 156.7 | 64.5 |
| 2011/3/18 17:00 | 188.6 | 66.9 | 156.9 | 64.5 |
| 2011/3/18 18:00 | 190.1 | 67.1 | 157.4 | 65.0 |
| 2011/3/18 19:00 | 191.8 | 67.3 | 158.0 | 65.0 |
| 2011/3/18 20:00 | 193.0 | 67.4 | 158.7 | 65.0 |
| 2011/3/18 21:00 | 194.8 | 67.6 | 159.2 | 65.0 |
| 2011/3/18 22:00 | 196.5 | 67.8 | 159.8 | 65.0 |
| 2011/3/18 23:00 | 197.9 | 67.9 | 160.4 | 65.0 |
| 2011/3/19 0:00 | 166.5 | 68.1 | 161.0 | 65.5 |
| 2011/3/19 1:00 | 163.0 | 68.2 | 161.5 | 66.0 |
| 2011/3/19 2:00 | 164.2 | 68.4 | 162.0 | 66.0 |
| 2011/3/19 3:00 | 166.5 | 68.6 | 162.5 | 66.0 |
| 2011/3/19 4:00 | 168.5 | 68.7 | 163.0 | 66.0 |
| 2011/3/19 5:00 | 171.0 | 68.8 | 163.6 | 66.5 |
| 2011/3/19 6:00 | 173.1 | 68.8 | 164.1 | 66.5 |
| 2011/3/19 7:00 | 175.3 | 68.5 | 164.6 | 66.5 |
| 2011/3/19 8:00 | 177.2 | 68.1 | 165.2 | 66.5 |
| 2011/3/19 9:00 | 179.1 | 67.6 | 165.8 | 66.5 |
| 2011/3/19 10:00 | 181.2 | 67.0 | 166.6 | 66.5 |
| 2011/3/19 11:00 | 183.0 | 66.6 | 167.2 | 66.5 |
| 2011/3/19 12:00 | 185.4 | 65.5 | 167.9 | 66.5 |
| 2011/3/19 13:00 | 186.2 | 65.2 | 168.2 | 66.5 |
| 2011/3/19 14:00 | 188.2 | 63.8 | 156.6 | 67.0 |
| 2011/3/19 15:00 | 190.1 | 56.1 | 153.6 | 67.0 |
| 2011/3/19 16:00 | 192.2 | 50.3 | 152.5 | 67.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/3/19 17:00 | 193.3 | 48.7 | 152.1 | 67.0 |
| 2011/3/19 18:00 | 194.5 | 48.1 | 152.4 | 67.0 |
| 2011/3/19 19:00 | 196.3 | 47.6 | 153.3 | 67.0 |
| 2011/3/19 20:00 | 197.7 | 47.5 | 154.2 | 67.0 |
| 2011/3/19 21:00 | 172.8 | 46.7 | 154.8 | 67.5 |
| 2011/3/19 22:00 | 165.5 | 46.2 | 155.8 | 67.5 |
| 2011/3/19 23:00 | 164.5 | 45.7 | 156.6 | 67.5 |
| 2011/3/20 0:00 | 166.2 | 44.8 | 157.2 | 66.5 |
| 2011/3/20 1:00 | 157.9 | 43.5 | 157.9 | 56.0 |
| 2011/3/20 2:00 | 171.0 | 41.7 | 158.7 | 54.0 |
| 2011/3/20 3:00 | 173.5 | 40.1 | 159.4 | 52.0 |
| 2011/3/20 4:00 | 175.5 | 39.0 | 160.0 | 48.0 |
| 2011/3/20 5:00 | 177.5 | 38.3 | 160.6 | 46.0 |
| 2011/3/20 6:00 | 179.2 | 37.7 | 161.1 | 44.0 |
| 2011/3/20 7:00 | 181.3 | 37.1 | 161.8 | 41.0 |
| 2011/3/20 8:00 | 183.0 | 36.7 | 162.5 | 38.5 |
| 2011/3/20 9:00 | 185.0 | 36.1 | 163.1 | 36.5 |
| 2011/3/20 10:00 | 186.0 | 35.7 | 163.5 | 35.0 |
| 2011/3/20 11:00 | 188.0 | 35.1 | 164.1 | 33.5 |
| 2011/3/20 12:00 | 154.9 | 35.3 | 164.7 | 32.0 |
| 2011/3/20 13:00 | 124.7 | 35.2 | 165.3 | 30.5 |
| 2011/3/20 14:00 | 107.2 | 35.2 | 166.0 | 30.0 |
| 2011/3/20 15:00 | 92.9 | 35.2 | 166.6 | 29.5 |
| 2011/3/20 16:00 | 76.5 | 35.1 | 167.2 | 28.0 |
| 2011/3/20 17:00 | 69.4 | 34.6 | 145.6 | 27.5 |
| 2011/3/20 18:00 | 62.5 | 34.9 | 141.8 | 27.5 |
| 2011/3/20 19:00 | 57.2 | 35.3 | 113.5 | 27.5 |
| 2011/3/20 20:00 | 52.3 | 35.7 | 87.6 | 28.0 |
| 2011/3/20 21:00 | 47.8 | 36.3 | 67.5 | 28.5 |
| 2011/3/20 22:00 | 44.8 | 36.7 | 56.3 | 29.0 |
| 2011/3/20 23:00 | 43.0 | 37.0 | 50.8 | 29.5 |
| 2011/3/21 0:00 | 41.2 | 37.3 | 45.0 | 30.0 |
| 2011/3/21 1:00 | 39.0 | 37.9 | 39.2 | 30.0 |
| 2011/3/21 2:00 | 37.6 | 38.3 | 35.4 | 30.0 |
| 2011/3/21 3:00 | 36.3 | 38.6 | 32.3 | 31.0 |
| 2011/3/21 4:00 | 35.2 | 39.1 | 29.9 | 31.0 |
| 2011/3/21 5:00 | 34.4 | 39.5 | 28.2 | 32.0 |
| 2011/3/21 6:00 | 33.6 | 39.9 | 26.7 | 32.0 |
| 2011/3/21 7:00 | 32.9 | 40.2 | 25.4 | 32.5 |
| 2011/3/21 8:00 | 32.4 | 40.6 | 24.8 | 33.0 |
| 2011/3/21 9:00 | 32.0 | 41.0 | 24.1 | 33.5 |
| 2011/3/21 10:00 | 31.5 | 41.5 | 23.4 | 34.0 |
| 2011/3/21 11:00 | 31.2 | 41.9 | 23.1 | 34.0 |
| 2011/3/21 12:00 | 45.0 | 42.2 | 22.8 | 35.0 |
| 2011/3/21 13:00 | 47.0 | 42.6 | 22.4 | 35.0 |
| 2011/3/21 14:00 | 49.1 | 42.6 | 22.2 | 35.5 |
| 2011/3/21 15:00 | 51.2 | 42.6 | 21.9 | 36.0 |
| 2011/3/21 16:00 | 53.2 | 42.3 | 23.6 | 36.0 |
| 2011/3/21 17:00 | 55.2 | 42.3 | 23.0 | 36.5 |
| 2011/3/21 18:00 | 57.7 | 42.1 | 22.8 | 37.0 |
| 2011/3/21 19:00 | 59.6 | 39.7 | 38.2 | 37.5 |
| 2011/3/21 20:00 | 62.6 | 37.8 | 40.1 | 37.5 |
| 2011/3/21 21:00 | 65.0 | 37.0 | 41.2 | 35.5 |
| 2011/3/21 22:00 | 68.4 | 36.4 | 42.4 | 33.5 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/3/21 23:00 | 70.9 | 36.1 | 43.3 | 32.5 |
| 2011/3/22 0:00 | 57.9 | 35.9 | 45.1 | 30.5 |
| 2011/3/22 1:00 | 53.9 | 35.8 | 46.0 | 30.0 |
| 2011/3/22 2:00 | 49.3 | 35.7 | 49.3 | 29.0 |
| 2011/3/22 3:00 | 45.0 | 35.7 | 50.9 | 27.5 |
| 2011/3/22 4:00 | 42.2 | 36.0 | 53.6 | 26.0 |
| 2011/3/22 5:00 | 39.3 | 36.3 | 55.3 | 25.5 |
| 2011/3/22 6:00 | 38.2 | 36.7 | 56.5 | 25.0 |
| 2011/3/22 7:00 | 36.7 | 37.1 | 58.0 | 24.0 |
| 2011/3/22 8:00 | 46.3 | 37.4 | 59.6 | 23.5 |
| 2011/3/22 9:00 | 48.6 | 37.7 | 47.0 | 23.5 |
| 2011/3/22 10:00 | 51.0 | 37.6 | 39.7 | 24.0 |
| 2011/3/22 11:00 | 53.2 | 37.5 | 34.1 | 25.0 |
| 2011/3/22 12:00 | 55.5 | 37.4 | 31.3 | 25.5 |
| 2011/3/22 13:00 | 58.4 | 37.3 | 28.3 | 26.0 |
| 2011/3/22 14:00 | 61.7 | 36.9 | 26.5 | 26.0 |
| 2011/3/22 15:00 | 64.4 | 35.5 | 24.3 | 26.5 |
| 2011/3/22 16:00 | 67.9 | 34.1 | 23.9 | 27.0 |
| 2011/3/22 17:00 | 70.6 | 33.5 | 21.6 | 27.5 |
| 2011/3/22 18:00 | 73.5 | 33.3 | 35.9 | 28.0 |
| 2011/3/22 19:00 | 75.6 | 33.1 | 37.1 | 28.5 |
| 2011/3/22 20:00 | 62.7 | 32.9 | 38.0 | 28.5 |
| 2011/3/22 21:00 | 56.1 | 33.2 | 39.2 | 28.5 |
| 2011/3/22 22:00 | 51.6 | 33.5 | 40.3 | 26.5 |
| 2011/3/22 23:00 | 47.7 | 33.8 | 41.7 | 26.0 |
| 2011/3/23 0:00 | 44.3 | 34.2 | 43.1 | 24.5 |
| 2011/3/23 1:00 | 41.8 | 34.6 | 44.6 | 24.0 |
| 2011/3/23 2:00 | 39.3 | 35.1 | 48.0 | 23.0 |
| 2011/3/23 3:00 | 37.8 | 35.4 | 49.9 | 22.5 |
| 2011/3/23 4:00 | 36.6 | 35.7 | 51.1 | 22.0 |
| 2011/3/23 5:00 | 35.3 | 36.2 | 52.4 | 21.5 |
| 2011/3/23 6:00 | 34.2 | 36.6 | 54.0 | 21.0 |
| 2011/3/23 7:00 | 33.4 | 36.9 | 55.3 | 20.5 |
| 2011/3/23 8:00 | 32.6 | 37.3 | 57.0 | 20.0 |
| 2011/3/23 9:00 | 31.9 | 37.8 | 59.1 | 20.0 |
| 2011/3/23 10:00 | 31.4 | 38.1 | 60.6 | 20.0 |
| 2011/3/23 11:00 | 31.1 | 38.6 | 62.5 | 20.0 |
| 2011/3/23 12:00 | 30.7 | 39.0 | 64.6 | 20.0 |
| 2011/3/23 13:00 | 30.4 | 39.3 | 66.4 | 20.0 |
| 2011/3/23 14:00 | 30.2 | 39.6 | 68.1 | 19.5 |
| 2011/3/23 15:00 | 29.9 | 40.1 | 70.3 | 19.5 |
| 2011/3/23 16:00 | 29.9 | 40.3 | 72.3 | 19.5 |
| 2011/3/23 17:00 | 38.5 | 40.7 | 74.0 | 19.0 |
| 2011/3/23 18:00 | 40.9 | 41.1 | 75.7 | 19.0 |
| 2011/3/23 19:00 | 43.1 | 41.5 | 56.1 | 19.5 |
| 2011/3/23 20:00 | 45.4 | 41.8 | 47.5 | 20.0 |
| 2011/3/23 21:00 | 47.8 | 42.2 | 40.6 | 20.5 |
| 2011/3/23 22:00 | 50.7 | 42.6 | 35.7 | 20.5 |
| 2011/3/23 23:00 | 53.5 | 43.0 | 31.9 | 21.0 |
| 2011/3/24 0:00 | 56.9 | 43.2 | 28.6 | 21.5 |
| 2011/3/24 1:00 | 59.4 | 43.6 | 26.7 | 21.5 |
| 2011/3/24 2:00 | 62.7 | 44.0 | 25.0 | 22.0 |
| 2011/3/24 3:00 | 65.3 | 44.3 | 23.9 | 23.0 |
| 2011/3/24 4:00 | 68.0 | 44.6 | 23.3 | 23.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/3/24 5:00 | 71.4 | 45.1 | 24.1 | 23.5 |
| 2011/3/24 6:00 | 73.5 | 45.4 | 24.2 | 24.0 |
| 2011/3/24 7:00 | 76.4 | 45.7 | 24.3 | 24.0 |
| 2011/3/24 8:00 | 79.2 | 46.1 | 24.3 | 24.5 |
| 2011/3/24 9:00 | 81.7 | 46.4 | 24.3 | 25.0 |
| 2011/3/24 10:00 | 84.3 | 46.9 | 24.4 | 25.5 |
| 2011/3/24 11:00 | 86.8 | 47.2 | 24.4 | 26.0 |
| 2011/3/24 12:00 | 89.2 | 47.5 | 23.8 | 26.5 |
| 2011/3/24 13:00 | 92.0 | 47.7 | 22.3 | 27.0 |
| 2011/3/24 14:00 | 94.5 | 48.1 | 21.5 | 27.0 |
| 2011/3/24 15:00 | 96.5 | 48.4 | 21.2 | 27.5 |
| 2011/3/24 16:00 | 97.8 | 48.7 | 20.8 | 28.0 |
| 2011/3/24 17:00 | 82.7 | 49.0 | 21.3 | 28.5 |
| 2011/3/24 18:00 | 72.0 | 49.4 | 30.5 | 29.0 |
| 2011/3/24 19:00 | 61.4 | 49.8 | 31.8 | 28.5 |
| 2011/3/24 20:00 | 55.9 | 50.1 | 33.3 | 26.5 |
| 2011/3/24 21:00 | 52.0 | 50.3 | 34.5 | 26.0 |
| 2011/3/24 22:00 | 47.8 | 50.6 | 35.9 | 25.0 |
| 2011/3/24 23:00 | 44.8 | 50.9 | 37.1 | 24.0 |
| 2011/3/25 0:00 | 48.8 | 51.1 | 39.4 | 23.0 |
| 2011/3/25 1:00 | 51.4 | 50.9 | 42.3 | 22.5 |
| 2011/3/25 2:00 | 54.3 | 50.6 | 44.0 | 22.0 |
| 2011/3/25 3:00 | 57.3 | 50.2 | 45.5 | 21.5 |
| 2011/3/25 4:00 | 59.9 | 49.4 | 46.8 | 21.0 |
| 2011/3/25 5:00 | 62.8 | 45.2 | 48.4 | 20.5 |
| 2011/3/25 6:00 | 65.8 | 43.4 | 50.2 | 20.5 |
| 2011/3/25 7:00 | 68.9 | 42.6 | 52.0 | 20.0 |
| 2011/3/25 8:00 | 71.2 | 42.1 | 53.5 | 20.0 |
| 2011/3/25 9:00 | 74.3 | 40.9 | 55.5 | 20.0 |
| 2011/3/25 10:00 | 77.0 | 39.5 | 57.4 | 19.5 |
| 2011/3/25 11:00 | 79.4 | 38.3 | 44.0 | 19.5 |
| 2011/3/25 12:00 | 82.0 | 37.5 | 39.0 | 20.0 |
| 2011/3/25 13:00 | 66.0 | 37.1 | 33.9 | 20.5 |
| 2011/3/25 14:00 | 59.1 | 37.0 | 30.4 | 20.5 |
| 2011/3/25 15:00 | 53.9 | 36.9 | 29.9 | 21.0 |
| 2011/3/25 16:00 | 49.8 | 37.2 | 32.5 | 21.5 |
| 2011/3/25 17:00 | 46.4 | 37.5 | 29.4 | 22.0 |
| 2011/3/25 18:00 | 43.2 | 37.9 | 26.9 | 22.0 |
| 2011/3/25 19:00 | 40.7 | 38.3 | 25.2 | 22.5 |
| 2011/3/25 20:00 | 38.6 | 38.8 | 23.8 | 23.0 |
| 2011/3/25 21:00 | 37.1 | 39.0 | 22.9 | 23.5 |
| 2011/3/25 22:00 | 35.5 | 39.4 | 23.0 | 23.5 |
| 2011/3/25 23:00 | 34.5 | 39.8 | 27.6 | 24.0 |
| 2011/3/26 0:00 | 33.6 | 40.1 | 27.3 | 24.5 |
| 2011/3/26 1:00 | 32.8 | 40.5 | 26.2 | 24.5 |
| 2011/3/26 2:00 | 32.1 | 40.9 | 25.0 | 25.0 |
| 2011/3/26 3:00 | 31.6 | 41.2 | 24.1 | 25.5 |
| 2011/3/26 4:00 | 31.1 | 41.6 | 23.2 | 26.0 |
| 2011/3/26 5:00 | 30.6 | 42.0 | 22.6 | 26.5 |
| 2011/3/26 6:00 | 30.3 | 42.3 | 22.1 | 27.0 |
| 2011/3/26 7:00 | 30.0 | 42.9 | 21.7 | 27.5 |
| 2011/3/26 8:00 | 29.7 | 43.0 | 21.4 | 28.0 |
| 2011/3/26 9:00 | 29.4 | 43.4 | 21.3 | 28.0 |
| 2011/3/26 10:00 | 34.3 | 43.8 | 21.4 | 29.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/3/26 11:00 | 36.5 | 43.7 | 21.3 | 29.0 |
| 2011/3/26 12:00 | 39.7 | 43.5 | 21.4 | 29.5 |
| 2011/3/26 13:00 | 44.2 | 43.2 | 21.3 | 29.5 |
| 2011/3/26 14:00 | 43.8 | 42.8 | 21.3 | 30.0 |
| 2011/3/26 15:00 | 47.6 | 39.5 | 21.4 | 30.0 |
| 2011/3/26 16:00 | 49.6 | 38.6 | 21.4 | 30.5 |
| 2011/3/26 17:00 | 52.7 | 38.1 | 21.4 | 30.5 |
| 2011/3/26 18:00 | 55.1 | 37.7 | 29.4 | 31.0 |
| 2011/3/26 19:00 | 58.0 | 36.7 | 30.6 | 31.0 |
| 2011/3/26 20:00 | 61.2 | 35.6 | 32.1 | 29.5 |
| 2011/3/26 21:00 | 63.4 | 34.8 | 33.3 | 28.5 |
| 2011/3/26 22:00 | 66.2 | 34.1 | 34.8 | 27.0 |
| 2011/3/26 23:00 | 68.8 | 33.6 | 36.6 | 26.0 |
| 2011/3/27 0:00 | 57.8 | 33.2 | 39.3 | 25.0 |
| 2011/3/27 1:00 | 52.5 | 33.0 | 41.2 | 24.0 |
| 2011/3/27 2:00 | 48.0 | 33.2 | 42.9 | 23.5 |
| 2011/3/27 3:00 | 44.9 | 33.4 | 44.4 | 23.0 |
| 2011/3/27 4:00 | 41.6 | 33.9 | 46.3 | 22.0 |
| 2011/3/27 5:00 | 39.6 | 34.2 | 47.8 | 21.0 |
| 2011/3/27 6:00 | 37.6 | 34.6 | 49.4 | 20.5 |
| 2011/3/27 7:00 | 36.1 | 34.9 | 51.2 | 20.5 |
| 2011/3/27 8:00 | 34.8 | 35.3 | 53.2 | 20.5 |
| 2011/3/27 9:00 | 33.3 | 35.8 | 55.8 | 20.0 |
| 2011/3/27 10:00 | 32.6 | 36.1 | 57.1 | 20.0 |
| 2011/3/27 11:00 | 31.9 | 36.5 | 43.9 | 20.0 |
| 2011/3/27 12:00 | 31.3 | 36.8 | 38.0 | 20.0 |
| 2011/3/27 13:00 | 30.7 | 37.4 | 32.6 | 21.0 |
| 2011/3/27 14:00 | 30.3 | 37.8 | 29.1 | 21.0 |
| 2011/3/27 15:00 | 30.0 | 38.0 | 27.7 | 21.5 |
| 2011/3/27 16:00 | 29.7 | 38.4 | 25.8 | 22.0 |
| 2011/3/27 17:00 | 29.5 | 38.8 | 24.9 | 22.5 |
| 2011/3/27 18:00 | 29.3 | 39.1 | 24.3 | 22.5 |
| 2011/3/27 19:00 | 29.1 | 39.5 | 23.8 | 23.0 |
| 2011/3/27 20:00 | 28.9 | 39.9 | 23.3 | 24.0 |
| 2011/3/27 21:00 | 32.7 | 40.2 | 23.1 | 24.0 |
| 2011/3/27 22:00 | 35.3 | 40.2 | 22.8 | 24.0 |
| 2011/3/27 23:00 | 38.1 | 40.0 | 22.6 | 24.5 |
| 2011/3/28 0:00 | 39.9 | 39.9 | 22.5 | 25.0 |
| 2011/3/28 1:00 | 43.1 | 39.7 | 22.3 | 25.5 |
| 2011/3/28 2:00 | 46.1 | 37.5 | 22.2 | 26.0 |
| 2011/3/28 3:00 | 49.5 | 36.0 | 22.0 | 26.5 |
| 2011/3/28 4:00 | 51.9 | 35.5 | 22.0 | 26.5 |
| 2011/3/28 5:00 | 54.9 | 35.1 | 22.0 | 27.0 |
| 2011/3/28 6:00 | 57.7 | 34.5 | 21.9 | 27.5 |
| 2011/3/28 7:00 | 60.4 | 33.7 | 22.0 | 28.0 |
| 2011/3/28 8:00 | 63.5 | 32.9 | 22.1 | 28.0 |
| 2011/3/28 9:00 | 66.4 | 32.3 | 22.2 | 28.5 |
| 2011/3/28 10:00 | 68.5 | 31.7 | 22.3 | 29.0 |
| 2011/3/28 11:00 | 71.3 | 31.2 | 22.4 | 29.5 |
| 2011/3/28 12:00 | 60.1 | 30.9 | 22.4 | 30.0 |
| 2011/3/28 13:00 | 55.4 | 30.7 | 22.4 | 30.0 |
| 2011/3/28 14:00 | 50.6 | 30.9 | 22.3 | 30.5 |
| 2011/3/28 15:00 | 47.1 | 31.3 | 22.3 | 30.5 |
| 2011/3/28 16:00 | 44.3 | 31.6 | 22.4 | 31.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/3/28 17:00 | 41.4 | 32.1 | 22.4 | 31.5 |
| 2011/3/28 18:00 | 39.5 | 32.5 | 22.4 | 32.0 |
| 2011/3/28 19:00 | 37.8 | 32.8 | 29.1 | 32.0 |
| 2011/3/28 20:00 | 36.4 | 33.3 | 30.3 | 31.0 |
| 2011/3/28 21:00 | 35.1 | 33.7 | 32.0 | 29.0 |
| 2011/3/28 22:00 | 34.2 | 33.9 | 33.7 | 28.5 |
| 2011/3/28 23:00 | 33.2 | 34.4 | 35.8 | 27.0 |
| 2011/3/29 0:00 | 32.5 | 34.8 | 38.4 | 26.0 |
| 2011/3/29 1:00 | 32.0 | 35.1 | 40.0 | 25.0 |
| 2011/3/29 2:00 | 31.4 | 35.5 | 41.7 | 24.5 |
| 2011/3/29 3:00 | 30.9 | 35.9 | 43.4 | 24.0 |
| 2011/3/29 4:00 | 30.4 | 36.3 | 45.3 | 23.0 |
| 2011/3/29 5:00 | 30.1 | 36.8 | 47.2 | 22.5 |
| 2011/3/29 6:00 | 29.8 | 37.1 | 48.9 | 22.0 |
| 2011/3/29 7:00 | 29.0 | 37.4 | 50.9 | 21.5 |
| 2011/3/29 8:00 | 29.3 | 37.8 | 53.1 | 21.0 |
| 2011/3/29 9:00 | 29.1 | 38.3 | 55.3 | 20.5 |
| 2011/3/29 10:00 | 29.0 | 38.5 | 56.9 | 20.5 |
| 2011/3/29 11:00 | 32.5 | 38.9 | 43.6 | 20.5 |
| 2011/3/29 12:00 | 35.0 | 38.8 | 37.7 | 21.0 |
| 2011/3/29 13:00 | 37.5 | 38.8 | 33.5 | 21.0 |
| 2011/3/29 14:00 | 40.5 | 38.6 | 30.3 | 21.5 |
| 2011/3/29 15:00 | 43.4 | 38.4 | 28.9 | 22.0 |
| 2011/3/29 16:00 | 46.3 | 37.5 | 30.1 | 22.5 |
| 2011/3/29 17:00 | 48.9 | 35.5 | 28.5 | 22.5 |
| 2011/3/29 18:00 | 51.8 | 34.5 | 27.1 | 23.0 |
| 2011/3/29 19:00 | 54.2 | 34.2 | 26.1 | 23.5 |
| 2011/3/29 20:00 | 57.1 | 33.9 | 25.1 | 24.0 |
| 2011/3/29 21:00 | 59.6 | 33.4 | 24.4 | 24.5 |
| 2011/3/29 22:00 | 54.8 | 32.6 | 23.8 | 24.5 |
| 2011/3/29 23:00 | 51.2 | 32.4 | 23.3 | 25.0 |
| 2011/3/30 0:00 | 49.8 | 32.1 | 22.9 | 25.5 |
| 2011/3/30 1:00 | 46.8 | 32.4 | 22.6 | 26.0 |
| 2011/3/30 2:00 | 43.7 | 32.7 | 22.2 | 26.5 |
| 2011/3/30 3:00 | 41.7 | 33.0 | 22.1 | 27.0 |
| 2011/3/30 4:00 | 37.4 | 33.4 | 21.8 | 27.0 |
| 2011/3/30 5:00 | 35.9 | 33.7 | 21.7 | 27.5 |
| 2011/3/30 6:00 | 34.7 | 34.2 | 21.6 | 28.0 |
| 2011/3/30 7:00 | 33.7 | 34.5 | 21.5 | 28.5 |
| 2011/3/30 8:00 | 32.8 | 34.9 | 21.4 | 28.5 |
| 2011/3/30 9:00 | 32.0 | 35.3 | 21.3 | 29.0 |
| 2011/3/30 10:00 | 31.5 | 35.7 | 27.2 | 29.0 |
| 2011/3/30 11:00 | 31.0 | 36.1 | 28.2 | 29.5 |
| 2011/3/30 12:00 | 30.6 | 36.5 | 29.5 | 29.5 |
| 2011/3/30 13:00 | 30.2 | 36.8 | 30.9 | 27.0 |
| 2011/3/30 14:00 | 29.9 | 37.2 | 32.6 | 26.5 |
| 2011/3/30 15:00 | 29.7 | 37.5 | 34.7 | 25.5 |
| 2011/3/30 16:00 | 29.4 | 37.9 | 37.6 | 24.5 |
| 2011/3/30 17:00 | 29.3 | 38.3 | 39.2 | 23.5 |
| 2011/3/30 18:00 | 29.2 | 38.7 | 40.9 | 23.0 |
| 2011/3/30 19:00 | 31.6 | 39.0 | 42.5 | 22.5 |
| 2011/3/30 20:00 | 33.7 | 39.0 | 44.2 | 22.0 |
| 2011/3/30 21:00 | 38.3 | 38.8 | 47.0 | 21.5 |
| 2011/3/30 22:00 | 39.4 | 38.8 | 47.8 | 21.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/3/30 23:00 | 42.3 | 38.5 | 37.2 | 21.0 |
| 2011/3/31 0:00 | 45.4 | 37.2 | 32.7 | 21.5 |
| 2011/3/31 1:00 | 48.2 | 35.6 | 29.6 | 22.0 |
| 2011/3/31 2:00 | 51.0 | 34.6 | 27.1 | 22.5 |
| 2011/3/31 3:00 | 53.9 | 34.2 | 25.4 | 22.5 |
| 2011/3/31 4:00 | 56.3 | 33.9 | 26.9 | 23.0 |
| 2011/3/31 5:00 | 58.7 | 33.3 | 27.7 | 23.0 |
| 2011/3/31 6:00 | 61.9 | 32.4 | 26.0 | 24.0 |
| 2011/3/31 7:00 | 64.8 | 31.7 | 24.8 | 24.5 |
| 2011/3/31 8:00 | 67.4 | 31.2 | 23.8 | 25.0 |
| 2011/3/31 9:00 | 69.4 | 30.8 | 23.3 | 25.0 |
| 2011/3/31 10:00 | 71.4 | 30.4 | 22.9 | 25.5 |
| 2011/3/31 11:00 | 62.4 | 30.0 | 22.3 | 26.0 |
| 2011/3/31 12:00 | 56.8 | 29.9 | 22.0 | 26.5 |
| 2011/3/31 13:00 | 51.8 | 30.2 | 21.7 | 27.0 |
| 2011/3/31 14:00 | 47.4 | 30.6 | 21.4 | 27.0 |
| 2011/3/31 15:00 | 44.4 | 30.9 | 21.3 | 27.5 |
| 2011/3/31 16:00 | 41.8 | 31.2 | 21.2 | 28.0 |
| 2011/3/31 17:00 | 41.7 | 31.7 | 21.1 | 28.5 |
| 2011/3/31 18:00 | 37.7 | 32.0 | 21.1 | 29.0 |
| 2011/3/31 19:00 | 36.3 | 32.4 | 21.1 | 29.0 |
| 2011/3/31 20:00 | 34.9 | 33.0 | 26.9 | 29.5 |
| 2011/3/31 21:00 | 34.0 | 33.3 | 27.6 | 29.0 |
| 2011/3/31 22:00 | 33.3 | 33.6 | 28.8 | 29.0 |
| 2011/3/31 23:00 | 32.4 | 34.0 | 31.1 | 27.0 |
| 2011/4/1 0:00 | 31.9 | 34.3 | 32.7 | 26.0 |
| 2011/4/1 1:00 | 31.4 | 34.7 | 34.8 | 25.0 |
| 2011/4/1 2:00 | 30.9 | 35.1 | 37.4 | 24.0 |
| 2011/4/1 3:00 | 30.6 | 35.5 | 39.1 | 23.5 |
| 2011/4/1 4:00 | 30.3 | 35.8 | 40.6 | 23.0 |
| 2011/4/1 5:00 | 30.0 | 36.2 | 42.2 | 22.5 |
| 2011/4/1 6:00 | 29.8 | 36.6 | 44.1 | 22.0 |
| 2011/4/1 7:00 | 29.6 | 37.0 | 45.8 | 21.0 |
| 2011/4/1 8:00 | 29.5 | 37.3 | 47.9 | 20.5 |
| 2011/4/1 9:00 | 29.3 | 37.8 | 50.1 | 20.5 |
| 2011/4/1 10:00 | 29.2 | 38.2 | 51.8 | 20.0 |
| 2011/4/1 11:00 | 32.1 | 38.2 | 53.7 | 20.0 |
| 2011/4/1 12:00 | 34.5 | 38.4 | 44.7 | 20.0 |
| 2011/4/1 13:00 | 37.8 | 38.2 | 37.9 | 20.5 |
| 2011/4/1 14:00 | 40.9 | 38.1 | 33.3 | 21.0 |
| 2011/4/1 15:00 | 44.2 | 37.8 | 29.8 | 21.0 |
| 2011/4/1 16:00 | 46.7 | 35.9 | 27.7 | 21.5 |
| 2011/4/1 17:00 | 49.5 | 34.8 | 26.0 | 22.0 |
| 2011/4/1 18:00 | 52.3 | 34.4 | 24.6 | 22.5 |
| 2011/4/1 19:00 | 55.0 | 34.0 | 23.5 | 22.5 |
| 2011/4/1 20:00 | 57.5 | 33.6 | 22.4 | 23.0 |
| 2011/4/1 21:00 | 61.2 | 32.6 | 21.9 | 23.5 |
| 2011/4/1 22:00 | 63.1 | 32.1 | 22.0 | 24.0 |
| 2011/4/1 23:00 | 52.2 | 31.9 | 22.1 | 24.5 |
| 2011/4/2 0:00 | 48.5 | 32.0 | 22.1 | 24.5 |
| 2011/4/2 1:00 | 45.2 | 32.3 | 22.0 | 25.0 |
| 2011/4/2 2:00 | 42.4 | 32.6 | 22.0 | 25.5 |
| 2011/4/2 3:00 | 40.0 | 33.0 | 21.9 | 26.0 |
| 2011/4/2 4:00 | 38.0 | 33.3 | 21.8 | 26.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/2 5:00 | 36.7 | 33.7 | 21.7 | 26.5 |
| 2011/4/2 6:00 | 35.5 | 34.1 | 21.6 | 27.0 |
| 2011/4/2 7:00 | 34.4 | 34.5 | 21.5 | 27.5 |
| 2011/4/2 8:00 | 33.5 | 34.8 | 21.5 | 28.0 |
| 2011/4/2 9:00 | 32.6 | 35.4 | 21.5 | 28.5 |
| 2011/4/2 10:00 | 32.0 | 35.7 | 21.5 | 28.5 |
| 2011/4/2 11:00 | 31.5 | 36.0 | 27.4 | 28.5 |
| 2011/4/2 12:00 | 31.1 | 36.4 | 28.6 | 28.0 |
| 2011/4/2 13:00 | 30.7 | 36.8 | 30.0 | 26.5 |
| 2011/4/2 14:00 | 30.4 | 37.1 | 31.8 | 25.5 |
| 2011/4/2 15:00 | 30.1 | 37.5 | 33.8 | 24.5 |
| 2011/4/2 16:00 | 29.8 | 37.9 | 36.2 | 24.0 |
| 2011/4/2 17:00 | 29.6 | 38.2 | 38.0 | 23.0 |
| 2011/4/2 18:00 | 31.4 | 38.5 | 39.5 | 22.5 |
| 2011/4/2 19:00 | 34.5 | 38.5 | 31.2 | 22.5 |
| 2011/4/2 20:00 | 37.2 | 38.3 | 28.6 | 23.0 |
| 2011/4/2 21:00 | 41.0 | 37.0 | 25.9 | 23.5 |
| 2011/4/2 22:00 | 43.5 | 35.9 | 24.6 | 24.0 |
| 2011/4/2 23:00 | 46.6 | 35.2 | 23.3 | 24.5 |
| 2011/4/3 0:00 | 49.3 | 34.8 | 23.5 | 24.5 |
| 2011/4/3 1:00 | 52.3 | 33.9 | 23.7 | 25.0 |
| 2011/4/3 2:00 | 54.8 | 33.3 | 23.1 | 25.5 |
| 2011/4/3 3:00 | 57.7 | 32.7 | 23.6 | 26.0 |
| 2011/4/3 4:00 | 60.8 | 32.0 | 23.4 | 26.5 |
| 2011/4/3 5:00 | 63.0 | 31.6 | 23.2 | 26.5 |
| 2011/4/3 6:00 | 65.5 | 31.0 | 23.2 | 27.0 |
| 2011/4/3 7:00 | 68.3 | 30.6 | 23.1 | 27.5 |
| 2011/4/3 8:00 | 70.7 | 30.2 | 23.0 | 28.0 |
| 2011/4/3 9:00 | 73.4 | 29.6 | 22.9 | 28.5 |
| 2011/4/3 10:00 | 75.6 | 29.3 | 22.8 | 29.0 |
| 2011/4/3 11:00 | 62.9 | 29.1 | 22.8 | 29.0 |
| 2011/4/3 12:00 | 56.7 | 29.3 | 22.8 | 29.5 |
| 2011/4/3 13:00 | 51.5 | 29.7 | 22.7 | 29.5 |
| 2011/4/3 14:00 | 47.6 | 30.1 | 22.8 | 30.0 |
| 2011/4/3 15:00 | 44.4 | 30.4 | 22.8 | 30.0 |
| 2011/4/3 16:00 | 41.8 | 30.9 | 22.7 | 30.5 |
| 2011/4/3 17:00 | 39.7 | 31.2 | 22.7 | 31.0 |
| 2011/4/3 18:00 | 37.9 | 31.6 | 27.1 | 31.0 |
| 2011/4/3 19:00 | 36.2 | 32.0 | 27.8 | 31.0 |
| 2011/4/3 20:00 | 34.9 | 32.3 | 29.3 | 30.0 |
| 2011/4/3 21:00 | 34.0 | 32.8 | 31.1 | 29.0 |
| 2011/4/3 22:00 | 32.9 | 33.2 | 33.7 | 27.0 |
| 2011/4/3 23:00 | 32.4 | 33.6 | 35.5 | 26.5 |
| 2011/4/4 0:00 | 31.9 | 33.9 | 37.3 | 25.5 |
| 2011/4/4 1:00 | 31.4 | 34.2 | 38.9 | 25.0 |
| 2011/4/4 2:00 | 31.0 | 34.6 | 40.7 | 24.0 |
| 2011/4/4 3:00 | 30.7 | 35.0 | 42.2 | 23.5 |
| 2011/4/4 4:00 | 30.4 | 35.4 | 44.0 | 23.0 |
| 2011/4/4 5:00 | 30.1 | 35.7 | 46.0 | 22.5 |
| 2011/4/4 6:00 | 29.9 | 36.1 | 48.0 | 21.5 |
| 2011/4/4 7:00 | 29.6 | 36.5 | 50.2 | 21.0 |
| 2011/4/4 8:00 | 29.6 | 36.8 | 51.6 | 21.0 |
| 2011/4/4 9:00 | 29.4 | 37.2 | 53.4 | 20.5 |
| 2011/4/4 10:00 | 32.3 | 37.4 | 55.5 | 20.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/4 11:00 | 35.3 | 37.2 | 42.6 | 20.5 |
| 2011/4/4 12:00 | 38.5 | 37.1 | 37.6 | 21.0 |
| 2011/4/4 13:00 | 41.5 | 35.6 | 33.4 | 21.0 |
| 2011/4/4 14:00 | 44.4 | 34.6 | 30.1 | 21.5 |
| 2011/4/4 15:00 | 47.3 | 34.2 | 27.7 | 22.0 |
| 2011/4/4 16:00 | 50.2 | 33.6 | 25.9 | 22.5 |
| 2011/4/4 17:00 | 52.9 | 32.9 | 24.5 | 23.0 |
| 2011/4/4 18:00 | 55.5 | 32.4 | 25.2 | 23.5 |
| 2011/4/4 19:00 | 58.1 | 31.9 | 25.5 | 23.5 |
| 2011/4/4 20:00 | 48.7 | 31.5 | 24.9 | 24.0 |
| 2011/4/4 21:00 | 45.0 | 31.8 | 24.2 | 24.5 |
| 2011/4/4 22:00 | 42.3 | 32.2 | 23.8 | 25.0 |
| 2011/4/4 23:00 | 40.1 | 32.5 | 23.4 | 25.0 |
| 2011/4/5 0:00 | 38.2 | 33.0 | 23.0 | 25.5 |
| 2011/4/5 1:00 | 38.5 | 33.2 | 22.7 | 26.0 |
| 2011/4/5 2:00 | 37.3 | 33.6 | 22.7 | 26.5 |
| 2011/4/5 3:00 | 36.0 | 34.0 | 22.7 | 27.0 |
| 2011/4/5 4:00 | 35.0 | 34.3 | 22.7 | 27.0 |
| 2011/4/5 5:00 | 34.3 | 34.7 | 22.6 | 27.5 |
| 2011/4/5 6:00 | 33.3 | 35.2 | 22.6 | 28.0 |
| 2011/4/5 7:00 | 32.8 | 35.5 | 22.5 | 28.5 |
| 2011/4/5 8:00 | 31.1 | 35.8 | 22.5 | 29.0 |
| 2011/4/5 9:00 | 30.8 | 36.2 | 22.5 | 29.0 |
| 2011/4/5 10:00 | 32.6 | 36.4 | 26.9 | 29.5 |
| 2011/4/5 11:00 | 36.0 | 36.3 | 27.8 | 29.0 |
| 2011/4/5 12:00 | 39.4 | 36.1 | 29.2 | 28.5 |
| 2011/4/5 13:00 | 42.4 | 34.8 | 30.9 | 27.5 |
| 2011/4/5 14:00 | 45.4 | 34.0 | 32.9 | 26.5 |
| 2011/4/5 15:00 | 48.0 | 33.6 | 34.8 | 26.0 |
| 2011/4/5 16:00 | 51.0 | 33.0 | 37.2 | 25.0 |
| 2011/4/5 17:00 | 53.8 | 32.4 | 38.8 | 24.5 |
| 2011/4/5 18:00 | 56.4 | 31.9 | 40.3 | 24.0 |
| 2011/4/5 19:00 | 59.0 | 31.4 | 42.0 | 23.5 |
| 2011/4/5 20:00 | 49.9 | 31.1 | 44.0 | 23.0 |
| 2011/4/5 21:00 | 48.9 | 31.4 | 34.2 | 23.0 |
| 2011/4/5 22:00 | 43.3 | 31.7 | 31.2 | 23.0 |
| 2011/4/5 23:00 | 41.2 | 32.2 | 28.7 | 23.5 |
| 2011/4/6 0:00 | 39.1 | 32.5 | 26.7 | 24.0 |
| 2011/4/6 1:00 | 37.6 | 32.9 | 26.2 | 24.0 |
| 2011/4/6 2:00 | 36.1 | 33.2 | 25.6 | 25.0 |
| 2011/4/6 3:00 | 35.1 | 33.6 | 25.2 | 25.5 |
| 2011/4/6 4:00 | 34.1 | 33.9 | 24.4 | 26.0 |
| 2011/4/6 5:00 | 33.3 | 34.4 | 23.6 | 26.0 |
| 2011/4/6 6:00 | 32.6 | 34.8 | 22.9 | 26.5 |
| 2011/4/6 7:00 | 32.1 | 35.1 | 22.5 | 26.5 |
| 2011/4/6 8:00 | 31.6 | 35.5 | 22.0 | 27.0 |
| 2011/4/6 9:00 | 31.2 | 35.9 | 21.8 | 28.0 |
| 2011/4/6 10:00 | 33.0 | 36.2 | 21.5 | 28.5 |
| 2011/4/6 11:00 | 37.0 | 36.1 | 21.3 | 28.5 |
| 2011/4/6 12:00 | 39.0 | 36.0 | 21.2 | 29.0 |
| 2011/4/6 13:00 | 42.3 | 35.2 | 21.1 | 29.5 |
| 2011/4/6 14:00 | 45.1 | 34.1 | 21.1 | 29.5 |
| 2011/4/6 15:00 | 47.8 | 33.6 | 21.1 | 30.0 |
| 2011/4/6 16:00 | 50.4 | 33.2 | 21.1 | 30.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/6 17:00 | 53.3 | 32.5 | 21.1 | 30.5 |
| 2011/4/6 18:00 | 56.0 | 31.9 | 26.5 | 30.5 |
| 2011/4/6 19:00 | 58.5 | 31.5 | 27.7 | 30.0 |
| 2011/4/6 20:00 | 49.8 | 31.3 | 29.4 | 28.0 |
| 2011/4/6 21:00 | 46.2 | 31.5 | 31.2 | 27.5 |
| 2011/4/6 22:00 | 43.4 | 31.8 | 33.1 | 26.5 |
| 2011/4/6 23:00 | 43.1 | 32.2 | 36.0 | 26.0 |
| 2011/4/7 0:00 | 39.4 | 32.5 | 37.2 | 25.0 |
| 2011/4/7 1:00 | 37.7 | 32.9 | 38.9 | 24.0 |
| 2011/4/7 2:00 | 36.4 | 33.3 | 40.6 | 23.5 |
| 2011/4/7 3:00 | 35.0 | 33.8 | 42.7 | 23.0 |
| 2011/4/7 4:00 | 34.2 | 34.1 | 44.3 | 22.5 |
| 2011/4/7 5:00 | 34.4 | 34.4 | 46.3 | 22.0 |
| 2011/4/7 6:00 | 34.8 | 34.8 | 48.1 | 21.5 |
| 2011/4/7 7:00 | 32.3 | 35.3 | 50.0 | 21.0 |
| 2011/4/7 8:00 | 31.8 | 35.6 | 51.7 | 21.0 |
| 2011/4/7 9:00 | 32.3 | 35.8 | 53.6 | 20.5 |
| 2011/4/7 10:00 | 32.8 | 36.2 | 55.4 | 20.0 |
| 2011/4/7 11:00 | 36.0 | 36.1 | 42.0 | 20.5 |
| 2011/4/7 12:00 | 39.1 | 36.0 | 37.1 | 21.0 |
| 2011/4/7 13:00 | 42.5 | 35.1 | 33.3 | 21.5 |
| 2011/4/7 14:00 | 45.3 | 34.1 | 30.4 | 22.0 |
| 2011/4/7 15:00 | 48.1 | 33.6 | 28.2 | 22.0 |
| 2011/4/7 16:00 | 50.8 | 33.2 | 26.6 | 22.5 |
| 2011/4/7 17:00 | 53.4 | 32.7 | 25.4 | 23.0 |
| 2011/4/7 18:00 | 56.0 | 32.2 | 24.3 | 23.5 |
| 2011/4/7 19:00 | 58.7 | 31.6 | 23.5 | 24.0 |
| 2011/4/7 20:00 | 50.3 | 31.2 | 22.8 | 24.0 |
| 2011/4/7 21:00 | 46.6 | 31.6 | 22.2 | 24.5 |
| 2011/4/7 22:00 | 43.9 | 31.9 | 21.8 | 25.0 |
| 2011/4/7 23:00 | 41.5 | 32.3 | 21.5 | 25.5 |
| 2011/4/8 0:00 | 39.6 | 32.7 | 21.2 | 26.0 |
| 2011/4/8 1:00 | 38.2 | 33.1 | 21.0 | 26.5 |
| 2011/4/8 2:00 | 36.8 | 33.4 | 20.8 | 26.5 |
| 2011/4/8 3:00 | 35.8 | 33.7 | 20.6 | 27.0 |
| 2011/4/8 4:00 | 34.8 | 34.2 | 21.2 | 26.5 |
| 2011/4/8 5:00 | 33.9 | 34.5 | 21.8 | 27.5 |
| 2011/4/8 6:00 | 33.2 | 34.8 | 22.1 | 28.0 |
| 2011/4/8 7:00 | 32.6 | 35.2 | 22.1 | 28.5 |
| 2011/4/8 8:00 | 32.1 | 35.7 | 22.1 | 29.0 |
| 2011/4/8 9:00 | 31.7 | 36.0 | 22.2 | 29.0 |
| 2011/4/8 10:00 | 33.3 | 36.3 | 22.2 | 29.5 |
| 2011/4/8 11:00 | 37.2 | 36.5 | 22.2 | 30.0 |
| 2011/4/8 12:00 | 39.7 | 36.3 | 22.5 | 30.0 |
| 2011/4/8 13:00 | 42.5 | 36.1 | 22.6 | 30.5 |
| 2011/4/8 14:00 | 45.5 | 34.7 | 22.7 | 30.5 |
| 2011/4/8 15:00 | 49.7 | 33.9 | 22.7 | 31.0 |
| 2011/4/8 16:00 | 51.3 | 33.6 | 22.7 | 31.5 |
| 2011/4/8 17:00 | 54.0 | 33.2 | 22.8 | 32.0 |
| 2011/4/8 18:00 | 56.4 | 32.7 | 22.8 | 32.5 |
| 2011/4/8 19:00 | 59.5 | 32.1 | 26.7 | 33.0 |
| 2011/4/8 20:00 | 52.1 | 31.8 | 27.6 | 33.0 |
| 2011/4/8 21:00 | 47.7 | 32.0 | 29.5 | 31.5 |
| 2011/4/8 22:00 | 45.6 | 32.2 | 30.8 | 30.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/8 23:00 | 43.2 | 32.5 | 32.7 | 29.5 |
| 2011/4/9 0:00 | 41.2 | 33.0 | 34.8 | 28.5 |
| 2011/4/9 1:00 | 39.2 | 33.3 | 37.1 | 28.0 |
| 2011/4/9 2:00 | 37.8 | 33.7 | 38.7 | 27.0 |
| 2011/4/9 3:00 | 36.5 | 34.2 | 40.4 | 26.0 |
| 2011/4/9 4:00 | 35.5 | 34.4 | 42.1 | 25.0 |
| 2011/4/9 5:00 | 34.6 | 34.8 | 44.0 | 24.0 |
| 2011/4/9 6:00 | 33.8 | 35.2 | 45.9 | 24.0 |
| 2011/4/9 7:00 | 33.2 | 35.6 | 47.7 | 23.0 |
| 2011/4/9 8:00 | 32.6 | 35.9 | 49.7 | 22.5 |
| 2011/4/9 9:00 | 31.8 | 36.3 | 51.4 | 22.5 |
| 2011/4/9 10:00 | 31.4 | 36.7 | 53.2 | 22.0 |
| 2011/4/9 11:00 | 35.6 | 36.6 | 42.6 | 22.0 |
| 2011/4/9 12:00 | 38.4 | 36.4 | 37.4 | 22.5 |
| 2011/4/9 13:00 | 41.3 | 36.0 | 33.3 | 22.5 |
| 2011/4/9 14:00 | 43.8 | 34.7 | 30.5 | 23.0 |
| 2011/4/9 15:00 | 47.0 | 34.1 | 27.8 | 23.5 |
| 2011/4/9 16:00 | 49.6 | 33.7 | 26.1 | 24.0 |
| 2011/4/9 17:00 | 51.9 | 33.0 | 24.9 | 24.0 |
| 2011/4/9 18:00 | 54.3 | 32.6 | 23.9 | 24.5 |
| 2011/4/9 19:00 | 56.9 | 32.1 | 23.0 | 24.5 |
| 2011/4/9 20:00 | 50.9 | 31.8 | 23.1 | 25.0 |
| 2011/4/9 21:00 | 46.2 | 32.1 | 22.9 | 26.0 |
| 2011/4/9 22:00 | 44.8 | 32.2 | 22.9 | 26.0 |
| 2011/4/9 23:00 | 42.4 | 32.7 | 22.8 | 26.5 |
| 2011/4/10 0:00 | 40.4 | 32.9 | 22.6 | 27.0 |
| 2011/4/10 1:00 | 38.8 | 33.3 | 22.6 | 27.5 |
| 2011/4/10 2:00 | 37.4 | 33.7 | 22.6 | 28.0 |
| 2011/4/10 3:00 | 36.2 | 34.0 | 22.4 | 28.0 |
| 2011/4/10 4:00 | 35.2 | 34.4 | 22.4 | 28.5 |
| 2011/4/10 5:00 | 34.4 | 34.4 | 22.3 | 28.5 |
| 2011/4/10 6:00 | 33.6 | 35.2 | 22.3 | 29.0 |
| 2011/4/10 7:00 | 33.1 | 35.5 | 22.2 | 29.5 |
| 2011/4/10 8:00 | 32.4 | 36.0 | 22.2 | 30.0 |
| 2011/4/10 9:00 | 32.0 | 36.3 | 22.2 | 30.0 |
| 2011/4/10 10:00 | 33.6 | 36.5 | 22.2 | 30.5 |
| 2011/4/10 11:00 | 36.4 | 36.4 | 22.2 | 31.0 |
| 2011/4/10 12:00 | 39.3 | 36.3 | 22.2 | 31.5 |
| 2011/4/10 13:00 | 42.3 | 35.4 | 22.2 | 32.0 |
| 2011/4/10 14:00 | 44.9 | 34.4 | 22.2 | 32.0 |
| 2011/4/10 15:00 | 48.2 | 33.9 | 22.3 | 32.5 |
| 2011/4/10 16:00 | 50.5 | 33.4 | 22.5 | 33.0 |
| 2011/4/10 17:00 | 53.0 | 32.8 | 22.6 | 33.5 |
| 2011/4/10 18:00 | 55.0 | 32.5 | 22.6 | 34.0 |
| 2011/4/10 19:00 | 50.5 | 32.0 | 27.3 | 33.5 |
| 2011/4/10 20:00 | 47.8 | 32.2 | 28.3 | 33.5 |
| 2011/4/10 21:00 | 44.8 | 32.4 | 30.0 | 30.5 |
| 2011/4/10 22:00 | 42.4 | 32.8 | 31.9 | 29.5 |
| 2011/4/10 23:00 | 40.3 | 33.2 | 33.7 | 29.0 |
| 2011/4/11 0:00 | 38.7 | 33.5 | 35.9 | 28.0 |
| 2011/4/11 1:00 | 37.4 | 33.8 | 37.5 | 27.0 |
| 2011/4/11 2:00 | 36.3 | 34.2 | 38.9 | 26.5 |
| 2011/4/11 3:00 | 35.3 | 34.6 | 40.6 | 25.5 |
| 2011/4/11 4:00 | 34.5 | 35.0 | 42.3 | 25.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/11 5:00 | 33.8 | 35.3 | 44.1 | 24.0 |
| 2011/4/11 6:00 | 33.1 | 35.8 | 45.9 | 24.0 |
| 2011/4/11 7:00 | 32.8 | 36.1 | 47.4 | 23.0 |
| 2011/4/11 8:00 | 32.3 | 36.4 | 49.4 | 23.0 |
| 2011/4/11 9:00 | 31.8 | 36.8 | 51.2 | 22.5 |
| 2011/4/11 10:00 | 33.5 | 37.1 | 52.0 | 22.0 |
| 2011/4/11 11:00 | 36.6 | 37.1 | 41.5 | 22.5 |
| 2011/4/11 12:00 | 39.5 | 36.9 | 37.2 | 23.0 |
| 2011/4/11 13:00 | 42.6 | 36.3 | 33.4 | 23.0 |
| 2011/4/11 14:00 | 45.6 | 34.9 | 30.5 | 23.5 |
| 2011/4/11 15:00 | 48.3 | 34.4 | 28.4 | 24.0 |
| 2011/4/11 16:00 | 50.7 | 33.9 | 27.0 | 24.5 |
| 2011/4/11 17:00 | 53.3 | 33.4 | 25.7 | 24.5 |
| 2011/4/11 18:00 | 55.9 | 32.8 | 25.8 | 25.0 |
| 2011/4/11 19:00 | 58.9 | 32.3 | 25.7 | 25.5 |
| 2011/4/11 20:00 | 49.2 | 32.0 | 24.9 | 24.9 |
| 2011/4/11 21:00 | 47.4 | 32.2 | 24.7 | 26.0 |
| 2011/4/11 22:00 | 44.6 | 32.4 | 24.3 | 26.5 |
| 2011/4/11 23:00 | 41.5 | 33.0 | 23.8 | 27.0 |
| 2011/4/12 0:00 | 40.4 | 33.2 | 23.7 | 27.5 |
| 2011/4/12 1:00 | 38.8 | 33.6 | 23.5 | 28.0 |
| 2011/4/12 2:00 | 37.4 | 33.9 | 23.3 | 28.0 |
| 2011/4/12 3:00 | 36.3 | 34.2 | 23.2 | 28.5 |
| 2011/4/12 4:00 | 35.2 | 34.7 | 23.0 | 29.0 |
| 2011/4/12 5:00 | 34.4 | 35.0 | 22.9 | 29.5 |
| 2011/4/12 6:00 | 33.6 | 35.4 | 22.9 | 29.5 |
| 2011/4/12 7:00 | 33.1 | 35.7 | 22.7 | 30.0 |
| 2011/4/12 8:00 | 32.8 | 36.0 | 22.6 | 30.0 |
| 2011/4/12 9:00 | 32.1 | 36.4 | 22.6 | 30.5 |
| 2011/4/12 10:00 | 34.1 | 36.6 | 22.6 | 31.0 |
| 2011/4/12 11:00 | 37.3 | 36.5 | 22.6 | 31.5 |
| 2011/4/12 12:00 | 41.0 | 36.2 | 22.5 | 32.0 |
| 2011/4/12 13:00 | 43.5 | 35.8 | 22.5 | 32.0 |
| 2011/4/12 14:00 | 46.2 | 34.3 | 22.5 | 32.5 |
| 2011/4/12 15:00 | 48.7 | 34.0 | 22.5 | 33.0 |
| 2011/4/12 16:00 | 51.5 | 33.4 | 22.5 | 33.0 |
| 2011/4/12 17:00 | 54.0 | 32.8 | 22.6 | 33.5 |
| 2011/4/12 18:00 | 56.5 | 32.4 | 26.8 | 33.5 |
| 2011/4/12 19:00 | 59.1 | 32.0 | 27.8 | 33.5 |
| 2011/4/12 20:00 | 48.0 | 32.0 | 30.0 | 31.0 |
| 2011/4/12 21:00 | 46.6 | 32.0 | 31.1 | 30.0 |
| 2011/4/12 22:00 | 43.7 | 32.5 | 33.2 | 29.5 |
| 2011/4/12 23:00 | 41.5 | 32.7 | 35.5 | 29.0 |
| 2011/4/13 0:00 | 39.7 | 33.1 | 37.0 | 28.0 |
| 2011/4/13 1:00 | 37.9 | 33.6 | 38.9 | 27.0 |
| 2011/4/13 2:00 | 37.1 | 33.8 | 39.8 | 26.0 |
| 2011/4/13 3:00 | 36.0 | 34.2 | 41.4 | 25.0 |
| 2011/4/13 4:00 | 35.1 | 34.5 | 43.1 | 24.5 |
| 2011/4/13 5:00 | 34.2 | 34.9 | 45.1 | 24.0 |
| 2011/4/13 6:00 | 33.6 | 35.2 | 46.7 | 23.5 |
| 2011/4/13 7:00 | 32.9 | 35.6 | 48.6 | 23.0 |
| 2011/4/13 8:00 | 32.5 | 36.0 | 50.3 | 23.0 |
| 2011/4/13 9:00 | 32.0 | 36.3 | 51.9 | 22.5 |
| 2011/4/13 10:00 | 34.1 | 36.6 | 53.8 | 22.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/13 11:00 | 37.2 | 36.5 | 42.6 | 22.0 |
| 2011/4/13 12:00 | 40.2 | 36.2 | 38.0 | 22.5 |
| 2011/4/13 13:00 | 43.4 | 35.1 | 34.2 | 23.0 |
| 2011/4/13 14:00 | 46.1 | 34.4 | 31.6 | 23.5 |
| 2011/4/13 15:00 | 49.0 | 33.9 | 29.3 | 24.0 |
| 2011/4/13 16:00 | 51.4 | 33.3 | 27.9 | 24.0 |
| 2011/4/13 17:00 | 54.4 | 32.8 | 26.5 | 24.5 |
| 2011/4/13 18:00 | 57.1 | 32.4 | 26.3 | 25.0 |
| 2011/4/13 19:00 | 59.2 | 32.0 | 26.0 | 25.5 |
| 2011/4/13 20:00 | 48.9 | 32.0 | 25.6 | 26.0 |
| 2011/4/13 21:00 | 46.1 | 32.2 | 25.4 | 26.0 |
| 2011/4/13 22:00 | 43.2 | 32.5 | 25.1 | 26.5 |
| 2011/4/13 23:00 | 41.4 | 32.8 | 24.9 | 27.0 |
| 2011/4/14 0:00 | 39.6 | 33.1 | 24.7 | 27.5 |
| 2011/4/14 1:00 | 38.2 | 33.6 | 24.6 | 28.0 |
| 2011/4/14 2:00 | 36.8 | 33.9 | 24.4 | 28.5 |
| 2011/4/14 3:00 | 35.9 | 34.2 | 24.3 | 29.0 |
| 2011/4/14 4:00 | 35.0 | 34.6 | 24.2 | 29.0 |
| 2011/4/14 5:00 | 34.2 | 35.0 | 24.1 | 29.5 |
| 2011/4/14 6:00 | 33.5 | 35.3 | 24.1 | 29.5 |
| 2011/4/14 7:00 | 33.0 | 35.7 | 24.0 | 30.0 |
| 2011/4/14 8:00 | 32.6 | 36.1 | 24.0 | 30.0 |
| 2011/4/14 9:00 | 32.1 | 36.5 | 23.9 | 30.5 |
| 2011/4/14 10:00 | 35.4 | 36.7 | 23.9 | 31.0 |
| 2011/4/14 11:00 | 37.5 | 36.6 | 23.9 | 31.5 |
| 2011/4/14 12:00 | 40.3 | 36.4 | 23.9 | 32.0 |
| 2011/4/14 13:00 | 43.2 | 35.5 | 23.9 | 32.0 |
| 2011/4/14 14:00 | 46.0 | 34.7 | 23.9 | 32.5 |
| 2011/4/14 15:00 | 48.9 | 34.1 | 24.0 | 33.0 |
| 2011/4/14 16:00 | 51.3 | 33.6 | 24.1 | 33.0 |
| 2011/4/14 17:00 | 53.8 | 33.2 | 24.0 | 33.5 |
| 2011/4/14 18:00 | 56.3 | 32.7 | 23.8 | 34.0 |
| 2011/4/14 19:00 | 58.6 | 32.3 | 27.9 | 34.0 |
| 2011/4/14 20:00 | 48.9 | 32.3 | 29.2 | 34.0 |
| 2011/4/14 21:00 | 45.6 | 32.6 | 31.1 | 31.0 |
| 2011/4/14 22:00 | 43.1 | 32.9 | 33.1 | 30.0 |
| 2011/4/14 23:00 | 41.3 | 33.4 | 35.3 | 29.5 |
| 2011/4/15 0:00 | 39.9 | 33.7 | 36.7 | 29.0 |
| 2011/4/15 1:00 | 38.6 | 34.0 | 38.2 | 28.5 |
| 2011/4/15 2:00 | 37.2 | 34.4 | 39.9 | 27.7 |
| 2011/4/15 3:00 | 36.3 | 34.7 | 41.3 | 27.0 |
| 2011/4/15 4:00 | 35.3 | 35.1 | 43.2 | 26.0 |
| 2011/4/15 5:00 | 34.6 | 35.4 | 45.1 | 25.0 |
| 2011/4/15 6:00 | 33.9 | 35.8 | 47.1 | 24.5 |
| 2011/4/15 7:00 | 33.4 | 36.1 | 48.7 | 24.0 |
| 2011/4/15 8:00 | 32.9 | 36.6 | 50.5 | 23.5 |
| 2011/4/15 9:00 | 32.4 | 37.0 | 52.4 | 23.0 |
| 2011/4/15 10:00 | 33.5 | 37.2 | 45.6 | 23.0 |
| 2011/4/15 11:00 | 36.7 | 37.1 | 39.8 | 23.0 |
| 2011/4/15 12:00 | 39.0 | 37.1 | 36.7 | 24.0 |
| 2011/4/15 13:00 | 42.3 | 36.6 | 33.0 | 24.5 |
| 2011/4/15 14:00 | 45.1 | 35.2 | 30.4 | 25.0 |
| 2011/4/15 15:00 | 48.1 | 34.8 | 28.2 | 25.5 |
| 2011/4/15 16:00 | 51.2 | 34.1 | 26.8 | 26.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/15 17:00 | 52.9 | 33.7 | 26.1 | 26.0 |
| 2011/4/15 18:00 | 55.8 | 33.2 | 25.9 | 26.5 |
| 2011/4/15 19:00 | 58.3 | 32.7 | 25.7 | 26.5 |
| 2011/4/15 20:00 | 49.6 | 32.5 | 25.4 | 27.0 |
| 2011/4/15 21:00 | 46.5 | 32.8 | 25.2 | 27.5 |
| 2011/4/15 22:00 | 44.1 | 33.1 | 25.0 | 28.0 |
| 2011/4/15 23:00 | 42.2 | 33.4 | 24.9 | 28.5 |
| 2011/4/16 0:00 | 40.5 | 33.8 | 24.6 | 29.0 |
| 2011/4/16 1:00 | 38.8 | 34.2 | 24.4 | 29.0 |
| 2011/4/16 2:00 | 37.7 | 34.5 | 24.2 | 29.5 |
| 2011/4/16 3:00 | 36.6 | 34.9 | 24.1 | 30.0 |
| 2011/4/16 4:00 | 35.6 | 35.2 | 24.0 | 30.0 |
| 2011/4/16 5:00 | 34.9 | 35.6 | 23.9 | 30.0 |
| 2011/4/16 6:00 | 34.2 | 36.0 | 23.8 | 30.5 |
| 2011/4/16 7:00 | 33.6 | 36.3 | 23.8 | 31.0 |
| 2011/4/16 8:00 | 33.1 | 36.8 | 23.8 | 31.5 |
| 2011/4/16 9:00 | 32.7 | 37.3 | 23.7 | 32.0 |
| 2011/4/16 10:00 | 32.3 | 37.3 | 23.7 | 32.0 |
| 2011/4/16 11:00 | 35.6 | 37.5 | 23.7 | 32.0 |
| 2011/4/16 12:00 | 38.5 | 37.4 | 23.7 | 32.5 |
| 2011/4/16 13:00 | 41.8 | 37.0 | 23.8 | 33.0 |
| 2011/4/16 14:00 | 45.3 | 35.7 | 23.8 | 33.5 |
| 2011/4/16 15:00 | 47.6 | 35.1 | 23.9 | 34.0 |
| 2011/4/16 16:00 | 49.9 | 34.7 | 24.0 | 34.0 |
| 2011/4/16 17:00 | 52.6 | 34.2 | 23.9 | 34.5 |
| 2011/4/16 18:00 | 55.3 | 33.7 | 23.8 | 35.0 |
| 2011/4/16 19:00 | 57.7 | 33.2 | 27.8 | 35.5 |
| 2011/4/16 20:00 | 48.2 | 33.1 | 29.3 | 35.0 |
| 2011/4/16 21:00 | 45.9 | 33.3 | 30.7 | 32.0 |
| 2011/4/16 22:00 | 43.5 | 33.7 | 32.9 | 31.5 |
| 2011/4/16 23:00 | 41.7 | 34.1 | 34.8 | 31.0 |
| 2011/4/17 0:00 | 40.1 | 34.3 | 36.8 | 30.0 |
| 2011/4/17 1:00 | 38.7 | 34.8 | 38.3 | 29.0 |
| 2011/4/17 2:00 | 37.7 | 35.1 | 39.8 | 28.0 |
| 2011/4/17 3:00 | 36.6 | 35.3 | 41.4 | 27.5 |
| 2011/4/17 4:00 | 35.5 | 35.9 | 43.5 | 27.0 |
| 2011/4/17 5:00 | 34.7 | 36.2 | 45.2 | 26.0 |
| 2011/4/17 6:00 | 34.0 | 36.6 | 47.0 | 25.0 |
| 2011/4/17 7:00 | 33.5 | 36.9 | 48.8 | 24.5 |
| 2011/4/17 8:00 | 33.0 | 37.2 | 50.4 | 24.5 |
| 2011/4/17 9:00 | 32.6 | 37.7 | 52.1 | 24.0 |
| 2011/4/17 10:00 | 33.3 | 37.9 | 53.8 | 24.0 |
| 2011/4/17 11:00 | 36.0 | 37.9 | 44.6 | 24.0 |
| 2011/4/17 12:00 | 38.9 | 37.8 | 39.6 | 24.0 |
| 2011/4/17 13:00 | 42.2 | 36.9 | 35.5 | 24.5 |
| 2011/4/17 14:00 | 44.4 | 35.9 | 33.3 | 24.5 |
| 2011/4/17 15:00 | 47.2 | 35.4 | 30.8 | 25.0 |
| 2011/4/17 16:00 | 49.5 | 34.9 | 29.3 | 26.0 |
| 2011/4/17 17:00 | 51.9 | 34.4 | 28.1 | 26.0 |
| 2011/4/17 18:00 | 55.1 | 33.7 | 26.8 | 26.5 |
| 2011/4/17 19:00 | 57.0 | 33.4 | 26.1 | 27.0 |
| 2011/4/17 20:00 | 47.5 | 33.3 | 25.4 | 27.5 |
| 2011/4/17 21:00 | 45.5 | 33.5 | 24.9 | 28.0 |
| 2011/4/17 22:00 | 43.4 | 33.9 | 24.5 | 28.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/17 23:00 | 41.4 | 34.3 | 24.1 | 28.5 |
| 2011/4/18 0:00 | 39.8 | 34.6 | 23.7 | 29.0 |
| 2011/4/18 1:00 | 38.5 | 35.0 | 23.4 | 29.0 |
| 2011/4/18 2:00 | 37.5 | 35.3 | 23.1 | 29.5 |
| 2011/4/18 3:00 | 36.4 | 35.6 | 22.9 | 29.5 |
| 2011/4/18 4:00 | 35.5 | 36.1 | 22.6 | 30.0 |
| 2011/4/18 5:00 | 34.8 | 36.3 | 22.5 | 30.5 |
| 2011/4/18 6:00 | 34.2 | 36.7 | 22.4 | 30.5 |
| 2011/4/18 7:00 | 33.5 | 37.2 | 22.3 | 31.0 |
| 2011/4/18 8:00 | 33.2 | 37.4 | 22.2 | 31.5 |
| 2011/4/18 9:00 | 32.8 | 37.9 | 22.1 | 32.0 |
| 2011/4/18 10:00 | 33.6 | 38.1 | 22.1 | 32.5 |
| 2011/4/18 11:00 | 36.8 | 38.0 | 22.1 | 33.0 |
| 2011/4/18 12:00 | 39.9 | 37.9 | 22.1 | 33.0 |
| 2011/4/18 13:00 | 42.4 | 37.2 | 22.1 | 33.5 |
| 2011/4/18 14:00 | 45.5 | 35.9 | 22.0 | 34.0 |
| 2011/4/18 15:00 | 48.0 | 35.5 | 22.0 | 34.0 |
| 2011/4/18 16:00 | 50.9 | 34.8 | 22.0 | 34.5 |
| 2011/4/18 17:00 | 53.0 | 34.4 | 22.0 | 35.0 |
| 2011/4/18 18:00 | 55.4 | 33.9 | 21.9 | 35.5 |
| 2011/4/18 19:00 | 57.9 | 33.4 | 26.9 | 35.5 |
| 2011/4/18 20:00 | 50.2 | 33.1 | 28.4 | 33.5 |
| 2011/4/18 21:00 | 47.7 | 33.3 | 29.8 | 32.5 |
| 2011/4/18 22:00 | 45.0 | 33.5 | 31.7 | 31.0 |
| 2011/4/18 23:00 | 44.5 | 34.0 | 33.8 | 30.5 |
| 2011/4/19 0:00 | 42.7 | 34.3 | 35.8 | 29.5 |
| 2011/4/19 1:00 | 39.6 | 34.6 | 37.5 | 29.0 |
| 2011/4/19 2:00 | 38.5 | 34.9 | 38.7 | 28.0 |
| 2011/4/19 3:00 | 37.1 | 35.3 | 40.6 | 27.5 |
| 2011/4/19 4:00 | 36.2 | 35.7 | 42.3 | 26.5 |
| 2011/4/19 5:00 | 35.3 | 36.2 | 44.0 | 26.0 |
| 2011/4/19 6:00 | 34.6 | 36.4 | 46.0 | 25.5 |
| 2011/4/19 7:00 | 34.0 | 36.8 | 47.7 | 25.0 |
| 2011/4/19 8:00 | 33.6 | 37.2 | 49.4 | 24.5 |
| 2011/4/19 9:00 | 33.2 | 37.5 | 50.9 | 24.5 |
| 2011/4/19 10:00 | 33.7 | 37.8 | 52.8 | 24.0 |
| 2011/4/19 11:00 | 35.2 | 37.9 | 44.0 | 24.0 |
| 2011/4/19 12:00 | 38.3 | 37.6 | 39.1 | 24.5 |
| 2011/4/19 13:00 | 41.2 | 37.2 | 35.4 | 25.0 |
| 2011/4/19 14:00 | 43.7 | 36.0 | 32.6 | 25.0 |
| 2011/4/19 15:00 | 46.3 | 35.4 | 30.3 | 25.5 |
| 2011/4/19 16:00 | 48.4 | 34.9 | 28.9 | 26.0 |
| 2011/4/19 17:00 | 51.0 | 34.3 | 27.4 | 26.5 |
| 2011/4/19 18:00 | 53.1 | 33.8 | 26.4 | 26.5 |
| 2011/4/19 19:00 | 55.6 | 33.2 | 25.5 | 27.0 |
| 2011/4/19 20:00 | 48.3 | 33.2 | 24.7 | 27.0 |
| 2011/4/19 21:00 | 44.9 | 33.4 | 24.0 | 28.0 |
| 2011/4/19 22:00 | 43.2 | 33.6 | 23.7 | 28.0 |
| 2011/4/19 23:00 | 41.6 | 34.0 | 23.4 | 28.5 |
| 2011/4/20 0:00 | 40.0 | 34.5 | 23.1 | 29.0 |
| 2011/4/20 1:00 | 38.6 | 34.7 | 22.8 | 29.5 |
| 2011/4/20 2:00 | 37.4 | 35.1 | 22.7 | 29.5 |
| 2011/4/20 3:00 | 36.5 | 35.5 | 22.5 | 30.0 |
| 2011/4/20 4:00 | 35.6 | 35.8 | 22.4 | 30.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/20 5:00 | 34.9 | 36.1 | 22.4 | 30.5 |
| 2011/4/20 6:00 | 34.2 | 36.6 | 22.5 | 31.0 |
| 2011/4/20 7:00 | 33.7 | 36.9 | 22.5 | 31.0 |
| 2011/4/20 8:00 | 33.4 | 37.2 | 22.6 | 32.0 |
| 2011/4/20 9:00 | 33.0 | 37.7 | 22.6 | 32.0 |
| 2011/4/20 10:00 | 34.2 | 37.9 | 26.6 | 32.5 |
| 2011/4/20 11:00 | 37.1 | 37.6 | 27.3 | 33.0 |
| 2011/4/20 12:00 | 39.9 | 37.5 | 28.8 | 33.0 |
| 2011/4/20 13:00 | 42.4 | 36.7 | 30.3 | 33.5 |
| 2011/4/20 14:00 | 45.2 | 35.7 | 32.1 | 34.0 |
| 2011/4/20 15:00 | 47.7 | 35.3 | 33.9 | 34.5 |
| 2011/4/20 16:00 | 50.1 | 34.9 | 35.9 | 35.0 |
| 2011/4/20 17:00 | 52.4 | 34.3 | 29.6 | 35.0 |
| 2011/4/20 18:00 | 54.8 | 33.8 | 28.2 | 35.5 |
| 2011/4/20 19:00 | 57.3 | 33.5 | 30.8 | 35.5 |
| 2011/4/20 20:00 | 50.5 | 33.1 | 31.5 | 35.5 |
| 2011/4/20 21:00 | 46.5 | 33.5 | 33.0 | 33.0 |
| 2011/4/20 22:00 | 45.5 | 33.7 | 35.3 | 32.0 |
| 2011/4/20 23:00 | 43.4 | 34.0 | 36.9 | 31.5 |
| 2011/4/21 0:00 | 41.6 | 34.3 | 38.6 | 30.5 |
| 2011/4/21 1:00 | 40.3 | 34.7 | 39.9 | 30.0 |
| 2011/4/21 2:00 | 39.0 | 35.1 | 41.6 | 29.5 |
| 2011/4/21 3:00 | 37.9 | 35.4 | 43.3 | 29.0 |
| 2011/4/21 4:00 | 37.1 | 35.6 | 44.7 | 28.0 |
| 2011/4/21 5:00 | 36.1 | 36.2 | 46.7 | 27.5 |
| 2011/4/21 6:00 | 35.3 | 36.4 | 48.8 | 27.0 |
| 2011/4/21 7:00 | 34.7 | 36.9 | 50.3 | 26.5 |
| 2011/4/21 8:00 | 34.0 | 37.2 | 51.5 | 26.0 |
| 2011/4/21 9:00 | 33.9 | 37.5 | 53.5 | 25.5 |
| 2011/4/21 10:00 | 34.4 | 37.9 | 47.1 | 25.5 |
| 2011/4/21 11:00 | 37.8 | 37.8 | 40.8 | 25.5 |
| 2011/4/21 12:00 | 38.6 | 37.7 | 38.1 | 26.0 |
| 2011/4/21 13:00 | 42.7 | 37.2 | 35.2 | 26.5 |
| 2011/4/21 14:00 | 45.5 | 36.2 | 32.7 | 27.0 |
| 2011/4/21 15:00 | 47.8 | 35.8 | 31.0 | 27.0 |
| 2011/4/21 16:00 | 50.5 | 35.3 | 29.5 | 27.0 |
| 2011/4/21 17:00 | 52.7 | 34.8 | 28.3 | 28.0 |
| 2011/4/21 18:00 | 55.2 | 34.4 | 27.3 | 28.0 |
| 2011/4/21 19:00 | 57.4 | 34.0 | 26.5 | 29.0 |
| 2011/4/21 20:00 | 50.9 | 33.8 | 25.7 | 29.0 |
| 2011/4/21 21:00 | 47.9 | 34.0 | 25.3 | 29.0 |
| 2011/4/21 22:00 | 45.5 | 34.4 | 24.9 | 29.5 |
| 2011/4/21 23:00 | 43.5 | 34.7 | 24.6 | 30.0 |
| 2011/4/22 0:00 | 42.0 | 35.0 | 24.3 | 30.0 |
| 2011/4/22 1:00 | 40.6 | 35.4 | 24.1 | 30.5 |
| 2011/4/22 2:00 | 39.3 | 35.7 | 23.9 | 31.0 |
| 2011/4/22 3:00 | 38.3 | 36.1 | 23.8 | 31.5 |
| 2011/4/22 4:00 | 37.4 | 36.4 | 23.7 | 31.5 |
| 2011/4/22 5:00 | 36.6 | 36.8 | 23.6 | 32.0 |
| 2011/4/22 6:00 | 35.9 | 37.1 | 23.6 | 32.0 |
| 2011/4/22 7:00 | 35.4 | 37.5 | 23.5 | 32.5 |
| 2011/4/22 8:00 | 34.9 | 37.9 | 23.5 | 33.0 |
| 2011/4/22 9:00 | 34.4 | 38.2 | 23.4 | 33.5 |
| 2011/4/22 10:00 | 35.0 | 38.5 | 23.4 | 33.5 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/22 11:00 | 38.1 | 38.4 | 23.4 | 34.0 |
| 2011/4/22 12:00 | 40.9 | 38.2 | 23.3 | 34.5 |
| 2011/4/22 13:00 | 43.6 | 37.7 | 23.3 | 35.0 |
| 2011/4/22 14:00 | 46.3 | 36.6 | 23.3 | 35.5 |
| 2011/4/22 15:00 | 48.9 | 36.2 | 23.3 | 36.0 |
| 2011/4/22 16:00 | 51.6 | 35.7 | 23.3 | 36.0 |
| 2011/4/22 17:00 | 53.8 | 35.2 | 23.3 | 36.5 |
| 2011/4/22 18:00 | 56.5 | 34.7 | 27.2 | 36.5 |
| 2011/4/22 19:00 | 58.7 | 34.3 | 28.5 | 36.5 |
| 2011/4/22 20:00 | 50.0 | 34.2 | 30.3 | 34.0 |
| 2011/4/22 21:00 | 47.5 | 34.5 | 31.9 | 33.0 |
| 2011/4/22 22:00 | 45.2 | 34.9 | 34.2 | 32.0 |
| 2011/4/22 23:00 | 43.4 | 35.1 | 35.8 | 31.0 |
| 2011/4/23 0:00 | 41.9 | 35.5 | 37.3 | 30.5 |
| 2011/4/23 1:00 | 40.3 | 35.8 | 38.9 | 29.5 |
| 2011/4/23 2:00 | 39.1 | 36.3 | 40.4 | 29.0 |
| 2011/4/23 3:00 | 38.2 | 36.5 | 42.0 | 28.5 |
| 2011/4/23 4:00 | 37.3 | 36.9 | 43.9 | 28.0 |
| 2011/4/23 5:00 | 36.5 | 37.3 | 45.5 | 27.5 |
| 2011/4/23 6:00 | 35.8 | 37.6 | 47.5 | 27.0 |
| 2011/4/23 7:00 | 35.3 | 37.9 | 49.1 | 26.5 |
| 2011/4/23 8:00 | 34.8 | 38.3 | 50.9 | 26.0 |
| 2011/4/23 9:00 | 34.4 | 38.7 | 52.3 | 25.5 |
| 2011/4/23 10:00 | 34.9 | 39.0 | 53.8 | 25.0 |
| 2011/4/23 11:00 | 38.3 | 38.9 | 46.8 | 25.0 |
| 2011/4/23 12:00 | 40.4 | 38.8 | 43.0 | 25.5 |
| 2011/4/23 13:00 | 43.5 | 38.2 | 39.2 | 26.0 |
| 2011/4/23 14:00 | 46.4 | 36.9 | 36.1 | 26.5 |
| 2011/4/23 15:00 | 48.8 | 36.6 | 34.1 | 27.0 |
| 2011/4/23 16:00 | 51.5 | 36.1 | 32.1 | 27.0 |
| 2011/4/23 17:00 | 53.8 | 35.6 | 30.8 | 27.5 |
| 2011/4/23 18:00 | 56.3 | 35.1 | 29.5 | 28.0 |
| 2011/4/23 19:00 | 58.6 | 34.8 | 28.6 | 28.5 |
| 2011/4/23 20:00 | 48.7 | 34.8 | 27.8 | 29.0 |
| 2011/4/23 21:00 | 46.3 | 35.1 | 27.1 | 29.0 |
| 2011/4/23 22:00 | 44.4 | 35.4 | 26.6 | 29.5 |
| 2011/4/23 23:00 | 42.7 | 35.8 | 26.1 | 29.5 |
| 2011/4/24 0:00 | 41.4 | 36.1 | 25.8 | 30.0 |
| 2011/4/24 1:00 | 40.2 | 36.4 | 25.5 | 30.0 |
| 2011/4/24 2:00 | 39.0 | 36.8 | 25.2 | 30.5 |
| 2011/4/24 3:00 | 38.2 | 37.1 | 25.0 | 31.0 |
| 2011/4/24 4:00 | 37.4 | 37.5 | 24.8 | 31.0 |
| 2011/4/24 5:00 | 36.7 | 37.8 | 24.4 | 31.5 |
| 2011/4/24 6:00 | 36.1 | 38.1 | 24.6 | 32.0 |
| 2011/4/24 7:00 | 35.6 | 38.6 | 24.4 | 32.5 |
| 2011/4/24 8:00 | 35.1 | 38.9 | 24.4 | 33.0 |
| 2011/4/24 9:00 | 34.7 | 39.2 | 24.3 | 33.5 |
| 2011/4/24 10:00 | 35.6 | 39.6 | 24.2 | 33.5 |
| 2011/4/24 11:00 | 39.7 | 39.3 | 24.2 | 34.0 |
| 2011/4/24 12:00 | 40.8 | 39.2 | 24.1 | 34.5 |
| 2011/4/24 13:00 | 43.4 | 38.4 | 24.1 | 34.5 |
| 2011/4/24 14:00 | 46.3 | 37.5 | 24.1 | 35.0 |
| 2011/4/24 15:00 | 48.5 | 37.1 | 24.1 | 35.5 |
| 2011/4/24 16:00 | 50.6 | 36.7 | 24.1 | 36.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/24 17:00 | 53.7 | 35.9 | 24.1 | 36.5 |
| 2011/4/24 18:00 | 56.1 | 35.5 | 24.2 | 37.0 |
| 2011/4/24 19:00 | 58.1 | 35.2 | 28.1 | 36.5 |
| 2011/4/24 20:00 | 60.8 | 34.7 | 30.1 | 35.0 |
| 2011/4/24 21:00 | 62.6 | 34.4 | 31.6 | 34.5 |
| 2011/4/24 22:00 | 58.4 | 34.1 | 33.3 | 34.0 |
| 2011/4/24 23:00 | 55.0 | 34.1 | 35.3 | 32.5 |
| 2011/4/25 0:00 | 51.8 | 34.4 | 36.9 | 32.0 |
| 2011/4/25 1:00 | 49.0 | 34.8 | 38.4 | 31.0 |
| 2011/4/25 2:00 | 46.8 | 35.1 | 39.9 | 30.0 |
| 2011/4/25 3:00 | 44.9 | 35.5 | 41.5 | 29.5 |
| 2011/4/25 4:00 | 43.3 | 35.8 | 43.3 | 29.5 |
| 2011/4/25 5:00 | 41.8 | 36.2 | 45.0 | 28.5 |
| 2011/4/25 6:00 | 40.5 | 36.6 | 46.9 | 28.5 |
| 2011/4/25 7:00 | 39.4 | 37.0 | 48.8 | 28.0 |
| 2011/4/25 8:00 | 38.7 | 37.3 | 50.2 | 27.5 |
| 2011/4/25 9:00 | 37.5 | 37.9 | 52.6 | 27.0 |
| 2011/4/25 10:00 | 37.2 | 38.0 | 53.5 | 26.5 |
| 2011/4/25 11:00 | 36.6 | 38.3 | 44.5 | 26.5 |
| 2011/4/25 12:00 | 36.1 | 38.6 | 41.2 | 27.0 |
| 2011/4/25 13:00 | 37.2 | 39.0 | 38.1 | 27.5 |
| 2011/4/25 14:00 | 39.7 | 39.3 | 36.1 | 28.0 |
| 2011/4/25 15:00 | 43.0 | 39.6 | 34.0 | 28.5 |
| 2011/4/25 16:00 | 45.9 | 40.0 | 32.3 | 28.5 |
| 2011/4/25 17:00 | 48.1 | 40.3 | 31.2 | 29.0 |
| 2011/4/25 18:00 | 50.5 | 40.1 | 30.1 | 29.5 |
| 2011/4/25 19:00 | 52.9 | 39.9 | 29.3 | 29.5 |
| 2011/4/25 20:00 | 55.6 | 39.0 | 28.5 | 30.0 |
| 2011/4/25 21:00 | 58.0 | 38.5 | 27.9 | 30.0 |
| 2011/4/25 22:00 | 60.6 | 38.0 | 27.3 | 30.5 |
| 2011/4/25 23:00 | 62.2 | 37.8 | 27.0 | 31.0 |
| 2011/4/26 0:00 | 53.3 | 37.5 | 26.6 | 31.5 |
| 2011/4/26 1:00 | 50.5 | 37.8 | 26.3 | 32.0 |
| 2011/4/26 2:00 | 48.0 | 38.1 | 26.1 | 32.5 |
| 2011/4/26 3:00 | 46.0 | 38.4 | 25.9 | 32.5 |
| 2011/4/26 4:00 | 44.2 | 38.8 | 25.7 | 33.0 |
| 2011/4/26 5:00 | 42.7 | 39.1 | 25.5 | 33.0 |
| 2011/4/26 6:00 | 41.1 | 39.5 | 25.4 | 33.5 |
| 2011/4/26 7:00 | 39.9 | 40.0 | 25.2 | 34.0 |
| 2011/4/26 8:00 | 39.1 | 40.3 | 25.1 | 34.5 |
| 2011/4/26 9:00 | 39.0 | 40.6 | 25.0 | 35.0 |
| 2011/4/26 10:00 | 40.6 | 40.6 | 25.0 | 35.5 |
| 2011/4/26 11:00 | 43.1 | 40.4 | 24.9 | 36.0 |
| 2011/4/26 12:00 | 45.9 | 40.0 | 24.9 | 36.0 |
| 2011/4/26 13:00 | 48.6 | 39.1 | 24.8 | 36.5 |
| 2011/4/26 14:00 | 51.1 | 38.7 | 24.8 | 37.0 |
| 2011/4/26 15:00 | 53.7 | 38.3 | 24.8 | 37.0 |
| 2011/4/26 16:00 | 55.8 | 37.9 | 24.8 | 37.5 |
| 2011/4/26 17:00 | 58.3 | 37.5 | 24.8 | 37.5 |
| 2011/4/26 18:00 | 60.6 | 37.1 | 27.6 | 38.0 |
| 2011/4/26 19:00 | 63.0 | 36.8 | 28.7 | 38.0 |
| 2011/4/26 20:00 | 54.9 | 36.8 | 30.2 | 37.0 |
| 2011/4/26 21:00 | 51.6 | 37.1 | 32.2 | 35.0 |
| 2011/4/26 22:00 | 49.0 | 37.3 | 34.3 | 34.5 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/26 23:00 | 46.7 | 37.7 | 36.3 | 34.0 |
| 2011/4/27 0:00 | 44.8 | 38.0 | 37.9 | 33.0 |
| 2011/4/27 1:00 | 43.2 | 38.3 | 39.3 | 32.0 |
| 2011/4/27 2:00 | 42.0 | 38.7 | 40.8 | 31.0 |
| 2011/4/27 3:00 | 41.0 | 39.0 | 42.3 | 31.0 |
| 2011/4/27 4:00 | 39.9 | 39.4 | 44.2 | 30.0 |
| 2011/4/27 5:00 | 39.0 | 39.7 | 45.9 | 29.5 |
| 2011/4/27 6:00 | 38.3 | 40.1 | 47.9 | 28.5 |
| 2011/4/27 7:00 | 37.6 | 40.4 | 49.5 | 28.5 |
| 2011/4/27 8:00 | 37.0 | 40.8 | 51.1 | 28.0 |
| 2011/4/27 9:00 | 35.4 | 41.1 | 52.8 | 27.5 |
| 2011/4/27 10:00 | 37.5 | 41.3 | 54.3 | 27.0 |
| 2011/4/27 11:00 | 40.4 | 41.1 | 44.3 | 27.0 |
| 2011/4/27 12:00 | 42.8 | 40.8 | 40.9 | 27.5 |
| 2011/4/27 13:00 | 45.8 | 39.5 | 37.6 | 28.5 |
| 2011/4/27 14:00 | 48.1 | 39.1 | 35.5 | 29.0 |
| 2011/4/27 15:00 | 50.4 | 38.8 | 33.6 | 29.0 |
| 2011/4/27 16:00 | 52.7 | 38.3 | 32.1 | 29.5 |
| 2011/4/27 17:00 | 55.0 | 37.8 | 30.9 | 30.0 |
| 2011/4/27 18:00 | 58.2 | 37.5 | 29.8 | 30.0 |
| 2011/4/27 19:00 | 59.4 | 37.1 | 29.2 | 30.0 |
| 2011/4/27 20:00 | 53.4 | 37.0 | 28.6 | 30.5 |
| 2011/4/27 21:00 | 50.5 | 37.4 | 32.6 | 30.5 |
| 2011/4/27 22:00 | 48.2 | 37.6 | 34.1 | 30.0 |
| 2011/4/27 23:00 | 47.5 | 37.9 | 35.9 | 29.5 |
| 2011/4/28 0:00 | 45.7 | 38.3 | 37.5 | 29.0 |
| 2011/4/28 1:00 | 43.3 | 38.6 | 39.0 | 29.0 |
| 2011/4/28 2:00 | 41.9 | 39.0 | 40.7 | 28.5 |
| 2011/4/28 3:00 | 41.0 | 39.2 | 42.1 | 28.0 |
| 2011/4/28 4:00 | 40.1 | 39.6 | 43.9 | 27.0 |
| 2011/4/28 5:00 | 39.4 | 39.9 | 45.6 | 27.0 |
| 2011/4/28 6:00 | 38.7 | 40.4 | 47.5 | 27.0 |
| 2011/4/28 7:00 | 38.1 | 40.7 | 49.3 | 26.5 |
| 2011/4/28 8:00 | 37.6 | 41.0 | 50.9 | 26.5 |
| 2011/4/28 9:00 | 37.1 | 41.3 | 52.5 | 26.0 |
| 2011/4/28 10:00 | 38.7 | 41.6 | 46.2 | 26.0 |
| 2011/4/28 11:00 | 41.3 | 41.4 | 43.2 | 26.5 |
| 2011/4/28 12:00 | 43.9 | 41.1 | 40.3 | 27.0 |
| 2011/4/28 13:00 | 46.4 | 40.1 | 37.7 | 27.5 |
| 2011/4/28 14:00 | 48.9 | 39.5 | 35.6 | 28.0 |
| 2011/4/28 15:00 | 51.4 | 39.1 | 33.7 | 28.0 |
| 2011/4/28 16:00 | 53.8 | 38.7 | 32.2 | 28.5 |
| 2011/4/28 17:00 | 55.8 | 38.3 | 31.2 | 29.0 |
| 2011/4/28 18:00 | 58.0 | 37.9 | 30.2 | 29.5 |
| 2011/4/28 19:00 | 60.5 | 37.5 | 29.3 | 30.0 |
| 2011/4/28 20:00 | 57.7 | 37.1 | 28.7 | 30.0 |
| 2011/4/28 21:00 | 54.2 | 37.2 | 28.2 | 30.0 |
| 2011/4/28 22:00 | 51.3 | 37.5 | 27.7 | 30.5 |
| 2011/4/28 23:00 | 48.7 | 37.9 | 27.2 | 30.5 |
| 2011/4/29 0:00 | 46.6 | 38.2 | 26.8 | 31.0 |
| 2011/4/29 1:00 | 45.1 | 38.5 | 26.6 | 31.0 |
| 2011/4/29 2:00 | 43.3 | 38.9 | 26.2 | 32.0 |
| 2011/4/29 3:00 | 42.0 | 39.2 | 26.0 | 32.5 |
| 2011/4/29 4:00 | 41.0 | 39.5 | 25.7 | 33.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/4/29 5:00 | 40.0 | 39.9 | 25.5 | 33.0 |
| 2011/4/29 6:00 | 39.1 | 40.3 | 25.3 | 33.5 |
| 2011/4/29 7:00 | 38.4 | 40.6 | 25.2 | 34.0 |
| 2011/4/29 8:00 | 37.9 | 41.1 | 25.1 | 34.0 |
| 2011/4/29 9:00 | 37.3 | 41.4 | 25.0 | 34.5 |
| 2011/4/29 10:00 | 38.2 | 41.6 | 24.9 | 35.0 |
| 2011/4/29 11:00 | 41.2 | 41.4 | 24.9 | 35.5 |
| 2011/4/29 12:00 | 43.7 | 41.2 | 24.8 | 36.0 |
| 2011/4/29 13:00 | 47.0 | 40.1 | 24.8 | 36.5 |
| 2011/4/29 14:00 | 48.9 | 39.6 | 24.8 | 36.5 |
| 2011/4/29 15:00 | 51.3 | 39.2 | 24.9 | 37.0 |
| 2011/4/29 16:00 | 53.7 | 38.9 | 24.9 | 37.0 |
| 2011/4/29 17:00 | 55.9 | 38.4 | 24.9 | 37.5 |
| 2011/4/29 18:00 | 58.4 | 38.0 | 24.9 | 38.0 |
| 2011/4/29 19:00 | 60.8 | 37.7 | 28.6 | 37.5 |
| 2011/4/29 20:00 | 62.7 | 37.3 | 30.1 | 37.5 |
| 2011/4/29 21:00 | 64.9 | 37.0 | 31.9 | 35.0 |
| 2011/4/29 22:00 | 57.1 | 36.9 | 33.8 | 35.0 |
| 2011/4/29 23:00 | 53.7 | 37.1 | 36.0 | 34.0 |
| 2011/4/30 0:00 | 50.7 | 37.4 | 37.6 | 33.0 |
| 2011/4/30 1:00 | 48.4 | 37.8 | 39.2 | 32.0 |
| 2011/4/30 2:00 | 46.3 | 38.1 | 40.8 | 31.0 |
| 2011/4/30 3:00 | 44.8 | 38.4 | 42.1 | 30.5 |
| 2011/4/30 4:00 | 42.7 | 38.9 | 44.6 | 30.0 |
| 2011/4/30 5:00 | 42.0 | 39.1 | 45.6 | 29.5 |
| 2011/4/30 6:00 | 40.7 | 39.6 | 47.7 | 29.0 |
| 2011/4/30 7:00 | 40.0 | 39.9 | 49.2 | 28.5 |
| 2011/4/30 8:00 | 39.3 | 40.3 | 50.7 | 28.0 |
| 2011/4/30 9:00 | 38.5 | 40.6 | 52.6 | 28.0 |
| 2011/4/30 10:00 | 40.9 | 40.6 | 54.2 | 27.5 |
| 2011/4/30 11:00 | 42.5 | 40.5 | 46.0 | 28.0 |
| 2011/4/30 12:00 | 46.1 | 40.1 | 42.5 | 28.0 |
| 2011/4/30 13:00 | 48.5 | 39.3 | 39.5 | 28.0 |
| 2011/4/30 14:00 | 51.4 | 38.6 | 36.7 | 29.0 |
| 2011/4/30 15:00 | 53.0 | 38.4 | 35.3 | 29.0 |
| 2011/4/30 16:00 | 55.5 | 38.0 | 33.4 | 29.5 |
| 2011/4/30 17:00 | 57.7 | 37.6 | 32.1 | 29.5 |
| 2011/4/30 18:00 | 59.7 | 37.3 | 31.0 | 30.0 |
| 2011/4/30 19:00 | 61.9 | 37.0 | 30.1 | 30.1 |
| 2011/4/30 20:00 | 64.0 | 36.8 | 30.0 | 29.3 |
| 2011/4/30 21:00 | 56.3 | 36.8 | 28.5 | 31.0 |
| 2011/4/30 22:00 | 53.4 | 37.0 | 28.1 | 31.0 |
| 2011/4/30 23:00 | 50.5 | 37.3 | 27.5 | 32.0 |
| 2011/5/1 0:00 | 48.2 | 37.6 | 27.1 | 32.0 |
| 2011/5/1 1:00 | 46.1 | 37.9 | 26.8 | 32.5 |
| 2011/5/1 2:00 | 44.5 | 38.3 | 26.4 | 33.0 |
| 2011/5/1 3:00 | 42.8 | 38.7 | 26.0 | 33.5 |
| 2011/5/1 4:00 | 41.8 | 38.9 | 25.8 | 33.5 |
| 2011/5/1 5:00 | 40.7 | 39.3 | 25.5 | 34.0 |
| 2011/5/1 6:00 | 39.7 | 39.7 | 25.3 | 34.5 |
| 2011/5/1 7:00 | 39.1 | 40.0 | 25.2 | 35.0 |
| 2011/5/1 8:00 | 38.4 | 40.5 | 25.0 | 35.0 |
| 2011/5/1 9:00 | 37.7 | 40.9 | 24.9 | 35.5 |
| 2011/5/1 10:00 | 40.0 | 40.8 | 27.8 | 36.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/5/1 11:00 | 42.9 | 40.5 | 28.9 | 36.0 |
| 2011/5/1 12:00 | 45.4 | 40.2 | 30.2 | 35.0 |
| 2011/5/1 13:00 | 48.2 | 39.4 | 32.1 | 33.5 |
| 2011/5/1 14:00 | 50.3 | 39.0 | 33.6 | 33.5 |
| 2011/5/1 15:00 | 53.1 | 38.6 | 36.1 | 32.0 |
| 2011/5/1 16:00 | 55.1 | 38.2 | 37.4 | 31.0 |
| 2011/5/1 17:00 | 57.6 | 37.8 | 39.0 | 30.0 |
| 2011/5/1 18:00 | 59.5 | 37.4 | 40.3 | 29.5 |
| 2011/5/1 19:00 | 62.5 | 37.0 | 42.2 | 29.0 |
| 2011/5/1 20:00 | 64.3 | 36.7 | 38.9 | 29.0 |
| 2011/5/1 21:00 | 56.0 | 36.9 | 36.8 | 29.0 |
| 2011/5/1 22:00 | 52.4 | 37.1 | 34.5 | 29.5 |
| 2011/5/1 23:00 | 50.0 | 37.4 | 32.8 | 30.0 |
| 2011/5/2 0:00 | 47.7 | 37.8 | 31.5 | 30.0 |
| 2011/5/2 1:00 | 46.3 | 38.0 | 30.5 | 30.5 |
| 2011/5/2 2:00 | 44.4 | 38.4 | 29.4 | 31.0 |
| 2011/5/2 3:00 | 43.1 | 38.7 | 28.6 | 31.0 |
| 2011/5/2 4:00 | 41.2 | 39.3 | 27.5 | 32.0 |
| 2011/5/2 5:00 | 40.8 | 39.4 | 27.3 | 32.0 |
| 2011/5/2 6:00 | 39.8 | 39.8 | 26.7 | 32.5 |
| 2011/5/2 7:00 | 39.2 | 40.1 | 26.4 | 32.5 |
| 2011/5/2 8:00 | 38.6 | 40.6 | 26.0 | 33.0 |
| 2011/5/2 9:00 | 38.0 | 40.8 | 25.7 | 33.5 |
| 2011/5/2 10:00 | 40.2 | 40.9 | 25.4 | 34.0 |
| 2011/5/2 11:00 | 43.0 | 40.7 | 25.2 | 34.5 |
| 2011/5/2 12:00 | 45.7 | 40.4 | 29.1 | 35.0 |
| 2011/5/2 13:00 | 48.3 | 39.6 | 30.3 | 35.5 |
| 2011/5/2 14:00 | 50.5 | 39.0 | 31.8 | 36.0 |
| 2011/5/2 15:00 | 53.1 | 39.1 | 30.4 | 36.0 |
| 2011/5/2 16:00 | 55.7 | 39.1 | 29.1 | 36.0 |
| 2011/5/2 17:00 | 58.0 | 39.0 | 28.3 | 36.5 |
| 2011/5/2 18:00 | 60.3 | 38.6 | 27.5 | 37.0 |
| 2011/5/2 19:00 | 63.0 | 37.9 | 26.8 | 37.5 |
| 2011/5/2 20:00 | 64.8 | 37.5 | 26.4 | 38.0 |
| 2011/5/2 21:00 | 59.0 | 37.1 | 29.7 | 37.5 |
| 2011/5/2 22:00 | 55.0 | 37.2 | 31.0 | 37.0 |
| 2011/5/2 23:00 | 51.8 | 37.5 | 32.7 | 35.5 |
| 2011/5/3 0:00 | 48.9 | 37.8 | 34.9 | 34.0 |
| 2011/5/3 1:00 | 46.7 | 38.2 | 36.3 | 33.0 |
| 2011/5/3 2:00 | 44.7 | 38.5 | 37.8 | 32.5 |
| 2011/5/3 3:00 | 43.0 | 38.9 | 39.2 | 32.0 |
| 2011/5/3 4:00 | 41.6 | 39.3 | 40.7 | 31.0 |
| 2011/5/3 5:00 | 40.4 | 39.5 | 42.2 | 30.0 |
| 2011/5/3 6:00 | 39.3 | 39.9 | 44.0 | 30.0 |
| 2011/5/3 7:00 | 38.4 | 40.2 | 45.7 | 29.0 |
| 2011/5/3 8:00 | 37.7 | 40.6 | 47.5 | 28.5 |
| 2011/5/3 9:00 | 37.1 | 41.0 | 49.0 | 28.0 |
| 2011/5/3 10:00 | 37.9 | 41.3 | 50.7 | 28.0 |
| 2011/5/3 11:00 | 40.4 | 41.1 | 42.1 | 28.0 |
| 2011/5/3 12:00 | 43.2 | 40.8 | 39.0 | 28.5 |
| 2011/5/3 13:00 | 46.4 | 39.9 | 36.2 | 29.0 |
| 2011/5/3 14:00 | 48.6 | 39.2 | 34.5 | 29.0 |
| 2011/5/3 15:00 | 51.4 | 39.0 | 32.6 | 29.5 |
| 2011/5/3 16:00 | 54.1 | 38.5 | 31.1 | 30.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/5/3 17:00 | 57.1 | 38.0 | 29.8 | 30.0 |
| 2011/5/3 18:00 | 58.6 | 37.5 | 29.2 | 30.5 |
| 2011/5/3 19:00 | 60.2 | 37.3 | 28.7 | 30.5 |
| 2011/5/3 20:00 | 62.9 | 36.8 | 27.9 | 31.0 |
| 2011/5/3 21:00 | 54.5 | 36.8 | 27.4 | 31.5 |
| 2011/5/3 22:00 | 51.4 | 37.1 | 26.9 | 32.0 |
| 2011/5/3 23:00 | 49.0 | 37.4 | 26.6 | 32.5 |
| 2011/5/4 0:00 | 47.0 | 37.7 | 26.3 | 33.0 |
| 2011/5/4 1:00 | 45.2 | 38.0 | 26.0 | 33.5 |
| 2011/5/4 2:00 | 43.8 | 38.3 | 25.8 | 33.5 |
| 2011/5/4 3:00 | 42.4 | 38.7 | 25.6 | 34.0 |
| 2011/5/4 4:00 | 41.1 | 39.1 | 25.4 | 34.5 |
| 2011/5/4 5:00 | 40.2 | 39.4 | 25.2 | 35.0 |
| 2011/5/4 6:00 | 39.3 | 39.7 | 25.1 | 35.0 |
| 2011/5/4 7:00 | 38.6 | 40.1 | 25.1 | 35.0 |
| 2011/5/4 8:00 | 37.9 | 40.5 | 24.9 | 35.5 |
| 2011/5/4 9:00 | 37.4 | 40.8 | 24.8 | 36.0 |
| 2011/5/4 10:00 | 36.3 | 41.1 | 24.8 | 36.5 |
| 2011/5/4 11:00 | 40.2 | 41.0 | 28.4 | 36.5 |
| 2011/5/4 12:00 | 42.9 | 40.8 | 29.9 | 36.0 |
| 2011/5/4 13:00 | 45.8 | 40.0 | 31.9 | 34.0 |
| 2011/5/4 14:00 | 48.0 | 39.0 | 33.5 | 33.5 |
| 2011/5/4 15:00 | 50.3 | 38.6 | 35.7 | 32.5 |
| 2011/5/4 16:00 | 52.8 | 38.3 | 37.3 | 31.5 |
| 2011/5/4 17:00 | 55.0 | 38.1 | 38.7 | 30.5 |
| 2011/5/4 18:00 | 57.0 | 37.6 | 40.1 | 30.5 |
| 2011/5/4 19:00 | 59.1 | 37.3 | 41.5 | 30.0 |
| 2011/5/4 20:00 | 61.7 | 36.8 | 43.4 | 29.5 |
| 2011/5/4 21:00 | 56.6 | 36.5 | 44.8 | 29.0 |
| 2011/5/4 22:00 | 53.4 | 36.8 | 37.5 | 29.0 |
| 2011/5/4 23:00 | 50.8 | 37.0 | 35.4 | 29.0 |
| 2011/5/5 0:00 | 48.7 | 37.4 | 33.8 | 29.5 |
| 2011/5/5 1:00 | 46.6 | 37.8 | 32.2 | 30.0 |
| 2011/5/5 2:00 | 45.0 | 38.1 | 32.1 | 30.0 |
| 2011/5/5 3:00 | 43.6 | 38.4 | 30.1 | 31.0 |
| 2011/5/5 4:00 | 42.2 | 38.7 | 29.2 | 31.0 |
| 2011/5/5 5:00 | 41.2 | 39.0 | 28.5 | 31.5 |
| 2011/5/5 6:00 | 40.2 | 39.4 | 27.9 | 32.0 |
| 2011/5/5 7:00 | 39.2 | 39.8 | 27.4 | 32.5 |
| 2011/5/5 8:00 | 38.6 | 40.1 | 27.0 | 33.0 |
| 2011/5/5 9:00 | 38.1 | 40.5 | 26.7 | 33.0 |
| 2011/5/5 10:00 | 39.1 | 40.7 | 26.3 | 33.5 |
| 2011/5/5 11:00 | 40.9 | 40.5 | 26.2 | 34.0 |
| 2011/5/5 12:00 | 43.4 | 40.3 | 26.0 | 34.5 |
| 2011/5/5 13:00 | 45.9 | 39.7 | 25.8 | 34.5 |
| 2011/5/5 14:00 | 48.4 | 39.1 | 25.6 | 35.0 |
| 2011/5/5 15:00 | 50.6 | 38.8 | 25.5 | 35.5 |
| 2011/5/5 16:00 | 53.1 | 38.5 | 25.4 | 36.0 |
| 2011/5/5 17:00 | 55.1 | 38.0 | 25.4 | 36.0 |
| 2011/5/5 18:00 | 57.5 | 37.7 | 25.4 | 36.5 |
| 2011/5/5 19:00 | 59.6 | 37.3 | 29.0 | 36.5 |
| 2011/5/5 20:00 | 61.7 | 37.0 | 30.5 | 35.5 |
| 2011/5/5 21:00 | 63.8 | 36.8 | 32.3 | 34.5 |
| 2011/5/5 22:00 | 65.8 | 36.5 | 34.1 | 33.5 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/5/5 23:00 | 57.7 | 36.2 | 36.2 | 32.5 |
| 2011/5/6 0:00 | 58.2 | 36.4 | 37.7 | 32.0 |
| 2011/5/6 1:00 | 55.4 | 36.7 | 36.7 | 31.5 |
| 2011/5/6 2:00 | 52.5 | 36.9 | 40.4 | 31.0 |
| 2011/5/6 3:00 | 50.1 | 37.4 | 41.9 | 30.5 |
| 2011/5/6 4:00 | 47.8 | 37.7 | 43.7 | 30.0 |
| 2011/5/6 5:00 | 46.1 | 38.0 | 45.3 | 29.5 |
| 2011/5/6 6:00 | 44.5 | 38.4 | 47.1 | 29.0 |
| 2011/5/6 7:00 | 42.8 | 38.9 | 49.3 | 28.5 |
| 2011/5/6 8:00 | 42.0 | 39.1 | 50.3 | 28.5 |
| 2011/5/6 9:00 | 41.1 | 39.4 | 52.0 | 28.0 |
| 2011/5/6 10:00 | 42.5 | 39.6 | 53.5 | 28.0 |
| 2011/5/6 11:00 | 45.1 | 39.5 | 44.3 | 28.0 |
| 2011/5/6 12:00 | 47.6 | 39.3 | 41.2 | 28.5 |
| 2011/5/6 13:00 | 50.3 | 38.7 | 38.3 | 29.0 |
| 2011/5/6 14:00 | 52.3 | 38.4 | 36.5 | 29.0 |
| 2011/5/6 15:00 | 54.8 | 38.1 | 34.6 | 29.5 |
| 2011/5/6 16:00 | 56.9 | 37.7 | 33.3 | 29.5 |
| 2011/5/6 17:00 | 59.2 | 37.5 | 32.1 | 30.0 |
| 2011/5/6 18:00 | 61.3 | 37.1 | 31.1 | 30.5 |
| 2011/5/6 19:00 | 63.6 | 36.7 | 30.2 | 30.5 |
| 2011/5/6 20:00 | 65.7 | 36.5 | 29.6 | 31.0 |
| 2011/5/6 21:00 | 67.6 | 36.4 | 29.0 | 31.5 |
| 2011/5/6 22:00 | 61.0 | 36.2 | 28.5 | 32.0 |
| 2011/5/6 23:00 | 57.6 | 36.5 | 28.1 | 32.0 |
| 2011/5/7 0:00 | 54.0 | 36.8 | 27.7 | 33.0 |
| 2011/5/7 1:00 | 51.9 | 37.1 | 27.5 | 33.0 |
| 2011/5/7 2:00 | 49.6 | 37.6 | 27.2 | 33.5 |
| 2011/5/7 3:00 | 47.8 | 37.8 | 27.0 | 34.0 |
| 2011/5/7 4:00 | 46.1 | 38.3 | 26.8 | 34.5 |
| 2011/5/7 5:00 | 44.8 | 38.6 | 26.7 | 34.5 |
| 2011/5/7 6:00 | 43.6 | 38.8 | 26.5 | 35.0 |
| 2011/5/7 7:00 | 42.6 | 39.3 | 26.4 | 35.0 |
| 2011/5/7 8:00 | 41.8 | 39.6 | 26.3 | 35.5 |
| 2011/5/7 9:00 | 41.1 | 39.9 | 26.2 | 36.0 |
| 2011/5/7 10:00 | 42.1 | 40.0 | 26.1 | 36.5 |
| 2011/5/7 11:00 | 44.9 | 40.0 | 26.1 | 37.0 |
| 2011/5/7 12:00 | 47.6 | 39.6 | 26.1 | 37.0 |
| 2011/5/7 13:00 | 50.0 | 39.2 | 26.1 | 37.5 |
| 2011/5/7 14:00 | 52.6 | 38.9 | 26.1 | 38.0 |
| 2011/5/7 15:00 | 55.0 | 38.5 | 26.1 | 38.0 |
| 2011/5/7 16:00 | 57.3 | 38.2 | 26.1 | 38.5 |
| 2011/5/7 17:00 | 59.4 | 38.0 | 26.1 | 38.5 |
| 2011/5/7 18:00 | 61.7 | 37.7 | 26.1 | 39.0 |
| 2011/5/7 19:00 | 64.0 | 37.3 | 29.7 | 39.0 |
| 2011/5/7 20:00 | 66.0 | 37.2 | 31.2 | 38.5 |
| 2011/5/7 21:00 | 59.4 | 37.1 | 32.9 | 36.5 |
| 2011/5/7 22:00 | 56.1 | 37.4 | 34.6 | 36.0 |
| 2011/5/7 23:00 | 53.3 | 37.6 | 36.8 | 35.0 |
| 2011/5/8 0:00 | 52.1 | 38.1 | 38.5 | 34.5 |
| 2011/5/8 1:00 | 50.1 | 38.4 | 39.9 | 33.5 |
| 2011/5/8 2:00 | 47.4 | 38.6 | 41.3 | 33.0 |
| 2011/5/8 3:00 | 46.0 | 39.1 | 42.8 | 32.5 |
| 2011/5/8 4:00 | 44.6 | 39.4 | 44.6 | 31.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/5/8 5:00 | 43.5 | 39.7 | 46.4 | 30.5 |
| 2011/5/8 6:00 | 42.5 | 40.1 | 47.9 | 30.0 |
| 2011/5/8 7:00 | 41.6 | 40.4 | 50.0 | 29.5 |
| 2011/5/8 8:00 | 40.9 | 40.7 | 51.2 | 29.0 |
| 2011/5/8 9:00 | 40.4 | 41.1 | 52.8 | 29.0 |
| 2011/5/8 10:00 | 42.3 | 41.3 | 54.3 | 29.5 |
| 2011/5/8 11:00 | 45.0 | 41.1 | 43.6 | 29.0 |
| 2011/5/8 12:00 | 47.4 | 40.8 | 40.7 | 29.0 |
| 2011/5/8 13:00 | 51.5 | 39.9 | 36.8 | 29.5 |
| 2011/5/8 14:00 | 52.9 | 39.6 | 35.7 | 30.0 |
| 2011/5/8 15:00 | 55.0 | 39.4 | 34.2 | 30.0 |
| 2011/5/8 16:00 | 57.1 | 39.2 | 32.9 | 30.5 |
| 2011/5/8 17:00 | 57.0 | 38.9 | 31.7 | 31.0 |
| 2011/5/8 18:00 | 61.7 | 38.5 | 30.8 | 31.0 |
| 2011/5/8 19:00 | 63.9 | 38.2 | 30.0 | 31.5 |
| 2011/5/8 20:00 | 66.0 | 38.0 | 29.4 | 32.0 |
| 2011/5/8 21:00 | 68.1 | 37.7 | 28.7 | 32.5 |
| 2011/5/8 22:00 | 60.4 | 37.6 | 28.3 | 33.0 |
| 2011/5/8 23:00 | 57.1 | 38.0 | 27.9 | 33.5 |
| 2011/5/9 0:00 | 54.5 | 38.3 | 27.5 | 34.0 |
| 2011/5/9 1:00 | 52.4 | 38.6 | 27.2 | 34.0 |
| 2011/5/9 2:00 | 50.3 | 39.0 | 27.0 | 34.5 |
| 2011/5/9 3:00 | 48.8 | 39.3 | 26.8 | 34.5 |
| 2011/5/9 4:00 | 47.2 | 39.6 | 26.5 | 35.0 |
| 2011/5/9 5:00 | 45.9 | 39.9 | 26.3 | 35.5 |
| 2011/5/9 6:00 | 44.8 | 40.3 | 26.2 | 35.5 |
| 2011/5/9 7:00 | 43.8 | 40.6 | 26.0 | 36.0 |
| 2011/5/9 8:00 | 42.5 | 41.2 | 25.9 | 36.5 |
| 2011/5/9 9:00 | 42.3 | 41.4 | 25.9 | 36.5 |
| 2011/5/9 10:00 | 44.7 | 41.3 | 25.7 | 37.0 |
| 2011/5/9 11:00 | 48.0 | 41.0 | 25.6 | 37.5 |
| 2011/5/9 12:00 | 50.5 | 40.6 | 25.6 | 38.0 |
| 2011/5/9 13:00 | 52.3 | 40.2 | 25.5 | 38.0 |
| 2011/5/9 14:00 | 54.5 | 40.0 | 25.5 | 38.5 |
| 2011/5/9 15:00 | 56.7 | 39.7 | 25.5 | 38.5 |
| 2011/5/9 16:00 | 59.2 | 39.4 | 25.6 | 39.0 |
| 2011/5/9 17:00 | 61.7 | 39.1 | 25.6 | 39.5 |
| 2011/5/9 18:00 | 63.5 | 38.9 | 26.0 | 39.5 |
| 2011/5/9 19:00 | 65.8 | 38.6 | 29.6 | 39.5 |
| 2011/5/9 20:00 | 67.9 | 38.4 | 31.3 | 38.0 |
| 2011/5/9 21:00 | 62.3 | 38.3 | 33.0 | 37.0 |
| 2011/5/9 22:00 | 58.4 | 38.5 | 35.1 | 36.0 |
| 2011/5/9 23:00 | 56.1 | 38.7 | 36.8 | 35.5 |
| 2011/5/10 0:00 | 53.7 | 39.1 | 38.3 | 35.0 |
| 2011/5/10 1:00 | 51.7 | 39.5 | 39.7 | 34.0 |
| 2011/5/10 2:00 | 50.0 | 39.8 | 41.2 | 33.0 |
| 2011/5/10 3:00 | 48.5 | 40.1 | 42.8 | 32.0 |
| 2011/5/10 4:00 | 47.2 | 40.5 | 44.5 | 32.0 |
| 2011/5/10 5:00 | 46.1 | 40.8 | 46.1 | 31.5 |
| 2011/5/10 6:00 | 45.2 | 41.1 | 47.8 | 30.5 |
| 2011/5/10 7:00 | 44.2 | 41.6 | 49.6 | 30.0 |
| 2011/5/10 8:00 | 43.4 | 41.8 | 51.2 | 30.0 |
| 2011/5/10 9:00 | 42.8 | 42.1 | 52.7 | 29.5 |
| 2011/5/10 10:00 | 44.9 | 42.2 | 54.1 | 29.0 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/5/10 11:00 | 47.8 | 42.0 | 44.0 | 29.5 |
| 2011/5/10 12:00 | 49.9 | 41.8 | 41.6 | 29.5 |
| 2011/5/10 13:00 | 52.7 | 41.1 | 38.6 | 30.0 |
| 2011/5/10 14:00 | 55.1 | 40.8 | 36.7 | 30.5 |
| 2011/5/10 15:00 | 57.3 | 40.4 | 34.9 | 31.0 |
| 2011/5/10 16:00 | 59.4 | 40.1 | 33.5 | 31.0 |
| 2011/5/10 17:00 | 61.6 | 39.8 | 32.3 | 31.5 |
| 2011/5/10 18:00 | 63.9 | 39.6 | 31.3 | 32.0 |
| 2011/5/10 19:00 | 65.8 | 39.3 | 30.5 | 32.0 |
| 2011/5/10 20:00 | 68.1 | 38.9 | 29.7 | 32.5 |
| 2011/5/10 21:00 | 70.1 | 38.7 | 29.1 | 33.0 |
| 2011/5/10 22:00 | 61.3 | 38.9 | 28.6 | 33.5 |
| 2011/5/10 23:00 | 58.2 | 39.2 | 28.1 | 34.0 |
| 2011/5/11 0:00 | 55.7 | 39.4 | 27.7 | 34.5 |
| 2011/5/11 1:00 | 53.4 | 39.7 | 27.4 | 34.5 |
| 2011/5/11 2:00 | 51.4 | 40.1 | 27.1 | 35.0 |
| 2011/5/11 3:00 | 49.8 | 40.5 | 26.9 | 35.0 |
| 2011/5/11 4:00 | 48.4 | 40.7 | 26.7 | 35.0 |
| 2011/5/11 5:00 | 47.0 | 41.2 | 26.5 | 36.0 |
| 2011/5/11 6:00 | 46.0 | 41.5 | 26.3 | 36.5 |
| 2011/5/11 7:00 | 44.8 | 41.8 | 26.2 | 37.0 |
| 2011/5/11 8:00 | 44.1 | 42.1 | 26.1 | 37.0 |
| 2011/5/11 9:00 | 42.7 | 42.5 | 26.0 | 37.5 |
| 2011/5/11 10:00 | 43.8 | 42.7 | 26.0 | 37.5 |
| 2011/5/11 11:00 | 46.3 | 42.5 | 25.9 | 38.0 |
| 2011/5/11 12:00 | 49.0 | 42.3 | 25.8 | 38.5 |
| 2011/5/11 13:00 | 51.5 | 41.8 | 25.9 | 39.0 |
| 2011/5/11 14:00 | 53.6 | 41.3 | 25.9 | 39.0 |
| 2011/5/11 15:00 | 55.9 | 40.9 | 25.9 | 39.5 |
| 2011/5/11 16:00 | 58.3 | 40.7 | 25.9 | 40.0 |
| 2011/5/11 17:00 | 60.1 | 40.4 | 25.9 | 40.0 |
| 2011/5/11 18:00 | 62.4 | 40.0 | 29.6 | 40.0 |
| 2011/5/11 19:00 | 64.4 | 39.7 | 31.2 | 39.0 |
| 2011/5/11 20:00 | 66.4 | 39.5 | 32.9 | 37.5 |
| 2011/5/11 21:00 | 62.1 | 39.2 | 35.2 | 36.0 |
| 2011/5/11 22:00 | 58.9 | 39.4 | 37.1 | 35.5 |
| 2011/5/11 23:00 | 56.5 | 39.7 | 38.4 | 34.5 |
| 2011/5/12 0:00 | 54.3 | 40.1 | 39.8 | 34.0 |
| 2011/5/12 1:00 | 52.2 | 40.4 | 41.3 | 33.5 |
| 2011/5/12 2:00 | 50.4 | 40.7 | 42.8 | 33.0 |
| 2011/5/12 3:00 | 49.0 | 41.0 | 44.4 | 32.5 |
| 2011/5/12 4:00 | 47.6 | 41.4 | 46.2 | 31.0 |
| 2011/5/12 5:00 | 46.4 | 41.7 | 47.8 | 30.5 |
| 2011/5/12 6:00 | 45.3 | 42.0 | 49.6 | 30.0 |
| 2011/5/12 7:00 | 44.6 | 42.4 | 51.1 | 29.5 |
| 2011/5/12 8:00 | 43.7 | 42.8 | 52.5 | 29.0 |
| 2011/5/12 9:00 | 43.0 | 43.0 | 54.3 | 29.0 |
| 2011/5/12 10:00 | 44.4 | 43.2 | 55.8 | 28.5 |
| 2011/5/12 11:00 | 47.1 | 43.0 | 46.1 | 29.0 |
| 2011/5/12 12:00 | 49.5 | 42.9 | 42.7 | 29.0 |
| 2011/5/12 13:00 | 52.1 | 42.2 | 39.8 | 29.5 |
| 2011/5/12 14:00 | 54.4 | 41.7 | 37.5 | 29.5 |
| 2011/5/12 15:00 | 56.7 | 41.3 | 35.5 | 30.0 |
| 2011/5/12 16:00 | 58.8 | 41.1 | 33.9 | 30.5 |

Fukushima Daiichi Nuclear Power Station Unit5・6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/5/12 17:00 | 61.1 | 40.8 | 32.4 | 30.5 |
| 2011/5/12 18:00 | 63.4 | 40.4 | 31.2 | 31.0 |
| 2011/5/12 19:00 | 65.1 | 40.1 | 30.5 | 31.5 |
| 2011/5/12 20:00 | 67.3 | 39.8 | 29.6 | 32.0 |
| 2011/5/12 21:00 | 69.2 | 39.6 | 29.0 | 32.5 |
| 2011/5/12 22:00 | 60.4 | 39.6 | 28.5 | 33.0 |
| 2011/5/12 23:00 | 57.6 | 39.9 | 27.9 | 33.0 |
| 2011/5/13 0:00 | 55.2 | 40.3 | 27.6 | 33.5 |
| 2011/5/13 1:00 | 53.2 | 40.5 | 27.2 | 34.0 |
| 2011/5/13 2:00 | 51.5 | 40.9 | 27.0 | 34.5 |
| 2011/5/13 3:00 | 50.0 | 41.2 | 26.8 | 35.0 |
| 2011/5/13 4:00 | 48.6 | 41.5 | 26.6 | 35.0 |
| 2011/5/13 5:00 | 47.4 | 41.9 | 26.5 | 35.5 |
| 2011/5/13 6:00 | 46.3 | 42.2 | 26.5 | 35.5 |
| 2011/5/13 7:00 | 45.5 | 42.5 | 26.4 | 36.0 |
| 2011/5/13 8:00 | 44.5 | 42.8 | 26.4 | 36.5 |
| 2011/5/13 9:00 | 43.3 | 43.1 | 26.3 | 36.5 |
| 2011/5/13 10:00 | 45.0 | 43.3 | 26.3 | 37.0 |
| 2011/5/13 11:00 | 47.4 | 43.2 | 26.2 | 37.0 |
| 2011/5/13 12:00 | 50.0 | 42.8 | 26.2 | 37.5 |
| 2011/5/13 13:00 | 52.3 | 42.2 | 26.2 | 38.0 |
| 2011/5/13 14:00 | 54.9 | 41.8 | 26.2 | 38.0 |
| 2011/5/13 15:00 | 57.1 | 41.6 | 26.1 | 38.5 |
| 2011/5/13 16:00 | 58.7 | 41.3 | 26.1 | 39.0 |
| 2011/5/13 17:00 | 60.9 | 41.0 | 26.1 | 39.0 |
| 2011/5/13 18:00 | 63.0 | 40.6 | 26.1 | 39.5 |
| 2011/5/13 19:00 | 65.3 | 40.3 | 29.7 | 39.5 |
| 2011/5/13 20:00 | 67.8 | 40.0 | 31.8 | 38.0 |
| 2011/5/13 21:00 | 68.9 | 39.9 | 32.8 | 37.0 |
| 2011/5/13 22:00 | 62.2 | 39.8 | 34.5 | 36.5 |
| 2011/5/13 23:00 | 59.1 | 40.1 | 36.7 | 35.5 |
| 2011/5/14 0:00 | 56.5 | 40.3 | 38.2 | 34.5 |
| 2011/5/14 1:00 | 54.6 | 40.7 | 39.6 | 34.0 |
| 2011/5/14 2:00 | 52.5 | 41.1 | 41.1 | 33.5 |
| 2011/5/14 3:00 | 51.0 | 41.4 | 42.4 | 33.0 |
| 2011/5/14 4:00 | 49.3 | 41.6 | 44.2 | 32.0 |
| 2011/5/14 5:00 | 48.0 | 42.1 | 45.9 | 31.5 |
| 2011/5/14 6:00 | 46.7 | 42.4 | 47.8 | 30.5 |
| 2011/5/14 7:00 | 45.8 | 42.7 | 49.5 | 30.0 |
| 2011/5/14 8:00 | 44.9 | 43.0 | 51.0 | 30.0 |
| 2011/5/14 9:00 | 44.2 | 43.4 | 52.7 | 29.5 |
| 2011/5/14 10:00 | 44.9 | 43.7 | 54.1 | 29.5 |
| 2011/5/14 11:00 | 47.7 | 43.4 | 44.6 | 29.0 |
| 2011/5/14 12:00 | 49.9 | 43.3 | 41.8 | 29.5 |
| 2011/5/14 13:00 | 52.4 | 42.7 | 39.1 | 30.0 |
| 2011/5/14 14:00 | 54.6 | 42.3 | 37.0 | 30.0 |
| 2011/5/14 15:00 | 56.7 | 41.9 | 35.4 | 30.5 |
| 2011/5/14 16:00 | 58.9 | 41.5 | 33.8 | 31.0 |
| 2011/5/14 17:00 | 61.1 | 41.3 | 32.5 | 31.5 |
| 2011/5/14 18:00 | 63.0 | 41.0 | 31.6 | 32.0 |
| 2011/5/14 19:00 | 65.3 | 40.6 | 30.7 | 32.0 |
| 2011/5/14 20:00 | 67.4 | 40.3 | 29.9 | 32.5 |
| 2011/5/14 21:00 | 69.0 | 40.1 | 29.4 | 33.0 |
| 2011/5/14 22:00 | 62.4 | 40.1 | 29.0 | 33.0 |

Fukushima Daiichi Nuclear Power Station Unit5·6 Reactor water/spent fuel pool temperature

| Date | Unit5 reactor water temperature | Unit5 spent fuel pool temperature | Unit6 reactor water temperature | Unit6 spent fuel pool temperature |
|-----------------|---------------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| 2011/5/14 23:00 | 58.9 | 40.4 | 28.5 | 34.0 |
| 2011/5/15 0:00 | 56.4 | 40.6 | 28.2 | 34.0 |
| 2011/5/15 1:00 | 54.4 | 41.0 | 27.9 | 34.5 |
| 2011/5/15 2:00 | 52.3 | 41.3 | 27.7 | 35.0 |
| 2011/5/15 3:00 | 50.7 | 41.7 | 27.4 | 35.0 |
| 2011/5/15 4:00 | 49.1 | 41.9 | 27.3 | 35.5 |
| 2011/5/15 5:00 | 47.8 | 42.4 | 27.1 | 36.0 |
| 2011/5/15 6:00 | 46.6 | 42.7 | 27.0 | 36.0 |
| 2011/5/15 7:00 | 45.7 | 42.9 | 26.9 | 36.5 |
| 2011/5/15 8:00 | 44.8 | 43.3 | 26.8 | 37.0 |
| 2011/5/15 9:00 | 44.1 | 43.7 | 26.7 | 37.5 |
| 2011/5/15 10:00 | 45.4 | 43.8 | 26.6 | 38.0 |
| 2011/5/15 11:00 | 47.9 | 43.6 | 26.6 | 38.0 |
| 2011/5/15 12:00 | 50.4 | 43.4 | 26.6 | 38.5 |
| 2011/5/15 13:00 | 53.1 | 42.8 | 26.6 | 38.5 |
| 2011/5/15 14:00 | 55.3 | 42.4 | 26.5 | 39.0 |
| 2011/5/15 15:00 | 57.3 | 42.0 | 26.6 | 39.0 |
| 2011/5/15 16:00 | 59.6 | 41.8 | 26.6 | 39.5 |
| 2011/5/15 17:00 | 61.7 | 41.5 | 26.6 | 40.0 |
| 2011/5/15 18:00 | 63.8 | 41.0 | 26.7 | 40.0 |
| 2011/5/15 19:00 | 65.7 | 40.8 | 29.8 | 40.5 |
| 2011/5/15 20:00 | 67.7 | 40.5 | 31.2 | 40.0 |
| 2011/5/15 21:00 | 69.1 | 40.3 | 32.6 | 38.0 |
| 2011/5/15 22:00 | 61.8 | 40.2 | 34.6 | 37.0 |
| 2011/5/15 23:00 | 59.1 | 40.4 | 36.6 | 37.0 |
| 2011/5/16 0:00 | 56.2 | 40.8 | 38.2 | 36.0 |