

The red words are revised due to the ' Incorrect data for pressure at Primary Containment Vessel of Unit1 ' which we announced on November 29.

Fukushima Daiichi Nuclear Power Station Plant Parameters

[Note]  
Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

As of 06:00 on June 14

Unit	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6	
Status of water injection to the reactor	Fresh water feeding Feed water system 5.2m <sup>3</sup> /h (as of 5:00 , 6/14)	Fresh water feeding Feed water system 5.0m <sup>3</sup> /h (as of 5:00 , 6/14)	Fresh water feeding Feed water system 11.2~11.3m <sup>3</sup> /h (as of 5:00 , 6/14)	※2 (Monitoring is unnecessary since all fuel are takeoff)	※2 (Heat removal of the reactor is functioning. Water injection is unnecessary)		
Water level in the reactor	Fuel range A: Downscale Fuel range B:-1700 mm (as of 5:00 , 6/14)	Fuel range A:-1500 mm Fuel range B:-2100 mm (as of 5:00 , 6/14)	Fuel range A:-1850 mm Fuel range B:-2200 mm (as of 5:00 , 6/14)		Stoppage range 1826mm (as of 6:00 , 6/14)	Stoppage range 2147mm (as of 6:00 , 6/14)	
Pressure in the reactor	System A:0.027 MPa g System B:-MPa g (as of 5:00 , 6/14)	System A:-0.011 MPa g (A)※3 System B:-0.005 MPa g (D)※3 (as of 5:00 , 6/14)	System A:-0.136 MPa g (A)※3 System B:-0.104 MPa g (C)※3 (as of 5:00 , 6/14)		0.010 MPa g (as of 6:00 , 6/14)	0.023 MPa g (as of 6:00 , 6/14)	
Water temperature of the reactor	(Since there is no water inflow in the system it is impossible to collect the data)						
Temperature around the reactor vessel	Temperature in feed-water nozzle:112.5 °C ※3 Temperature at reactor vessel bottom:97.1 °C (as of 5:00 , 6/14)	Temperature in feed-water nozzle:108.2 °C ※1 Temperature at reactor vessel bottom:106.4 °C (as of 5:00 , 6/14)	Temperature in feed-water nozzle:149.2 °C ※3 Temperature at reactor vessel bottom:164.5 °C (as of 5:00 , 6/14)		※2 (Monitoring is unnecessary since all fuel are takeoff)	※2 (monitoring through water temperature of the reactor)	
Pressure in D/W · S/C	D/W:0.1304 MPa abs※ S/C:0.115 MPa abs ※3 (as of 5:00 , 6/14)	D/W:0.015 MPa abs ※3 S/C: Downscale ※1 (as of 5:00 , 6/14)	D/W:0.1003 MPa abs S/C:0.1841 MPa abs (as of 5:00 , 6/14)				
D/W Atmosphere temperature	RPV bellow seal:97.1 °C HVH return:98.0 °C (as of 5:00 , 6/14)	RPV bellow seal:82.0 Downscale ※1 HVH return:100°C (as of 5:00 , 6/14)	RPV bellow seal:162.9 °C ※3 HVH return:154.8 °C (as of 5:00 , 6/14)			※2 (Monitoring is unnecessary since heat removal of reactor is functioning.)	
CAMS radiation monitor	D/W(A):0.00E+00Sv/h ※1 (B):3.95E-01Sv/h ※1 S/C(A):8.09E-01Sv/h ※3 (B):8.31E-01Sv/h ※3 (as of 5:00 , 6/14)	D/W(A):1.47E+01Sv/h ※1 (B):1.62E+01Sv/h ※3 S/C(A):2.68E-01Sv/h ※3 (B):2.42E+01Sv/h ※1 (as of 5:00 , 6/14)	D/W(A):5.58E+00Sv/h ※3 (B):3.16E+00Sv/h ※3 S/C(A):3.47E-01Sv/h ※3 (B):3.21E-01Sv/h ※3 (as of 5:00 , 6/14)				
Temperature in S/C	System A:50.6 °C System B:50.4 °C (as of 5:00 , 6/14)	System A:61.8 °C System B:61.8 °C (as of 5:00 , 6/14)	System A:46.9 °C System B:47.0 °C (as of 5:00 , 6/14)				
Designed usable D/W pressure	0.384MPa g (0.485MPa abs)	0.384MPa g (0.485MPa abs)	0.384MPa g (0.485MPa abs)				
Designed usable D/W maximum pressure	0.427MPa g (0.528MPa abs)	0.427MPa g (0.528MPa abs)	0.427MPa g (0.528MPa abs)				
Temperature in the spent fuel pool	※1	32°C (as of 5:00 , 6/14)	62 °C (as of 5/8) : ※4	85~86 °C (as of 21:02 , 6/13)	43.9 °C (as of 6:00 , 6/14)	39.0 °C (as of 6:00 , 6/14)	
FPC skimmer surge tank level	1350mm (as of 5:00 , 6/14)	3100mm (as of 5:00 , 6/14)	※1	5700mm (as of 5:00 , 6/14)	※2		
Power source	Receiving offsite power (P/C2C)			Receiving offsite power (P/C4D)		Receiving offsite power	
Others	- Regarding reactor water level fuel range A of Unit 1, inspection of the instrument was completed at 17:00, May 11 - Regarding pressure in Unit 1, due to installment of the temporary instrument, its reading instead of those of System A and B will be described in the column of System A from 11:00, June 4. *Data of Pressure in D/W of Unit 1 on 11/29 was corrected because it was incorrect.			Temperature in the Common Spent Fuel Storage: 33°C (as of 6:30 , 6/13)	5u : SHC mode (from 21:02 , 6/13)	6u: SHC mode (from 10:04 , 6/13)	

Pressure conversion Gauge pressure(MPa g) = Absolute pressure(MPa abs) - atmospheric pressure (normal atmospheric pressure0.1013 MPa)  
Absolute pressure(MPa abs) = Gauge pressure(MPa g) + atmospheric pressure (normal atmospheric pressure0.1013 MPa)

※1 : Instrument failure  
※2 : Not covered for collecting data  
※3 : continuously monitoring the status  
※4 : measured at SFP sampling

## Fukushima Daiichi Nuclear Power Station Supplemental explanation for the plant parameters

### ■ Supplemental explanation for each parameter

Item	Recording manner	Measurement manner	Ch number or number of systems
Status of water injection to the reactor	Water inflow	Temporary	System 1 / 1
Water level in the reactors	Data measured by the water gauge, which monitor the fuel range	Main indicator	System A 1 / 1 Ch System B 1 / 1 Ch
Pressure in the reactor	Measure voltage value of pressure instrument by the main indicator panel and convert to the pressure. One representing value is noted among multiple data on each System A, B.	Unit 1 Temporary Unit 2/3 Measures voltage value through the main indicator panel and converts them to the pressure	Temporary indicator: 1 / 1 system Main: System A 1 / 2 Ch System B 1 / 2 Ch
Temperature in the reactor	Since there is no water inflow at the points, where thermometers are set, no data is collected.	—	—
Temperature around the reactor vessel	Data measured at feed-water nozzle and at reactor vessel bottom are noted among multiple data to view the whole picture.	Main recorder	Point of Feed-water nozzle 1 / 4 Ch reactor vessel bottom 1 / 2 Ch (Unit 1) 1 / 1 Ch (Unit 2/3)
Pressure in D/W · S/C	Data from main indicator. Measure voltage value by the main indicator panel converted to the pressure in case main indicator are not in function. (D/W : Dry Well, S/C : Suppression Chamber)	Unit 1/2: Main indicator Unit 3: Main indicator panel (converted from voltage) :	Main indicator system 1 / 1 Main recorder regular use 1 / 1 Ch wide range 1 / 1 Ch
D/W Atmosphere temperature	Data at upper point (RPV Bellows Air) and middle point (HVH return) are noted among multiple data to view the whole picture. (RPV : Reactor Pressure Vessel, HVH : Heating Ventilating Handling Unit)	Main recorder	RPV Bellows Air 1 / 5 Ch D/W HVH return 1 / 5 Ch
CAMS radiation monitor	Data from the instrument reading of main indicator. (CAMS : Containment Atmospheric Monitoring System)	Main indicator	D/W System A 1 / 1 Ch System B 1 / 1 Ch S/C System A 1 / 1 Ch System B 1 / 1 Ch
Temperature in S/C	Data from the instrument reading of main recorder. One representing value is noted among multiple data on each System A, B.	Main recorder	System A 1 / 4 Ch (Unit 1) 、 8 Ch (Unit 2/3) System B 1 / 4 Ch (Unit 1) 、 8 Ch (Unit 2/3)
Temperature in the spent fuel pool	Data from the instrument reading of main recorder or temporary indicator. (Non-thermal mode : Urgent Heat load Mode, SHC mode : Shut down Cooling Mode)	Unit 1/2/3: Main recorder Unit 4: Temporary indicator	Main: 1 / 2 Ch (Unit 1) 、 1 Ch (Unit 2~3) Temporary indicator: 1 / 1 system (Unit 4)
FPC skimmer surge tank level	Data from the instrument reading of main indicator (FPC : Fuel Pool Cooling and Filtering System)	Main indicator	System 1 / 1

### ■ Supplemental explanation for notes

Item	Contents	Status As of 06:00 on June 14
Instrument failure	Instrument failure : down of instrument reading (over) scale/failure of instrument	Unit 1 Spent fuel pool temperature, CAMS D/W radiation monitor Unit 2 Temperature at reactor vessel bottom, pressure in S/C, RPV Bellows Air temperature, CAMS S/C(B) radiation monitor Unit 3 Spent fuel pool temperature, level of skimmer surge tanks Unit 4 Spent fuel pool temperature
Not covered for collecting data	Unit 4: Monitoring is not implemented since all fuel are takeoff. Unit 5/6: Monitoring is not implemented since heat removal of reactor is functioning	
Continuously monitoring the status	Inaccurate Data defined from relation with other Parameters such as negative figure.	Unit 1 feed-water nozzle temperature, pressure in D/W, CAMS S/C radiation monitor Unit 2 Reactor pressure, pressure in D/W, CAMS S/C(A) radiation monitor Unit 3 Reactor pressure, RPV bellow air temperature, feed-water nozzle temperature, CAMS D/W(A) · S/C radiation monitor