


Fukushima Daiichi Nuclear Power Station Unit 2 Parameters of Water level and Pressure



Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]
Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.
We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room(mSv/h)	note
6/22 2:00	-1450	-2150	-0.020	-0.007	0.010		1.41E+01	1.55E+01	2.30E-01	1.97E+01	0.012	
6/22 5:00	-1450	-2150	-0.018	-0.007	0.010		1.41E+01	1.55E+01	2.31E-01	1.97E+01	0.014	
6/22 8:00	-1450	-2150	-0.016	-0.005	0.010		1.41E+01	1.55E+01	2.31E-01	1.96E+01	0.015	
6/22 11:00	-1450	-2150	-0.016	-0.005	0.010		1.41E+01	1.55E+01	2.33E-01	1.95E+01	0.011	
6/22 14:00		-2150	-0.014	-0.002	0.010		1.41E+01	1.54E+01	2.33E-01	1.92E+01	0.010	Indicator being inspected (Reactor water level fuel range A)
6/22 17:00		-2150	-0.014	-0.002	0.010		1.41E+01	1.54E+01	2.32E-01	1.92E+01	0.011	Indicator being inspected (Reactor water level fuel range A)
6/22 20:00		-2150	-0.014	-0.005	0.010		1.41E+01	1.54E+01	2.32E-01	1.91E+01	0.014	Indicator being inspected (Reactor water level fuel range A)
6/22 23:00		-2150	-0.016	-0.005	0.010		1.41E+01	1.54E+01	2.32E-01	1.90E+01	0.014	Indicator being inspected (Reactor water level fuel range A)
6/23 2:00		-2150	-0.016	-0.005	0.010		1.41E+01	1.54E+01	2.33E-01	1.89E+01	0.012	Indicator being inspected (Reactor water level fuel range A)
6/23 5:00		-2150	-0.014	-0.005	0.010		1.41E+01	1.54E+01	2.33E-01	1.88E+01	0.012	Indicator being inspected (Reactor water level fuel range A)
6/23 8:00		-2200	-0.018	-0.005	0.010		1.41E+01	1.54E+01	2.35E-01	1.87E+01	0.011	Indicator being inspected (Reactor water level fuel range A)
6/23 11:00		-2150	-0.018	-0.005	0.010		1.40E+01	1.54E+01	2.35E-01	1.85E+01	0.012	Indicator being inspected (Reactor water level fuel range A)
6/23 14:00		-2150	-0.014	-0.005	0.005		1.40E+01	1.54E+01	2.36E-01	1.84E+01	0.012	Indicator being inspected (Reactor water level fuel range A)
6/23 17:00		-2150	-0.016	-0.007	0.005		1.40E+01	1.54E+01	2.37E-01	1.84E+01	0.012	Indicator being inspected (Reactor water level fuel range A)
6/23 20:00		-2200	-0.016	-0.005	0.005		1.40E+01	1.54E+01	2.38E-01	1.83E+01	0.012	Indicator being inspected (Reactor water level fuel range A)
6/23 23:00		-2150	-0.018	-0.007	0.005		1.40E+01	1.54E+01	2.39E-01	1.83E+01	0.012	Indicator being inspected (Reactor water level fuel range A)
6/24 2:00		-2150	-0.016	-0.005	0.005		1.40E+01	1.54E+01	2.39E-01	1.83E+01	0.012	Indicator being inspected (Reactor water level fuel range A)
6/24 5:00		-2150	-0.018	-0.007	0.005		1.40E+01	1.54E+01	2.39E-01	1.83E+01	0.011	Indicator being inspected (Reactor water level fuel range A)
6/24 8:00		-2150	-0.016	-0.005	0.005		1.40E+01	1.54E+01	2.39E-01	1.82E+01	0.011	Indicator being inspected (Reactor water level fuel range A)
6/24 11:00		-2150	-0.014	-0.005	0.005		1.40E+01	1.54E+01	2.39E-01	1.82E+01	0.014	Indicator being inspected (Reactor water level fuel range A)
6/24 14:00		-2150	-0.011	-0.002	0.005		1.40E+01	1.54E+01	2.39E-01	1.82E+01	0.014	Indicator being inspected (Reactor water level fuel range A)
6/24 17:00		-2150	-0.014	-0.002	0.005		1.40E+01	1.54E+01	2.38E-01	1.82E+01	0.013	Indicator being inspected (Reactor water level fuel range A)
6/24 20:00	-1900	-2150	0.012	-	0.005		1.40E+01	1.54E+01	2.38E-01	1.83E+01	0.012	
6/24 23:00	-1900	-2150	0.011	-	0.005		1.40E+01	1.54E+01	2.38E-01	1.85E+01	0.013	
6/25 2:00	-1850	-2150	0.011	-	0.005		1.40E+01	1.54E+01	2.37E-01	1.82E+01	0.013	
6/25 5:00	-1800	-2150	0.011	-	0.005		1.40E+01	1.53E+01	2.37E-01	1.81E+01	0.012	
6/25 8:00	-1750	-2150	0.010	-	0.005		1.40E+01	1.53E+01	2.36E-01	1.79E+01	0.015	
6/25 11:00	-1750	-2150	0.009	-	0.005		1.40E+01	1.53E+01	2.36E-01	1.77E+01	0.012	
6/25 14:00	-1750	-2150	0.009	-	0.005		1.40E+01	1.53E+01	2.35E-01	1.76E+01	0.012	
6/25 17:00	-1850	-2150	0.009	-	0.005		1.40E+01	1.53E+01	2.35E-01	1.77E+01	0.014	
6/25 20:00	-1800	-2150	0.009	-	0.005		1.40E+01	1.53E+01	2.34E-01	1.76E+01	0.012	
6/25 23:00	-1800	-2150	0.009	-	0.005		1.40E+01	1.53E+01	2.34E-01	1.75E+01	0.012	
6/26 2:00	-1800	-2150	0.009	-	0.005		1.40E+01	1.53E+01	2.33E-01	1.74E+01	0.011	
6/26 5:00	-1800	-2150	0.009	-	0.005		1.39E+01	1.53E+01	2.33E-01	1.74E+01	0.011	
6/26 8:00	-1800	-2150	0.009	-	0.005		1.39E+01	1.53E+01	2.32E-01	1.74E+01	0.012	
6/26 11:00	-1800	-2150	0.009	-	0.005		1.39E+01	1.53E+01	2.32E-01	1.74E+01	0.012	
6/26 14:00	-1800	-2150	0.009	-	0.005		1.39E+01	1.53E+01	2.31E-01	1.73E+01	0.011	
6/26 17:00	-1800	-2150	0.009	-	0.005		1.39E+01	1.53E+01	2.31E-01	1.69E+01	0.011	
6/26 20:00	-1800	-2150	0.009	-	0.005		1.39E+01	1.53E+01	2.31E-01	1.69E+01	0.013	
6/26 23:00	-1800	-2150	0.009	-	0.005		1.39E+01	1.53E+01	2.30E-01	1.68E+01	0.012	
6/27 2:00	-1800	-2150	0.009	-	0.005		1.39E+01	1.53E+01	2.30E-01	1.67E+01	0.012	
6/27 5:00	-1850	-2150	0.009	-	0.005		1.39E+01	1.53E+01	2.30E-01	1.66E+01	0.012	
6/27 7:30	-1850	-2150	0.009	-	0.005		1.39E+01	1.53E+01	2.29E-01	1.65E+01	0.012	
6/27 8:00												Not available due to changeover of station power source
6/27 11:00												Not available due to changeover of station power source
6/27 14:00												Not available due to changeover of station power source
6/27 15:30	-1900	-2150	0.009	-	0.005		1.34E+01	1.52E+01	2.28E-01	3.40E+01	0.010	
6/27 17:00	-1900	-2150	0.009	-	0.005		1.35E+01	1.52E+01	2.29E-01	2.02E+01	0.012	
6/27 20:00	-1900	-2150	0.009	-	0.005		1.36E+01	1.52E+01	2.29E-01	1.78E+01	0.012	
6/27 23:00	-1900	-2150	0.009	-	0.005		1.37E+01	1.52E+01	2.28E-01	1.72E+01	0.010	
6/28 2:00	-1900	-2150	0.009	-	0.005		1.37E+01	1.52E+01	2.28E-01	1.53E+01	0.010	
6/28 5:00	-1900	-2150	0.009	-	0.005		1.37E+01	1.52E+01	2.27E-01	1.63E+01	0.010	

measurement instrument malfunction

measurement instrument malfunction