

The red words are revised due to the ' Incorrect data for pressure at Primary Containment Vessel of Unit1 ' which we announced on November 29.

[Note]  
Some indicators might not be functioning prc condition for usage affected by the earthqua We comprehensively evaluate situation in plar information from indicators and also focusing of indicators into consideration.

## Fukushima Daiichi Nuclear Power Station Plant Parameters

As of 06:00 on November 14

Unit	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5
Status of water injection to the reactor	Fresh water feeding Feed water system 7.7m <sup>3</sup> /h (as of 5:00 , 11/14)	Fresh water feeding Feed water system 2.8m <sup>3</sup> /h, CS line 7.3m <sup>3</sup> /h (as of 5:00 , 11/14)	Fresh water feeding Feed water system 2.7m <sup>3</sup> /h, CS line 8.1m <sup>3</sup> /h (as of 5:00 , 11/14)		※2 (Heat removal c injection is unnece
Water level in the reactor	Fuel range A: Downscale Fuel range B:-1790 mm (as of 5:00 , 11/14) ※3	Fuel range A: Downscale ※3 Fuel range B:-2111 mm ※3 (as of 5:00 , 11/14)	Fuel range A:-2221 mm ※3 Fuel range B:-2222 mm ※3 (as of 5:00 , 11/14)		Stoppage r 1829m (as of 6:00 ,
Pressure in the reactor	System A:0.012 MPa g System B:-MPa g (as of 5:00 , 11/14)	System A:0.007 MPa g System B:-MPa g (as of 5:00 , 11/14)	System A: Downscale (A)※3 System B: Downscale (C)※3 (as of 5:00 , 11/14)		0.010 MF (as of 6:00 ,
Water temperature of the reactor	(Since there is no water inflow in the system it is impossible to collect the data)				26.1 ℃ (as of 6:00 ,
Temperature around the reactor vessel	Temperature in feed-water nozzle:37.9 ℃ Temperature at reactor vessel bottom:38.6 ℃ (as of 5:00 , 11/14)	Temperature in feed-water nozzle:66.1 ℃ Temperature at reactor vessel bottom:69.1 ℃ (as of 5:00 , 11/14)	Temperature in feed-water nozzle:58.4 ℃ Temperature at reactor vessel bottom:69.0 ℃ (as of 5:00 , 11/14)	※2 (Monitoring is unnecessary since all fuel are takeoff)	※2 (monitoring reactor)
Pressure in D/W · S/C	D/W:0.1226 MPa abs* S/C:0.084 MPa abs (as of 5:00 , 11/14) ※3	D/W:0.109 MPa abs S/C: Downscale ※1 (as of 5:00 , 11/14)	D/W:0.1015 MPa abs S/C:0.1877 MPa abs (as of 5:00 , 11/14)		
D/W Atmosphere temperature	RPV bellow seal:39.7 ℃ HVH return:40.3 ℃ (as of 5:00 , 11/14)	RPV bellow seal:64.7 ℃ HVH return:70.2 ℃ (as of 5:00 , 11/14) ※3	RPV bellow seal:82.1 ℃ HVH return:59.4 ℃ (as of 5:00 , 11/14) ※3		
CAMS radiation monitor	D/W(A):1.00E-02Sv/h ※1 (B):1.48E+01Sv/h ※1 S/C(A):6.70E-01Sv/h (B):7.00E-01Sv/h (as of 5:00 , 11/14)	D/W(A):7.58E+00Sv/h ※1 (B):2.90E+00Sv/h ※1 S/C(A):6.00E-02Sv/h ※1 (B):3.24E+00Sv/h ※1 (as of 5:00 , 11/14)	D/W(A):3.23E+00Sv/h ※3 (B):2.19E+00Sv/h S/C(A):2.66E-01Sv/h (B):2.53E-01Sv/h (as of 5:00 , 11/14)		※2 (Monitoring is u reactor is functio
Temperature in S/C	System A:47.0 ℃ System B:47.0 ℃ (as of 5:00 , 11/14)	System A:49.8 ℃ System B:49.7 ℃ (as of 5:00 , 11/14)	System A:41.0 ℃ System B:41.2 ℃ (as of 5:00 , 11/14)		
Designed usable D/W pressure	0.384MPa g (0.485MPa abs)	0.384MPa g (0.485MPa abs)	0.384MPa g (0.485MPa abs)		
Designed usable D/W maximum pressure	0.427MPa g (0.528MPa abs)	0.427MPa g (0.528MPa abs)	0.427MPa g (0.528MPa abs)		
Temperature in the spent fuel pool	20.5 ℃ (as of 5:00 , 11/14)	22.2 ℃ (as of 5:00 , 11/14)	22.2 ℃ (as of 5:00 , 11/14)	31 ℃ (as of 5:00 , 11/14)	23.4 ℃ (as of 6:00 ,
FPC skimmer surge tank level	3510mm (as of 5:00 , 11/14)	4080mm (as of 5:00 , 11/14)	5500mm (as of 5:00 , 11/14)	4914mm (as of 5:00 , 11/14)	
Power source	Receiving offsite power (P/C2C)		Receiving offsite power (P/C4D)		
Others	Hydrogen concentration by Pressure Containment Vessel (PCV) gas management system, Unit 2: 1.4vol% (as of 5:00 , 11/14) *Data of Pressure in D/W of Unit 1 on 11/29 was corrected because it was incorrect.			Temperature in the Common Spent Fuel Storage: 25℃ (as of 9:50 , 11/13)	5u : SHC r (from 10:46 ,

Pressure conversion Gauge pressure(MPa g) = Absolute pressure(MPa abs) - atmospheric pressure (normal atmospheric pressure0.1013 MPa)  
Absolute pressure(MPa abs) = Gauge pressure(MPa g) + atmospheric pressure (normal atmospheric pressure0.1013 MPa)

※1 : Ins  
※2 : Nc  
※3 : coi

# Fukushima Daiichi Nuclear Power Station Supplemental explanation for the plant parameters

## ■Supplemental explanation for each parameter

Item	Recording manner	Measurement manner	Ch nu
Status of water injection to the reactor	Water inflow (CS line : Core Spray system)	Temporary	System 1 / 1
Water level in the reactors	Data measured by the water gauge, which monitor the fuel range	Temporary	System A 1 / 1 Ch System B 1 / 1 Ch
Pressure in the reactor	One representing value is noted among multiple data on each System A, B. Readings of temporary instruments are represented in A system for Unit 1 and 2.	Temporary	1 / 1 system (Unit 1) System A 1 / 2 Ch
Temperature in the reactor	Since there is no water inflow at the points, where thermometers are set, no data is collected.	—	—
Temperature around the reactor vessel	Data measured at feed-water nozzle and at reactor vessel bottom (1U, 3U : RPV Bottom Head, 2U : RPV Wall Above Bottom Head) are noted among multiple data to view the whole picture.	Temporary	Point of Feed-water reactor vessel bottom
Pressure in D/W · S/C	Data from temporary instrument. (D/W : Dry Well, S/C : Suppression Chamber)	Temporary	(D/W) wide range 1 / 1 Ch 1 / 1 system (Unit 1) 1 / 4 Ch (Unit 3) (S/C) 1 / 1 system (Unit 1, 1 / 2 Ch (Unit 3)
D/W Atmosphere temperature	Data at upper point (RPV Bellows Air) and middle point (HVH return) are noted among multiple data to view the whole picture. (RPV : Reactor Pressure Vessel, HVH : Heating Ventilating Handling Unit)	Temporary	RPV Bellows Air D/W HVH return
CAMS radiation monitor	Data from temporary instrument. (CAMS : Containment Atmospheric Monitoring System)	Temporary	D/W System A 1 / 1 System B 1 / 1 S/C System A 1 / 1 System B 1 / 1
Temperature in S/C	Data from temporary instrument. One representing value is noted among multiple data on each System A, B.	Temporary	System A 1 / 4 Ch (Unit 1) System B 1 / 4 Ch (Unit 2)
Temperature in the spent fuel pool	Data from temporary instrument. (Non-thermal mode : Urgent Heat load Mode, SHC mode : Shut down Cooling Mode)	Temporary	1 / 1 Ch (Unit 2) 1 / 1 system (Unit 1)
FPC skimmer surge tank level	<ul style="list-style-type: none"> <li>Unit 2, 4 are the FPC skimmer surge tank level measured temporary instrument.</li> <li>Unit 1, 3 are the FPC skimmer surge tank level estimated from temporary pressure gages.(reference value) (FPC : Fuel Pool Cooling system)</li> </ul>	Temporary	1 / 1 system

## ■Supplemental explanation for notes

Item	Contents	Status As of 06:00 on November 11, 2011
Instrument failure	Instrument failure : down of instrument reading (over) scale / failure of instrument	Unit 1 CAMS D/W radiation monitor Unit 2 Pressure in S/C, CAMS D/W(B) radiation monitor, CAMS D/W radiation monitor Unit 3 —
Not covered for collecting data	Unit 4: Monitoring is not implemented since all fuel are takeoff. Unit 5/6: Monitoring is not implemented since heat removal of reactor is functioning	—

Continuously monitoring the status	Inaccurate Data defined from relation with other Parameters such as negative figure.	Unit 1 Reactor water level(B), Pressure in S/C Unit 2 Reactor water level, RPV bellow air temperature, Unit 3 Reactor water level, reactor pressure, RPV bellow air te CAMS D/W(A) radiation monitor
------------------------------------	--	---



umber or number of systems
1/2) System B 1 / 2Ch (Unit 3)
nozzle 1 / 4Ch m 1 / 2Ch (Unit 1) 1 / 1Ch (Unit 2/3)
(Unit 1) 2)
/2)
1 / 5Ch 1 / 5Ch
1 / 1Ch 1 / 1Ch 1 / 1Ch 1 / 1Ch
Unit 1) , 8Ch (Unit 2/3) Unit 1) , 8Ch (Unit 2/3)
1/3/4)

umber 14
1S S/C(B) radiation monitor

temperature.