

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
2011/3/12 10:19					0.750						
2011/3/12 10:20					0.750						
2011/3/12 10:27					0.750						
2011/3/12 10:33	-500	-700									
2011/3/12 10:38	-550	-700			0.740	0.740					
2011/3/12 10:47	-550	-750			0.740	0.740					
2011/3/12 10:52	-600	-750			0.750	0.750					
2011/3/12 11:00	-700	-800			0.750	0.750					
2011/3/12 11:10	-800	-800									
2011/3/12 11:20	-900	-800			0.750	0.750					
2011/3/12 11:30	-1100	-900			0.750	0.750					
2011/3/12 11:41	-1250	-1000			0.750	0.750					
2011/3/12 11:52	-1350	-1100			0.750	0.740					
2011/3/12 12:05	-1500	-1400			0.750	0.740					
2011/3/12 12:12	-1550	-1450			0.750	0.740					
2011/3/12 12:35	-1700	-1450			0.750	0.750					
2011/3/12 12:45	-1700	-1450			0.750	0.745					
2011/3/12 12:55	-1700	-1500			0.750	0.745					
2011/3/12 13:05	-1700	-1500			0.750	0.745					
2011/3/12 13:14	-1700	-1550			0.750	0.745					
2011/3/12 13:26	-1700	-1550			0.755	0.745					
2011/3/12 13:38	-1700	-1550			0.755	0.745					
2011/3/12 13:48	-1700	-1650			0.755	0.745					
2011/3/12 13:52	-1700	-1650			0.755	0.744					
2011/3/12 13:58	-1700	-1650			0.755	0.744					
2011/3/12 14:05	-1700	-1650			0.735	0.735					
2011/3/12 14:10	-1700	-1650			0.730	0.730					
2011/3/12 14:18	-1700	-1600			0.725	0.725					
2011/3/12 14:20	-1700	-1600			0.710	0.710					
2011/3/12 14:25	-1700	-1600			0.690	0.690					
2011/3/12 14:30	-1700	-1600			0.670						
2011/3/12 14:35	-1700	-1600			0.640	0.640					
2011/3/12 14:40	-1700	-1650			0.620	0.620					

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
2011/3/12 14:41	-1700	-1650			0.610	0.610					
2011/3/12 14:50	-1700	-1600			0.580	0.580					
2011/3/12 14:52	-1700	-1650			0.570	0.570					
2011/3/12 14:54	-1700	-1650			0.565	0.565					
2011/3/12 14:56	-1700	-1650			0.555	0.555					
2011/3/12 14:58	-1700	-1650			0.550	0.550					
2011/3/12 15:00					0.540	0.540					
2011/3/12 15:02					0.535	0.535					
2011/3/12 15:04	-1700	-1650			0.530	0.530					
2011/3/12 15:06	-1700	-1650			0.525	0.525					
2011/3/12 15:08	-1700	-1650			0.525	0.525					
2011/3/12 15:10	-1700	-1650			0.520	0.515					
2011/3/12 15:12	-1700	-1650			0.520	0.515					
2011/3/12 15:14	-1700	-1650			0.525	0.520					
2011/3/12 15:18	-1700	-1650			0.525	0.520					
2011/3/12 15:20	-1700	-1650			0.530	0.520					
2011/3/12 15:22	-1700	-1650			0.535	0.520					
2011/3/12 15:26	-1700	-1650			0.535	0.520					
2011/3/12 15:28	-1700	-1650			0.540	0.525					
2011/3/12 15:30	-1700	-1650			0.540	0.525					
2011/3/12 15:35	-1700	-1650			0.540	0.525					
2011/3/12 15:37	-1700	-1650									
2011/3/12 16:10	-1700	-1650									
2011/3/12 16:31	-1700	-1650									
2011/3/12 16:45	-1700	-1700									
2011/3/12 17:00	-1700	-1700									
2011/3/12 17:30	-1700	-1700									
2011/3/12 18:00	-1700	-1700									
2011/3/12 20:08		-1700		0.370							
2011/3/12 20:20				0.367							
2011/3/12 20:30		-1600		0.367							
2011/3/12 21:00		-1750		0.360							
2011/3/12 21:30		-1700		0.355							

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
2011/3/12 22:00		-1700		0.355							
2011/3/12 22:20		-1700		0.353							
2011/3/12 23:00		-1750		0.358							
2011/3/12 23:30		-1750		0.368							
2011/3/13 0:00		-1750		0.368							
2011/3/13 0:30		-1750		0.378							
2011/3/13 1:00		-1700		0.375							
2011/3/13 2:00		-1700		0.375							
2011/3/13 3:00		-1700		0.373							
2011/3/13 4:00		-1700		0.248							
2011/3/13 5:00		-1700	0.389								
2011/3/13 5:30		-1700	0.389								
2011/3/13 6:00		-1700	0.389								
2011/3/13 6:30		-1700	0.389								
2011/3/13 7:00		-1700	0.394								
2011/3/13 7:30		-1700	0.392								
2011/3/13 8:00		-1700	0.392								
2011/3/13 8:20		-1700	0.396								
2011/3/13 8:55		-1700	0.398								
2011/3/13 9:25		-1700	0.392								
2011/3/13 9:55		-1700	0.392								
2011/3/13 10:35		-1750	0.402								
2011/3/13 10:55		-1700	0.398								
2011/3/13 11:25		-1700	0.404								
2011/3/13 11:55		-1700	0.405								
2011/3/13 12:20		-1700	0.405								
2011/3/13 12:40		-1700	0.405								
2011/3/13 13:00		-1700	0.408								
2011/3/13 13:37					0.595	0.590					
2011/3/13 14:00		-1700	0.413		0.595	0.590					
2011/3/13 14:10		-1700	0.413		0.600	0.600					
2011/3/13 14:30		-1700		0.415	0.600	0.600					
2011/3/13 14:45		-1700		0.415	0.600	0.600					

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
2011/3/13 15:00		-1700	0.415		0.600	0.600					
2011/3/13 15:15		-1700		0.418	0.605	0.600					
2011/3/13 15:30		-1700		0.418	0.605	0.600					
2011/3/13 15:45		-1700		0.420	0.605	0.600					
2011/3/13 16:00		-1700	0.420		0.605	0.600					
2011/3/13 16:15		-1700	0.420		0.605	0.600					
2011/3/13 16:30		-1700	0.420		0.605	0.600					
2011/3/13 16:45		-1700	0.422		0.605	0.600					
2011/3/13 17:00		-1700	0.422		0.605	0.600					
2011/3/13 17:15		-1700	0.418		0.605	0.600					
2011/3/13 17:30		-1700	0.415		0.600	0.600					
2011/3/13 18:00		-1700	0.415		0.600	0.600					
2011/3/13 18:20		-1700	0.408		0.590	0.590					
2011/3/13 18:40		-1700	0.403		0.590	0.585					
2011/3/13 19:00		-1750	0.398		0.580	0.580					
2011/3/13 19:30		-1750	0.393		0.575	0.570					
2011/3/13 19:45		-1750	0.388		0.570	0.570					
2011/3/13 20:00		-1750	0.388		0.570	0.565					
2011/3/13 20:15		-1750	0.382		0.560	0.560					
2011/3/13 20:30		-1750	0.382		0.560	0.560					
2011/3/13 20:45		-1750	0.378		0.550	0.550					
2011/3/13 21:00		-1750	0.382		0.550	0.550					
2011/3/13 21:15		-1750	0.380		0.550	0.550					
2011/3/13 21:30		-1750	0.380		0.550	0.550					
2011/3/13 21:45		-1700			0.550	0.550					
2011/3/13 22:00		-1700			0.540	0.540					
2011/3/13 22:15		-1750	0.370		0.540	0.540					
2011/3/13 22:30		-1750	0.030	0.368	0.540	0.540					
2011/3/13 22:45		-1750	0.028	0.366	0.540	0.530					
2011/3/13 23:00		-1750	0.062	0.366	0.540	0.530					
2011/3/13 23:15		-1750	0.068	0.360	0.530	0.530					
2011/3/13 23:30		-1750	0.056	0.360	0.530	0.530					
2011/3/14 0:00		-1700	0.156	0.356	0.520	0.520					

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
2011/3/14 0:15		-1700	0.072	0.356	0.520	0.520					
2011/3/14 0:30		-1700	0.070	0.356	0.520	0.520					
2011/3/14 0:45		-1700	0.106	0.356	0.520	0.520					
2011/3/14 1:00		-1700	0.056	0.350	0.515	0.510					
2011/3/14 1:15		-1700	0.150	0.350							
2011/3/14 1:30		-1750	0.050	0.350	0.515	0.510					
2011/3/14 1:45		-1750	0.040	0.350	0.515	0.505					
2011/3/14 2:00		-1700	0.040	0.350	0.510	0.505					
2011/3/14 2:15		-1700	0.040	0.346	0.510	0.505					
2011/3/14 2:30		-1700	0.036	0.342	0.505	0.500					
2011/3/14 2:45		-1700	0.032	0.340	0.505	0.500					
2011/3/14 3:00		-1700	0.032	0.340	0.505	0.500					
2011/3/14 3:15		-1700	0.032	0.340	0.500	0.500					
2011/3/14 3:30		-1700	0.032	0.340	0.500	0.495					
2011/3/14 3:45		-1700	0.032	0.338	0.500	0.495					
2011/3/14 4:00		-1700	0.032	0.338	0.495	0.490					
2011/3/14 4:15		-1700	0.030	0.328	0.495	0.490					
2011/3/14 4:30		-1700	0.030	0.328	0.495	0.490					
2011/3/14 4:45		-1700	0.038	0.332	0.490	0.485					
2011/3/14 5:00	-1700	-1700	0.030	0.326	0.485	0.480					
2011/3/14 5:15	-1700	-1700	0.030	0.326	0.485	0.480					
2011/3/14 5:30	-1750	-1750	0.030	0.326	0.480	0.480					
2011/3/14 5:45	-1750	-1750	0.030	0.323	0.480	0.475					
2011/3/14 6:00	-1750	-1750	0.030	0.326	0.480	0.475	1.64E+02		2.66E+01		
2011/3/14 6:15	-1750	-1750	0.030	0.318	0.480	0.470					
2011/3/14 6:30	-1750	-1750	0.036	0.320	0.475	0.470	1.62E+02		2.66E+01		
2011/3/14 6:45	-1750	-1750	0.030	0.316	0.475	0.470					
2011/3/14 7:00	-1750	-1750	0.036	0.318	0.470	0.467	1.61E+02		2.65E+01		
2011/3/14 7:15	-1750	-1750	0.038	0.318	0.465	0.460					
2011/3/14 7:30	-1750	-1750	0.038	0.316	0.465	0.460	1.60E+02		2.65E+01		
2011/3/14 7:45							1.60E+02		2.65E+01		
2011/3/14 8:00	-1750	-1750	0.038	0.316	0.460	0.455	1.60E+02		2.65E+01		
2011/3/14 8:15							1.57E+02		2.65E+01		

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
2011/3/14 8:30	-1800	-1750	0.038	0.312	0.460	0.455	1.52E+02		2.65E+01		
2011/3/14 8:45	-1800	-1750					1.49E+02		2.65E+01		
2011/3/14 9:00	-1800	-1750	0.036	0.306	0.450	0.445	1.45E+02		2.65E+01		
2011/3/14 9:35	-1800	-1750	0.040	0.306	0.450	0.445	1.41E+02		2.65E+01		
2011/3/14 9:45	-1800	-1750	0.040	0.306	0.450	0.445	1.40E+02		2.65E+01		
2011/3/14 10:00	-1800	-1750	0.042	0.310	0.445	0.440	1.39E+02		2.65E+01		
2011/3/14 10:15	-1800	-1750					1.37E+02		2.65E+01		
2011/3/14 10:30	-1800	-1750	0.038	0.306	0.440	0.435	1.35E+02		2.65E+01		
2011/3/14 10:45	-1800	-1750					1.33E+02		2.65E+01		
2011/3/14 11:00			0.038	0.306							
2011/3/14 12:00	-1800	-1750	0.040	0.306			1.23E+02		2.64E+01		
2011/3/14 12:30	-1800	-1750	0.040	0.306			1.18E+02		2.64E+01		
2011/3/14 14:45	-1800	-1750	0.046	0.300			9.80E+01		2.62E+01		
2011/3/14 15:00	-1800	-1750	0.046	0.298			9.48E+01		2.62E+01		
2011/3/14 15:30	-1750	-1750	0.048	0.300			9.17E+01		2.62E+01		
2011/3/14 16:00	-1750	-1750	0.052	0.300			8.97E+01		2.62E+01		
2011/3/14 19:15	-1750	-1750	0.062	0.272			7.88E+01		2.59E+01		
2011/3/14 21:00	-1750	-1750	0.060	0.270			6.56E+01		2.57E+01		
2011/3/14 22:00	-1700	-1700	0.058	0.260			6.10E+01		2.56E+01		
2011/3/15 2:30	-1700	-1700									
2011/3/15 3:00	-1700	-1700	0.068	0.248			5.73E+01		2.46E+01		
2011/3/15 4:00	-1750	-1750	0.068	0.240			6.27E+01		2.47E+01		
2011/3/15 5:00	-1750		0.066	0.240			7.74E+01		2.47E+01		
2011/3/15 11:25	-1700	-1700	0.078	0.206			8.70E+01		2.42E+01		
2011/3/15 11:42	-1700	-1700	0.080	0.206			8.58E+01		2.41E+01		
2011/3/15 11:58	-1700	-1700	0.079	0.202			8.44E+01		2.41E+01		
2011/3/15 13:00	-1700	-1700	0.076	0.206			8.19E+01		2.41E+01		
2011/3/15 15:25	-1800	-1750	0.082	0.195			1.04E+02		2.37E+01		
2011/3/15 16:10	-1800	-1750	0.090	0.200			9.75E+01		2.36E+01		
2011/3/15 18:43	-1800	-1800	0.188				6.89E+01		2.33E+01		
2011/3/16 1:24	-1750	-1750	0.180	0.096			3.84E+01		2.31E+01		
2011/3/16 1:44	-1750	-1750	0.092	0.176			3.50E+01		2.36E+01		
2011/3/16 1:54	-1750	-1750	0.092	0.176			3.44E+01		2.33E+01		

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
2011/3/16 5:00	-1800	-1750	0.096	0.178			7.92E+00		2.42E+01		
2011/3/16 5:10	-1800	-1750		0.180			4.15E+00		2.42E+01		
2011/3/16 5:15	-1800	-1750	0.098	0.180			4.15E+00		2.42E+01		
2011/3/16 5:35	-1800	-1750	0.100	0.180			9.81E+01		3.64E+01		
2011/3/16 6:55	-1800	-1750	0.120	0.186							
2011/3/16 12:35	-1750	-1750	0.230	0.190							
2011/3/16 15:30	-1750	-1750	0.232	0.188				1.85E+01		2.20E+01	
2011/3/16 20:00	-1800	-1800	0.228	0.188				3.70E-03		2.27E+01	
2011/3/16 20:20	-1800	-1800	0.228	0.188				3.70E-03		2.27E+01	
2011/3/16 23:50	-1800	-1750	0.238	0.188				3.05E-03		2.29E+01	
2011/3/17 3:10	-1750	-1750	0.220	0.172				3.09E-03		2.40E+01	
2011/3/17 6:00	-1750	-1750	0.206	0.168				3.15E-03		1.38E+01	
2011/3/17 11:00	-1800	-1800	0.192	0.160				3.60E-03		2.38E+01	
2011/3/17 11:15	-1800	-1800	0.192	0.160				2.70E-03		3.08E+01	
2011/3/17 11:30	-1800	-1800	0.192	0.160				4.10E-03		3.15E+01	
2011/3/17 12:50	-1700	-1750	0.206	0.160				4.10E-03		3.16E+01	
2011/3/17 21:40	-1700		0.192	0.168				3.23E-03		4.82E+01	
2011/3/17 21:50	-1700		0.192	0.168				4.15E-03		4.81E+01	
2011/3/18 2:20	-1700		0.186	0.158				2.65E-03		4.78E+01	
2011/3/18 2:50	-1700		0.182	0.158				3.80E-03		4.77E+01	
2011/3/18 7:40	-1700		0.190	0.162				3.50E-03		4.70E+01	
2011/3/18 7:55	-1700		0.188	0.162				3.75E-03		4.69E+01	
2011/3/18 9:40	-1750	-1700	0.192	0.160				2.75E-03		4.67E+01	
2011/3/18 16:00	-1700	-1800	0.212	0.170	0.180	0.160		3.56E-03		4.60E+01	
2011/3/18 20:55	-1750	-1800	0.212	0.162	0.180	0.160		2.97E-03		4.54E+01	
2011/3/18 21:10	-1750	-1800	0.216	0.168	0.180	0.160		4.00E-03		4.53E+01	
2011/3/19 2:40	-1700	-1700	0.228	0.172	0.180	0.165		3.55E-03		4.46E+01	
2011/3/19 3:30	-1750	-1750	0.228	0.172	0.180	0.165		2.63E-03		1.45E+01	
2011/3/19 7:10	-1700	-1700	0.222	0.170	0.180	0.170		2.33E-03		4.40E+01	
2011/3/19 11:00	-1800	-1700	0.218	0.168	0.180	0.170		2.32E-03		4.35E+01	
2011/3/19 16:30	-1750	-1750	0.228	0.178	0.180	0.170		3.67E+01		4.29E+01	
2011/3/19 16:45	-1750	-1750	0.228	0.178	0.180	0.170		3.60E+01		4.28E+01	
2011/3/19 16:50	-1750	-1750	0.228	0.178	0.180	0.170		3.60E+01		4.28E+01	
2011/3/19 19:00	-1750	-1700	0.232	0.180	0.170	0.165		3.35E+01		4.26E+01	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
2011/3/19 22:30	-1750	-1750	0.228	0.182	0.180	0.170		2.49E+01		4.21E+01	
2011/3/20 0:00	-1750	-1750	0.228	0.186	0.180	0.170		1.89E+01		4.19E+01	
2011/3/20 4:50	-1750	-1750	0.226	0.180	0.180	0.170		1.20E+01		4.13E+01	
2011/3/20 5:00	-1750	-1750	0.226	0.180	0.180	0.170		1.11E+01		4.12E+01	
2011/3/20 10:00	-1750	-1750	0.226	0.182	0.170	0.160		3.83E+00		4.07E+01	
2011/3/20 11:00	-1750	-1750	0.216	0.178	0.170	0.160		2.76E+01		4.05E+01	
2011/3/20 15:00	-1700	-1750	0.208	0.176	0.170	0.160		1.20E+01		4.00E+01	
2011/3/20 22:00	-1750	-1800	0.216	0.178	0.160	0.160		4.80E+01		3.91E+01	
2011/3/21 3:00	-1750	-1800	0.216	0.176	0.160	0.160		4.66E+01		3.85E+01	
2011/3/21 8:00	-1750	-1750	0.218	0.182	0.160	0.160		4.71E+01		3.79E+01	
2011/3/21 13:30	-1750	-1750	0.218	0.188	0.160	0.155		4.75E+01		3.74E+01	
2011/3/21 14:00	-1750	-1750	0.220	0.190	0.160	0.155		4.76E+01		3.73E+01	
2011/3/21 14:25	-1750	-1750	0.220	0.190	0.160	0.155		4.76E+01		3.73E+01	
2011/3/21 14:30	-1750	-1750	0.220	0.190	0.160	0.155		4.76E+01		3.73E+01	
2011/3/22 0:15	-1750	-1700	0.218	0.190	0.160	0.155		4.77E+01		3.62E+01	
2011/3/22 5:00	-1750	-1700	0.232	0.200	0.160	0.155		4.80E+01		3.56E+01	
2011/3/22 6:00	-1750	-1700	0.218	0.186	0.160	0.155		4.80E+01		3.55E+01	
2011/3/22 10:30	-1800	-1750	0.250	0.228	0.175	0.155		4.79E+01		3.49E+01	
2011/3/22 11:20	-1800	-1750	0.252	0.228	0.175	0.155		4.78E+01		3.49E+01	
2011/3/22 15:30	-1800	-1750	0.240	0.188	0.180	0.160		4.65E+01		3.40E+01	
2011/3/22 17:00	-1800	-1750	0.242	0.212	0.180	0.160		4.68E+01		3.40E+01	
2011/3/22 18:00	-1750	-1750	0.242	0.212	0.180	0.160		4.64E+01		3.40E+01	
2011/3/22 23:00	-1750	-1750	0.246	0.218	0.185	0.160		4.71E+01		3.36E+01	
2011/3/23 4:00	-1750	-1750	0.336	0.300	0.260	0.240		4.60E+01		3.16E+01	
2011/3/23 4:40	-1750	-1750	0.348	0.322	0.280	0.260		4.76E+01		3.15E+01	
2011/3/23 9:00	-1750	-1750	0.376	0.342	0.305	0.285		4.88E+01		3.06E+01	
2011/3/23 9:30	-1750	-1750	0.412	0.368	0.310	0.290					
2011/3/23 10:00	-1750	-1750	0.388	0.358	0.320	0.295					
2011/3/23 10:30	-1750	-1750	0.390	0.358	0.320	0.295					
2011/3/23 11:00	-1750	-1750	0.396	0.360	0.325	0.300					
2011/3/23 11:30	-1750	-1750	0.400	0.366	0.320	0.300					
2011/3/23 12:00	-1750	-1750	0.396	0.356	0.320	0.300					
2011/3/23 12:30	-1750	-1750	0.392	0.362	0.325	0.305					
2011/3/23 13:00	-1750	-1750	0.400	0.366	0.330	0.305					
2011/3/23 13:30	-1750	-1700	0.400	0.370	0.330	0.310					

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
2011/3/23 14:00	-1700	-1700	0.418	0.398	0.345	0.320		4.80E+01		2.98E+01	
2011/3/23 14:20	-1700	-1700	0.390	0.430	0.340	0.320		4.80E+01		2.99E+01	
2011/3/23 14:30	-1700	-1700	0.428	0.390	0.340	0.320					
2011/3/23 15:00	-1700	-1700	0.416	0.380	0.345	0.325					
2011/3/23 15:30	-1700	-1700	0.416	0.378	0.345	0.330					
2011/3/23 16:00	-1750	-1700	0.422	0.398	0.360	0.330					
2011/3/23 18:09	-1740	-1670	0.483		0.347	0.339					
2011/3/23 18:10	-1740	-1680	0.481		0.347	0.339					
2011/3/23 19:32	-1740	-1680	0.490		0.360	0.346					
2011/3/23 20:21	-1740	-1660	0.492		0.354	0.347					
2011/3/23 21:00	-1700	-1650	0.440	0.416	0.375	0.355		3.12E+01		2.88E+01	
2011/3/23 23:00	-1750	-1750	0.466	0.440	0.380	0.365					
2011/3/24 1:00	-1700	-1700	0.456	0.430	0.385	0.370		4.39E+01		2.79E+01	
2011/3/24 3:00	-1700	-1700	0.470	0.440	0.395	0.380					
2011/3/24 5:00	-1700	-1700	0.472	0.446	0.400	0.390		4.37E+01		2.71E+01	
2011/3/24 7:00	-1700	-1700	0.480	0.450	0.400	0.390		4.37E+01		2.71E+01	
2011/3/24 9:00	-1700	-1700	0.496	0.466	0.400	0.400		4.41E+01		2.67E+01	
2011/3/24 11:00	-1700	-1700	0.480	0.446	0.400	0.395		4.35E+01		2.63E+01	
2011/3/24 13:00	-1700	-1650	0.470	0.430	0.390	0.382		4.24E+01		2.61E+01	
2011/3/24 17:00	-1650	-1650	0.488	0.408	0.355	0.355		4.09E+01		2.58E+01	
2011/3/24 20:00	-1700	-1650	0.430	0.402	0.345	0.340		4.05E+01		2.56E+01	
2011/3/24 21:45	-1700	-1650	0.420	0.388	0.330	0.325		4.13E+01		2.55E+01	
2011/3/24 22:00	-1700	-1650	0.422	0.388	0.325	0.325		4.16E+01		2.55E+01	
2011/3/25 0:00	-1700	-1650	0.416	0.388	0.325	0.320		4.16E+01		2.54E+01	
2011/3/25 2:00	-1700	-1650	0.418	0.398	0.325	0.315		4.11E+01		2.54E+01	
2011/3/25 6:00	-1700	-1650	0.406	0.390	0.310	0.305		4.00E+01		2.51E+01	
2011/3/25 10:00	-1650	-1650	0.388	0.388	0.295	0.290		3.89E+01		2.49E+01	
2011/3/25 14:00	-1650	-1600	0.380	0.388	0.280	0.280		3.78E+01		2.47E+01	
2011/3/25 15:45	-1650	-1600	0.376	0.382	0.275	0.275		3.78E+01		2.47E+01	
2011/3/25 16:00	-1650	-1600	0.378	0.382	0.275	0.275		3.72E+01		2.46E+01	
2011/3/25 16:30	-1650	-1600	0.380	0.380	0.275	0.275		3.71E+01		2.45E+01	
2011/3/25 18:30	-1650	-1600	0.376	0.376	0.275	0.275		3.67E+01		2.44E+01	
2011/3/25 23:00	-1650	-1600	0.388	0.392	0.275	0.275		3.60E+01		2.42E+01	
2011/3/26 5:00	-1650	-1600	0.392	0.400	0.270	0.270		3.53E+01		2.38E+01	
2011/3/26 9:30	-1650	-1600	0.418	0.400	0.270	0.270		3.51E+01		2.36E+01	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level(fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
2011/3/26 11:30	-1650	-1600	0.418	0.392	0.275	0.275		3.57E+01		2.35E+01	
2011/3/26 12:00	-1650	-1600	0.396	0.420	0.275	0.275		3.57E+01		2.35E+01	
2011/3/26 13:00	-1650	-1600	0.390	0.422	0.275	0.275		3.54E+01		2.34E+01	
2011/3/26 17:30	-1650	-1650	0.388	0.416	0.275	0.275		3.63E+01		2.31E+01	
2011/3/26 21:00	-1650	-1650	0.406	0.432	0.270	0.270		3.47E+01		2.29E+01	
2011/3/27 1:00	-1650	-1650	0.406	0.440	0.265	0.265		3.41E+01		2.27E+01	
2011/3/27 5:00	-1650	-1600	0.412	0.452	0.270	0.270		3.40E+01		2.25E+01	
2011/3/27 9:00	-1650	-1600	0.416	0.462	0.270	0.270		3.46E+01		2.22E+01	
2011/3/27 15:30	-1650	-1650	0.412	0.476	0.270	0.270		3.36E+01		2.19E+01	
2011/3/27 16:20	-1650	-1650	0.410	0.482	0.265	0.270		3.36E+01		2.18E+01	
2011/3/27 22:00	-1650	-1650	0.412	0.492	0.265	0.270		3.36E+01		2.16E+01	
2011/3/28 0:00	-1650	-1600	0.416	0.490	0.270	0.270		3.36E+01		2.15E+01	
2011/3/28 3:00	-1700	-1650	0.418	0.492	0.270	0.270		3.38E+01		2.13E+01	
2011/3/28 7:00	-1700	-1650	0.420	0.506	0.270	0.270		3.37E+01		2.11E+01	
2011/3/28 12:30	-1700	-1650	0.418	0.502	0.270	0.270		3.39E+01		2.08E+01	
2011/3/28 17:30	-1650	-1650	0.422	0.528	0.280	0.280		3.39E+01		2.06E+01	
2011/3/28 21:00	-1700	-1700	0.430	0.530	0.290	0.290		3.40E+01		2.04E+01	
2011/3/28 21:20	-1700	-1700	0.428	0.536	0.290	0.290		3.39E+01		2.04E+01	
2011/3/28 21:40	-1700	-1700	0.424	0.536	0.290	0.290					
2011/3/28 22:00	-1700	-1700	0.432	0.539	0.290	0.290		3.40E+01		2.03E+01	
2011/3/28 22:20	-1700	-1700	0.432	0.536	0.290	0.290					
2011/3/29 1:00	-1500	-1650	0.438	0.556	0.290	0.290		3.38E+01		2.02E+01	
2011/3/29 4:00	-1600	-1600	0.436	0.558	0.285	0.285		3.60E+01		2.00E+01	
2011/3/29 7:00	-1650	-1700	0.430	0.552	0.275	0.275		3.77E+01		1.99E+01	
2011/3/29 8:30	-1650	-1650	0.430	0.552	0.275						
2011/3/29 8:35	-1650	-1650	0.430	0.552	0.275						
2011/3/29 8:45	-1650	-1650	0.426	0.550	0.275	0.275		4.01E+01		1.98E+01	
2011/3/29 9:10	-1650	-1650	0.428	0.550	0.275	0.275		3.37E+01		1.98E+01	
2011/3/29 9:40	-1650	-1650	0.426	0.546	0.275	0.275		3.94E+01		1.98E+01	
2011/3/29 13:00	-1650	-1600	0.412	0.546	0.265	0.265		3.38E+01		1.97E+01	
2011/3/29 16:00	-1650	-1600	0.408	0.546	0.265	0.265		3.36E+01		1.96E+01	
2011/3/29 19:00	-1650	-1650	0.398	0.536	0.250	0.250		3.48E+01		1.94E+01	
2011/3/29 22:00	-1650	-1650	0.392	0.536	0.245	0.250		3.94E+01		1.93E+01	

Fukushima Daiichi Nuclear Power Station Unit1 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events.We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	note
2011/3/30 1:00	-1600	-1600	0.400	0.546	0.240	0.240		3.97E+01		1.92E+01	
2011/3/30 4:00	-1600	-1600	0.392	0.542	0.235	0.235		3.32E+01		1.91E+01	
2011/3/30 7:00	-1600	-1600	0.380	0.538	0.235	0.235		3.71E+01		1.90E+01	
2011/3/30 10:00	-1600	-1600	0.376	0.536	0.230	0.230		4.06E+01		1.89E+01	
2011/3/30 13:00	-1600	-1600	0.378	0.546	0.230	0.230		3.77E+01		1.82E+01	
2011/3/30 16:00	-1600	-1600	0.366	0.538	0.230	0.230		4.00E+01		1.85E+01	
2011/3/30 18:00	-1600	-1600	0.366	0.538	0.225	0.225		4.07E+01		1.85E+01	
2011/3/30 20:00	-1600	-1600	0.362	0.548	0.220	0.220		4.01E+01		1.85E+01	
2011/3/30 22:00	-1650	-1650	0.372	0.562	0.220	0.220		4.00E+01		1.84E+01	
2011/3/31 0:00	-1600	-1600	0.362	0.552	0.220	0.220		4.12E+01		1.83E+01	
2011/3/31 2:00	-1600	-1600	0.362	0.552	0.210	0.210		4.23E+01		1.83E+01	
2011/3/31 4:00	-1650	-1650	0.370	0.568	0.210	0.210		4.17E+01		1.82E+01	
2011/3/31 6:00	-1650	-1650	0.368	0.568	0.210	0.210		3.82E+01		1.81E+01	
2011/3/31 8:00	-1650	-1650	0.366	0.550	0.210	0.210		3.42E+01		1.80E+01	
2011/3/31 10:00	-1600	-1600	0.358	0.566	0.210	0.210		4.23E+01		1.80E+01	
2011/3/31 12:00	-1600	-1650	0.366	0.562	0.210	0.205		4.12E+01		1.72E+01	
2011/3/31 13:00	-1600	-1550	0.356	0.552	0.205	0.205		4.12E+01		1.72E+01	
2011/3/31 14:00	-1600	-1550	0.352	0.552	0.205	0.205		3.44E+01		1.76E+01	
2011/3/31 16:00	-1600	-1550	0.350	0.552	0.190	0.190		4.35E+01		1.77E+01	
2011/3/31 18:00	-1600	-1600	0.340	0.548	0.180	0.180		4.10E+01		1.77E+01	
2011/3/31 20:00	-1650	-1650	0.336	0.538	0.180	0.180		4.25E+01		1.76E+01	
2011/3/31 22:00	-1650	-1650	0.340	0.546	0.180	0.180		4.29E+01		1.76E+01	

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 8:55	3700		6.080		0.360							
2011/3/13 9:25		3700	6.080		0.365							
2011/3/13 9:55		3700	1.283		0.160							
2011/3/13 10:30		3800			0.100							
2011/3/13 10:35		3700			0.010							
2011/3/13 10:40		3700										
2011/3/13 10:55		3700										
2011/3/13 11:05		3700										
2011/3/13 11:15		3700										
2011/3/13 11:25		3700										
2011/3/13 11:35		3700			0.380							
2011/3/13 11:45		3700										
2011/3/13 11:55	3750											
2011/3/13 12:10		3750										
2011/3/13 12:20		3750										
2011/3/13 12:30		3750										
2011/3/13 12:40		3750										
2011/3/13 13:00		3750										
2011/3/13 13:10		3750										
2011/3/13 13:45					0.390							
2011/3/13 13:58					0.390							
2011/3/13 14:15	3750				0.390							
2011/3/13 14:30		3750			0.390							
2011/3/13 14:45	3750				0.395							
2011/3/13 15:00		3750			0.395							
2011/3/13 15:15		3750			0.395							
2011/3/13 15:30		3750	5.850		0.400							
2011/3/13 15:45		3800	5.850		0.400							
2011/3/13 16:00		3750	5.850		0.400							
2011/3/13 16:15	3750	3800	5.850		0.400							
2011/3/13 16:30	3750	3800	5.850		0.400							
2011/3/13 16:45	3750	3800	5.810		0.405							
2011/3/13 17:00	3750	3800	5.810		0.405							
2011/3/13 17:15	3750	3800	5.810		0.405							
2011/3/13 17:30	3750	3750	5.780		0.410							
2011/3/13 18:00	3750	3800			0.410							
2011/3/13 18:20	3800	3800			0.410							

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 9:45	3800	3800	5.445		0.460	0.476	1.00E-03		1.20E-02			
2011/3/14 10:00	3800	3850	5.490		0.460	0.480	1.00E-03		1.15E-02			
2011/3/14 10:15							1.00E-03		9.70E-03			
2011/3/14 10:30	3800	3850	5.648		0.460	0.481	1.00E-03		9.50E-03			
2011/3/14 11:30	3400	3400	6.008		0.460	0.485	1.00E-03		1.20E-02			
2011/3/14 12:00	3400	3400	6.008		0.460	0.485	1.00E-03		1.20E-02			
2011/3/14 12:30	2950	3000	6.188		0.465	0.486	1.00E-03		1.10E-02			
2011/3/14 13:00	2500	2500	7.065									
2011/3/14 13:10	2500	2500	7.065		0.465							
2011/3/14 13:24	2400	2400	7.470		0.465							
2011/3/14 13:30			7.459									
2011/3/14 13:40	2250	2250										
2011/3/14 13:45	2200	2200	7.225		0.460							
2011/3/14 14:00	2000	2000	7.527		0.460							
2011/3/14 14:10	1850	1850	7.392		0.460							
2011/3/14 14:20	1650	1650			0.455							
2011/3/14 14:27	1650	1650			0.455							
2011/3/14 14:40	1550	1550	7.425		0.450		1.00E-03		1.30E-02			
2011/3/14 14:50	1250	1250	7.470		0.445							
2011/3/14 15:00	1200	1200	7.392		0.440		1.00E-03		1.30E-02			
2011/3/14 15:15	1100	1100	7.302		0.440		1.08E-03		1.03E-02			
2011/3/14 15:30	900	900	7.020		0.430							
2011/3/14 15:40	700	700	7.070		0.430							
2011/3/14 15:50	500	500	7.425		0.420							
2011/3/14 16:00	300	300	7.448		0.420							
2011/3/14 16:10	100	100	7.448		0.420							
2011/3/14 16:20	0	0	6.998		0.420							
2011/3/14 16:34			6.998									
2011/3/14 16:36			7.403									
2011/3/14 16:37			7.425									
2011/3/14 16:43	-300											
2011/3/14 16:57	-520				0.400							
2011/3/14 17:12	-800		7.403									
2011/3/14 17:14	-850		7.403									
2011/3/14 17:16	-950		6.975		0.405							
2011/3/14 17:17	-1000											
2011/3/14 17:20			7.290									
2011/3/14 17:24			7.358		0.400							

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 17:28	-1050		7.358									
2011/3/14 17:30	-1100		6.970									
2011/3/14 17:31			7.380									
2011/3/14 17:33			7.880									
2011/3/14 17:35	-1300		6.975									
2011/3/14 17:48	-1450		7.358									
2011/3/14 17:52	-1500		7.358									
2011/3/14 17:55	-1600		6.975		0.400							
2011/3/14 18:00	-1600		7.133									
2011/3/14 18:03			6.075									
2011/3/14 18:05	-2000		5.625									
2011/3/14 18:06	-1100		5.400									
2011/3/14 18:07	-2100		4.950									
2011/3/14 18:08	-2000		4.500									
2011/3/14 18:09	-3000		3.150		0.395							
2011/3/14 18:10	-3000		2.925		0.395							
2011/3/14 18:12	-3250		2.475		0.395							
2011/3/14 18:13	-3400		2.183		0.395							
2011/3/14 18:14	-3500		1.913		0.395							
2011/3/14 18:17	-3500		1.643		0.395							
2011/3/14 18:18	-3600		1.530		0.400							
2011/3/14 18:19	-3600		1.463		0.400							
2011/3/14 18:20	-3600		1.395		0.400							
2011/3/14 18:21	-3600		1.305		0.400							
2011/3/14 18:22	-3700		1.215		0.400							
2011/3/14 18:23	-3700		1.170		0.400							
2011/3/14 18:24	-3700		1.125		0.400							
2011/3/14 18:25	-3700		1.080		0.400							
2011/3/14 18:26	-3700		1.035		0.400							
2011/3/14 18:27	-3700		0.990		0.400							
2011/3/14 18:28	-3700		0.945		0.400							
2011/3/14 18:29	-3700		0.900		0.400							
2011/3/14 18:30	-3700		0.878		0.400							
2011/3/14 18:31	-3700		0.855		0.400							
2011/3/14 18:32	-3700		0.810		0.400							
2011/3/14 18:33	-3700		0.780		0.400							
2011/3/14 18:34	-3700		0.765		0.400							
2011/3/14 18:35	-3700		0.720		0.400							

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 18:36	-3700		0.698		0.400							
2011/3/14 18:37	-3700		0.675		0.400							
2011/3/14 18:39	-3700		0.540		0.400							
2011/3/14 18:40	-3700		0.563		0.400							
2011/3/14 18:42	-3700		0.540		0.400							
2011/3/14 18:45	-3700		0.563		0.400							
2011/3/14 18:47	-3700		0.585		0.400							
2011/3/14 18:50			0.585		0.400							
2011/3/14 18:52			0.638		0.400							
2011/3/14 18:55			0.608		0.400							
2011/3/14 19:00			0.630		0.400							
2011/3/14 19:03			0.630		0.400							
2011/3/14 19:12			0.653		0.400							
2011/3/14 19:13			0.653		0.400							
2011/3/14 19:18			0.653		0.400							
2011/3/14 19:22			0.650		0.395							
2011/3/14 19:35			0.608		0.395							
2011/3/14 19:45			0.585		0.395							
2011/3/14 19:49			0.585		0.395							
2011/3/14 19:54			0.585		0.395							
2011/3/14 19:55			0.563		0.395							
2011/3/14 19:57			0.563		0.400							
2011/3/14 19:59			0.563		0.405							
2011/3/14 20:00			0.563		0.405							
2011/3/14 20:03			0.540		0.405							
2011/3/14 20:04			0.540		0.410							
2011/3/14 20:05			0.540		0.410							
2011/3/14 20:07			0.540		0.415							
2011/3/14 20:08			0.563		0.415							
2011/3/14 20:10			0.540		0.418							
2011/3/14 20:12			0.563		0.419							
2011/3/14 20:13			0.540		0.420							
2011/3/14 20:15			0.540		0.420							
2011/3/14 20:18			0.563		0.420							
2011/3/14 20:20			0.563		0.420							
2011/3/14 20:21			0.563		0.420							
2011/3/14 20:23			0.563		0.420							
2011/3/14 20:26			0.585		0.420							
2011/3/14 20:28			0.608		0.420							

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 20:32			0.608		0.420							
2011/3/14 20:33			0.653		0.420							
2011/3/14 20:37			0.810		0.421							
2011/3/14 20:43			0.833		0.421							
2011/3/14 20:54			1.170		0.420							
2011/3/14 20:59			1.373		0.419							
2011/3/14 21:03			1.418		0.419							
2011/3/14 21:06					0.419							
2011/3/14 21:09			1.440		0.418							
2011/3/14 21:18			1.463		0.418							
2011/3/14 21:20	-3400		0.833		0.470							
2011/3/14 21:21	-3500		0.675		0.465							
2011/3/14 21:26	-3300		0.608		0.470							
2011/3/14 21:27	-3300		0.563		0.470							
2011/3/14 21:29	-3200		0.518		0.475							
2011/3/14 21:30	-3000		0.495		0.475							
2011/3/14 21:31	-3000		0.450		0.480							
2011/3/14 21:32	-3000		0.450		0.480							
2011/3/14 21:33	-2000		0.450		0.480							
2011/3/14 21:34	-2000		0.405		0.480							
2011/3/14 21:35	-2000		0.405		0.480							
2011/3/14 21:38	-2000				0.480							
2011/3/14 21:42	-2000				0.480							
2011/3/14 21:55	-1800		0.405		0.470		5.36E+00		3.83E-01			
2011/3/14 22:00	-1600		0.405		0.480		5.79E+00		3.95E-01			
2011/3/14 22:10	-1600		0.405		0.480	0.400	6.49E+00		5.04E-01			
2011/3/14 22:20	-1400		0.405		0.480	0.370	6.88E+00		5.06E-01			
2011/3/14 22:30	-1200		0.405		0.482	0.370	7.46E+00		5.51E-01			
2011/3/14 22:40	-700		0.428		0.482	0.350	7.92E+00		7.35E-01			
2011/3/14 22:50	-1600		1.823		0.540	0.380	6.54E+00		1.01E+00			
2011/3/14 23:00	-1700		2.070		0.580	0.360						
2011/3/14 23:10	-2000		2.655		0.620	0.350						
2011/3/14 23:11	-2000		2.655		0.620	0.350						
2011/3/14 23:20			3.150				8.81E+00		6.61E+00			
2011/3/14 23:25			3.150		0.700		8.81E+00		6.61E+00			
2011/3/14 23:30			1.913		0.700	0.310	1.50E+01		7.40E+00			
2011/3/14 23:35			1.733		0.740	0.300						
2011/3/14 23:38			1.463			0.300						

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 23:40			1.170		0.740	0.300						
2011/3/14 23:41			0.968		0.740	0.300						
2011/3/14 23:42			0.810		0.740	0.300	2.25E+01		9.11E+00			
2011/3/14 23:44			0.698		0.750	0.340	2.29E+01		9.12E+00			
2011/3/14 23:46			0.675		0.750	0.350	2.33E+01		9.11E+00			
2011/3/14 23:50			0.675		0.750	0.330	2.35E+01		9.07E+00			
2011/3/14 23:52			0.653		0.750	0.300	2.42E+01		9.04E+00			
2011/3/14 23:54			0.653		0.745	0.300	2.45E+01		9.10E+00			
2011/3/15 0:02					0.740							
2011/3/15 0:04					0.740							
2011/3/15 0:05			0.653		0.740	0.300						
2011/3/15 0:06			0.675		0.740	0.300						
2011/3/15 0:07			0.675		0.740	0.300						
2011/3/15 0:08			0.788		0.740	0.300						
2011/3/15 0:10			0.833		0.740	0.300						
2011/3/15 0:16			1.035		0.740	0.300						
2011/3/15 0:22			1.170		0.735	0.300						
2011/3/15 0:28			1.350		0.730	0.300						
2011/3/15 0:32			1.485		0.725	0.330						
2011/3/15 0:41			1.710		0.720	0.330						
2011/3/15 0:45			1.823									
2011/3/15 0:49			2.003									
2011/3/15 1:00			2.430									
2011/3/15 1:02			2.520									
2011/3/15 1:10			1.440		0.725							
2011/3/15 1:11			1.058		0.725	0.330						
2011/3/15 1:12			0.923									
2011/3/15 1:13			0.855		0.730	0.330						
2011/3/15 1:14			0.743		0.730	0.310						
2011/3/15 1:16			0.698		0.720	0.310						
2011/3/15 1:18			0.675		0.730	0.300	2.88E+01		8.08E+00			
2011/3/15 1:20			0.653		0.730	0.330	2.89E+01		8.12E+00			
2011/3/15 1:22			0.653		0.730	0.310	2.90E+01		8.13E+00			
2011/3/15 1:28			0.630		0.730	0.330	2.90E+01		7.96E+00			
2011/3/15 1:31			0.630		0.730	0.320	2.91E+01		7.81E+00			
2011/3/15 1:40			0.630		0.725	0.310	2.94E+01		7.84E+00			
2011/3/15 1:48			0.630		0.725	0.310						
2011/3/15 1:53			0.630		0.725	0.330	3.04E+01		7.56E+00			

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/15 2:03			0.630		0.725	0.330	3.04E+01		7.40E+00			
2011/3/15 2:08			0.630		0.725	0.330	3.09E+01		7.37E+00			
2011/3/15 2:10			0.630		0.730	0.340	3.11E+01		7.27E+00			
2011/3/15 2:17			0.630		0.730	0.340	3.15E+01		7.15E+00			
2011/3/15 2:22			0.675		0.740	0.330	3.22E+01		7.00E+00			
2011/3/15 2:39			0.653		0.750	0.330	3.46E+01		6.96E+00			
2011/3/15 2:45			0.653		0.750	0.320	3.65E+01		6.88E+00			
2011/3/15 2:50			0.653		0.750	0.330	3.78E+01		6.82E+00			
2011/3/15 3:00			0.653		0.750	0.330	4.09E+01		6.60E+00			
2011/3/15 3:05			0.653		0.750	0.330	4.18E+01		6.58E+00			
2011/3/15 3:20			0.653		0.750	0.330	4.30E+01		6.42E+00			
2011/3/15 3:30			0.653		0.750	0.330	4.59E+01		6.31E+00			
2011/3/15 3:40			0.653		0.750	0.330	4.76E+01		6.23E+00			
2011/3/15 3:50			0.653		0.750	0.330	4.94E+01		6.22E+00			
2011/3/15 4:00			0.653		0.750	0.330	5.01E+01		6.09E+00			
2011/3/15 4:05			0.653		0.750	0.330	5.12E+01		5.87E+00			
2011/3/15 4:10			0.653		0.750	0.310	5.19E+01		5.72E+00			
2011/3/15 4:20			0.637		0.750	0.310	5.32E+01		5.65E+00			
2011/3/15 4:30			0.632		0.750	0.300	5.44E+01		5.58E+00			
2011/3/15 4:45			0.632		0.750	0.310	5.55E+01		5.52E+00			
2011/3/15 5:00			0.626		0.750	0.300	5.75E+01		5.29E+00			
2011/3/15 5:15			0.623		0.740	0.300	5.83E+01		5.19E+00			
2011/3/15 5:30			0.621		0.730	0.310	5.95E+01		5.08E+00			
2011/3/15 5:45			0.617		0.740	0.320	6.06E+01		5.00E+00			
2011/3/15 6:00			0.614		0.730	0.270	6.16E+01		4.89E+00			
2011/3/15 6:02			0.612		0.730	0.000	6.26E+01		4.80E+00			
2011/3/15 6:10	-2800				0.730	0.000						
2011/3/15 6:20	-2700		0.612		0.730	0.000	6.27E+01		4.80E+00			
2011/3/15 6:25	-2300		0.610		0.730	0.000	4.30E+01		4.70E+00			
2011/3/15 7:20	-2500		0.612		0.730	0.000						
2011/3/15 11:25	-1200		0.270		0.155		4.56E+01		5.79E+00			Instrument failure - S/C pressure
2011/3/15 11:42	-1400		0.315		0.155		4.61E+01		5.52E+00			
2011/3/15 11:58	-1350		0.428		0.155		4.65E+01		5.27E+00			
2011/3/15 13:00	-1700		0.608		0.415		4.77E+01		4.62E+00			
2011/3/15 15:25	-1950		0.119		0.275		1.35E+02		6.92E+00			
2011/3/15 15:50	-1750		0.117		0.270							
2011/3/15 16:10	-1700		0.119		0.270		1.38E+02		6.49E+00			
2011/3/15 18:43	-1200		0.099		0.250		1.22E+02		4.40E+00			

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/16 1:24	-1400		-0.023		0.120		1.03E+02		3.68E+00			
2011/3/16 1:44	-1400		-0.023		0.120		1.02E+02		3.66E+00			
2011/3/16 1:54	-1400		-0.023		0.120		1.02E+02		3.65E+00			
2011/3/16 5:00	-1475		-0.038		0.125		9.85E+01		3.67E+00			
2011/3/16 5:15	-1475		-0.041		0.120		9.83E+01		3.69E+00			
2011/3/16 5:35	-1450		-0.041		0.040		6.05E+01		2.43E+00			
2011/3/16 6:10	-1425		-0.043		0.050		9.77E+01		3.63E+00			
2011/3/16 6:55	-1400		-0.043		0.045		9.72E+01		3.57E+00			
2011/3/16 12:35	-1400				0.040		9.38E+01		3.01E+00			
2011/3/16 15:30	-1400		-0.061		0.075	0.145	9.24E+01		2.86E+00			
2011/3/16 20:00	-1400		-0.063		0.075		9.03E+01		2.75E+00			
2011/3/16 20:20	-1400		-0.063		0.075		9.03E+01		2.75E+00			
2011/3/16 20:40	-1400		-0.063		0.075		9.03E+01		2.75E+00			
2011/3/16 23:50	-1400		-0.063		0.075		9.03E+01		2.75E+00			
2011/3/17 3:10	-1400		-0.065		0.075		8.70E+01		2.65E+00			
2011/3/17 6:00	-1400		-0.068		0.075		8.63E+01		2.63E+00			
2011/3/17 11:00	-1600		-0.029		0.110		8.46E+01		2.50E+00			
2011/3/17 11:15	-1700		-0.029		0.115		8.46E+01		2.50E+00			
2011/3/17 11:30	-1800		-0.029		0.115		8.46E+01		2.50E+00			
2011/3/17 12:50	-1800		-0.027		0.110		8.44E+01		2.43E+00			
2011/3/17 14:00	-1800				0.110							
2011/3/17 21:40	-1400				0.130		8.21E+01		2.40E+00			
2011/3/17 21:50	-1400				0.130		8.24E+01		2.41E+00			
2011/3/18 2:20	-1400		-0.018		0.130		8.02E+01		2.40E+00			
2011/3/18 2:50	-1400		-0.016		0.130		7.98E+01		2.40E+00			
2011/3/18 7:40	-1400		-0.014		0.130		7.81E+01		2.37E+00			
2011/3/18 7:55	-1400		-0.014		0.130		7.80E+01		2.37E+00			
2011/3/18 9:40	-1400		-0.009		0.135		7.74E+01		2.36E+00			
2011/3/18 16:00	-1400		-0.002		0.139		7.50E+01		2.34E+00			
2011/3/18 20:55	-1400		-0.002		0.140		7.35E+01		2.33E+00			
2011/3/18 21:10	-1400		-0.005		0.140		7.35E+01		2.32E+00			
2011/3/19 2:40	-1400		-0.005		0.135		7.18E+01		2.30E+00			
2011/3/19 3:30	-1400		-0.005		0.135		7.15E+01		2.30E+00			
2011/3/19 7:10	-1350		-0.005		0.135		7.06E+01		2.29E+00			
2011/3/19 11:00	-1400	-400	-0.009		0.135		6.96E+01		2.27E+00			
2011/3/19 16:30	-1300	-300	-0.009		0.135		6.83E+01		2.26E+00			
2011/3/19 19:00	-1300	-350	-0.009		0.135		6.76E+01		2.25E+00			
2011/3/19 22:30	-1350	-400	-0.009		0.130		6.68E+01		2.20E+00			
2011/3/20 0:00	-1300	-380	-0.007		0.130		6.58E+01		2.20E+00			

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/20 4:50	-1300	-380	-0.014		0.130		6.97E+01		2.18E+00			
2011/3/20 5:00	-1300	-500	-0.014		0.130		6.47E+01		2.17E+00			
2011/3/20 10:00			-0.011		0.130		6.36E+01		2.16E+00			
2011/3/20 11:00	-1400	-400	-0.016		0.125		1.34E+01		2.15E+00			
2011/3/20 15:00	-1400	-400	-0.016	-0.020	0.125		6.25E+01		2.13E+00		0.060	
2011/3/20 22:00	-1400	-200	-0.018	-0.020	0.120		6.12E+01		2.11E+00		0.060	
2011/3/21 3:00	-1350	-250	-0.018	-0.020	0.120		6.01E+01		2.09E+00		0.060	
2011/3/21 8:00	-1350	-300	-0.020	-0.020	0.120		5.91E+01		2.06E+00		0.060	
2011/3/21 13:30	-1350	-200	-0.020	-0.025	0.120		5.83E+01		2.04E+00			
2011/3/21 14:00	-1350	-200	-0.023	-0.025	0.120		5.81E+01		2.03E+00			
2011/3/21 14:25	-1350	-200	-0.023	-0.025	0.120		5.81E+01		2.03E+00			
2011/3/21 14:30	-1350	-200	-0.023	-0.025	0.120		5.81E+01		2.03E+00			
2011/3/22 0:15	-1400	-200	-0.025	-0.027	0.110		5.64E+01		1.99E+00			
2011/3/22 5:00	-1300	-100	-0.016	-0.018	0.110		5.55E+01		1.90E+00			
2011/3/22 6:00	-1350	0	-0.005	-0.029	0.110		5.54E+01		1.95E+00			
2011/3/22 10:30	-1350	0	-0.020	-0.023	0.110		5.47E+01		1.93E+00			
2011/3/22 11:20	-1350	175	-0.018	-0.018	0.110							
2011/3/22 15:30	-1300	-400	-0.029	-0.032	0.110		5.36E+01		1.90E+00			
2011/3/22 17:00	-1350	-150	-0.027	-0.032	0.110		5.35E+01		1.88E+00			
2011/3/22 18:00	-1350	-100	-0.029	-0.034	0.110		5.34E+01		1.88E+00			
2011/3/22 23:00	-1350	-500	-0.020	-0.043	0.110		5.28E+01		1.83E+00			
2011/3/23 4:20	-1300	0	-0.025	-0.025	0.110		5.20E+01		1.80E+00			
2011/3/23 4:40	-1300	0	-0.025	-0.025	0.110		5.20E+01		1.80E+00			
2011/3/23 9:00	-1300	-150	-0.023	-0.023	0.110		5.14E+01		1.76E+00			
2011/3/23 14:00	-1250	100	-0.036	-0.036	0.110		5.07E+01		1.67E+00			
2011/3/23 21:00	-1200	-550	-0.036	-0.036	0.110		4.98E+01		1.53E+00			
2011/3/24 1:00	-1200	-250	-0.025	-0.025	0.105		4.93E+01		1.49E+00			
2011/3/24 5:00	-1150	-100	-0.027	-0.027	0.110		4.88E+01		1.43E+00			
2011/3/24 9:00	-1150	-100	-0.135	-0.038	0.110		4.84E+01		1.40E+00		0.100	
2011/3/24 13:00	-1150	-200	-0.023	-0.025	0.100		4.79E+01		1.37E+00		0.100	
2011/3/24 17:00	-1200	-250	-0.036	-0.036	0.110		4.74E+01		1.36E+00			
2011/3/24 20:00	-1100	0	-0.036	-0.036	0.100		4.71E+01		1.34E+00			
2011/3/24 22:00	-1150	-150	-0.020	-0.020	0.105		4.68E+01		1.39E+00			
2011/3/24 22:30	-1150	-50	-0.032	-0.032	0.105		4.68E+01		1.47E+00			
2011/3/25 0:00	-1400	-600	-0.025	-0.027	0.120		4.66E+01		1.50E+00			
2011/3/25 1:20	-1600	-750	-0.025	-0.027	0.120						0.120	
2011/3/25 2:00	-1300	-1400	-0.023	-0.025	0.120		4.64E+01		1.52E+00			
2011/3/25 2:30	-1200	-300										
2011/3/25 6:00	-1100	-200	-0.020	-0.020	0.120		4.59E+01		1.54E+00		0.100	
2011/3/25 10:00	-1200	-500	-0.020	-0.020	0.120		4.56E+01		1.54E+00			

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/25 14:00	-1400	-400	-0.016	-0.018	0.120		4.52E+01		1.54E+00			
2011/3/25 18:30	-1150	-250	-0.020	-0.018	0.120		4.47E+01		1.54E+00			
2011/3/25 23:00	-1150	-450	-0.009	-0.009	0.120		4.43E+01		1.53E+00			
2011/3/26 5:00	-1000	-300	-0.014	-0.014	0.120		4.38E+01		1.51E+00			
2011/3/26 9:30	-1100	-500	-0.014	-0.014	0.115		4.34E+01		1.49E+00			
2011/3/26 10:21	-1000	-500	-0.014	-0.014	0.115							
2011/3/26 10:40	-1100	-500	-0.014	-0.016	0.115							
2011/3/26 11:00	-1100	-500	-0.014	-0.016	0.115							
2011/3/26 11:30	-1100	-600	-0.025	-0.027	0.110		4.33E+01		1.49E+00			
2011/3/26 12:00	-1100	-700	-0.027	-0.027	0.110		4.32E+01		1.49E+00			
2011/3/26 13:00	-1200	-1000	-0.027	-0.027	0.110		4.32E+01		1.48E+00			
2011/3/26 17:30	-1150	-1600	-0.018	-0.038	0.110		4.28E+01		1.47E+00			
2011/3/26 17:50	-1150	-1650										
2011/3/26 18:00	-1200	-1600										
2011/3/26 18:10	-1200	-1600	-0.016	-0.016	0.110							
2011/3/26 18:30	-1200	-1550	-0.016	-0.016	0.110							
2011/3/26 19:00	-1200	-1650	-0.018	-0.016	0.110							
2011/3/26 21:00	-1200	-1850	-0.016	-0.018	0.110		4.26E+01		1.46E+00			
2011/3/27 1:00	-1200	-1850	-0.018	-0.018	0.110	0.160	4.22E+01		1.45E+00			
2011/3/27 5:00	-1200	-1850	-0.018	-0.018	0.110	0.040	4.19E+01		1.43E+00			
2011/3/27 9:00	-1200	-1850	-0.018	-0.020	0.110		4.16E+01		1.41E+00			
2011/3/27 15:30	-1250	-1900	-0.018	-0.020	0.110		4.11E+01		1.39E+00			
2011/3/27 16:20	-1150	-1850	-0.018	-0.020	0.110		4.11E+01		1.38E+00			
2011/3/27 17:50	-1200	-1900	-0.018	-0.020	0.110		4.10E+01		1.38E+00			
2011/3/27 18:40	-1400	-1850	-0.018	-0.020	0.110							
2011/3/27 19:00	-1250	-1950	-0.020	-0.020	0.110							
2011/3/27 19:20	-1300	-1900	-0.020	-0.023	0.110							
2011/3/27 19:40	-1400	-1900	-0.020	-0.020	0.110							
2011/3/27 20:00	-1400	-1900	-0.020	-0.023	0.110							
2011/3/27 20:20	-1500	-2000	-0.020	-0.023	0.110		4.08E+01		1.37E+00			
2011/3/27 20:40	-1500	-2000	-0.020	-0.023	0.110							
2011/3/27 22:00	-1500	-2050	-0.020	-0.020	0.110		4.07E+01		1.37E+00		0.120	
2011/3/28 0:00	-1400	-2000	-0.020	-0.020	0.110		4.06E+01		1.36E+00			
2011/3/28 0:15	-1400	-1950	-0.020	-0.020	0.110							
2011/3/28 0:35	-1500	-2100	-0.020	-0.020	0.110							
2011/3/28 0:55	-1500	-2100	-0.020	-0.020	0.110		4.05E+01		1.36E+00			
2011/3/28 1:15	-1500	-2100	-0.020	-0.020	0.110							
2011/3/28 3:00	-1500	-2100	-0.020	-0.020	0.110		4.05E+01		1.37E+00		0.150	

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/28 3:30	-1500	-2100	-0.020	-0.020	0.110		4.05E+01		1.37E+00			
2011/3/28 4:00	-1500	-2100	-0.020	-0.023	0.110		4.05E+01		1.37E+00			
2011/3/28 7:00	-1500	-2100	-0.020	-0.023	0.105		4.05E+01		1.39E+00			
2011/3/28 12:30	-1500	-2100	-0.032	-0.032	0.100		4.04E+01		1.39E+00			
2011/3/28 17:30	-1500	-2100	-0.032	-0.032	0.100		4.04E+01		1.40E+00			
2011/3/28 21:00	-1500	-2100	-0.034	-0.034	0.100		4.04E+01		1.40E+00			
2011/3/29 1:00	-1500	-2050	-0.027	-0.029	0.100		4.04E+01		1.39E+00		0.120	
2011/3/29 4:00	-1500	-2100	-0.027	-0.029	0.100		4.04E+01		1.37E+00		0.120	
2011/3/29 7:00	-1500	-2100	-0.027	-0.029	0.100		4.04E+01		1.36E+00		0.100	
2011/3/29 10:00	-1500	-2100	-0.025	-0.027	0.100		4.04E+01		1.35E+00		0.110	
2011/3/29 13:00	-1500	-2100	-0.025	-0.025	0.100		4.05E+01		1.33E+00		0.110	
2011/3/29 16:00	-1500	-2100	-0.025	-0.025	0.100		4.04E+01		1.32E+00		0.120	
2011/3/29 19:00	-1500	-2100	-0.034	-0.032	0.100		4.02E+01		1.31E+00		0.120	
2011/3/29 22:00	-1500	-2100	-0.032	-0.032	0.100		4.01E+01		1.30E+00		0.110	
2011/3/30 1:00	-1500	-2100	-0.025	-0.025	0.100		4.01E+01		1.29E+00		0.100	
2011/3/30 4:00	-1500	-2100	-0.025	-0.025	0.100		4.00E+01		1.28E+00		0.110	
2011/3/30 7:00	-1500	-2100	-0.032	-0.032	0.100		3.99E+01		1.28E+00		0.100	
2011/3/30 10:00	-1500	-2100	-0.032	-0.032	0.100		3.98E+01		1.27E+00		0.110	
2011/3/30 10:30	-1500	-2100	-0.025	-0.027	0.100							
2011/3/30 10:50	-1500	-2100	-0.032	-0.034	0.100							
2011/3/30 11:10	-1500	-2100	-0.032	-0.034	0.100							
2011/3/30 11:30	-1500	-2100	-0.032	-0.034	0.100							
2011/3/30 13:00	-1500	-2100	-0.023	-0.023	0.100		3.96E+01		1.26E+00		0.100	
2011/3/30 14:00	-1500	-2100	-0.025	-0.023	0.100							
2011/3/30 14:20	-1500	-2100	-0.027	-0.025	0.100							
2011/3/30 14:40	-1500	-2050	-0.027	-0.027	0.100							
2011/3/30 15:00	-1500	-2050	-0.027	-0.027	0.100							
2011/3/30 15:20	-1500	-2050	-0.029	-0.027	0.100							
2011/3/30 16:00	-1500	-2050	-0.032	-0.032	0.100		3.95E+01		1.24E+00		0.130	
2011/3/30 18:00	-1500	-2050	-0.029	-0.027	0.100		3.94E+01		1.23E+00		0.130	
2011/3/30 18:30	-1500	-2050	-0.029	-0.027	0.100							
2011/3/30 22:00	-1500	-2050	-0.014	-0.011	0.120		3.92E+01		1.22E+00		0.100	
2011/3/31 0:00	-1500	-2050	-0.027	-0.025	0.110		3.91E+01		1.21E+00		0.110	
2011/3/31 2:00	-1500	-2050	-0.025	-0.025	0.110		3.89E+01		1.21E+00		0.100	
2011/3/31 4:00	-1500	-2050	-0.018	-0.020	0.110		3.87E+01		1.19E+00		0.100	
2011/3/31 6:00	-1500	-2050	-0.014	-0.014	0.110		3.86E+01		1.19E+00		0.110	
2011/3/31 8:00	-1500	-2050	-0.016	-0.018	0.110		3.85E+01		1.17E+00		0.120	
2011/3/31 10:00	-1500	-2050	-0.018	-0.020	0.110		3.84E+01		1.17E+00		0.130	

Fukushima Daiichi Nuclear Power Station Unit2 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/31 12:00	-1500	-2100	-0.011	-0.011	0.110		3.79E+01		1.16E+00		0.110	
2011/3/31 14:00	-1500	-2100	-0.011	-0.011	0.110		3.80E+01		1.16E+00		0.110	
2011/3/31 16:00	-1500	-2100	-0.009	-0.011	0.110		3.79E+01		1.16E+00		0.110	
2011/3/31 18:00	-1500	-2100	-0.011	-0.011	0.110		3.78E+01		1.15E+00		0.110	
2011/3/31 20:00	-1500	-2050	-0.014	-0.016	0.110		3.78E+01		1.15E+00		0.110	
2011/3/31 22:00	-1500	-2050	-0.007	-0.009	0.110		3.77E+01		1.14E+00		0.110	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/11 19:30					0.1450							
2011/3/11 19:37			7.170									
2011/3/11 20:00					0.1450							
2011/3/11 20:07			7.100									
2011/3/11 20:15					0.1450							
2011/3/11 20:30			7.100		0.1450							
2011/3/11 21:10			7.190		0.1550							
2011/3/11 21:30			7.250									
2011/3/11 22:00			7.200									
2011/3/11 22:10			7.260									
2011/3/11 22:20			7.200									
2011/3/11 22:30			7.300									
2011/3/11 22:58			7.300									
2011/3/11 23:05			7.300									
2011/3/11 23:19			7.380									
2011/3/11 23:35			7.320									
2011/3/11 23:50			7.340									
2011/3/12 0:00			7.340		0.2200							
2011/3/12 0:30			7.350		0.2300							
2011/3/12 1:00			7.400		0.2400							
2011/3/12 1:25			7.100		0.2450							
2011/3/12 1:55			7.370		0.2500							
2011/3/12 2:30			7.340		0.2650							
2011/3/12 2:50												
2011/3/12 3:30			7.400		0.2800							
2011/3/12 3:40												
2011/3/12 3:55			7.470		0.2850							
2011/3/12 4:19			6.800		0.2900							
2011/3/12 4:35			7.400		0.2950							
2011/3/12 4:55			7.400		0.3000							
2011/3/12 5:15			7.400		0.3000							
2011/3/12 5:20			7.400		0.3000							
2011/3/12 5:30			7.290		0.3050							
2011/3/12 5:55			7.430		0.3100							
2011/3/12 6:00			7.250		0.3100							
2011/3/12 6:30			7.490		0.3200							
2011/3/12 7:00			7.390		0.3300							
2011/3/12 7:30			7.230		0.3400							

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 2:44			0.580									
2011/3/13 3:00			0.770									
2011/3/13 3:30			3.000									
2011/3/13 3:38			4.000									
2011/3/13 3:44			4.100									
2011/3/13 3:50			4.500									
2011/3/13 4:00	-1600		5.300									
2011/3/13 4:15	-1800		6.500									
2011/3/13 4:20	-1800		6.900									
2011/3/13 4:25	-1850		7.200									
2011/3/13 4:35	-2000		7.300									
2011/3/13 4:40	-2000		7.380									
2011/3/13 4:45	-2000											
2011/3/13 4:55	-2100		7.380		0.3600							
2011/3/13 5:00	-2000		7.380		0.3600							
2011/3/13 5:10	-2300		7.350		0.3450	0.3350						
2011/3/13 5:25	-2400		7.270		0.3550	0.3400						
2011/3/13 5:40	-2500											
2011/3/13 5:45	-2500		7.300		0.3650	0.3500						
2011/3/13 6:00	-2600		7.390		0.3900	0.3700						
2011/3/13 6:10	-2700		7.390		0.4000	0.3900						
2011/3/13 6:20	-2800		7.400		0.4100	0.4000						
2011/3/13 6:30	-2800		7.390		0.4250	0.4050						
2011/3/13 6:40	-2800		7.370		0.4350	0.4200						
2011/3/13 6:45	-2850		7.360		0.4400	0.4200						
2011/3/13 6:50	-2850		7.350		0.4400	0.4200						
2011/3/13 6:55	-2850		7.350		0.4450	0.4250						
2011/3/13 7:00	-2900		7.350		0.4450	0.4250						
2011/3/13 7:05	-2900		7.350		0.4500	0.4300						
2011/3/13 7:10	-2900		7.340		0.4500	0.4300						
2011/3/13 7:15	-2950		7.340		0.4550	0.4350						
2011/3/13 7:20	-2950		7.340		0.4550	0.4350						
2011/3/13 7:25	-2950		7.330		0.4550	0.4350						
2011/3/13 7:30	-2950		7.330		0.4600	0.4400						
2011/3/13 7:35	-3000		7.320		0.4600	0.4400						
2011/3/13 7:39	-3000		7.310		0.4600	0.4400						
2011/3/13 7:45	-3000		7.310		0.4600	0.4400						
2011/3/13 7:50	-3000		7.270		0.4650	0.4450						
2011/3/13 7:55	-3000		7.260		0.4650	0.4450						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 8:00	-3000		7.270		0.4650	0.4450						
2011/3/13 8:05	-3000		7.250		0.4650	0.4450						
2011/3/13 8:10	-3000		7.250		0.4650	0.4450						
2011/3/13 8:15	-3000		7.240		0.4650	0.4450						
2011/3/13 8:20	-3000		7.240		0.4650	0.4450						
2011/3/13 8:25	-3000		7.240		0.4650	0.4450						
2011/3/13 8:30	-3000		7.240		0.4650	0.4450						
2011/3/13 8:35	-3000		7.240		0.4650	0.4450						
2011/3/13 8:40	-3000		7.230		0.4650	0.4450						
2011/3/13 8:45	-3000		7.220		0.4650	0.4450						
2011/3/13 8:50	-3000		7.220		0.4650	0.4450						
2011/3/13 8:55	-3000		7.300		0.4700	0.4550						
2011/3/13 9:08			0.500									
2011/3/13 9:10	1800		0.460		0.6370	0.5900						
2011/3/13 9:15	900	1150	0.410		0.6300	0.5900						
2011/3/13 9:20			0.390		0.5700	0.5200						
2011/3/13 9:20			0.380		0.5600	0.5000						
2011/3/13 9:22	700	1300	0.380		0.5500	0.5000						
2011/3/13 9:24			0.360		0.5400	0.4900						
2011/3/13 9:25	1000	1300	0.350		0.5300	0.4700						
2011/3/13 9:27	1000	1100	0.340		0.5000	0.4500						
2011/3/13 9:29	1050	1650	0.340		0.5000	0.4500						
2011/3/13 9:30	1000	900	0.320		0.4800	0.4300						
2011/3/13 9:32	1000	600	0.310		0.4750	0.4250						
2011/3/13 9:35	1000	600	0.300		0.4700	0.4200						
2011/3/13 9:36	1000	700	0.290		0.4600	0.4100						
2011/3/13 9:37	900	800	0.280		0.4500	0.4000						
2011/3/13 9:38	1000	800	0.280		0.4400	0.3900						
2011/3/13 9:40	900	700	0.270		0.4350	0.3850						
2011/3/13 9:41	900	700	0.260		0.4250	0.3750						
2011/3/13 9:43	1000	800	0.250		0.4200	0.3700						
2011/3/13 9:45	800	650	0.250		0.4100	0.3600						
2011/3/13 9:47	1000	600	0.250		0.4050	0.3550						
2011/3/13 9:49	1000	600	0.240		0.4000	0.3500						
2011/3/13 9:53	850	1550	0.230		0.3900	0.3350						
2011/3/13 9:55	1000	600	0.240		0.4000	0.3500						
2011/3/13 9:56	850	450	0.210		0.3800	0.3300						
2011/3/13 9:59	500	300	0.210		0.3700	0.3200						
2011/3/13 10:02	2300	2400	0.380		0.3700	0.3300						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 10:05	2250	2200	0.330		0.4100	0.3500						
2011/3/13 10:07	1400	400	0.270		0.3900	0.3400						
2011/3/13 10:10	2600	200	0.240		0.3800	0.3300						
2011/3/13 10:13	350	-100	0.220		0.3700	0.3200						
2011/3/13 10:16	-300	-500	0.200		0.3500	0.3000						
2011/3/13 10:19	-600	-300	0.180		0.3400	0.2900						
2011/3/13 10:22	-600	-700	0.170		0.3300	0.2700						
2011/3/13 10:27	-500	300	0.150		0.3100	0.2600						
2011/3/13 10:30	-500	0	0.140		0.2900	0.2400						
2011/3/13 10:35	-200	-700	0.120		0.2800	0.2300						
2011/3/13 10:40	-500	-900	0.110		0.2700	0.2200						
2011/3/13 10:45	-700	-1000	0.100		0.2700	0.2200						
2011/3/13 10:50	-900	-1200	0.100		0.2700	0.2200						
2011/3/13 10:55	-900	-1200	0.100		0.2700	0.2200						
2011/3/13 11:00	-1000	-1300	0.090		0.2700	0.2200						
2011/3/13 11:05	-1000	-1400	0.080		0.2700	0.2200						
2011/3/13 11:10	-900	-1300	0.090		0.2700	0.2200						
2011/3/13 11:15	1000	-700	0.150		0.2800	0.2300						
2011/3/13 11:20	200	-200	0.100		0.2800	0.2300						
2011/3/13 11:25	0	1600	0.110		0.2800	0.2300						
2011/3/13 11:30	2800	2100	0.170		0.3100	0.2600						
2011/3/13 11:35	900	1600	0.150		0.3100	0.2600						
2011/3/13 11:40	600	900	0.120		0.3100	0.2600						
2011/3/13 11:50	1900	2200	0.120									
2011/3/13 11:55	1000	1000	0.120									
2011/3/13 12:00	1100	1400	0.120									
2011/3/13 12:05	4300	4500	0.180		0.3200	0.2700						
2011/3/13 12:20			0.850		0.7500	0.7000						
2011/3/13 12:21			0.790		0.7500	0.7100						
2011/3/13 12:22			0.760		0.7500	0.7100						
2011/3/13 12:25	-1000	-1000	0.620		0.6800	0.6400						
2011/3/13 12:27	-1000	-1000	0.630		0.6400	0.5900						
2011/3/13 12:33			0.480									
2011/3/13 12:35	-1600	600	0.460		0.5200	0.4700						
2011/3/13 12:38	-1400	0	0.450		0.4800	0.4300						
2011/3/13 12:40	-1400	0	0.450		0.4800	0.4800						
2011/3/13 12:43	-1500	800	0.360		0.4300	0.3700						
2011/3/13 12:45	-1500	-200	0.320		0.4000	0.3600						
2011/3/13 12:47	-1300	-1000	0.300		0.3900	0.3400						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 12:48	-1300	-1300	0.280		0.3800	0.3300						
2011/3/13 12:49	-1300	-1600	0.270		0.3700	0.3200						
2011/3/13 12:50	-1300	-1600	0.260		0.3600	0.3100						
2011/3/13 12:51	-1300	-1700	0.250		0.3500	0.3000						
2011/3/13 12:52	-1300	-1800	0.240		0.3500	0.3000						
2011/3/13 12:55	-1300	-1900	0.220		0.3300	0.2800						
2011/3/13 13:00	-1400	-2000	0.190		0.3000	0.2500						
2011/3/13 13:05	-1600	-2200	0.180		0.2900	0.2400						
2011/3/13 13:10	-1700	-2200	0.170		0.2800	0.2300						
2011/3/13 13:15	-1600	-2200	0.150		0.2600	0.2200						
2011/3/13 13:18	-1600	-2200	0.140		0.2600	0.2100						
2011/3/13 13:25	-1700	-2200	0.130		0.3500	0.2000						
2011/3/13 13:30	-1700	-2200	0.110		0.2400	0.1900						
2011/3/13 13:35	-1800	-2200	0.100		0.2350	0.1900						
2011/3/13 13:40	-1800	-2200	0.100		0.2350	0.1900						
2011/3/13 13:45	-1800	-2200	0.090		0.2350	0.1850						
2011/3/13 13:50	-1800	-2200	0.120		0.2350	0.1850						
2011/3/13 13:55	-1800	-2200	0.100		0.2350	0.1850						
2011/3/13 14:00	-1800	-2200	0.090		0.2350	0.1850						
2011/3/13 14:05	-1800	-2200	0.090		0.2350	0.1850						
2011/3/13 14:10	-1800	-2200	0.080		0.2350	0.1850						
2011/3/13 14:15	-1800	-2200	0.080		0.2350	0.1850						
2011/3/13 14:20	-1800	-2200	0.080		0.2300	0.1800						
2011/3/13 14:25	-1800	-2200	0.080		0.2300	0.1800						
2011/3/13 14:30	-1800	-2200	0.080		0.2300	0.1800						
2011/3/13 14:35	-1800	-2200	0.080		0.2300	0.1800						
2011/3/13 14:40	-1800	-2200	0.080		0.2300	0.1800						
2011/3/13 14:45	-1600	-2200	0.080		0.2400	0.1900						
2011/3/13 14:50	-1600	-2000	0.085		0.2500	0.2000						
2011/3/13 14:55	-1600	-2000	0.090		0.2550	0.2050						
2011/3/13 15:00	-1600	-2000	0.090		0.2600	0.2100						
2011/3/13 15:05	-1600	-2000	0.100		0.2700	0.2200						
2011/3/13 15:10	-1600	-2000	0.110		0.2750	0.2250						
2011/3/13 15:15	-1600	-2000	0.120		0.2850	0.2350						
2011/3/13 15:20	-1600	-2000	0.130		0.2900	0.2400						
2011/3/13 15:25	-1500	-1900	0.140		0.3000	0.2500						
2011/3/13 15:30	-1500	-1900	0.140		0.3100	0.2600						
2011/3/13 15:35	-1400	-1900	0.160		0.3200	0.2700						
2011/3/13 15:40	-1500	-1900	0.160		0.3300	0.2800						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 15:45	-1500	-2000	0.170		0.3300	0.2850						
2011/3/13 15:50	-1500	-2000	0.180		0.3400	0.2900						
2011/3/13 15:55	-1500	-2000	0.180		0.3450	0.2950						
2011/3/13 16:00	-1500	-2000	0.180		0.3500	0.3000						
2011/3/13 16:05	-1500	-2000	0.180		0.3550	0.3050						
2011/3/13 16:10	-1500	-2000	0.190		0.3600	0.3100						
2011/3/13 16:15	-1500	-2000	0.190		0.3600	0.3100						
2011/3/13 16:20	-1500	-2000	0.200		0.3650	0.3150						
2011/3/13 16:25	-1500	-1400	0.260		0.3800	0.3300						
2011/3/13 16:30	-1500	-1700	0.260		0.3950	0.3450						
2011/3/13 16:35	-1500	-1700	0.250		0.4000	0.3500						
2011/3/13 16:40	-1500	-1900	0.240		0.4100	0.3600						
2011/3/13 16:45	-1500	-1900	0.240		0.4100	0.3600						
2011/3/13 16:50	-1500	-1900	0.240		0.4100	0.3600						
2011/3/13 16:55	-1500	-1900	0.240		0.4100	0.3600						
2011/3/13 17:00	-1500	-1900	0.240		0.4100	0.3600						
2011/3/13 17:05	-1700	-2000	0.240		0.4100	0.3600						
2011/3/13 17:10	-1700	-2000	0.240		0.4100	0.3600						
2011/3/13 17:15	-1500	-1900	0.240		0.4100	0.3600						
2011/3/13 17:20	-1800	-2100	0.240		0.4100	0.3600						
2011/3/13 17:25	-1800	-2100	0.240		0.4150	0.3650						
2011/3/13 17:30	-1800	-2100	0.240		0.4150	0.3650						
2011/3/13 17:35	-1800	-2100	0.240		0.4150	0.3650						
2011/3/13 17:40	-1800	-2100	0.240		0.4150	0.3650						
2011/3/13 17:45	-1800	-2100	0.240		0.4150	0.3650						
2011/3/13 17:50	-1800	-2100	0.240		0.4150	0.3650						
2011/3/13 17:55	-1800	-2100	0.260		0.4200	0.3700						
2011/3/13 18:00	-1800	-2100	0.250		0.4200	0.3700						
2011/3/13 18:05	-1800	-2200	0.250		0.4200	0.3700						
2011/3/13 18:10	-1800	-2200	0.250		0.4200	0.3700						
2011/3/13 18:15	-1800	-2200	0.250		0.4200	0.3700						
2011/3/13 18:20	-1800	-2200	0.250		0.4200	0.3700						
2011/3/13 18:25	-1800	-2200	0.250		0.4200	0.3700						
2011/3/13 18:30	-1800	-2200	0.250		0.4200	0.3750						
2011/3/13 18:35	-1800	-2200	0.250		0.4200	0.3750						
2011/3/13 18:40	-1800	-2200	0.250		0.4200	0.3750						
2011/3/13 18:45	-1800	-2200	0.250		0.4200	0.3750						
2011/3/13 18:50	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 18:55	-1800	-2200	0.250		0.4250	0.3750						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 19:00	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:05	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:10	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:15	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:20	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:25	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:30	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:35	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:40	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:45	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:50	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 19:55	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 20:00	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 20:05	-1800	-2200	0.250		0.4250	0.3750						
2011/3/13 20:10	-1800	-2200			0.4250	0.3750						
2011/3/13 20:15	-1800	-2200			0.4250	0.3750						
2011/3/13 20:20	-1800	-2200			0.4250	0.3750						
2011/3/13 20:25	-1800	-2200			0.4250	0.3750						
2011/3/13 20:30	-1800	-2200			0.4250	0.3750						
2011/3/13 20:35	-1800	-2200			0.4250	0.3750						
2011/3/13 20:40	-1800	-2200			0.4250	0.3750						
2011/3/13 20:45	-1800	-2200			0.4100	0.3700						
2011/3/13 20:50	-1800	-2200			0.4050	0.3650						
2011/3/13 20:55	-1800	-2200			0.4000	0.3650						
2011/3/13 21:00	-1800	-2200			0.3950	0.3650						
2011/3/13 21:05	-1800	-2200			0.3800	0.3600						
2011/3/13 21:10	-1800	-2200			0.3800	0.3600						
2011/3/13 21:15	-1800	-2200			0.3750	0.3550						
2011/3/13 21:20	-1800	-2200			0.3650	0.3450						
2011/3/13 21:25	-1800	-2200			0.3550	0.3400						
2011/3/13 21:30	-1800	-2200			0.3400	0.3300						
2011/3/13 21:35	-1800	-2200			0.3350	0.3200						
2011/3/13 21:40	-1800	-2200			0.3300	0.3200						
2011/3/13 21:45	-1800	-2200			0.3200	0.3100						
2011/3/13 21:50	-1800	-2250			0.3200	0.3100						
2011/3/13 21:55	-1800	-2250			0.3100	0.3050						
2011/3/13 22:00	-1800	-2250			0.3050	0.3000						
2011/3/13 22:05	-1800	-2250			0.3000	0.3000						
2011/3/13 22:10	-1800	-2250			0.3000	0.2950						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/13 22:15	-1800	-2250			0.2950	0.2950						
2011/3/13 22:20	-1800	-2250			0.2950	0.2950						
2011/3/13 22:25	-1800	-2250			0.2900	0.2900						
2011/3/13 22:30	-1800	-2200			0.2850	0.2900						
2011/3/13 22:35	-1800	-2200			0.2800	0.2850						
2011/3/13 22:40	-1800	-2250			0.2800	0.2850						
2011/3/13 22:45	-1800	-2250			0.2750	0.2850						
2011/3/13 22:50	-1800	-2250			0.2750	0.2800						
2011/3/13 22:55	-1800	-2250			0.2700	0.2800						
2011/3/13 23:00	-1800	-2250	0.084	0.082	0.2650	0.2750						
2011/3/13 23:05	-1800	-2250			0.2650	0.2700						
2011/3/13 23:10	-1800	-2250			0.2600	0.2700						
2011/3/13 23:15	-1800	-2250			0.2600	0.2700						
2011/3/13 23:20	-1800	-2250			0.2550	0.2700						
2011/3/13 23:25	-1800	-2250			0.2500	0.2650						
2011/3/13 23:30	-1800	-2250	0.062	0.064	0.2500	0.2600						
2011/3/13 23:40	-1800	-2250			0.2450	0.2600						
2011/3/13 23:50	-1800	-2250			0.2400	0.2600						
2011/3/14 0:00	-1800	-2250	0.050	0.050	0.2400	0.2550						
2011/3/14 0:10	-1800	-2250			0.2400	0.2550						
2011/3/14 0:20	-1800	-2250			0.2400	0.2550						
2011/3/14 0:30	-1800	-2250	0.048	0.048	0.2400	0.2550						
2011/3/14 0:40	-1850	-2250			0.2400	0.2550						
2011/3/14 0:50	-1800	-2250			0.2400	0.2600						
2011/3/14 1:00	-1800	-2250	0.054	0.057	0.2450	0.2600						
2011/3/14 1:10	-1800	-2250			0.2450	0.2600						
2011/3/14 1:20	-1800	-2250			0.2500	0.2650						
2011/3/14 1:30	-1800	-2250	0.062	0.062	0.2550	0.2650						
2011/3/14 1:40	-1800	-2250			0.2550	0.2700						
2011/3/14 1:50	-1800	-2250			0.2600	0.2750						
2011/3/14 2:00	-1800	-2250	0.073	0.075	0.2650	0.2750						
2011/3/14 2:10	-1800	-2250			0.2700	0.2800						
2011/3/14 2:30	-1850	-2250	0.091	0.091	0.2800	0.2800						
2011/3/14 2:45	-1850	-2300			0.3050	0.3000						
2011/3/14 2:50	-1850	-2300	0.116	0.116	0.3100	0.3000						
2011/3/14 3:00	-1850	-2300	0.127	0.127	0.3150	0.3050						
2011/3/14 3:10	-1850	-2300			0.3200	0.3100						
2011/3/14 3:15	-1850											
2011/3/14 3:20	-1850	-2400			0.3300	0.3100						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 3:30	-1850	-2400	0.137	0.139	0.3300	0.3200						
2011/3/14 3:40	-1850	-2300	0.143	0.145	0.3400	0.3250						
2011/3/14 3:50	-1800	-2400			0.3400	0.3250						
2011/3/14 4:00	-1800	-2800	0.150	0.150	0.3400	0.3250						
2011/3/14 4:10	-1800	-3600			0.3450	0.3300	1.40E+02		4.28E+00			
2011/3/14 4:20	-1850	-2900			0.3550	0.3400	1.40E+02		4.28E+00			
2011/3/14 4:30	-1850	-3000	0.166	0.166	0.3600	0.3400	1.44E+02		3.94E+00			
2011/3/14 4:40	-1850	-3000			0.3600	0.3400						
2011/3/14 4:50	-1850	-2600			0.3650	0.3450	1.53E+02		3.80E+00	3.60E+00		
2011/3/14 5:00	-2000		0.171	0.171	0.3650	0.3450	1.58E+02		3.78E+00	3.59E+00		
2011/3/14 5:10	-1800				0.3700	0.3500						
2011/3/14 5:20	-1900				0.3750	0.3550						
2011/3/14 5:30	-2000		0.198	0.201	0.3900	0.3650	1.58E+02		3.62E+00	3.50E+00		
2011/3/14 5:40	-1800				0.4100	0.3900						
2011/3/14 5:50	-1950				0.4150	0.3950						
2011/3/14 6:00	-2350		0.225	0.229	0.4250	0.4000	1.66E+02		3.53E+00	3.77E+00		
2011/3/14 6:10					0.4600	0.4300						
2011/3/14 6:20					0.4700	0.4500						
2011/3/14 6:30	-100	-3500			0.4950	0.4700	1.68E+02		3.54E+00	3.89E+00		
2011/3/14 6:35	-1300		0.311	0.315	0.5200	0.5000	1.70E+02			3.89E+00		
2011/3/14 6:40	300	-3300	0.314	0.319	0.5200	0.5000	1.70E+02		3.54E+00	3.91E+00		
2011/3/14 6:45	300	-1100	0.315	0.319	0.5200	0.5000	1.70E+02		3.55E+00	3.90E+00		
2011/3/14 6:50	650	-1200	0.321	0.325	0.5300	0.5050			3.52E+00	3.97E+00		
2011/3/14 6:55		-2700	0.319	0.323	0.5300	0.5050			3.55E+00			
2011/3/14 7:00		-3000	0.319	0.315	0.5200	0.5000	1.67E+02		3.58E+00	4.01E+00		
2011/3/14 7:05		-2900	0.311	0.307	0.5150	0.4950	1.66E+02		3.67E+00	4.05E+00		
2011/3/14 7:10		-2700	0.303	0.307	0.5100	0.4900	1.65E+02		3.72E+00			
2011/3/14 7:15	1000	-2100	0.299	0.303	0.5050	0.4900	1.65E+02		3.78E+00	4.14E+00		
2011/3/14 7:20	2000	-1600	0.298	0.299	0.5000	0.4800	1.64E+02		3.83E+00	4.44E+00		
2011/3/14 7:25	1700	-1300	0.298	0.299	0.5000	0.4800	1.63E+02		3.82E+00	4.31E+00		
2011/3/14 7:30	1500	-1400	0.298	0.301	0.5000	0.4850	1.63E+02		3.80E+00	4.31E+00		
2011/3/14 7:35	1400	-1500	0.295	0.301	0.5000	0.4850	1.62E+02		3.79E+00	4.31E+00		
2011/3/14 7:40	1100	-800	0.295	0.301	0.5000	0.4800	1.61E+02		3.79E+00	4.32E+00		
2011/3/14 7:45	800	-500	0.295	0.299	0.5000	0.4800	1.61E+02		3.79E+00	4.34E+00		
2011/3/14 7:50	400	100	0.298	0.293	0.5000	0.4800	1.60E+02		3.78E+00	4.36E+00		
2011/3/14 8:00	-1000	650	0.291	0.298	0.5000	0.4800	1.60E+02		3.80E+00	4.40E+00		
2011/3/14 8:05	-800	2100	0.289	0.293	0.5000	0.4800	1.60E+02		3.80E+00	4.43E+00		
2011/3/14 8:10	-500	2800	0.287	0.291	0.4950	0.4750	1.60E+02		3.87E+00	4.49E+00		
2011/3/14 8:15	-200	3100	0.285	0.289	0.4950	0.4750	1.59E+02		3.91E+00	4.53E+00		

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 8:20	-200	2600	0.285	0.289	0.4900	0.4700	1.59E+02		3.94E+00	4.57E+00		
2011/3/14 8:30	-1800	200	0.281	0.287	0.4900	0.4700	1.57E+02		4.00E+00	4.62E+00		
2011/3/14 8:40	-1800	1200	0.289	0.287	0.4900	0.4700	1.57E+02		4.01E+00	4.63E+00		
2011/3/14 8:45	-1700	1600	0.289	0.285	0.4900	0.4750	1.57E+02		3.93E+00	4.56E+00		
2011/3/14 8:55	-1700	2500	0.285	0.291	0.4900	0.4750	1.58E+02		3.89E+00	4.53E+00		
2011/3/14 9:05	-1500	2800	0.287	0.291	0.4900	0.4750	1.57E+02		3.87E+00	4.50E+00		
2011/3/14 9:10	-1700	3100	0.287	0.293	0.4950	0.4750	1.57E+02		3.86E+00	4.49E+00		
2011/3/14 9:15	-1500	2500	0.289	0.295	0.4950	0.4750	1.57E+02		3.83E+00	4.47E+00		
2011/3/14 9:20	-1500	1700	0.293	0.298	0.4950	0.4800	1.56E+02		3.77E+00	4.42E+00		
2011/3/14 9:25	-1500	1100	0.295	0.299	0.5000	0.4800	1.56E+02		3.77E+00	4.42E+00		
2011/3/14 9:30	-1500	800	0.298	0.301	0.5000	0.4800	1.55E+02		3.70E+00	4.36E+00		
2011/3/14 9:35	-1500	200	0.299	0.301	0.5000	0.4850	1.55E+02		3.68E+00	4.39E+00		
2011/3/14 9:40	-1500	-400	0.299	0.303	0.5000	0.4850	1.56E+02		3.66E+00	4.48E+00		
2011/3/14 9:45	-1500	-400	0.299	0.305	0.5000	0.4850	1.55E+02		3.65E+00	4.55E+00		
2011/3/14 9:50	-1400	-400	0.301	0.307	0.5000	0.4850	1.55E+02		3.65E+00	4.55E+00		
2011/3/14 9:55	-1500	800	0.303	0.309	0.5050	0.4900	1.54E+02		3.59E+00	4.47E+00		
2011/3/14 10:00	-1400	-300	0.305	0.311	0.5100	0.4900	1.54E+02		3.56E+00	4.41E+00		
2011/3/14 10:05	-1500	800	0.309	0.314	0.5100	0.4950	1.54E+02		3.54E+00	4.40E+00		
2011/3/14 10:10	-1600	-200	0.309	0.315	0.5150	0.4950	1.55E+02		3.51E+00	4.38E+00		
2011/3/14 10:15	-1700	600	0.314	0.317	0.5150	0.4950	1.54E+02		3.50E+00	4.35E+00		
2011/3/14 10:20	-1400	-100	0.315	0.319	0.5200	0.5000	1.54E+02		3.48E+00	4.28E+00		
2011/3/14 10:25	-1700	-500	0.315	0.321	0.5200	0.5000	1.54E+02		3.48E+00	4.30E+00		
2011/3/14 10:30	-1500	-1000	0.315	0.321	0.5200	0.5000	1.54E+02		3.49E+00	4.35E+00		
2011/3/14 10:35	-1600	-600	0.315	0.321	0.5200	0.5000	1.54E+02		3.49E+00	4.35E+00		
2011/3/14 10:40	-1700	0	0.315	0.321	0.5200	0.5000	1.55E+02		3.49E+00	4.34E+00		
2011/3/14 10:45	-1700	-100	0.315	0.321	0.5200	0.5000	1.55E+02		3.49E+00	4.35E+00		
2011/3/14 10:50	-1800	-400	0.317	0.323	0.5200	0.5000	1.54E+02		3.49E+00	4.35E+00		
2011/3/14 10:55	-1500	-600	0.317	0.323	0.5200	0.5000	1.54E+02		3.50E+00	4.34E+00		
2011/3/14 11:02	-1400	3200	0.291	0.285	0.4800	0.4700						
2011/3/14 11:15	-1600		0.195	0.203	0.3800	0.3900						
2011/3/14 11:20	-1800		0.166	0.175	0.3600	0.3800						
2011/3/14 11:25	-1800		0.175	0.180	0.3600	0.3800						
2011/3/14 11:30	-1800		0.166	0.175	0.3600	0.3800						
2011/3/14 11:35	-1800		0.164	0.171	0.3600	0.3800						
2011/3/14 11:45	-1800	-2200	0.169	0.175	0.3600	0.3800						
2011/3/14 11:55	-1800	-2200	0.173	0.180	0.3600	0.3800						
2011/3/14 12:05	-1800	-2200	0.180	0.187	0.3700	0.3900						
2011/3/14 12:15	-1800	-2200	0.189	0.195	0.3800	0.3900						
2011/3/14 12:30	-1800	-2200	0.205	0.219	0.4000	0.4050						

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 12:40	-1800	-2200	0.214	0.219	0.4050	0.4100						
2011/3/14 12:50	-1800	-2200	0.223	0.229	0.4150	0.4200						
2011/3/14 13:00	-1800	-2200	0.233	0.237	0.4300	0.4300						
2011/3/14 13:10	-1800	-2200	0.241	0.247	0.4400	0.4300						
2011/3/14 13:20	-1800	-2200	0.247	0.251	0.4450	0.4400						
2011/3/14 13:30	-1800	-2200	0.251	0.255	0.4500	0.4400						
2011/3/14 13:40	-1800	-2200	0.255	0.259	0.4500	0.4450						
2011/3/14 13:50	-1800	-2200	0.257	0.261	0.4500	0.4450						
2011/3/14 14:00	-1800	-2200	0.261	0.265	0.4600	0.4500						
2011/3/14 14:10	-1800	-2200	0.267	0.269	0.4600	0.4550						
2011/3/14 14:20	-1800	-2200	0.273	0.275	0.4700	0.4600						
2011/3/14 14:30	-1800	-2200	0.273	0.277	0.4700	0.4600						
2011/3/14 14:40	-1800	-2200	0.275	0.279	0.4750	0.4650						
2011/3/14 14:50	-1800	-2300	0.277	0.281	0.4800	0.4700						
2011/3/14 15:00	-1800	-2200	0.279	0.281	0.4800	0.4700						
2011/3/14 15:10	-1800	-2200	0.279	0.281	0.4800	0.4700						
2011/3/14 15:20	-1800	-2200	0.281	0.283	0.4800	0.4700						
2011/3/14 15:30	-1800	-2200	0.281	0.283	0.4800	0.4700						
2011/3/14 15:40	-1800	-2200	0.283	0.285	0.4800	0.4700						
2011/3/14 15:50	-1800	-2200	0.285	0.285	0.4800	0.4750						
2011/3/14 16:00	-1800	-2200	0.287	0.289	0.4800	0.4750						
2011/3/14 16:10	-1800	-2200	0.287	0.289	0.4800	0.4750						
2011/3/14 16:20	-1800	-2200	0.287	0.289	0.4800	0.4750						
2011/3/14 16:30	-1800	-2200	0.285	0.287	0.4800	0.4750						
2011/3/14 16:40	-1800	-2200	0.279	0.281	0.4750	0.4700						
2011/3/14 16:50	-1800	-2200	0.259	0.261	0.4600	0.4500						
2011/3/14 17:00	-1800	-2200	0.247	0.247	0.4400	0.4400						
2011/3/14 17:10	-1800	-2200	0.233	0.235	0.4300	0.4300						
2011/3/14 17:20	-1800	-2200	0.223	0.225	0.4200	0.0200						
2011/3/14 17:30	-1800	-2200	0.213	0.213	0.4000							
2011/3/14 17:40	-1800	-2200	0.205	0.205	0.4000							
2011/3/14 17:50	-1800	-2200	0.195	0.195	0.3850							
2011/3/14 18:00	-1850	-2200	0.191	0.191	0.3800							
2011/3/14 18:10	-1900	-2300	0.185	0.185	0.3700							
2011/3/14 18:20	-1850	-2300	0.180	0.180	0.3700							
2011/3/14 18:30	-1850	-2300	0.179	0.179	0.3700							
2011/3/14 18:40	-1900	-2300	0.175	0.175	0.3600							
2011/3/14 18:50	-1900	-2300	0.175	0.175	0.3600							
2011/3/14 19:00	-1900	-2300	0.173	0.173	0.3600							

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/14 19:10	-1900	-2300	0.173	0.173	0.3600							
2011/3/14 19:20	-1900	-2300	0.173	0.173	0.3600							
2011/3/14 19:30	-1900	-2300	0.173	0.173	0.3550							
2011/3/14 19:40	-1900	-2300	0.173	0.173	0.3550							
2011/3/14 19:50	-1900	-2300	0.175	0.175	0.3550							
2011/3/14 20:00	-1900	-2300	0.175	0.175	0.3550							
2011/3/14 20:10	-1900	-2300	0.175	0.175	0.3550							
2011/3/14 20:20	-1900	-2300	0.173	0.173	0.3550							
2011/3/14 20:30	-1900	-2300	0.173	0.173	0.3550							
2011/3/14 20:40	-1850	-2300	0.173	0.173	0.3600							
2011/3/14 20:50	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 21:00	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 21:10	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 21:20	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 21:30	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 21:40	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 21:45	-1850	-2300	0.175	0.175	0.3600							
2011/3/14 22:00	-1850	-2300	0.177	0.177	0.3600							
2011/3/14 22:15	-1850	-2300	0.179	0.179	0.3600							
2011/3/14 22:30	-1900	-2300	0.180	0.180	0.3600							
2011/3/14 22:40	-1900	-2300	0.185	0.185	0.3700							
2011/3/14 22:45	-1900	-2300	0.185	0.185	0.3700							
2011/3/14 23:00	-1900	-2300	0.189	0.189	0.3700							
2011/3/14 23:15	-1900	-2300	0.193	0.193	0.3700							
2011/3/14 23:30	-1850	-2300	0.195	0.195	0.3800							
2011/3/14 23:45	-1900	-2300	0.201	0.198	0.3950							
2011/3/15 0:00	-1900	-2300	0.203	0.203	0.3900							
2011/3/15 0:15	-1900	-2300	0.207	0.205	0.3900							
2011/3/15 0:30	-1900	-2300	0.209	0.209	0.3900							
2011/3/15 0:45	-1900	-2300	0.211	0.211	0.4000							
2011/3/15 1:00	-1900	-2300	0.213	0.213	0.4000							
2011/3/15 1:15	-1800	-2200	0.214	0.214	0.4000							
2011/3/15 1:30	-1800	-2300	0.214	0.214	0.4000							
2011/3/15 1:45	-1850	-2300	0.219	0.219	0.4000							
2011/3/15 2:00	-1900	-2300	0.221	0.221	0.4000							
2011/3/15 2:15	-1900	-2300	0.221	0.221	0.4100							
2011/3/15 2:30	-1900	-2300	0.225	0.223	0.4050							
2011/3/15 2:45	-1900	-2300	0.227	0.227	0.4050							
2011/3/15 3:00	-1900	-2300	0.229	0.229	0.4100							

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/15 3:10	-1900	-2300	0.233	0.233	0.4150							
2011/3/15 3:45	-1900	-2300	0.233	0.233	0.4150							
2011/3/15 4:00	-1900	-2300	0.235	0.235	0.4150							
2011/3/15 4:15	-1900	-2300	0.233	0.233	0.4150							
2011/3/15 4:30	-1800	-2300	0.233	0.233	0.4150							
2011/3/15 4:47	-1800	-2300	0.230	0.230	0.4150							
2011/3/15 5:00	-1800	-2300	0.230	0.230	0.4150							
2011/3/15 5:15	-1800	-2300	0.230	0.230	0.4150							
2011/3/15 5:30	-1800	-2300	0.230	0.230	0.4150							
2011/3/15 5:45	-1800	-2300	0.230	0.230	0.4150							
2011/3/15 6:00	-1800	-2300	0.230	0.230	0.4150							
2011/3/15 6:15	-1800	-2300	0.245	0.245	0.4300							
2011/3/15 11:20	-1900	-2300	0.235	0.237	0.4200							
2011/3/15 11:30	-1900	-2300	0.235	0.235	0.4200							
2011/3/15 11:50	-1900	-2300	0.235	0.237	0.4200							
2011/3/15 13:00	-1900	-2300	0.235	0.237	0.4200							
2011/3/15 16:00	-1900	-2300	0.227	0.227	0.4150							
2011/3/15 20:45	-1900	-2300	0.170	0.170	0.3400							
2011/3/15 20:55	-1900	-2300	0.170	0.170	0.3400							
2011/3/15 21:05	-1900	-2300	0.161	0.170	0.3350							
2011/3/16 1:35	-1900	-2300	0.146	0.151	0.3200							
2011/3/16 2:05	-1900	-2300	0.143	0.149	0.3200							
2011/3/16 2:20	-1900	-2300	0.143	0.149	0.3200							
2011/3/16 6:15	-1900	-2300	0.117	0.117	0.2950							
2011/3/16 9:10	-1900	-2300	0.128	0.134	0.3050							
2011/3/16 9:20	-1900	-2300	0.100	0.104	0.2750							
2011/3/16 9:30	-1900	-2300	0.094	0.098	0.2700							
2011/3/16 9:40	-1900	-2300	0.094	0.090	0.2650							
2011/3/16 9:55	-1900	-2300	0.083	0.090	0.2600							
2011/3/16 10:00	-1900	-2300	0.077	0.083	0.2500							
2011/3/16 10:10	-1900	-2300	0.073	0.078	0.2500							
2011/3/16 10:20	-1900	-2300	0.068	0.075	0.2450							
2011/3/16 10:30	-1900	-2300	0.068	0.075	0.2450							
2011/3/16 11:45	-1900	-2300	0.051	0.058	0.2250							
2011/3/16 12:20	-1900	-2300	0.056	0.061	0.2300							
2011/3/16 12:24	-1900	-2300	0.056	0.061	0.2300							
2011/3/16 12:35	-1900	-2300	0.056	0.061	0.2300							
2011/3/16 12:40	-1900	-2300	0.056	0.061	0.2300							
2011/3/16 12:45	-1900	-2300	0.056	0.061	0.2300							

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/16 14:35	-1900	-2300	0.043	0.051	0.2200							
2011/3/16 14:45	-1900	-2300	0.043	0.051	0.2200							
2011/3/16 19:25	-1900	-2300	0.036	0.041	0.1900							
2011/3/16 20:40	-1900	-2300	0.041	0.041	0.1900							
2011/3/16 23:50	-1950	-2300	0.009	0.015	0.1850							
2011/3/16 23:51	-1950	-2300	0.009	0.015	0.1850							
2011/3/17 0:07	-1950	-2300	0.010	0.017	0.1850							
2011/3/17 3:05	-1950	-2300	0.022	0.030	0.2000							
2011/3/17 3:20	-1950	-2300	0.022	0.030	0.2000							
2011/3/17 4:00	-1950	-2300	0.022	0.030	0.2000							
2011/3/17 6:15	-1900	-2300	0.022	0.030	0.2000	0.0100						
2011/3/17 6:30	-1900	-2300	0.024	0.032	0.2000	0.0950						
2011/3/17 6:45	-1900	-2300	0.024	0.032	0.2000	0.3250						
2011/3/17 6:50	-1900	-2300	0.024	0.032	0.2000	0.2250						
2011/3/17 6:55	-1900	-2300	0.024	0.032	0.2000	0.1250						
2011/3/17 7:00	-1900	-2300	0.024	0.032	0.2000	0.1900						
2011/3/17 7:05	-1900	-2300	0.024	0.032	0.2000	0.2700						
2011/3/17 7:10	-1900	-2300	0.024	0.032	0.2000	0.1700						
2011/3/17 7:15	-1900	-2300	0.024	0.032	0.2000	0.3700						
2011/3/17 7:20	-1900	-2300	0.026	0.034	0.2000	0.0700						
2011/3/17 7:25	-1900	-2300	0.026	0.034	0.2000	0.5500						
2011/3/17 7:30	-1900	-2300	0.024	0.034	0.2000	0.4150						
2011/3/17 7:35	-1900	-2300	0.026	0.034	0.2000	0.0500						
2011/3/17 7:45	-1900	-2300	0.026	0.034	0.2000	0.1900						
2011/3/17 7:55	-1900	-2350	0.026	0.034	0.2000	0.4150						
2011/3/17 8:15	-1900	-2300	0.026	0.034	0.2000	0.1500						
2011/3/17 8:30	-1900	-2300	0.026	0.034	0.2000	0.2500						
2011/3/17 8:45	-1900	-2300	0.026	0.036	0.2000	0.2800						
2011/3/17 11:06	-1950	-2300	0.013	0.024	0.1900	0.3250						
2011/3/17 11:10	-1950	-2300	0.013	0.022	0.1900							
2011/3/17 16:10	-1950	-2300		-0.002	0.1700							
2011/3/17 16:17	-1950	-2300	-0.015	-0.002	0.1700							
2011/3/17 16:25	-1950	-2300	0.005	0.017	0.1700							
2011/3/17 16:35	-1950	-2300	0.005	0.017	0.1700							
2011/3/17 21:35	-1950	-2300	-0.030	-0.017	0.1500							
2011/3/17 21:50	-1950	-2300	-0.010	0.002	0.1500							
2011/3/17 22:00	-1950	-2300	-0.009	0.005	0.1500							
2011/3/18 2:00	-2000	-2300	-0.007	0.009	0.1500							
2011/3/18 2:20	-2000	-2300	-0.009	0.009	0.1500							

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/18 2:30	-2000	-2300	-0.005	0.013	0.1550							
2011/3/18 2:45	-2000	-2300	-0.005	0.013	0.1550							
2011/3/18 7:20	-1900	-2300	-0.010	0.007	0.1500							
2011/3/18 7:30	-1900	-2300	-0.007	0.009	0.1500							
2011/3/18 7:50	-1900	-2300	-0.009	0.009	0.1500							
2011/3/18 8:00	-1900	-2300	-0.005	0.009	0.1500		5.44E+01		3.40E+00			
2011/3/18 11:50	-1900	-2300	0.000	-0.017	0.1550		1.05E+02	9.52E+01	5.90E+00	3.81E+00		
2011/3/18 12:15	-2000	-2300	0.000	-0.017	0.1550		1.05E+02	9.52E+01	5.90E+00	3.81E+00		
2011/3/18 12:35	-2000	-2300	0.000	-0.017	0.1550		1.05E+02	9.52E+01	5.90E+00	3.81E+00		
2011/3/18 15:45	-2000	-2300	0.015	-0.015	0.1600		1.02E+02	9.33E+01	5.28E+00	3.71E+00	0.400	
2011/3/18 15:55	-2000	-2300	0.015	-0.015	0.1600		1.02E+02	9.33E+01	5.28E+00	3.71E+00		
2011/3/18 20:50	-1900	-2300	0.017	-0.015	0.1600		9.68E+01	9.07E+01	5.10E+00	3.58E+00		
2011/3/18 21:05	-1900	-2300	0.015	-0.017	0.1600		9.64E+01	9.06E+01	5.09E+00	3.58E+00		
2011/3/19 2:10	-3200	-3300	0.020	-0.143	0.0550		9.21E+01	8.61E+01	4.90E+00	3.46E+00		
2011/3/19 2:25	-3200	-3350	0.020	-0.143	0.0550		9.24E+01	8.58E+01	4.90E+00	3.45E+00		
2011/3/19 2:40	-3250	-3350	0.019	-0.015	0.0500		9.19E+01	8.56E+01	4.89E+00	3.45E+00		
2011/3/19 2:55	-3300	-3400	0.019	-0.015	0.0450		9.19E+01	8.53E+01	4.88E+00	3.44E+00		
2011/3/19 3:11	-3350	-3400	0.026	-0.015	0.0400		9.14E+01	8.51E+01	4.88E+00	3.44E+00		
2011/3/19 4:40			0.007	0.043			8.99E+01	8.40E+01	4.36E+00	3.21E+00		
2011/3/19 5:40	-1650	-2300	0.010	0.043	0.1900		9.09E+01	8.33E+01	3.70E+00	3.15E+00		
2011/3/19 6:00	-1300	-2300	0.005	0.041	0.1850		8.86E+01	8.32E+01	3.78E+00	3.11E+00		
2011/3/19 6:10	-1200	-2300	0.005	0.043	0.1850		8.83E+01	8.31E+01	3.76E+00	3.09E+00		
2011/3/19 8:00	-2400	-2300	0.009	0.044	0.1800		8.74E+01	8.27E+01	3.72E+00	3.06E+00		
2011/3/19 8:20	-2700	-2300	0.015	0.053	0.1900		8.97E+01	8.25E+01	3.80E+00	3.13E+00		
2011/3/19 8:30	-2600	-2300	0.013	0.051	0.1900		8.95E+01	8.24E+01	3.83E+00	3.12E+00	0.350	
2011/3/19 11:00	-1950	-2300	0.017	-0.019	0.1600							
2011/3/19 11:15	-1950	-2300	0.015	-0.022	0.1600						0.320	
2011/3/19 16:30	-1950	-2300	0.060	0.026	0.1900		7.63E+01	7.76E+01	3.52E+00	3.13E+00	0.300	
2011/3/19 16:35	-1950	-2300	0.060	-0.026	0.1900		7.63E+01	7.76E+01	3.52E+00	3.31E+00		
2011/3/19 16:50	-1950	-2300	0.083	-0.043	0.2100		7.85E+01	7.79E+01	3.90E+00	3.68E+00		
2011/3/19 17:20	-1850	-2200	0.081	0.047	0.2100		7.84E+01	7.78E+01	3.85E+00	3.49E+00	0.300	
2011/3/19 17:25	-1850	-2300	0.081	-0.047	0.2100		7.84E+01	7.78E+01	3.85E+00	3.49E+00		
2011/3/19 21:30	-1950	-2250	0.112	0.081	0.2550						0.330	
2011/3/19 21:55	-1950	-2250	0.115	0.083	0.2550						0.330	
2011/3/20 0:25	-1950	-2350	0.136	0.104	0.2700		6.12E+01	6.70E+01	3.24E+00	3.39E+00	0.300	
2011/3/20 0:50	-1950	-2350	0.138	0.102	0.2800		6.59E+01	6.71E+01	3.10E+00	3.35E+00	0.300	
2011/3/20 1:10	-1950	-2350	0.141	0.107	0.2800		6.70E+01	6.80E+01	3.12E+00	3.37E+00	0.300	
2011/3/20 3:10	-1950	-2250	0.187	0.151	0.3200	0.1800	7.20E+01	6.47E+01	3.08E+00	3.04E+00	0.330	
2011/3/20 4:10	-1950	-2300	0.197	0.163	0.3350	0.0600	7.05E+01	6.45E+01	3.07E+00	2.88E+00	0.330	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue: Add Point
Green: Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/20 4:30	-1950	-2300	0.204	0.170	0.3400	0.0500	6.96E+01	6.47E+01	3.07E+00	2.86E+00	0.330	
2011/3/20 9:55	-1950	-2350	0.180	0.146	0.3200	0.4000	7.08E+01	6.31E+01	2.30E+00	2.31E+00	0.330	
2011/3/20 10:10	-1950	-2350	0.175	0.136	0.3100	0.4000	7.11E+01	6.29E+01	2.23E+00	2.25E+00	0.330	
2011/3/20 10:35	-1950	-2300	0.170	0.132	0.3100	0.4000	7.08E+01	6.28E+01	2.18E+00	2.23E+00	0.330	
2011/3/20 11:00	-1950	-2250	0.179	0.141	0.3100	0.4000	7.09E+01	6.28E+01	2.20E+00	2.25E+00	0.330	
2011/3/20 15:00	-1600	-2000	0.155	0.121	0.3000	0.3150	7.20E+01	6.30E+01	2.02E+00	2.11E+00	0.330	
2011/3/20 15:35	-1550	-2000	0.158	0.117	0.2900	0.1250	7.18E+01	6.29E+01	2.01E+00	2.09E+00	0.330	
2011/3/20 16:00	-1650	-2000	0.153	0.112	0.2900	0.4000	7.17E+01	6.28E+01	2.00E+00	2.08E+00	0.330	
2011/3/20 19:40	-2000	-2000	0.095	0.056	0.2300		7.11E+01	6.27E+01	1.93E+00	2.05E+00	0.330	
2011/3/20 19:50	-2000	-2000	0.095	0.056	0.2300		7.11E+01	6.27E+01	1.93E+00	2.05E+00	0.330	
2011/3/20 20:00	-1625	-1900	0.094	0.049	0.2250		7.10E+01	6.25E+01	1.92E+00	2.05E+00	0.330	
2011/3/21 1:25	-1700	-2000	8.968	-0.005	0.1800		6.99E+01	6.14E+01	1.88E+00	2.00E+00	0.310	
2011/3/21 1:45	-1650	-2000	11.571	-0.010	0.1700		6.97E+01	6.12E+01	1.88E+00	2.00E+00	0.300	
2011/3/21 2:30	-1650	-2000	10.774	-0.009	0.1700		6.96E+01	6.10E+01	1.87E+00	2.00E+00	0.290	
2011/3/21 4:00	-1650	-1950	0.202	-0.026	0.1600		6.92E+01	6.05E+01	1.88E+00	1.99E+00	0.290	
2011/3/21 10:00	-2550	-2750	-0.500	-0.043	0.1200		6.74E+01	5.90E+01	1.86E+00	1.87E+00	0.290	
2011/3/21 12:15	-1600	-2000	0.041	-0.078	0.1200		6.72E+01	5.86E+01	1.83E+00	1.85E+00	0.290	
2011/3/21 14:40	-1550	-2025	0.043	-0.083	0.1100		6.63E+01	5.76E+01			0.280	
2011/3/21 14:55	-1550	-2025	0.043	-0.083	0.1100						0.280	
2011/3/21 23:40	-1500	-2300	0.039	-0.094	0.1000						0.280	
2011/3/22 0:15	-1575	-2250	0.041	-0.094	0.1000						0.280	
2011/3/22 5:15	-1550	-2350	0.036	-0.095	0.1000						0.280	
2011/3/22 5:30	-1575	-2350	0.036	-0.095	0.1000						0.280	
2011/3/22 10:20	-1575	-2325	0.036	-0.094	0.1000						0.260	
2011/3/22 10:35	-1575	-2350	0.034	-0.095	0.1000		6.00E+01	5.28E+01	1.58E+00	1.59E+00	0.260	
2011/3/22 17:10	-1525	-2250	0.036	-0.094	0.1000						0.240	
2011/3/22 17:40	-1525	-2250	0.034	-0.094	0.1000						0.240	
2011/3/22 22:00	-1750	-2350	0.036	-0.094	0.1000						0.240	
2011/3/22 22:40	-1750	-2350	0.036	-0.094	0.1000		6.10E+01	5.15E+01	1.69E+00	1.59E+00	0.240	
2011/3/23 3:00	-1900	-2300	0.032	-0.098	0.1000		6.05E+01	5.05E+01	1.75E+00	1.60E+00	0.240	
2011/3/23 4:00	-1900	-2300	0.034	-0.095	0.1000		6.05E+01	5.04E+01	1.75E+00	1.60E+00	0.240	
2011/3/23 8:20	-1800	-2300	0.034	-0.098	0.1000		6.02E+01	4.95E+01	1.74E+00	1.57E+00	0.240	
2011/3/23 8:50	-1900	-2300	0.032	-0.098	0.1000		6.02E+01	4.94E+01	1.74E+00	1.57E+00	0.250	
2011/3/23 9:10	-1800	-2300	0.032	-0.098	0.1000		6.02E+01	4.93E+01	1.74E+00	1.56E+00	0.250	
2011/3/23 13:40	-1800	-2300	0.041	-0.094	0.1000		5.95E+01	4.85E+01	1.72E+00	1.54E+00	0.230	
2011/3/23 21:10	-1700	-2300	0.041	-0.095			5.88E+01	4.73E+01	1.69E+00	1.51E+00	0.200	
2011/3/23 21:40	-1800	-2300	0.036	-0.095			5.87E+01	4.72E+01	1.68E+00	1.51E+00	0.200	
2011/3/24 2:20	-1800	-2300	0.041	-0.092			5.81E+01	4.65E+01	1.66E+00	1.50E+00	0.230	
2011/3/24 2:40	-1800	-2300	0.039	-0.092			5.79E+01	4.64E+01	1.66E+00	1.50E+00	0.220	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level (fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/24 6:20	-1800	-2300	0.039	-0.090	0.1076	0.1955	5.80E+01	4.59E+01	1.64E+00	1.49E+00	0.210	
2011/3/24 6:35	-1800	-2300	0.039	-0.090	0.1078	0.1958	5.72E+01	4.57E+01	1.64E+00	1.49E+00	0.200	
2011/3/24 10:00	-1900	-2300	0.036	-0.094	0.1074	0.1978	5.59E+01	4.50E+01	1.62E+00	1.48E+00	0.200	
2011/3/24 10:20	-1900	-2300	0.034	-0.094	0.1071	0.1986	5.59E+01	4.49E+01	1.62E+00	1.47E+00	0.200	
2011/3/24 18:00	-1850	-2300	0.036	-0.095	0.1073	0.1999	5.33E+01	4.37E+01	1.45E+00	1.59E+00	0.300	
2011/3/24 21:40	-1900	-2300	0.041	-0.092	0.1066	0.1993	5.47E+01	4.28E+01	1.57E+00	1.42E+00	0.250	
2011/3/24 22:00	-1800	-2300	0.030	-0.098	0.1068	0.1997	5.29E+01	4.28E+01	1.56E+00	1.42E+00	0.240	
2011/3/24 23:30	-1700	-2300	0.039	-0.092	0.1085	0.1981	5.20E+01	4.25E+01	1.55E+00	1.41E+00	0.250	
2011/3/25 0:30	-1700	-2300	0.041	-0.092	0.1085	0.1972	5.18E+01	4.24E+01	1.54E+00	1.40E+00	0.250	
2011/3/25 5:30	-1900	-2300	0.039	-0.092	0.1076	0.1948	5.00E+01	4.15E+01	1.50E+00	1.36E+00	0.200	
2011/3/25 6:10	-1900	-2300	0.036	-0.092	0.1074	0.1937	5.10E+01	4.14E+01	1.50E+00	1.36E+00	0.200	
2011/3/25 9:30	-1900	-2300	0.034	-0.092	0.1074	0.1923	4.93E+01	4.08E+01	1.47E+00	1.34E+00	0.200	
2011/3/25 14:10	-1900	-2300	0.036	-0.098	0.1089	0.1913	4.85E+01	4.00E+01	1.31E+00	1.44E+00	0.200	
2011/3/25 16:10	-1900	-2300	0.034	-0.094	0.1075	0.1895	3.88E+01	2.94E+01	1.31E+00	1.44E+00		
2011/3/25 18:10	-1800	-2300	0.036	-0.098	0.1069	0.1883	3.78E+01	2.85E+01	1.43E+00	1.30E+00	0.170	
2011/3/25 19:10	-1900	-2300	0.034	-0.098	0.1069	0.1824	3.73E+01	2.83E+01	1.42E+00	1.20E+00	0.180	
2011/3/26 4:20	-1825	-2300	0.036	-0.094	0.1068	0.1850	3.68E+01	2.77E+01	1.41E+00	1.30E+00	0.180	
2011/3/26 5:05	-1850	-2300	0.036	-0.095	0.1069	0.1848	3.66E+01	2.77E+01	1.41E+00	1.30E+00	0.180	
2011/3/26 10:00	-1800	-2300	0.036	-0.095	0.1066	0.1839	3.61E+01	2.75E+01	1.40E+00	1.30E+00	0.190	
2011/3/26 11:15	-1850	-2300	0.036	-0.095	0.1068	0.1836	3.61E+01	2.74E+01	1.40E+00	1.30E+00	0.220	
2011/3/26 14:30	-1850	-2300	0.032	-0.100	0.1068	0.1831	3.57E+01	2.71E+01	1.30E+00	1.39E+00	0.200	
2011/3/26 16:00	-1900	-2250	0.034	-0.100	0.1066	0.1825	3.55E+01	2.69E+01	1.39E+00	1.29E+00	0.190	
2011/3/26 20:00	-1900	-2300	0.034	-0.098	0.1071	0.1824	3.56E+01	2.66E+01	1.37E+00	1.28E+00	0.170	
2011/3/26 21:20	-1900	-2250	0.036	-0.098	0.1071	0.1818	3.50E+01	2.64E+01	1.37E+00	1.27E+00	0.170	
2011/3/26 23:10	-1900	-2250	0.034	-0.094	0.1076	0.1818	3.49E+01	2.62E+01	1.36E+00	1.27E+00	0.170	
2011/3/27 4:15	-1850	-2300	0.030	-0.092	0.1073	0.1804	3.41E+01	2.57E+01	1.34E+00	1.25E+00	0.160	
2011/3/27 4:45	-1850	-2300	0.027	-0.094	0.1073	0.1804	3.42E+01	2.56E+01	1.34E+00	1.25E+00	0.160	
2011/3/27 9:25	-1900	-2300	0.027	-0.094	0.1078	0.1808	3.43E+01	2.52E+01	1.32E+00	1.23E+00	0.160	
2011/3/27 10:10	-1900	-2300	0.030	-0.094	0.1076	0.1806	3.37E+01	2.51E+01	1.31E+00	1.23E+00	0.170	
2011/3/27 16:00	-1850	-2300	0.027	-0.094	0.1069	0.1797	3.31E+01	2.45E+01	1.31E+00	1.22E+00	0.160	
2011/3/27 16:25	-1850	-2300	0.032	-0.092	0.1069	0.1797	3.22E+01	2.45E+01	1.30E+00	1.22E+00	0.160	
2011/3/27 17:30	-1900	-2300	0.030	-0.092	0.1073	0.1799	3.29E+01	2.44E+01	1.29E+00	1.21E+00	0.150	
2011/3/27 18:30	-1900	-2300	0.032	-0.092	0.1075	0.1801	3.31E+01	2.43E+01	1.29E+00	1.21E+00	0.150	
2011/3/27 19:00	-1900	-2300	0.030	-0.094	0.1080	0.1804	3.29E+01	2.43E+01	1.29E+00	1.21E+00	0.150	
2011/3/28 0:00	-1900	-2300	0.027	-0.087	0.1082	0.1796	3.20E+01	2.38E+01	1.26E+00	1.18E+00	0.150	
2011/3/28 0:50	-1900	-2300	0.026	-0.087	0.1083	0.1797	3.20E+01	2.38E+01	1.26E+00	1.18E+00	0.150	
2011/3/28 5:00	-1900	-2300	0.030	-0.085	0.1085	0.1797	3.16E+01	2.35E+01	1.24E+00	1.17E+00	0.140	
2011/3/28 5:30	-1900	-2300	0.027	-0.085	0.1083	0.1794	3.15E+01	2.34E+01	1.24E+00	1.16E+00	0.140	
2011/3/28 10:00	-1850	-2250	0.024	-0.090	0.1082	0.1799	3.11E+01	2.31E+01	1.23E+00	1.14E+00	0.140	

Fukushima Daiichi Nuclear Power Station Unit3 Parameters of Water level and Pressure

[Note]:Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty of indicators into consideration.

Blue : Add Point
Green : Correction Point

Date	reactor water level (fuel range)(A) (mm)	reactor water level(fuel range)(B) (mm)	A system/ reactor pressure (MPa)	B system/ reactor pressure (MPa)	D/W pressure (MPa abs)	S/C pressure (MPa abs)	CAMS D/W(A) (Sv/h)	CAMS D/W(B) (Sv/h)	CAMS S/C(A) (Sv/h)	CAMS S/C(B) (Sv/h)	radiation dose in main control room (mSv/h)	note
2011/3/28 10:30	-1850	-2250	0.024	-0.090	0.1076	0.1792	3.10E+01	2.31E+01	1.23E+00	1.14E+00	0.140	
2011/3/28 15:00	-1850	-2250	0.027	-0.092	0.1076	0.1797	3.06E+01	2.27E+01	1.21E+00	1.13E+00	0.150	
2011/3/28 16:00	-1850	-2300	0.030	-0.090	0.1078	0.1797	3.05E+01	2.27E+01	1.21E+00	1.13E+00	0.140	
2011/3/28 19:30	-1850	-2300	0.030	-0.087	0.1083	0.1794	3.01E+01	2.24E+01	1.20E+00	1.12E+00	0.140	
2011/3/28 20:35	-1850	-2300	0.030	-0.087	0.1085	0.1797	3.00E+01	2.04E+01	1.20E+00	1.12E+00	0.150	
2011/3/28 21:00	-1850	-2300	0.030	-0.087	0.1083	0.1796	3.00E+01	2.23E+01	1.20E+00	1.11E+00	0.140	
2011/3/28 21:20	-1900	-2300	0.026	-0.090	0.1082	0.1794	2.99E+01	2.23E+01	1.20E+00	1.11E+00	0.140	
2011/3/28 21:40	-1900	-2300	0.026	-0.090	0.1082	0.1796	3.01E+01	2.23E+01	1.20E+00	1.11E+00	0.140	
2011/3/28 23:30	-1800	-2250	0.034	-0.090	0.1082	0.1796	3.09E+01	2.22E+01	1.19E+00	1.11E+00	0.140	
2011/3/29 0:00	-1800	-2250	0.027	-0.087	0.1073	0.1792	2.95E+01	2.21E+01	1.19E+00	1.11E+00	0.140	
2011/3/29 4:45	-1900	-2300	0.032	-0.085	0.1085	0.1792	2.92E+01	2.18E+01	1.18E+00	1.09E+00	0.140	
2011/3/29 5:15	-1900	-2300	0.026	-0.090	0.1083	0.1792	2.91E+01	2.18E+01	1.17E+00	1.09E+00	0.130	
2011/3/29 10:15	-1900	-2300	0.027	-0.087	0.1075	0.1790	2.93E+01	2.15E+01	1.16E+00	1.08E+00	0.140	
2011/3/29 10:45	-1850	-2250	0.024	-0.092	0.1073	0.1790	2.86E+01	2.14E+01	1.16E+00	1.08E+00	0.150	
2011/3/29 12:00	-1850	-2250	0.027	-0.090	0.1075	0.1796	2.86E+01	2.14E+01	1.16E+00	1.08E+00	0.150	
2011/3/29 14:30	-1900	-2250	0.026	-0.092	0.1068	0.1785	2.86E+01	2.12E+01	1.15E+00	1.07E+00	0.130	
2011/3/29 15:15	-1850	-2250	0.026	-0.094	0.1076	0.1803	2.86E+01	2.12E+01	1.15E+00	1.07E+00	0.130	
2011/3/29 15:45	-1850	-2250	0.027	-0.092	0.1073	0.1801	2.84E+01	2.11E+01	1.15E+00	1.07E+00	0.140	
2011/3/29 16:50	-1850	-2250	0.027	-0.092	0.1069	0.1790	2.84E+01	2.11E+01	1.14E+00	1.06E+00	0.130	
2011/3/29 22:10	-1900	-2300	0.027	-0.090	0.1069	0.1790	2.80E+01	2.08E+01	1.13E+00	1.05E+00	0.130	
2011/3/29 23:00	-1900	-2300	0.027	-0.090	0.1069	0.1785	2.78E+01	2.07E+01	1.13E+00	1.05E+00	0.130	
2011/3/30 3:20	-1900	-2250	0.024	-0.087	0.1071	0.1780	2.77E+01	2.05E+01	1.11E+00	1.04E+00	0.140	
2011/3/30 3:50	-1850	-2250	0.022	-0.087	0.1071	0.1780	2.76E+01	2.05E+01	1.11E+00	1.03E+00	0.130	
2011/3/30 8:30	-1850	-2250	0.022	-0.087	0.1073	0.1782	2.72E+01	2.02E+01	1.10E+00	1.02E+00	0.130	
2011/3/30 13:00	-1850	-2250	0.024	-0.085	0.1062	0.1771	2.69E+01	2.00E+01	1.09E+00	1.01E+00	0.140	
2011/3/30 13:30	-1850	-2250	0.017	-0.090	0.1064	0.1775	2.68E+01	2.00E+01	1.09E+00	1.01E+00	0.140	
2011/3/30 18:20	-1850	-2250	0.019	-0.087	0.1068	0.1773	2.65E+01	1.97E+01	1.07E+00	9.90E-01	0.140	
2011/3/30 19:00	-1850	-2250	0.022	-0.085	0.1068	0.1769	2.64E+01	1.97E+01	1.07E+00	9.98E-01	0.140	
2011/3/30 23:20	-1850	-2250	0.022	-0.085	0.1071	0.1775	2.61E+01	1.95E+01	1.06E+00	9.88E-01	0.130	
2011/3/30 23:50	-1850	-2250	0.019	-0.085	0.1073	0.1773	2.61E+01	1.95E+01	1.06E+00	9.87E-01	0.130	
2011/3/31 4:10	-1900	-2300	0.019	-0.085	0.1075	0.1768	2.60E+01	1.93E+01	1.05E+00	9.79E-01	0.130	
2011/3/31 4:40	-1900	-2300	0.019	-0.085	0.1073	0.1764	2.57E+01	1.92E+01	1.05E+00	9.77E-01	0.130	
2011/3/31 9:40	-1850	-2250	0.015	-0.087	0.1066	0.1755	2.54E+01	1.90E+01	1.04E+00	9.67E-01	0.130	
2011/3/31 16:10	-1900	-2250	0.015	-0.085	0.1071	0.1761	2.51E+01	1.87E+01	1.02E+00	9.55E-01	0.130	
2011/3/31 16:45	-1900	-2250	0.017	-0.085	0.1071	0.1761	2.59E+01	1.87E+01	1.02E+00	9.54E-01	0.130	
2011/3/31 19:00	-1850	-2250	0.010	-0.090	0.1069	0.1761	2.48E+01	1.86E+01	1.02E+00	9.49E-01	0.130	
2011/3/31 19:30	-1850	-2250	0.019	-0.083	0.1064	0.1754	2.54E+01	1.86E+01	1.02E+00	9.49E-01	0.130	
2011/3/31 19:50	-1850	-2250	0.022	-0.083	0.1068	0.1759	2.48E+01	1.86E+01	1.02E+00	9.47E-01	0.130	