

Nuclide Analysis Results of Sub-drain Water in the Surroundings of "Centralized Radiation Waste Treatment Facility"

I-131(Bq/cm<sup>3</sup>)

Sampling point	After transfer																						
	Dec 11	Dec 12	Dec 13	Dec 14	Dec 15	Dec 16	Dec 17	Dec 18	Dec 19	Dec 20	Dec 21	Dec 22	Dec 23	Dec 24	Dec 25	Dec 26	Dec 27	Dec 28	Dec 29				
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		

Cs-134(Bq/cm<sup>3</sup>)

Sampling point	After transfer																						
	Dec 11	Dec 12	Dec 13	Dec 14	Dec 15	Dec 16	Dec 17	Dec 18	Dec 19	Dec 20	Dec 21	Dec 22	Dec 23	Dec 24	Dec 25	Dec 26	Dec 27	Dec 28	Dec 29				
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	0.032	0.029	ND	0.026	ND	0.033	ND	0.026	0.038	0.022	ND	0.026	0.036	ND	0.034	ND	0.037	ND	0.032				
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-		
	0.17	0.16	0.17	0.11	0.13	0.18	0.083	0.13	0.22	0.09	0.088	0.17	0.057	0.22	0.16	0.11	0.076	0.19	0.062				
	ND	ND	0.031	ND	ND	ND	ND	ND	ND	0.032	0.023	0.03	ND	ND	ND	ND	ND	ND	0.033				
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			

Cs-137(Bq/cm<sup>3</sup>)

Sampling point	After transfer																						
	Dec 11	Dec 12	Dec 13	Dec 14	Dec 15	Dec 16	Dec 17	Dec 18	Dec 19	Dec 20	Dec 21	Dec 22	Dec 23	Dec 24	Dec 25	Dec 26	Dec 27	Dec 28	Dec 29				
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	0.041	0.041	0.031	0.04	0.031	ND	ND	0.028	ND	0.026	0.034	0.035	ND	ND	ND	0.032	ND	0.026	0.038				
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-		
	0.24	0.19	0.21	0.18	0.14	0.21	0.1	0.16	0.31	0.14	0.09	0.22	0.08	0.3	0.2	0.16	0.094	0.24	0.087				
	ND	ND	0.034	0.043	0.036	ND	ND	ND	0.03	ND	0.025	ND	ND	ND	0.033	0.027	0.039	0.025	0.046				
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			

\* Hyphen "-" indicates that neither sampling nor measurements were implemented.

\* was conducted as upstream of the groundwater once a week from April 29 since it was unable to sample at .

\* We have been sampling at since May 26, for it is located downstream of the groundwater.

\* We have been sampling at since May 30.

\* We have been sampling at since August 2.

\* "ND" means the sampled data is below measurable limit.

I-131: approx. 0.01Bq/cm<sup>3</sup>, Cs-134: approx. 0.02Bq/cm<sup>3</sup>, Cs-137: approx. 0.03Bq/cm<sup>3</sup> ( 12/29 )

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

<Place of sampling>  
 Southeast part of Unit 4 Turbine Building  
 Northeast part of Process Main Building  
 Southeast part of Process Main Building  
 Southwest part of Process Main Building  
 South part of Miscellaneous Solid Waste Volume  
 Reduction Treatment Building  
 Southwest part of On-site Bunker Building  
 West part of Incineration Workshop Building  
 North part of Miscellaneous Solid Waste Volume  
 Reduction Treatment Building  
 Southeast part of On-site Bunker Building