

<Reference>

May 24, 2012

Tokyo Electric Power Company

Nuclide Analysis Results of Radioactive Fallout at and around the Site of Fukushima Daiichi Reference

	Sampling Point	Sampling Period		Radioactivity density of samples (Bq/m ²) (half life)		
		From	To	I-131 (approx. 8 days)	Cs-134 (approx. 2 years)	Cs-137 (approx. 30 years)
Fukushima Daiichi NPS	Environment Management Building	2012/4/2 10:30am	2012/5/2 10:30am	ND	7700	11000
Fukushima Daini NPS	Administrative office building	2012/4/2 2:50pm	2012/5/2 10:05am	ND	150	220

* Bq/m² = MBq/km²

* "ND" means the sampled data is below measurable limit. (I-131: approx. 390Bq/m², Cs-134: approx. 35Bq/m², Cs-137: approx. 30Bq/m²)

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.