

Reference

Nuclide Analysis Results of Radioactive Materials in Seawater < Coast, Fukushima Daiichi Nuclear Power Station >

(Data summarized on May 23)

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	May 22, 2012 8:45 AM		May 22, 2012 8:25 AM		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (approx. 8 days)	ND	-	ND	-	40
Cs-134 (approx. 2 years)	ND	-	ND	-	60
Cs-137 (approx. 30 years)	ND	-	ND	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* Data of other nuclides are under evaluation.


* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

I-131: approx. 0.55Bq/L, Cs-134: approx. 1.3Bq/L, Cs-137: approx. 1.6Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

Radioactivity Density of Seawater at North of 1F5-6 Discharge Channel (Bq/L)



Radioactivity Density of Seawater at South Discharge Channel of 1F (Bq/L)

