

Reference

Nuclides Analysis Result of the Radioactive Materials in the Seawater < Coast, Fukushima Daiichi Nuclear Power Station >

(Data summarized on July 7)

Place of Sampling	North of Unit 5-6 Discharge Channel at 1F (Approx. 30m North of Unit 5-6 Discharge Channel)	Around 1F South Discharge Channel of 1F (Approx. 330m South of Unit 1-4 Discharge Channel)	Density Limit Specified by the Reactor Regulation (Bq/L) (The density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2.)		
Time of Sampling	Jul 6, 2012 7:55 AM	Jul 6, 2012 7:35 AM			
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (Approx. 8 days)	ND	-	ND	-	40
Cs-134 (Approx. 2 years)	1.7	0.03	ND	-	60
Cs-137 (Approx. 30 years)	3.2	0.04	ND	-	90

*The density specified by the Reactor Regulation is converted from Bq/cm³ to Bq/L.

* Data of other nuclides is under evaluation.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.50Bq/L, Cs-134: Approx.1.2Bq/L, Cs-137: Approx.1.5Bq/L

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Nuclides Analysis Result of Radioactive Materials in the Seawater < 1/2 >

(Data summarized on July 7)

Place of Sampling (Place No.)	3km Offshore of Ukedo River (T-D1) Upper Layer		3km(T-D5) Offshore of Fukushima Daiichi NPS Upper Layer		3km(T-D9) Offshore of Fukushima Daiini NPS Upper Layer		② Density Limit Specified by the Reactor Regulation (Bq/L) (The density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2.)
Date of Sampling	May 9, 2012		May 17, 2012		May 13, 2012		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
Cs-134 (Approx. 2 years)	0.28	0.00	0.11	0.00	0.045	0.00	60
Cs-137 (Approx. 30 years)	0.40	0.00	0.17	0.00	0.068	0.00	90
H-3 (approx. 12yrs)	ND	—	ND	—	ND	—	60,000
All α	ND	—	ND	—	ND	—	—
All β	ND	—	ND	—	ND	—	—
Sr-89 (about 51 days)	**	—	**	—	**	—	300
Sr-90 (About 29 years)	**	—	**	—	**	—	30

* The density specified by the Reactor Regulation is converted from Bq/cm³ to Bq/L.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* Nuclide analysis results of Cs-134 and Cs-137 were announced on June 6 and 12.

* When the measurement value is below the detection limit, "ND" is marked. The detection limits are as follows.

H-3: Approx. 2.9Bq/L, All α: Approx. 3.2Bq/L, All β: Approx. 22Bq/L

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

** Sr-89 and Sr-90 now under nuclides analysis.

(Evaluation)

H-3, All α radiations and All β radiations were not detected in the sample collected this time.

Nuclides Analysis Result of Radioactive Materials in the Seawater <2/2>

(Data summarized on July 7)

Place of Sampling (Place No.)	15km Offshore of Fukushima Daiichi NPS(T-5) Upper Layer						②Density Limit Specified by the Reactor Regulation (Bq/L) (The density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2.)
Date of Sampling	May 18, 2012						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
Cs-134 (Approx. 2 years)	0.014	0.00					60
Cs-137 (Approx. 30 years)	0.022	0.00					90
H-3 (approx. 12yrs)	ND	—					60,000
All α	ND	—					—
All β	ND	—					—
Sr-89 (about 51 days)	**	—					300
Sr-90 (About 29 years)	**	—					30

* The density specified by the Reactor Regulation is converted from Bq/cm³ to Bq/L.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* Nuclide analysis results of Cs-134 and Cs-137 were announced on June 22.

* When the measurement value is below the detection limit, "ND" is marked. The detection limits are as follows.

H-3: Approx. 2.9Bq/L, All α: Approx. 3.2Bq/L, All β: Approx. 22Bq/L


As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

** Sr-89 and Sr-90 now under nuclides analysis.

(Evaluation)

H-3, All α radiations and All β radiations were not detected in the sample collected this time.

Radioactivity Density of the Seawater at the North of 1F Unit 5-6 Discharge Channel (Bq/L)



Radioactivity Density of the Seawater at 1F South Discharge Channel (Bq/L)

