

Nuclide Analysis Results of Sub-drain Water in the Surroundings of "Centralized Radiation Waste Treatment Facility"

I-131(Bq/cm³)

| Sampling point | After transfer | | | | | | | | | | | | | | | | | | | |
|----------------|----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | Feb 19 | Feb 20 | Feb 21 | Feb 22 | Feb 23 | Feb 24 | Feb 25 | Feb 26 | Feb 27 | Feb 28 | Feb 29 | Mar 01 | Mar 02 | Mar 03 | Mar 04 | Mar 05 | Mar 06 | Mar 07 | Mar 08 | Mar 09 |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | - | ND | - | - | - | - | - | - | ND | - | - | - | - | - | - | ND | - | - | - | - |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |

Cs-134(Bq/cm³)

| Sampling point | After transfer | | | | | | | | | | | | | | | | | | | |
|----------------|----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | Feb 19 | Feb 20 | Feb 21 | Feb 22 | Feb 23 | Feb 24 | Feb 25 | Feb 26 | Feb 27 | Feb 28 | Feb 29 | Mar 01 | Mar 02 | Mar 03 | Mar 04 | Mar 05 | Mar 06 | Mar 07 | Mar 08 | Mar 09 |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | - | ND | - | - | - | - | - | - | ND | - | - | - | - | - | - | ND | - | - | - | - |
| | 0.041 | 0.1 | 0.087 | 0.11 | 0.11 | 0.12 | 0.11 | 0.036 | 0.11 | 0.097 | 0.088 | 0.088 | 0.086 | 0.084 | 0.059 | 0.09 | 0.52 | 0.31 | 0.18 | 0.079 |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |

Cs-137(Bq/cm³)

| Sampling point | After transfer | | | | | | | | | | | | | | | | | | | |
|----------------|----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | Feb 19 | Feb 20 | Feb 21 | Feb 22 | Feb 23 | Feb 24 | Feb 25 | Feb 26 | Feb 27 | Feb 28 | Feb 29 | Mar 01 | Mar 02 | Mar 03 | Mar 04 | Mar 05 | Mar 06 | Mar 07 | Mar 08 | Mar 09 |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | - | ND | - | - | - | - | - | - | ND | - | - | - | - | - | - | ND | - | - | - | - |
| | 0.061 | 0.14 | 0.12 | 0.15 | 0.14 | 0.17 | 0.11 | 0.049 | 0.13 | 0.11 | 0.14 | 0.12 | 0.12 | 0.13 | 0.08 | 0.14 | 0.74 | 0.45 | 0.26 | 0.11 |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |

* Hyphen "-" indicates that neither sampling nor measurements were implemented.
 * was conducted as upstream of the groundwater once a week from April 29 since it was unable to sample at .
 * We have been sampling at since May 26, 2011, for it is located downstream of the groundwater.
 * We have been sampling at since May 30, 2011
 * We have been sampling at since August 2, 2011
 * "ND" means the sampled data is below measurable limit.
 I-131: approx. 0.01Bq/cm³, Cs-134: approx. 0.02Bq/cm³, Cs-137: approx. 0.03Bq/cm³ (March 09, 2012)
 Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

- <Place of sampling>
- Southeast part of Unit 4 Turbine Building
- Northeast part of Process Main Building
- Southeast part of Process Main Building
- Southwest part of Process Main Building
- South part of Miscellaneous Solid Waste Volume Reduction Treatment Building
- Southwest part of On-site Bunker Building
- West part of Incineration Workshop Building
- North part of Miscellaneous Solid Waste Volume Reduction Treatment Building
- Southeast part of On-site Bunker Building