

Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm³)

Sampling Location	After transfer																				
	May 27	May 28	May 29	May 30	May 31	Jun 1	Jun 2	Jun 3	Jun 4	Jun 5	Jun 6	Jun 7	Jun 8	Jun 9	Jun 10	Jun 11	Jun 12	Jun 13	Jun 14	Jun 15	Jun 16
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		ND							ND							ND					
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Cs-134(Bq/cm³)

Sampling Location	After transfer																				
	May 27	May 28	May 29	May 30	May 31	Jun 1	Jun 2	Jun 3	Jun 4	Jun 5	Jun 6	Jun 7	Jun 8	Jun 9	Jun 10	Jun 11	Jun 12	Jun 13	Jun 14	Jun 15	Jun 16
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		ND							ND							ND					
	0.13	0.13	0.14	0.16	0.13	0.13	0.12	0.13	0.14	0.1	0.11	0.11	0.11	0.075	0.11	0.15	0.16	0.11	0.081	0.094	0.088
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Cs-137(Bq/cm³)

Sampling Location	After transfer																				
	May 27	May 28	May 29	May 30	May 31	Jun 1	Jun 2	Jun 3	Jun 4	Jun 5	Jun 6	Jun 7	Jun 8	Jun 9	Jun 10	Jun 11	Jun 12	Jun 13	Jun 14	Jun 15	Jun 16
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		ND							ND							ND					
	0.21	0.2	0.22	0.19	0.2	0.21	0.18	0.19	0.18	0.16	0.18	0.17	0.16	0.13	0.18	0.23	0.22	0.12	0.12	0.12	0.16
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

* Hyphen "-" indicates that neither sampling nor measurement was implemented.

* was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at .

* Sampling at (located in the downstream of the groundwater) has been done since May 26, 2011.

* Sampling at since May 30, 2011

* Sampling at has been done since August 2, 2011

* "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.01Bq/cm³, Cs-134: Approx.0.02Bq/cm³, Cs-137: Approx.0.02Bq/cm³ (June 16, 2012)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

<Place of Sampling>
Southeast of Unit 4 Turbine Building
Northeast of the Process Main Building
Southeast of the Process Main Building
Southwest of the Process Main Building
South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
Southwest Part of the On-site Bunker Building
West Side of the Incineration Workshop Building
North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
Southeast Part of the On-site Bunker Building