## Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

## I-131(Bq/cm<sup>3</sup>)

Sampling	After transfer																				
Location			Jun 19	Jun 20	Jun 21	Jun 22	Jun 23	Jun 24	Jun 25	Jun 26	Jun 27	Jun 28	Jun 29	Jun 30	Jul 01	Jul 02	Jul 03	Jul 04	Jul 05	Jul 06	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	

## Cs-134(Bq/cm<sup>3</sup>)

00 101(	Dq/oiii /																				
Sampling	After tra	After transfer																			
Location	Jun 17	Jun 18	Jun 19	Jun 20	Jun 21	Jun 22	Jun 23	Jun 24	Jun 25	Jun 26	Jun 27	Jun 28	Jun 29	Jun 30	Jul 01	Jul 02	Jul 03	Jul 04	Jul 05	Jul 06	
	ND	ND	ND	0.019	ND	0.021	ND	ND	ND												
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	
	0.063	0.092	0.099	0.13	0.12	0.096	0.11	0.14	0.15	0.07	0.14	0.14	0.15	0.11	0.12	0.13	0.12	0.12	0.12	0.12	
	ND	ND	ND	0.068	0.11	0.077	0.051	0.044	0.074	0.041	0.025	0.068	0.033	0.024	ND	0.032	ND	0.021	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	

## Cs-137(Bq/cm<sup>3</sup>)

Sampling	After tra	ınsfer																			
Location			Jun 19	Jun 20	Jun 21	Jun 22	Jun 23	Jun 24	Jun 25	Jun 26	Jun 27	Jun 28	Jun 29	Jun 30	Jul 01	Jul 02	Jul 03	Jul 04	Jul 05	Jul 06	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.035	ND	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	
	0.076	0.15	0.15	0.2	0.16	0.16	0.17	0.19	0.19	0.095	0.22	0.21	0.23	0.19	0.15	0.2	0.16	0.16	0.18	0.17	
	ND	ND	ND	0.1	0.2	0.11	0.086	0.067	0.11	0.062	0.022	0.092	0.042	0.049	0.034	0.041	0.039	0.045	0.051	0.034	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	

- \* Hyphen "-" indicates that neither sampling nor measurement was implemented.
- \* was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at
- \* Sampling at (located in the downstream of the groundwater) has been done since May 26, 2011.
- \* Samping at since May 30, 2011
- \* Sampling at has been done since August 2, 2011
- \* "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.01Bq/cm<sup>3</sup>, Cs-134: Approx.0.02Bq/cm<sup>3</sup>, Cs-137: Approx.0.02Bq/cm<sup>3</sup> (Jul 6,2012)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

<Place of Sampling>

Southeast of Unit 4 Turbine Building

Northeast of the Process Main Building

Southeast of the Process Main Building

Southwest of the Process Main Building

South Part of the Miscellaneous Solid Waste Volume Reduction

Treatment Building

Southwest Part of the On-site Bunker Building

West Side of the Incineration Workshop Building

North Part of the Miscellaneous Solid Waste Volume Reduction

Treatment Building

Southeast Part of the On-site Bunker Building