Nov 12, 2012 Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm<sup>3</sup>)

Sampling	After tra	Insfer																
Location	Oct 28	Oct 29	Oct 30	Oct 31	Nov 1	Nov 2	Nov 3	Nov 4	Nov 5	Nov 6	Nov 7	Nov 8	Nov 9	Nov 10	Nov 11			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			

## Cs-134(Bq/cm<sup>3</sup>)

Sampling																		
Location	Oct 28	Oct 29	Oct 30	Oct 31	Nov 1	Nov 2	Nov 3	Nov 4	Nov 5	Nov 6	Nov 7	Nov 8	Nov 9	Nov 10	Nov 11			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-			
	0.15	0.12	0.14	0.14	0.12	0.12	0.15	0.12	0.12	0.05	0.11	0.093	0.11	0.12	0.11			
	0.036	ND	0.028	ND	0.018	0.028	ND	ND	0.017	ND	ND	ND	ND	0.02	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			

## Cs-137(Bq/cm<sup>3</sup>)

Sampling																			
Location	Oct 28	Oct 29	Oct 30	Oct 31	Nov 1	Nov 2	Nov 3	Nov 4	Nov 5	Nov 6	Nov 7	Nov 8	Nov 9	Nov 10	Nov 11				
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.023	ND	ND				
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-				
	0.22	0.21	0.2	0.23	0.22	0.21	0.24	0.19	0.22	0.08	0.2	0.19	0.17	0.19	0.21				
	0.045	ND	0.036	0.037	0.027	0.05	ND	ND	0.034	0.037	ND	0.031	ND	0.021	ND				
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				

\* Hyphen "-" indicates that neither sampling nor measurement was implemented.

\* was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at

\* Sampling at (located in the downstream of the groundwater) has been done since May 26, 2011.

\* Samping at since May 30, 2011

\* Sampling at has been done since August 2, 2011

\* "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.01Bq/cm<sup>3</sup>, Cs-134: Approx.0.02Bq/cm<sup>3</sup>, Cs-137: Approx.0.02Bq/cm<sup>3</sup> (November 11, 2012)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Place of Sampling> Southeast of Unit 4 Turbine Building Northeast of the Process Main Building Southeast of the Process Main Building Southwest of the Process Main Building South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building Southwest Part of the On-site Bunker Building West Side of the Incineration Workshop Building North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building Southeast Part of the On-site Bunker Building