# Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

#### I-131(Bq/cm<sup>3</sup>)

Sampling	After transfer																				
Location	Nov 11	Nov 12	Nov 13	Nov 14	Nov 15	Nov 16	Nov 17	Nov 18	Nov 19	Nov 20	Nov 21	Nov 22	Nov 23	Nov 24	Nov 25	Nov 26	Nov 27	Nov 28	Nov 29		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		

## Cs-134(Bq/cm<sup>3</sup>)

Sampling																				
Location	Nov 11	Nov 12	Nov 13	Nov 14	Nov 15	Nov 16	Nov 17	Nov 18	Nov 19	Nov 20	Nov 21	Nov 22	Nov 23	Nov 24	Nov 25	Nov 26	Nov 27	Nov 28	Nov 29	
	ND																			
	ND																			
	ND																			
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	ND																			
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	
	0.11	0.1	0.12	0.12	0.12	0.079	0.11	0.052	0.12	0.097	0.11	0.053	0.11	0.063	0.12	0.13	0.1	0.12	0.097	
	ND	ND	ND	ND	ND	0.022	ND	0.021	ND	0.017	ND	ND	ND							
	ND																			

## Cs-137(Bq/cm<sup>3</sup>)

Sampling																				
Location	Nov 11	Nov 12	Nov 13	Nov 14	Nov 15	Nov 16	Nov 17	Nov 18	Nov 19	Nov 20	Nov 21	Nov 22	Nov 23	Nov 24	Nov 25	Nov 26	Nov 27	Nov 28	Nov 29	
	ND	0.031	0.035	ND	0.022	ND	ND	ND	ND	ND	ND									
	ND																			
	ND																			
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	ND																			
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	
	0.21	0.15	0.21	0.2	0.2	0.15	0.18	0.12	0.21	0.16	0.19	0.088	0.18	0.081	0.19	0.21	0.18	0.18	0.19	
	ND	ND	ND	0.024	0.027	0.033	ND	0.026	ND	0.022	ND	ND	ND	0.024	0.022	0.025	ND	ND	0.025	
	ND																			

- \* Hyphen "-" indicates that neither sampling nor measurement was implemented.
- \* was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at
- \* Sampling at (located in the downstream of the groundwater) has been done since May 26, 2011.
- \* Samping at since May 30, 2011
- \* Sampling at has been done since August 2, 2011
- \* "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.01Bq/cm<sup>3</sup>, Cs-134: Approx.0.02Bq/cm<sup>3</sup>, Cs-137: Approx.0.02Bq/cm<sup>3</sup> (November 29, 2012)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

#### <Place of Sampling>

Southeast of Unit 4 Turbine Building

Northeast of the Process Main Building

Southeast of the Process Main Building

Southwest of the Process Main Building

South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building Southwest Part of the On-site Bunker Building

West Side of the Incineration Workshop Building

North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building Southeast Part of the On-site Bunker Building