

The Result of analysis for Pu of sub-drains at Fukushima Daiichi

1. Place of sampling: Fukushima Daiichi sub-drain of Unit 2
sub-drain of Unit 3
sub-drain of Unit 5
2. Analytical body : Japan Chemical Analysis Center (JCAC)
3. Sampling result:

(Unit: Bq/cm³)

Place of sampling	Date of sampling	Pu-238	Pu-239,Pu-240
Sub-drain of Unit 2	12/12	N.D. [$<5.1 \times 10^{-7}$]	N.D. [$<5.1 \times 10^{-7}$]
Sub-drain of Unit 3		N.D. [$<4.8 \times 10^{-7}$]	N.D. [$<4.8 \times 10^{-7}$]
Sub-drain of Unit 5		N.D. [$<4.9 \times 10^{-7}$]	N.D. [$<4.7 \times 10^{-7}$]

[] : Detection Limit

4. Evaluation:

There is no detection of Pu-238, Pu-239 and Pu-240 from this sampling

END