

## Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference
-----------

(Data summarized on April 5)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	Apr 04, 2012 09:42 am	Apr 04, 2012 09:15 am	Apr 04, 2012 09:25 am	Apr 04, 2012 09:12 am	N/A	N/A	Apr 04, 2012 09:00 am
Detected Nuclides (Half-life)	Density of sample ( Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	-	-	ND
Cs-134 (about 2 years)	2.8E-01	1.0E+00	ND	ND	-	-	ND
Cs-137 (about 30 years)	4.4E-01	1.5E+00	ND	ND	-	-	ND

\* O.OE - O means O.O x 10-O


\* Data of other nuclides are under evaluation.

\* "ND" means the sampled data is below measurable limit.


I-131: approx. 2E-2Bq/cm3, Cs-134: approx. 2E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3 )

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.


Fukushima Daiichi Nuclear Power Station : Radioactivity Density of Sub-drain at Unit 1 (Bq/cm<sup>3</sup>)




Fukushima Daiichi Nuclear Power Station : Radioactivity Density of Sub-drain at Unit 2 (Bq/cm<sup>3</sup>)



Fukushima Daiichi Nuclear Power Station : Radioactivity Density of Sub-drain at Unit 3 (Bq/cm<sup>3</sup>)



Fukushima Daiichi Nuclear Power Station : Radioactivity Density of Sub-drain at Unit 4 (Bq/cm<sup>3</sup>)



Fukushima Daiichi Nuclear Power Station : Radioactivity Density at the Deep Well at the Site (Bq/cm<sup>3</sup>)

