

Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

(Data summarized on May 6)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	N/A	May 5, 2012 9:10 AM	N/A	N/A	N/A	N/A	N/A
Detected Nuclides (Half-life)	Density of sample (Bq/cm ³)						
I-131 (approx. 8 days)	-	ND	-	-	-	-	-
Cs-134 (approx. 2 years)	-	8.0E-01	-	-	-	-	-
Cs-137 (approx. 30 years)	-	1.3E+00	-	-	-	-	-

* O.OE - O means O.O x 10-O

* Data of other nuclides are under evaluation.

* "ND" means the sampled data is below measurable limit.

I-131: approx. 2E-2Bq/cm³)

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

Fukushima Daiichi Nuclear Power Station : Radioactivity Density of Sub-drain at Unit 2 (Bq/cm³)

