

Reference

Result of Nuclide Analysis of Sub Drain of Fukushima Daiichi NPS

(Data summarized on May 19)

Place of Sampling	Fukushima Daiichi NPS 1U Sub-drain	Fukushima Daiichi NPS 2U Sub-drain	Fukushima Daiichi NPS 3U Sub-drain	Fukushima Daiichi NPS 4U Sub-drain	Fukushima Daiichi NPS 5U Sub-drain	Fukushima Daiichi NPS 6U Sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	May 18, 2012 9:04 AM	May 18, 2012 10:50 AM	May 18, 2012 10:55 AM	May 18, 2012 9:09 AM	May 18, 2012 10:40 AM	May 18, 2012 10:30 AM	May 18, 2012 10:15 AM
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)						
I-131 (approx. 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (approx. 2 years)	3.5E-02	3.7E-01	ND	ND	ND	ND	ND
Cs-137 (approx. 30 years)	7.0E-02	6.1E-01	ND	ND	ND	ND	ND

* O.OE - O means O.O x 10-O


* Data of other nuclides are under evaluation.

* "ND" means the sampled data is below measurable limit.


I-131: approx. 2E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³)

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.


Fukushima Daiichi Nuclear Power Station : Radioactivity Density of Sub-drain at Unit 1 (Bq/cm³)




Fukushima Daiichi Nuclear Power Station : Radioactivity Density of Sub-drain at Unit 2 (Bq/cm³)




Fukushima Daiichi Nuclear Power Station : Radioactivity Density of Sub-drain at Unit 3 (Bq/cm³)




Fukushima Daiichi Nuclear Power Station : Radioactivity Density of Sub-drain at Unit 4 (Bq/cm³)



Fukushima Daiichi Nuclear Power Station : Radioactivity Density of Sub-drain at Unit 5 (Bq/cm³)



Fukushima Daiichi Nuclear Power Station : Radioactivity Density of Sub-drain at Unit 6 (Bq/cm³)



Fukushima Daiichi Nuclear Power Station : Radioactivity Density at the Deep Well at the Site (Bq/cm³)

