

## Nuclides Analysis Result of the Sub-drain of Fukushima Daiichi NPS

(Data summarized on June 19)

Place of Sampling	Fukushima Daiichi NPS Unit 1 Sub- drain	Fukushima Daiichi NPS Unit 2 Sub- drain	Fukushima Daiichi NPS Unit 3 Sub- drain	Fukushima Daiichi NPS Unit 4 Sub- drain	Fukushima Daiichi NPS Unit 5 Sub- drain	Fukushima Daiichi NPS Unit 6 Sub- drain	Deep Well at Fukushima Daiichi NPS
Time of Sampling	Jun 18, 2012 9:50 AM	Jun 18, 2012 9:46 AM	Jun 18, 2012 9:45 AM	Jun 18, 2012 9:08 AM	N/A	N/A	Jun 18, 2012 9:25 AM
Detected Nuclides (Half-life)	Density of Sample (Bq/cm <sup>3</sup> )						
I-131 (Approx. 8 days)	ND	ND	ND	ND	-	-	ND
Cs-134 (Approx. 2 years)	7.9E-02	9.8E-02	ND	ND	-	-	ND
Cs-137 (Approx. 30 years)	1.4E-01	1.7E-01	ND	ND	-	-	ND

\* O.OE - O is the same as  $O.O \times 10^{-O}$

\* Data of other nuclides is under evaluation.


\* "ND" indicates that the measurement result is below the detection limit.

I-131: Approx.  $1E-2$ Bq/cm<sup>3</sup>, Cs-134: Approx. $2E-2$ Bq/cm<sup>3</sup>, Cs-137: Approx. $2E-2$ Bq/cm<sup>3</sup> )


As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.


Fukushima Daiichi Nuclear Power Station: Radioactivity Density of Unit 1 Sub-drain (Bq/cm<sup>3</sup>)




Fukushima Daiichi Nuclear Power Station: Radioactivity Density of Unit 2 Sub-drain (Bq/cm<sup>3</sup>)



Fukushima Daiichi Nuclear Power Station: Radioactivity Density of Unit 3 Sub-drain (Bq/cm3)



Fukushima Daiichi Nuclear Power Station: Radioactivity Density of Unit 4 Sub-drain (Bq/cm3)



Fukushima Daiichi Nuclear Power Station: Radioactivity Density at the Deep Well at the Site (Bq/cm<sup>3</sup>)

