

Result of Pu Nuclide Analysis of Sub-Drain at Fukushima Daiichi Nuclear Power Station

1. Measurement Result:

(Unit: Bq/cm³)

| Place of Sampling | Date of Sampling | Pu-238 | Pu-239+Pu-240 |
|-------------------|------------------|--------------------------------|--------------------------------|
| Unit 2 Sub-Drain | June 11, 2012 | N.D. [$<1.9 \times 10^{-6}$] | N.D. [$<1.6 \times 10^{-6}$] |
| Unit 4 Sub-Drain | | N.D. [$<2.1 \times 10^{-6}$] | N.D. [$<1.8 \times 10^{-6}$] |

The detection limit is provided in parentheses.

2. Analytical Institution:

KAKEN Inc.

3. Evaluation:

Pu-238 and Pu-239+Pu-240 were not detected in the sample collected this time.

End