

Result of Pu Nuclide Analysis of Sub-Drain at Fukushima Daiichi Nuclear Power Station

1. Measurement Result:

(Unit: Bq/cm³)

Place of Sampling	Date of Sampling	Pu-238	Pu-239+Pu-240
	July 9, 2012	N.D. [$<1.8 \times 10^{-6}$]	N.D. [$<1.6 \times 10^{-6}$]
	July 6, 2012	N.D. [$<1.9 \times 10^{-6}$]	N.D. [$<1.6 \times 10^{-6}$]

[] shows below the detection limit.

2. Analytical Institution:

KAKEN Inc.

3. Evaluation:

Pu-238 and Pu-239+Pu-240 were not detected in the sample collected this time.

End