

Detailed Analysis Results in the Port, around Discharge Channel and Bank Protection of Fukushima
Daiichi NPS
Underground Water Obtained at Bank Protection

<Data summarized on June 22>

Unit: Bq/L

		Underground water observation hole No.1	Underground water observation hole No.2	Underground water observation hole No.3
Date of sampling		May 31, 2013	May 31, 2013	May 31, 2013
Time of sampling		3:01 PM	3:16 PM	3:32 PM
Cs-134 (Approx. 2 years)		0.53	ND (0.41)	1.6
Cs-137 (Approx.30 years)		0.57	0.95	2.7
The other γ	Ru-106 (Approx. 1 year)	19	ND	ND
		—	—	—
		—	—	—
All β		1,300	76	ND (17)
H-3 (Approx. 12 years)		460,000	340	1,800
Sr-90 (Approx. 29 years)		890	54	0.25

(Note) Data of the nuclides other than Sr-90 was announced on June 19.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.