

<Reference>

June 26, 2013

Tokyo Electric Power Company

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/2)  
Underground Water Obtained at Bank Protection

Unit: Bq/L

		Underground water observation hole No.1	Underground water observation hole No.2	Underground water observation hole No.3
Date of sampling		Jun 25, 2013		
Time of sampling		1:39 PM		
Cs-134 (Approx. 2 years)		ND(0.39)		
Cs-137 (Approx.30 years)		ND(0.49)		
The other $\gamma$	Ru-106 (Approx. 370 days)	20		
All $\beta$		1.4E+03		
H-3 (Approx. 12 years)		Under analysis		
Sr-90 (Approx. 29 years)		-		

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

<Reference>

June 26, 2013

Tokyo Electric Power Company

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/2)  
Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)
Date of Sampling		Jun 25, 2013						
Time of sampling		7:15 AM						
Cs-134(Approx. 2 years)		ND (3.3)						
Cs-137(Approx.30 years)		ND (2.1)						
All β		ND (18)						
H-3 (Approx. 12 years)		Under analysis						
Sr-90 (Approx. 29 years)		—						

Unit: Bq/L

	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port
Date of Sampling								
Time of sampling								
Cs-134(Approx. 2 years)								
Cs-137(Approx.30 years)								
All β								
H-3 (Approx. 12 years)								
Sr-90 (Approx. 29 years)								

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.