

<Reference>

July 6, 2013

Tokyo Electric Power Company

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/2)  
Underground Water Obtained at Bank Protection

Unit: Bq/L

		Underground water observation hole No.1	Underground water observation hole No.1-1	Underground water observation hole No.1-2	Underground water observation hole No.2	Underground water observation hole No.3
Date of sampling		Jul 4, 2013			Jul 4, 2013	Jul 4, 2013
Time of sampling		11:50 AM			1:05 PM	2:00 PM
Cs-134 (Approx. 2 years)		ND(0.64)			ND(0.39)	1.5
Cs-137 (Approx.30 years)		ND(0.47)			ND(0.46)	2.8
The other $\gamma$	Ru-106 (Approx. 370 days)	24			ND	ND
	Mn-54 (Approx. 310 days)	ND			ND	ND
	Co-60 (Approx. 5 years)	ND			ND	ND
	Sb-125 (Approx. 3 years)	ND			ND	ND
All $\beta$		1,500			93	ND(18)
H-3 (Approx. 12 years)		430,000			530	1,500
Sr-90 (Approx. 29 years)		-			-	-

\* Data announced this time is provided in a thick-frame. The other data was announced on July 5.

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

<Reference>

July 6, 2013

Tokyo Electric Power Company

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/2)  
Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)
Date of Sampling	/	/	/	Jul 3, 2013	/	/	Jul 3, 2013	Jul 3, 2013	/
Time of sampling	/	/	/	6:08 AM	/	/	6:15 AM	6:15 AM	/
Cs-134(Approx. 2 years)	/	/	/	13	/	/	5.3	3	/
Cs-137(Approx.30 years)	/	/	/	23	/	/	9.3	8.9	/
All β	/	/	/	310	/	/	130	120	/
H-3 (Approx. 12 years)	/	/	/	<b>2300</b>	/	/	<b>230</b>	<b>ND(120)</b>	/
Sr-90 (Approx. 29 years)	/	/	/	-	/	/	-	-	/

Unit: Bq/L

	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port
Date of Sampling	/	/	/	/	/	/	/	/
Time of sampling	/	/	/	/	/	/	/	/
Cs-134(Approx. 2 years)	/	/	/	/	/	/	/	/
Cs-137(Approx.30 years)	/	/	/	/	/	/	/	/
All β	/	/	/	/	/	/	/	/
H-3 (Approx. 12 years)	/	/	/	/	/	/	/	/
Sr-90 (Approx. 29 years)	/	/	/	/	/	/	/	/

\* Data announced this time is provided in a thick-frame. The other data was announced on July 4.

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.