

<Reference>

July 9, 2013

Tokyo Electric Power Company

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection  
Underground Water Obtained at Bank Protection

Unit: Bq/L

	Underground water observation hole No.1	Underground water observation hole No.1-1	Underground water observation hole No.1-2	Underground water observation hole No.1-4	Underground water observation hole No.2	Underground water observation hole No.3
Date of sampling	Jul 8, 2013	Jul 8, 2013	Jul 8, 2013		Jul 8, 2013	
Time of sampling	1:30 PM	2:35 PM	2:00 PM		1:00 PM	
Cs-134 (Approx. 2 years)	ND(0.50)	1.9	9,000		ND(0.49)	
Cs-137 (Approx.30 years)	ND(0.47)	3.6	18,000		0.74	
The other γ	Mn-54 (Approx. 310 days)	ND	0.78	25	ND	
	Co-60 (Approx. 5 years)	ND	ND	3.1	ND	
	Ru-106 (Approx. 370 days)	16	7.9	ND	ND	
	Sb-125 (Approx. 3 years)	ND	ND	62	ND	
All β	1,800	4,400	890,000		1,700	
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis		Under analysis	
Sr-90 (Approx. 29 years)	-	-	-		-	

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.