

<Reference>

July 12, 2013

Tokyo Electric Power Company

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection
Underground Water Obtained at Bank Protection

Unit: Bq/L

	Underground water observation hole No.1	Underground water observation hole No.1-1	Underground water observation hole No.1-2	Underground water observation hole No.1-3	Underground water observation hole No.1-4	Underground water observation hole No.2	Underground water observation hole No.3
Date of sampling				Jul 12, 2013			
Time of sampling				12:20 PM			
Cs-134 (Approx. 2 years)				ND(0.66)			
Cs-137 (Approx.30 years)				1.4			
The other γ	Ru-106 (Approx. 370 days)			16			
	Sb-125 (Approx. 3 years)			1.4			
All β				92,000			
H-3 (Approx. 12 years)				Under analysis			
Sr-90 (Approx. 29 years)				Under analysis			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.