

<Reference>

July 14, 2013

Tokyo Electric Power Company

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection
Underground Water Obtained at Bank Protection

Unit: Bq/L

	Underground water observation hole No.1	Underground water observation hole No.1-1	Underground water observation hole No.1-2	Underground water observation hole No.1-3	Underground water observation hole No.1-4	Underground water observation hole No.2	Underground water observation hole No.3
Date of sampling				Jul 12, 2013		Jul 11, 2013	Jul 11, 2013
Time of sampling				12:20 PM		11:30 AM	10:55 AM
Cs-134 (Approx. 2 years)				ND(0.66)		ND(0.47)	1.9
Cs-137 (Approx.30 years)				1.4		1.2	4.8
The other γ				16		ND	ND
				1.4		ND	ND
All β				92,000		1,400	1400
H-3 (Approx. 12 years)				290,000		410	1,700
Sr-90 (Approx. 29 years)				Under analysis		-	-

* Data announced this time is provided in a thick-frame. The other data was announced on July 12.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.