

Transition of Radioactive Density After Filtration Treatment of the Samples Obtained in the "Groundwater Observation Hole No.1-2" Near the Bank Protection at Fukushima Daiichi Nuclear Power Station

(Unit: Bq/L)

| Groundwater observation hole No.1-2 | | Comparison | |
|--|------------------------|------------------------------|------|
| Date of sampling | Jul 18, 2013 | | |
| Time of sampling | 1:23 PM | | |
| Treatment | Without filtration (①) | Filtration ^{*1} (②) | ②/① |
| Cs-134 (Approx. 2 years) | 5,400 | ND(25) | 0.00 |
| Cs-137 (Approx.30 years) | 11,000 | ND(25) | 0.00 |

*1 0.45μm filter is used in the filtration,

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.