

<Reference>

July 22, 2013

Tokyo Electric Power Company

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/2)
Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)
Date of Sampling	/	/	/	Jul 18, 2013	/	/	Jul 18, 2013	Jul 18, 2013	/
Time of sampling	/	/	/	6:06 AM	/	/	6:14 AM	6:14 AM	/
Cs-134(Approx. 2 years)	/	/	/	14	/	/	9.5	7.0	/
Cs-137(Approx.30 years)	/	/	/	35	/	/	23	14	/
All β	/	/	/	380	/	/	320	320	/
H-3 (Approx. 12 years)	/	/	/	1,900	/	/	420	420	/
Sr-90(Approx. 29 years)	/	/	/	-	/	/	-	-	/

Unit: Bq/L

	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port
Date of Sampling	/	/	/	/	/	Jul 17, 2013	Jul 17, 2013	Jul 17, 2013
Time of sampling	/	/	/	/	/	12:20 PM	2:40 PM	2:47 PM
Cs-134(Approx. 2 years)	/	/	/	/	/	ND(2.2)	ND(1.7)	ND(2.2)
Cs-137(Approx.30 years)	/	/	/	/	/	ND(2.0)	ND(2.5)	2.4
All β	/	/	/	/	/	ND(20)	ND(20)	ND(20)
H-3 (Approx. 12 years)	/	/	/	/	/	4.8	7.0	20
Sr-90(Approx. 29 years)	/	/	/	/	/	-	-	-

* Data announced this time is provided in a thick-frame. The other data was announced on July 18, 19.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/2)
Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)
Date of Sampling	/	/	/	Jul 21, 2013	/	/	Jul 21, 2013	Jul 21, 2013	/
Time of sampling	/	/	/	5:51 AM	/	/	5:59 AM	5:59 AM	/
Cs-134(Approx. 2 years)	/	/	/	16	/	/	3.3	ND(1.6)	/
Cs-137(Approx.30 years)	/	/	/	29	/	/	8.5	3.2	/
All β	/	/	/	250	/	/	96	19	/
H-3 (Approx. 12 years)	/	/	/	Under analysis	/	/	Under analysis	Under analysis	/
Sr-90(Approx. 29 years)	/	/	/	-	/	/	-	-	/

Unit: Bq/L

	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port
Date of Sampling	/	/	/	/	/	/	/	/
Time of sampling	/	/	/	/	/	/	/	/
Cs-134(Approx. 2 years)	/	/	/	/	/	/	/	/
Cs-137(Approx.30 years)	/	/	/	/	/	/	/	/
All β	/	/	/	/	/	/	/	/
H-3 (Approx. 12 years)	/	/	/	/	/	/	/	/
Sr-90(Approx. 29 years)	/	/	/	/	/	/	/	/

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.