

## Transition of Radioactive Density After Filtration Treatment of the Samples Obtained in the "Groundwater Observation Hole No.1-2" Near the Bank Protection at Fukushima Daiichi Nuclear Power Station

(Unit: Bq/L)

		Groundwater observation hole No.1-2		Comparison
Date of sampling	Aug 1, 2013			
Time of sampling				
Treatment	Without filtration (①)	Filtration <sup>*1</sup> (②)	②/①	
Cs-134 (Approx. 2 years)	760	ND(26)	-	
Cs-137 (Approx.30 years)	1,600	45	0.03	

\*1 0.45μm filter is used in the filtration,

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* When the amount after filtration was ND, "-" will be stated at the comparison column.