

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/2)  
Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)
Date of Sampling	/	/	/	Aug 11, 2013	/	/	Aug 11, 2013	Aug 11, 2013	/
Time of sampling	/	/	/	6:04 AM	/	/	6:15 AM	6:15 AM	/
Cs-134(Approx. 2 years)	/	/	/	27	/	/	27	5.7	/
Cs-137(Approx.30 years)	/	/	/	55	/	/	56	11	/
All β	/	/	/	1,000	/	/	600	270	/
H-3 (Approx. 12 years)	/	/	/	<b>3,800</b>	/	/	<b>2,300</b>	<b>510</b>	/
Sr-90 (Approx. 29 years)	/	/	/	-	/	/	-	-	/

Unit: Bq/L

	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port
Date of Sampling	/	/	/	/	/	/	/	/
Time of sampling	/	/	/	/	/	/	/	/
Cs-134(Approx. 2 years)	/	/	/	/	/	/	/	/
Cs-137(Approx.30 years)	/	/	/	/	/	/	/	/
All β	/	/	/	/	/	/	/	/
H-3 (Approx. 12 years)	/	/	/	/	/	/	/	/
Sr-90 (Approx. 29 years)	/	/	/	/	/	/	/	/

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/2)  
Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)
Date of Sampling	/	/	/	Aug 13, 2013	/	/	Aug 13, 2013	Aug 13, 2013	/	/	/
Time of sampling	/	/	/	6:11 AM	/	/	6:19 AM	6:19 AM	/	/	/
Cs-134(Approx. 2 years)	/	/	/	34	/	/	15	6.1	/	/	/
Cs-137(Approx.30 years)	/	/	/	81	/	/	31	14	/	/	/
All β	/	/	/	930	/	/	390	250	/	/	/
H-3 (Approx. 12 years)	/	/	/	Under analysis	/	/	Under analysis	Under analysis	/	/	/
Sr-90 (Approx. 29 years)	/	/	/	-	/	/	-	-	/	/	/

Unit: Bq/L

	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater	East side of the port entrance	South side of the south breakwater
Date of Sampling	/	/	/	/	/	/	/	/	/	/	/
Time of sampling	/	/	/	/	/	/	/	/	/	/	/
Cs-134(Approx. 2 years)	/	/	/	/	/	/	/	/	/	/	/
Cs-137(Approx.30 years)	/	/	/	/	/	/	/	/	/	/	/
All β	/	/	/	/	/	/	/	/	/	/	/
H-3 (Approx. 12 years)	/	/	/	/	/	/	/	/	/	/	/
Sr-90 (Approx. 29 years)	/	/	/	/	/	/	/	/	/	/	/

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

<Reference> The Highest Dose Until the Previous Measurement\* (Seawater)

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)
Cs-134(Approx. 2 years)	1.8 [ 6/21 ]	ND	5.3 [ 8/5 ]	31 [ 3/11 ]	16 [ 8/12 ]	24 [ 8/12 ]	27 [ 8/10 ]	9.9 [ 7/23 ]	20 [ 8/12 ]
Cs-137(Approx.30 years)	3.3 [ 6/26 ]	3.1 [ 7/15 ]	8.6 [ 8/5 ]	56 [ 3/11 ]	33 [ 8/12 ]	51 [ 8/12 ]	56 [ 8/10 ]	19 [ 7/23 ]	42 [ 8/12 ]
All β	ND	20 [ 7/2 ]	40 [ 7/3 ]	1,000 [ 8/11 ]	320 [ 8/12 ]	700 [ 8/12 ]	600 [ 8/10 ]	450 [ 7/16 ]	370 [ 8/12 ]
H-3 (Approx. 12 years)	8.6 [ 6/26 ]	11 [ 7/15 ]	340 [ 6/26 ]	3,100 [ 7/28 ]	460 [ 7/15 ]	1,500 [ 7/29 ]	1,800 [ 7/28 ]	1,200 [ 8/4 ]	500 [ 8/5 ]
Sr-90 (Approx. 29 years)	5.8 [ 6/26 ]	-	7.4 [ 6/26 ]	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis

Unit: Bq/L

	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port
Cs-134(Approx. 2 years)	21 [ 8/12 ]	350 [ 7/15 ]	22 [ 8/12 ]	46 [ 7/8 ]	ND	ND	ND	ND	ND	ND
Cs-137(Approx.30 years)	37 [ 8/12 ]	770 [ 7/15 ]	45 [ 8/12 ]	93 [ 7/8 ]	3.0 [ 7/15 ]	3.7 [ 6/26 ]	3.3 [ 7/4 ]	3.3 [ 6/26 ]	ND	ND
All β	410 [ 8/12 ]	1,000 [ 7/15 ]	390 [ 8/12 ]	310 [ 8/12 ]	ND	31 [ 6/26 ]	40 [ 7/4 ]	60 [ 7/4 ]	ND	ND
H-3 (Approx. 12 years)	660 [ 7/29 ]	240 [ 8/5 ]	430 [ 7/15 ]	260 [ 6/26 ] [ 7/29 ]	ND	29 [ 6/26 ]	44 [ 7/4 ]	37 [ 7/4 ]	Under analysis	Under analysis
Sr-90 (Approx. 29 years)	Under analysis	Under analysis	Under analysis	Under analysis	0.36 [ 6/26 ]	3.5 [ 6/20 ]	Under analysis	Under analysis	-	-

\* The highest result announced in "Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection" or the other handouts is provided.

As for "1F, North side of Unit 1-4 water intake channel", the data is obtained since January 14, 2013. For the other locations, the data is obtained since June 14.

\* "ND" indicates that the measurement result is below the detection limit.

\* Date of sampling is provided in parentheses.

\* "-" indicates that the measurement was out of range.