

Transition of Radioactive Density After Filtration Treatment of the Samples Obtained in the "Groundwater Observation Hole No.1-2" Near the Bank Protection at Fukushima Daiichi Nuclear Power Station

(Unit: Bq/L)

	Groundwater observation hole No.1-2		Comparison
Date of sampling	Aug 29, 2013		
Time of sampling	11:42 AM		
Treatment	Without filtration (①)	Filtration ^{*1} (②)	②/①
Cs-134 (Approx. 2 years)	120	75	0.63
Cs-137 (Approx.30 years)	260	160	0.62

*1 0.45μm filter is used in the filtration,

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* When the amount after filtration was ND, "-" will be stated at the comparison column.