Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/4) Underground Water Obtained at Bank Protection

		Underground water observation hole No.0-1	Underground water observation hole No.1	Underground water observation hole No.1-2	Underground water observation hole No.1-3	Underground water observation hole No.1-4	Underground water observation hole No.1-5	Underground water observation hole No.1-8	Groundwater pumped up from the well point	Underground water observation hole No.2	Underground water observation hole No.2-1	Underground water observation hole No.3	Underground water observation hole No.3-1
	Date of sampling							/	/	Aug 29, 2013	Aug 29, 2013	/	
	Time of sampling									10:10 AM	9:36 AM		
С	s-134 (Approx. 2 years)									ND(0.43)	ND(0.43)		
C	s-137 (Approx.30 years)									ND(0.54)	1.1		
The other y													
	ΑΙΙ β									140	ND(20)		
I	H-3 (Approx. 12 years)									590	370		
S	r-90 (Approx. 29 years)								/	-	-	/	

^{*} Data announced this time is provided in a thick-frame. The other data was announced on August 30.

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

^{* &}quot;-" indicates that the measurement was out of range.

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/4) Underground Water Obtained at Bank Protection

		Underground water observation hole No.0-1	Underground water observation hole No.1	Underground water observation hole No.1-2	Underground water observation hole No.1-3	Underground water observation hole No.1-4	Underground water observation hole No.1-5	Underground water observation hole No.1-8	Groundwater pumped up from the well point	Underground water observation hole No.2	Underground water observation hole No.2-1	Underground water observation hole No.3	Underground water observation hole No.3-1
	Date of sampling	Sep 1, 2013	/	/	/	/	/	1 /	/	Sep 1, 2013	Sep 1, 2013	/	
	Time of sampling	11:03 AM		/						10:00 AM	9:30 AM		
Cs	s-134 (Approx. 2 years)	0.8								ND(0.41)	0.66		
Cs	s-137 (Approx.30 years)	2.1								ND(0.55)	1.1		
The other y													
	ΑΙΙ β	160								230	ND(19)		
Н	H-3 (Approx. 12 years)	Under analysis								Under analysis	Under analysis		
Sr-	-90 (Approx. 29 years)	-								-	-		

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

^{* &}quot;-" indicates that the measurement was out of range.

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (3/4) Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)
Date of Sampling				Aug 29, 2013	/	/	Aug 29, 2013	Aug 29, 2013			
Time of sampling				6:13 AM			6:25 AM	6:25 AM			
Cs-134(Approx. 2 years)				35			26	13			
Cs-137(Approx.30 years)	/			78			57	25			
ΑΙΙ β				830			500	340			
H-3 (Approx. 12 years)				4,200			1,400	1,200			
Sr-90 (Approx. 29 years)				-			-	-			

	1F, Between the water intake channel of Unit 3 and Unit 4	Screen	1F, Around the south discharge channel	I POIT	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater*	East side of the port entrance*	South side of the south breakwater*
Date of Sampling		/		/		/	/	/		/	
Time of sampling											
Cs-134(Approx. 2 years)								/			
Cs-137(Approx.30 years)								/			
ΑΙΙ β											
H-3 (Approx. 12 years)						/		/			
Sr-90(Approx. 29 years)	/	/	/		/	/	/	/	/	/	/

^{*} Data announced this time is provided in a thick-frame. The other data was announced on August 30.

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

^{* &}quot;-" indicates that the measurement was out of range.

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (4/4) Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)
Date of Sampling			/	Sep 1, 2013	/		Sep 1, 2013	Sep 1, 2013	/		
Time of sampling				6:05 AM			6:12 AM	6:12 AM			
Cs-134(Approx. 2 years)				28	/		23	11			
Cs-137(Approx.30 years)				62			40	24			
ΑΙΙ β				500			370	370			
H-3 (Approx. 12 years)				Under analysis			Under analysis	Under analysis			
Sr-90 (Approx. 29 years)				-			-	-		/	

	1F, Between the water intake channel of Unit 3 and Unit 4	Screen	1F, Around the south discharge channel	I POIT	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater*	East side of the port entrance*	South side of the south breakwater*
Date of Sampling		/		/		/	/	/		/	
Time of sampling											
Cs-134(Approx. 2 years)								/			
Cs-137(Approx.30 years)								/			
ΑΙΙ β											
H-3 (Approx. 12 years)						/		/			
Sr-90(Approx. 29 years)	/	/	/		/	/	/	/	/	/	/

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

^{* &}quot;-" indicates that the measurement was out of range.

<Reference> The Highest Dose Until the Previous Measurement (Groundwater Obtained at Bank Protection)

Unit: Bq/L

		observa	dwater tion hole .0-1	Ground observat No	tion hole	Ground observat No.	on hole	Ground observat No.	ion hole	Ground observat No.	tion hole	observa	dwater tion hole .1-4	observa	dwater tion hole .1-5	Ground observat No.	ion hole	Groundwat up from the	er pumped e well point
С	s-134 (Approx. 2 years)	1.4	[8/29]	13	[8/29]	1.9	[7/8]	11,000	[7/9]	1.3	[8/29]	1.5	[7/8]	310	[8/5]	26	[8/26]	1.5	[8/19]
С	s-137 (Approx.30 years)	3.0	[8/29]	31	[8/29]	3.6	[7/8]	22,000	[7/9]	3.3	[8/29]	3.6	[7/8]	650	[8/5]	58	[8/26]	3.4	[8/19]
	Ru-106 (Approx. 370 days)	ND		26	[5/24]	7.9	[7/8]	160	[8/15]	17	(7/22) (8/8)	3.1	[8/8]	ND		ND		17	[8/19]
The	Mn-54 (Approx. 310 days)	ND		ND		1.0	[7/5]	62	[7/5]	ND		ND		ND		0.52	[8/26]	ND	
other y	Co-60 (Approx. 5 years)	ND		0.50	[7/19]	ND		3.1	[7/8]	ND		ND		ND		ND		ND	
	Sb-125 (Approx. 3 years)	ND		1.7	[7/11]	ND		250	[7/15]	1.4	(7/12) (8/26)	ND		12	[8/8]	ND		ND	
	ΑΙΙ β	300	[8/22]	1,900	[5/24]	4,400	[7/8]	900,000	[7/5] [7/9]	160,000	(8/12) (8/15)	380	[8/19]	56,000	[8/5]	1,200	[8/26]	190,000	[8/19]
1	H-3 (Approx. 12 years)	42,000	[8/22]	500,000	[5/24] [6/7]	630,000	[7/8]	400,000	[8/22]	290,000	[7/12]	98,000	[7/11]	72,000	[8/15]	950	[8/20]	460,000	[8/19]
S	r-90(Approx. 29 years)	Under analysis		1,200	[6/7]	Under analysis		Under analysis		Under analysis		Under analysis		Under analysis		Under analysis		-	

		observa	ndwater ution hole o.2	Ground observati No.		observ	ndwater ation hole lo.3	Ground observat No.	ion hole
Cs	s-134 (Approx. 2 years)	0.50	[7/9]	0.44	[8/1]	3.5	[7/25]	1.2	(7/25) (8/8)
Cs	s-137 (Approx.30 years)	1.2	(7/11) (8/1)	1.1	[8/29]	5.9	[8/8]	2.6	[8/1]
	Ru-106 (Approx. 370 days)	ND		ND		ND		ND	
The	Mn-54 (Approx. 310 days)	ND		ND		ND		ND	
other y	Co-60 (Approx. 5 years)	ND		ND		ND		ND	
	Sb-125 (Approx. 3 years)	ND		ND		ND		ND	
	ΑΙΙ β	1,700	[7/8]	380	[7/29]	1,400	[7/11]	180	[8/1]
H	H-3 (Approx. 12 years)	850	[6/26]	440	[8/26]	3,200	[2012/12/1 2]	460	[8/1]
S	r-90(Approx. 29 years)	54	[5/31]	Under analysis		8.3	[2012/12/1 2]	Under analysis	

^{* &}quot;ND" indicates that the measurement result is below the detection limit.

^{*} Date of sampling is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement* (Seawater)

Unit: Bq/L

	Unit 5,6	orth side of 6 discharge 1annel		ont of Unit 6 ake channel	,	front of draft quay		th side of rater intake nnel	Unit 1-4 w channel (of East	th side of vater intake (north side Seawall eak)	(Inside	t 1 Screen e the Silt ence)	water inta	and Unit 2	water intal of Unit 1		(Inside	2 Screen the Silt nce)	water inta of Unit 2		water into	tween the ake channel and Unit 3 er layer)	(Inside	3 Screen the Silt nce)
Cs-134(Approx. 2 years)	1.8	[6/21]	2.4	[8/19]	5.3	[8/5]	35	[8/29]	16	[8/12]	24	/12〕 〔8/1	27	[8/11]	13	[8/29]	26	[8/19]	21	[8/12]	3.5	[8/20]	350	[7/15]
Cs-137(Approx.30 years)	3.3	[6/26]	4.7	[8/19]	8.6	[8/5]	81	[8/13]	33	[8/12]	51	[8/12]	64	[8/27]	25	[8/29]	52	[8/19]	37	[8/12]	9.8	[8/20]	770	[7/15]
ΑΙΙ β	ND		46	[8/19]	40	[7/3]	1,100	[8/15]	320	[8/12]	700	[8/12]	740	[8/15]	450	[7/16]	490	[8/19]	410	[8/12]	85	[8/20]	1,000	(7/15)
H-3 (Approx. 12 years)	8.6	[6/26]	24	[8/19]	340	[6/26]	4,700	[8/15]	460	[7/15]	2,500	[8/12]	2,600	[8/15]	1,200	[8/4]	820	[8/19]	720	[8/12]	-		380	[8/12]
Sr-90 (Approx. 29 years)	5.8	[6/26]	-		7.4	[6/26]	Under analysis		Under analysis		Under analysis		Under analysis		Under analysis		Under analysis		Under analysis		-		Under analysis	

	water into		water into	tween the ake channel and Unit 4 er layer)	(Inside	4 Screen the Silt nce)	south o	ound the discharge annel	1F, Por	t entrance		side in the ort	-	side in the ort		side in the ort		n side in the port	North sid north bre		East side of the port entrance	South side of the south breakwater
Cs-134(Approx. 2 years)	22	[8/12]	4.8	[8/20]	46	[7/8]	ND		1.6	(8/19)	2.9	[8/19]	2.6	[8/19]	ND		2.1	[8/19]	ND		ND	ND
Cs-137(Approx.30 years)	45	[8/12]	7.7	[8/20]	93.0	[7/8]	3.0	[7/15]	4.7	[8/19]	6.6	[8/19]	6.5	[8/19]	4.7	[8/19]	4.6	[8/19]	ND		ND	ND
ΑΙΙ β	390	[8/12]	57	[8/20]	310	[8/12]	ND		69	[8/19]	74	[8/19]	60	[7/4]	69	[8/19]	79	[8/19]	ND		ND	ND
H-3 (Approx. 12 years)	650	[8/12]	-		400	[8/12]	ND		68	[8/19]	67	[8/19]	59	[8/19]	52	[8/19]	60	[8/19]	4.7	[8/14]	ND	ND
Sr-90 (Approx. 29 years)	Under analysis		-		Under analysis		0.36	[6/26]	3.5	[6/20]	Under analysis		Under analysis		-		-		-		-	-

^{*} The highest result announced in "Detailed Analysis Results in the Port of Fukushima Dailchi NPS, around Discharge Channel and Bank Protection" or the other handouts is provided. As for "1F, North side of Unit 1-4 water intake channel", the data is obtained since January 14, 2013. For the other locations, the data is obtained since June 14.

^{* &}quot;ND" indicates that the measurement result is below the detection limit.

^{*} Date of sampling is provided in parentheses.

^{* &}quot;-" indicates that the measurement was out of range.