

Transition of Radioactive Density After Filtration Treatment of the Samples Obtained in the "Groundwater Observation Hole No.1-9" Near the Bank Protection at Fukushima Daiichi Nuclear Power Station

(Unit: Bq/L)

Groundwater observation hole No.1-9		Comparison	
Date of sampling	Sep 5, 2013		
Time of sampling	10:20 AM		
Treatment	Without filtration (①)	Filtration ^{*1} (②)	②/①
Cs-134 (Approx. 2 years)	110	41	0.37
Cs-137 (Approx.30 years)	240	110	0.46

*1 0.45μm filter is used in the filtration,

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* When the amount after filtration was ND, "-" will be stated at the comparison column.