


### Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Underground Water Obtained at Bank Protection)

● Sampling locations of underground water obtained at bank protection

East seawall break



— : Location where ground improvement work was completed, or being implemented (as of September 26)

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection  
Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-2	Underground water observation hole No.1	Underground water observation hole No.1-2	Underground water observation hole No.1-8	Underground water observation hole No.1-9	Underground water observation hole No.1-11	Groundwater pumped up from the well point	Underground water observation hole No.2	Underground water observation hole No.2-1	Underground water observation hole No.2-6	Underground water observation hole No.3	Underground water observation hole No.3-4
Date of sampling								Sep 26, 2013					
Time of sampling								11:30 AM					
Chloride (unit: ppm)								—					
Cs-134 (Approx. 2 years)								ND(0.99)					
Cs-137 (Approx.30 years)								2					
The other γ													
All β								400,000					
H-3 (Approx. 12 years)								Under analysis					
Sr-90 (Approx. 29 years)								Under analysis					

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

<Reference> The Highest Dose Until the Previous Measurement (Groundwater Obtained at Bank Protection)

Unit: Bq/L

	Groundwater observation hole No.0-1	Groundwater observation hole No.0-2	Groundwater observation hole No.1	Groundwater observation hole No.1-1	Groundwater observation hole No.1-2	Groundwater observation hole No.1-3	Groundwater observation hole No.1-4	Groundwater observation hole No.1-5	Groundwater observation hole No.1-8	Groundwater observation hole No.1-9	Groundwater observation hole No.1-11	Groundwater pumped up from the well point (notch tank)
Cs-134 (Approx. 2 years)	2.1 [9/22]	ND	13 [8/29]	1.9 [7/8]	11,000 [7/9]	10 [9/2]	1.5 [7/8]	310 [8/5]	31 [9/16]	170 [9/3]	[1/0] [9/23]	110 [9/23]
Cs-137 (Approx.30 years)	4.6 [9/22]	0.93 [9/15]	31 [8/29]	3.6 [7/8]	22,000 [7/9]	24 [9/2]	3.6 [7/8]	650 [8/5]	67 [9/16]	380 [9/3]	1.2 [9/23]	250 [9/23]
The other Y	Ru-106 (Approx. 370 days)	ND	26 [5/24]	7.9 [7/8]	160 [8/15]	17 [7/22] [8/8]	3.1 [8/8]	ND	ND	ND	ND	25 [9/2]
	Mn-54 (Approx. 310 days)	ND	ND	1.0 [7/5]	62 [7/5]	ND	ND	ND	0.76 [9/16]	ND	ND	ND
	Co-60 (Approx. 5 years)	ND	ND	0.50 [7/19]	ND	3.1 [7/8]	ND	ND	ND	ND	ND	ND
	Sb-125 (Approx. 3 years)	ND	ND	1.7 [7/11]	ND	250 [7/15]	1.4 [7/12] [8/26]	ND	12 [8/8]	ND	ND	ND
All β	300 [8/22]	[2/6] [9/22]	1,900 [5/24]	4,400 [7/8]	900,000 [7/5] [7/9]	160,000 [8/12] [8/15]	380 [8/19]	56,000 [8/5]	2,100 [9/16]	600 [9/8]	57 [9/19]	700,000 [9/23]
H-3 (Approx. 12 years)	45,000 [8/29]	ND	500,000 [5/24] [6/7]	630,000 [7/8]	430,000 [9/16]	290,000 [7/12]	98,000 [7/11]	72,000 [8/15]	1900 [9/16]	680 [9/15]	85000 [9/13]	460,000 [8/19]
Sr-90(Approx. 29 years)	Under analysis	Under analysis	1,200 [6/7]	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	-

Unit: Bq/L

	Groundwater observation hole No.2	Groundwater observation hole No.2-1	Groundwater observation hole No.2-6	Groundwater observation hole No.3	Groundwater observation hole No.3-1	Groundwater observation hole No.3-4
Cs-134 (Approx. 2 years)	0.50 [7/9]	0.66 [9/1]	0.42 [9/22]	3.5 [7/25]	1.2 [7/25] [8/8]	1.0 [9/25]
Cs-137 (Approx.30 years)	1.2 [7/11] [8/1]	1.1 [8/29] [9/1]	0.6 [9/22]	5.9 [8/8]	2.6 [8/1]	1.8 [9/18]
The other Y	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	ND
	Mn-54 (Approx. 310 days)	ND	ND	ND	ND	ND
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND
	Sb-125 (Approx. 3 years)	ND	ND	ND	1.1 [9/5]	ND
All β	1,700 [7/8]	380 [7/29]	ND	1,400 [7/11]	180 [8/1]	ND
H-3 (Approx. 12 years)	850 [6/26]	440 [8/26]	210 [9/22]	3,200 [2012/12/12]	460 [8/1]	170 [9/18]
Sr-90(Approx. 29 years)	54 [5/31]	Under analysis	Under analysis	8.3 [2012/12/12]	Under analysis	Under analysis

\* "ND" indicates that the measurement result is below the detection limit.

\* Date of sampling is provided in parentheses.