

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Pumped Water Obtained from Bank Protection)

Unit: Bq/L

		Pumped water from groundwater observation hole No.0-3-2	Pumped water from groundwater observation hole No.1-16
Date of Sampling		Dec 11, 2013	/
Time of sampling		1:00 PM	
Cs-134 (Approx. 2 years)		ND(0.38)	
Cs-137 (Approx.30 years)		ND(0.46)	
The other γ			
Gross β		67	
H-3 (Approx. 12 years)		Under analysis	

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

