

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Pumped Water Obtained from Bank Protection)

Unit: Bq/L


| | | Pumped water from groundwater observation hole No.0-3-2 | Dec 17, 2013 | Pumped water from groundwater observation hole No.1-16 |
|--------------------------|--|---|----------------|--|
| Date of Sampling | | Dec 16, 2013 | Dec 17, 2013 | 12月16日 |
| Time of sampling | | 1:00 PM | 12:00 PM | 1:00 PM |
| Cs-134 (Approx. 2 years) | | ND(0.62)* | ND(0.37) | ND(2.8) |
| Cs-137 (Approx.30 years) | | ND(0.64)* | ND(0.48) | ND(1.5) |
| The other γ | | | | |
| | | | | |
| | | | | |
| Gross β | | 63,000* | ND(17) | 1,700,000 |
| H-3 (Approx. 12 years) | | 65,000* | Under analysis | 39,000 |

* Data announced this time is provided in a thick-frame. The other data was announced on December 17.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

"*" next to the value indicates that this value is just for a reference, since the result of gross β in the groundwater observation hole No.0-3-2 obtained on December 17 was below the detection limit value (equivalent to the result obtained previously on December 13), and it is supposed that the radioactive material has mixed into the water obtained on December 16.



[Sampling locations at bank protection]