

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Pumped Water Obtained from Bank Protection)

Unit: Bq/L

		Pumped water from groundwater observation hole No.0-3-2		
Date of Sampling		Dec 17, 2013	Dec 18, 2013	Dec 19, 2013
Time of sampling		12:00 PM	12:00 PM	12:00 PM
Cs-134 (Approx. 2 years)		ND(0.37)	ND(0.40)	ND(0.44)
Cs-137 (Approx.30 years)		ND(0.48)	ND(0.51)	ND(0.51)
The other γ				
Gross β		ND(17)	ND(20)	ND(20)
H-3 (Approx. 12 years)		69,000	64,000	Under analysis

* Data announced this time is provided in a thick-frame. The other data was announced on December 18 and 19.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

