

Nuclides Analysis Result of the Radioactive Materials in the Air at Fukushima Nuclear Power Stations

(Data summarized on April 28)

Place of Sampling	The West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini NPS (Reference)				② Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
	April 27, 2013 7:00 AM - 12:00 PM		April 27, 2013 9:42 AM - 9:52 AM				
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-			
Cs-134 (Approx. 2 years)	ND	-	ND	-			2E-03
Cs-137 (Approx. 30 years)	ND	-	ND	-			3E-03

* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE—O is the same as $O.O \times 10^{-O}$

Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits at the west gate of Fukushima Daiichi NPS are as follows.

Volatile; I-131: Approx. $8E-8Bq/cm^3$, Cs-134: Approx. $2E-7Bq/cm^3$, Cs-137: Approx. $3E-7Bq/cm^3$


Particulate; I-131: Approx. $5E-8Bq/cm^3$, Cs-134: Approx. $1E-7Bq/cm^3$, Cs-137: Approx. $1E-7Bq/cm^3$

The detection limits at MP-1 of Fukushima Daini NPS are as follows.

Volatile; I-131: Approx. $2E-6Bq/cm^3$, Cs-134: Approx. $2E-6Bq/cm^3$, Cs-137: Approx. $2E-6Bq/cm^3$

Particulate; I-131: Approx. $8E-7Bq/cm^3$, Cs-134: Approx. $1E-6Bq/cm^3$, Cs-137: Approx. $8E-7Bq/cm^3$

Dust Nuclides Analysis Result: The West Gate of Fukushima Daiichi Nuclear Power Station (Bq/cm³)



(Reference) Dust Nuclides Analysis Results of MP-1 at Fukushima Daini NPS (Bq/cm³)

